

2016 LEAD ACTION LEVEL EXCEEDANCES IN GEORGIA--Updates As Of 11-29-2016

WATER SYSTEM ID#	WATER SYSTEM NAME	WATER SYSTEM TYPE	WATER SYSTEM POPULATION	SAMPLE COLLECT DATE	90TH% RESULT	UNIT OF MEASURE	# OF SAMPLES SUBMITTED	# OF SAMPLES EXCEEDING THE ACTION LEVEL	REQUIRED FOLLOW-UP ACTIVITES COMPLETED? (WQPs & SOURCE-WATER LEAD TESTING, & PUBLIC EDUCATION)	STATUS/COMMENTS
GA0290072	ANDERSON S/D	COMMUNITY	26	9/22/2016	33.1	UG/L	5	1	YES	Water System was notified by the State on 10/27/2016. Additional round of sampling bottles have been sent to Water System and sampling projected to be done by the end of the year (2016). Water System collecting samples on 11/30/16 for Water Quality Parameters (WQPs) and source/entry point lead-copper testing to be done via a private lab.
GA0330005	BOGGS ACADEMY	NON TRANSIENT-NON COMMUNITY	35	8/22/2016	48.5	UG/L	5	1	YES	Water System was notified by the State on 9/27/16. Water System representative indicated the high sample was improperly collected by the occupant of a rental home located on the property from an outdoor spigot and not from an interior cold water tap regularly used for consumption. Additional round of sampling bottles have been sent to Water System and sampling projected to be done by the end of the year (2016).
GA1270007	MORNINGSTAR CHILDREN & FAMILY SERV., INC	COMMUNITY	50	9/19/2016	23.1	UG/L	5	1	YES	Water System was notified by the State on 10/17/2016. Additional round of sampling bottles have been sent to Water System and sampling projected to be done by the end of the year (2016).
GA1270118	PITTMAN'S CIRCLE	COMMUNITY	42	9/17/2016	44	UG/L	5	3	YES	Water System was notified by the State on 10/17/2016. Additional round of sampling bottles have been sent to Water System and sampling projected to be done by the end of the year (2016).

GA1410007	SCENIC SHORES S/D	COMMUNITY	952	7/28/2016	18	UG/L	10	2	YES	Water System was notified by the State on 9/27/16. Sanitary survey inspection performed on 9/28/16 at which time WQP testing and source sampling was done. Additional round of sampling bottles have been sent to Water System and sampling projected to be done by the end of the year (2016).
GA1450039	KINGS GAP WATER SYSTEM #3	COMMUNITY	36	9/21/2016	15.4	UG/L	5	1	WQPs & source water lead testing done. Public Education not done yet.	Water System was notified by the State on 10/17/2016. Additional round of sampling bottles have been sent to Water System and sampling projected to be done by the end of the year (2016).
GA1690027	JONES ACRES MHP	COMMUNITY	169	8/2/2016	17.5	UG/L	5	2	YES	Water System was notified by the State on 9/27/16. Water System representative indicated high samples were collected from vacant mobile homes where the water was not being used/stagnant instead of from occupied homes where water is actually being used regularly for consumption. Additional round of sampling bottles have been sent to Water System and sampling projected to be done by the end of the year (2016).
GA1770029	DAWSON ROAD APARTMENTS	COMMUNITY	36	9/29/2016	41	UG/L	5	2	WQPs & source water lead testing done. Public Education not done yet.	Water System was notified by the State on 11/7/16. Additional round of sampling bottles have been sent to Water System and sampling projected to be done by the end of the year (2016).
GA1850300	SUMMERPLACE NORTH S/D	COMMUNITY	44	8/15/2016	15.9	UG/L	5	1	WQPs & source water lead testing done. Public Education not done yet.	Water System was notified by the State on 9/27/16. Additional round of sampling bottles have been sent to Water System and sampling projected to be done by the end of the year (2016).

GA1990009	ROOSEVELT WARM SPRINGS INST.	COMMUNITY	700	9/23/2016	21	UG/L	10	2	NOT YET	Water System was notified by the State on 10/27/16. Water System indicated that 2 exceeding samples were collected from dormant/unoccupied cottages by mistake and shouldn't have been part of the sampling pool. They will revise their Lead/Copper site selection list to remove vacant/unoccupied buildings/housing units that are not being used. Additional round of sampling bottles have been sent to Water System and sampling projected to be done by the end of the year (2016).
GA2190073	BRIDLEGATE S/D	COMMUNITY	26	7/15/2016	15.5	UG/L	5	1	YES	Discovered existing corrosion control chemical feed pump was not functioning properly during sampling time frame. Repairs have been made. Additional round of sampling was performed at the same sites 9/12/16 and all results are well below the action levels.
GA2270004	BIG CANOE S/D	COMMUNITY	6396	8/16/2016	16	UG/L	20	3	YES	Water System was notified by the State on 10/5/16. Additional round of sampling bottles have been sent to Water System and sampling projected to be done by the end of the year (2016).
GA2410127	HEATHERSTONE AT FORD MTN HOA	COMMUNITY	62	7/22/2016	16.5	UG/L	5	1	YES	Water system was notified by the State on 9/27/16. In addition to distributing public education printed materials, the topic was discussed at the annual HOA meeting on 10/8/16. Further discussions/updates will take place at quarterly HOA Board meetings. Will be evaluating additional testing results to determine if they need to install corrosion control. Will also review/improve sampling techniques. Additional round of sampling bottles have been sent to Water System and sampling projected to be done by the end of the year (2016).

GA2890012	TWIGGS CO.-KAOLIN HEIGHTS	COMMUNITY	42	3/31/2016	24	UG/L	5	5	YES	<p>Water System is actively working on optimizing corrosion control and making significant system upgrades/improvements.</p> <p>They are in process of being considered for/approved for ITAD (immediate threat and danger) Grant money to make the upgrades/improvements. Additional round of sampling bottles have been sent to Water System and sampling projected to be done by the end of the year (2016).</p>
GA2970041	WILDWOOD ESTATES	COMMUNITY	39	7/15/2016	18.9	UG/L	5	1	YES	<p>Discovered existing corrosion control filter media was low (using calcite filters) and was too low to be effective. Filters were serviced, calcite media replenished.</p> <p>Additional round of sampling was performed at the same sites 10/7/16 and all results are well below the action levels.</p>