

January 13, 2019

Mr. William Cook  
Georgia Environmental Protection Division  
Solid Waste Program  
4244 International Parkway, Suite 104  
Atlanta, Georgia 30354

**Re: Georgia Power Company – Plant Branch  
Proposed CCR Landfill – Site Acceptability Review Comments  
APL 1579**

Dear Mr. Cook:

Enclosed please find Georgia Power Company's (GPC) response to comments on the Site Acceptability Report (SAR) submitted for the proposed Plant Branch CCR Landfill. The comments were received in a letter dated October 23, 2019, which were generated by EPD's review of the Site Acceptability Report prepared by Geosyntec. Following are each of the comments from the EPD and a written response.

For clarity we have written out each EPD comment followed by a written response. The responses have been prepared with assistance from our engineering consultant, Geosyntec. Supporting information as requested by the EPD comments, is included as attachments to this letter.

**Comment No. 1:** *A legal description of the proposed permit boundary needs to be included in the report.*

**Response:** The legal description of the proposed permit boundary is provided in the Property Boundary Survey drawing included as Attachment A.

**Comment No. 2:** *EPD has identified several deficiencies and requests the following additions and/or corrections to the report figures:*

- *Cross-sections B and C show BH-12 encountering Gneiss bedrock. This is not consistent with the drilling log for BH-12 included in Appendix D.*
- *According to the drilling log, BH-19 encountered ash to total depth.*
- *Cross-section B should be revised to show Ash Pond D.*
- *Cross-section B shows a deep well completion at PB-1D that is not consistent with the drilling log included in Appendix D.*

- *Add the outline of Ash Pond C and D to Figure 2-7 and Figure 3-1 and the key map of Figure 3-1.*

**Response:** The items noted above (bullets 1 to 5) have been addressed and the requested revisions to existing cross-section B, as well as Figures 2-7 and 3-1 have been made. The revised cross-sections and figures are included in Attachment B.

**Comment No. 3:** *An additional geologic cross-section should be constructed that transects Ash Pond D. EPD suggests that this cross-section include BRGWC-47, BH-19, and BRGWC-301 and show the original topography beneath the ash pond.*

**Response:** The additional cross-section (cross-section D) has been prepared and is included in Attachment B.

**Comment No. 4:** *A location map and logs for the cone penetrometer (CPT) borings should be included in the report.*

**Response:** The location map showing the CPT locations was included as Figure 2-2 in the Site Acceptability Report. However, as requested, the CPT logs from these borings identified in Figure 2-2 are provided as Attachment C.

**Comment No. 5:** *The Golder report [Golder, 2018a] referenced in Section 2.3.3 should be included in the site acceptability report as an appendix, if possible or submitted separately if that is more practical.*

**Response:** The referenced report by Golder (Geologic and Hydrogeologic Summary Report) is included in Attachment D.

**Comment No. 6:** *Groundwater potentiometric surface maps should be signed and sealed by the Georgia PG that authored the report.*

**Response:** The two potentiometric surface maps included in the Site Acceptability Report have been reproduced, signed and sealed by the Georgia P.G. that authored the report, and included in Attachment B.

**Comment No. 7:** *All data and supporting analysis for slug test results shown in Table 3-2 that were conducted in the PZ, BH, and BRGWC series of piezometers and monitoring wells should be included in Appendix F.*

**Response:** Slug test data plots produced by Geosyntec, SCS, and Golder for the piezometers and wells shown in Table 3-2 are included in Attachment E.

**Comment No. 8:** *The groundwater elevation values used to generate the estimated seasonal high potentiometric surface (Figure 3-1) should be tabulated and posted on the figure.*

**Response:** The potentiometric surface presented in Figure 3-1 is an estimated or projected surface based on multiple lines of evidence, including historical water level data, seasonal groundwater fluctuations, "pre-ash" topography and surface water drainage at Ash Pond D, and projected conditions following closure of Ash Pond D, as described in more detail under the response to Comment No. 9. Groundwater elevation values could be estimated at each individual



well based on the projected surface, but these would be estimates only, interpolated between the 5-foot contours of the projected post-closure groundwater surface, and therefore, we do not recommend including these values in tabular format.

**Comment No. 9:** *The original topography beneath Ash Pond D should be overlain on Figure on 3-1 to help evaluate the estimated seasonal high potentiometric surface after removal of Ash Pond D. The report should indicate what specific data was used to forecast the future groundwater elevations in the area of Ash Pond D following breaching of the pond dike and dewatering and removal of the ash.*

**Response:** The original “pre-ash” topography beneath Ash Pond D has been added to Figure 3-1, and the revised figure included in Attachment B. The estimated seasonal high potentiometric surface after removal of CCR presented in this figure is based on several factors, namely (i) observed groundwater elevations, (ii) seasonal variations from historical measurements, (iii) “pre-ash” topography and surface water drainage at Ash Pond D, and (iv) conditions likely to result from the construction of the proposed CCR landfill.

#### **Observed Conditions**

Potentiometric surfaces generated from water level measurements collected by Golder (February and June 2018) and Geosyntec (January 2019) were used as a basis for developing this estimated surface. Portions of the proposed landfill boundary situated on the topographic ridge and areas west of Ash Pond D (and less likely to be influenced by current Ash Pond D water levels) are consistent with current observed groundwater conditions at the Site.

#### **Seasonal Variation**

There are five well/piezometer locations in the vicinity of the Site that have been gauged for groundwater elevations routinely since 2016, and one additional location (PZ-46) that has been gauged since early 2018. Historical ranges of groundwater levels were considered for these wells, and the ranges summarized in Table 3-1 of the Site Acceptability Report. The difference between the maximum observed water level at each well and the levels measured in January 2019 is approximately 5 feet. This maximum increase was used as an estimate of the expected seasonal high groundwater level for the Site. Additionally, monthly groundwater level measurements at the Site through 2019 indicate that the observed water levels remain within this range.

#### **Pre-Ash Topography and Surface Drainage**

A topographic surface representing the bottom of Ash Pond D was used to approximate the pre-ash conditions at the pond, which will be re-encountered following excavation of the CCR material. This surface (included in the revised Figure 3-1) was used to project the expected future flow of groundwater, based on the regional conceptual model in the Piedmont of the water table surface being a subdued reflection of topography. Following removal of CCR, and removal of the standing water within Ash Pond D, the surface water drainage within and in the near vicinity of Ash Pond D is expected to return to conditions present prior to pond construction. These conditions would allow for natural baseflow of groundwater into the local drainage channels, thereby lowering the water table surface in the vicinity of Ash Pond D. In addition, the surface water elevation of Lake Sinclair remains fairly constant at approximately 340 ft MSL and is a major boundary condition influencing the potentiometric contours.

#### **Post-Closure Conditions**

The post-closure conditions at the Site will be affected by dewatering and removal of CCR from Ash Ponds B, C, D, and E, the diversion of surface water drainage in these areas, and by the

installation of a liner and cover system at the proposed CCR landfill. These factors are expected to contribute to an overall reduction in groundwater levels by eliminating the elevated heads at the ponds, allowing for drainage, and eliminating recharge over a large portion of the Site area. The conditions shown in Figure 3-1 are conservative in that they do not assume that the elimination of recharge has a significant impact on the groundwater levels beneath the proposed CCR landfill, due to the difficulty in quantifying that effect. It is likely that the post-closure groundwater levels will be even lower than those shown in Figure 3-1 due to this reduction in recharge.

In summary, the estimated seasonal high potentiometric surface after removal of CCR is a composite surface, based on observed groundwater elevations from January 2019, historical seasonal variations in groundwater elevations, and projected conditions that are based on commonly accepted hydrogeologic principles. It is an approximation of the conditions that we would likely expect during the later stages of pond closure activities, but should not be confused with measured, observed groundwater levels under current conditions.

**Comment No. 10:** *Groundwater elevation contouring should consider that the highest groundwater elevations determined in a site suitability study conducted in 2008 and 2009 for a proposed coal combustion by-product disposal facility were 403.90 feet (BH-16) and 403.91 (BH-19).*

**Response:** The temporary piezometer BH-16 was installed at the edge of the waste limit of Ash Pond D, and the temporary piezometer BH-19 was installed and screened within the CCR material in the footprint of Ash Pond D. At the time of the water level measurements in 2008-2009, the pond was still in operation, accepting sluice water from Plant activities. Water levels measured in these two piezometers (abandoned in 2009) were directly related to the free water contained in the pond during operational conditions. These water level measurements did not represent actual groundwater conditions in the near vicinity and do not represent current conditions, as water within Ash Pond D has been substantially reduced since the decommissioning of the Plant. Furthermore, the pond will be dewatered during the closure-by-removal activities. Therefore, the historical water level measurements at BH-16 and BH-19 should not factor in to the estimated post-closure seasonal high groundwater elevations.

**Comment No. 11:** *Soil laboratory test results, such as CEC values, for BH-1 through BH-19 should be included in the report.*

**Response:** The laboratory results from soil samples collected to estimate geotechnical properties and the cation exchange capacity of site soils were previously reported in the Plant Branch Proposed Coal Combustion By-Product Disposal Facility Site Acceptability Report (2009), and are included here as Attachment F.

Should you have any questions regarding this submittal, please contact David Gibbons 404-506-6234.

Sincerely,




Aaron D. Mitchell  
General Manager, Environmental Affairs  
**Georgia Power Company**  
Attachments

## **Attachment A**

---

### **Permit Boundary Legal Description**





FOR CLERK'S OFFICE USE

**SURVEYOR'S CERTIFICATION**  
This plat is a retracement of an existing parcel or parcels of land and does not subdivide or create a new parcel or make any changes to any real property boundaries. The recording information of the documents, maps, plats, or other instruments which created the parcel or parcels are stated herein. RECOGNITION OF THIS PLAT DOES NOT IMPLY APPROVAL OF ANY LOCAL JURISDICTION, AVAILABILITY OF PERMITS, COMPLIANCE WITH LOCAL REGULATIONS OR REQUIREMENTS, OR SUITABILITY FOR ANY USE OR PURPOSE OF THE LAND. Furthermore, the undersigned land surveyor certifies that this plat complies with the minimum technical standards for property surveys in Georgia as set forth in the rules and regulations of the Georgia Board of Registration for Professional Engineers and Land Surveyors and as set forth in O.C.G.A. Section 15-6-2.

*Hollie S. Hall*  
Hollie S. Hall, GA RLS 3368

CONTROL	STATE PLANE
CP 1	N 1169521.62 E: 2553558.67
EL: 436.38	
CP 2	N 1169747.21 E: 2548645.78
EL: 453.95	

**COORDINATE SYSTEM INFORMATION TABLE**

**COORDINATE SYSTEM BASED ON STATE PLANE WEST**

AVERAGE ELEVATION: 445.16'  
STATE PLANE AVE. SCALE FACTOR: 1.00594949  
COMPUTED ELEVATION FACTOR: 0.99997871  
CONVERGENCE: 03'36"30"  
GA WEST NAD83(2011) ZONE, NAD (98)  
CONTROL INFORMATION ESTABLISHED WITH  
JAVAD TRIUMPH-S DUAL-FREQUENCY GPS  
RECEIVER REFERENCE: 4GPS VIRTUAL BASE  
STATION DATA.

DENOTES PAINTED TREES  
OR FENCE NEAR PROPERTY  
LINE. LETTER IS CODE BELOW,  
NUMBER IS FEET FROM LINE,  
AND ARROW IS DIRECTION FROM  
LINE THAT EVIDENCE WAS FOUND.

TP: STEEL TEE POST W: WHITE PAINT  
B: BLUE PAINT CL: CHAIN LINK  
Y: YELLOW PAINT BW: BARBED WIRE  
R: RED PAINT HW: HOG WIRE

LINE LEGEND	
	PROPERTY BOUNDARY
	COUNTY LINE
	OVERHEAD POWER
	EASEMENT
	ADJOINING PROPERTY LINE
	ASPHALT PAVEMENT
	EDGE OF DIRT/GRAVEL
	STRUCTURE (AERIAL LOC)
	WIRE FENCE
	CHAIN LINK FENCE
	DRAINAGE PIPE
	340' CONTOUR-FULL POOL ELEVATION
	350' CONTOUR-LAKE SINCLAIR FERC
	PROJECT BOUNDARY
	WATER

PLAT ABBREVIATIONS	MONUMENTATION LEGEND
IPF Iron Pin Found	
IPS Iron Pin Set w/plastic cap	
stamped Jordan Engineering RLS 2902	
CTP Crimp-Top Pipe	
OTF Open Top Pipe	
CM Concrete Monument	
AI Angle Iron	
LL Land Lot	
D.B. Dead Book	
P.B. Plot Book	
SL Slide	
P.O.B. Point of Beginning	
P.O.R. Point of Reference	
FEMA Federal Emergency Management Agency	
OHP Overhead Power	
N.T.S. Not to Scale	
GPC Georgia Power Company	
NOF Now or Formerly	

**SURVEY CLOSURE STATEMENT**

FIELD DATA WAS COLLECTED USING A LEICA TS12 ROBOTIC TOTAL STATION AND A JAVAD TRIUMPH-S DUAL-FREQUENCY GPS RECEIVER REFERENCE THE 4GPS STATEWIDE NETWORK AND HAVING A RELATIVE POSITIONAL ACCURACY OF 0.04 FEET.

THIS PLAT HAS BEEN CALCULATED FOR CLOSURE AND IS FOUND TO BE ACCURATE WITHIN 1 FOOT IN 1,513,367 FEET.

ORIGINAL FIELD WORK FOR THE OVERALL PLANT BRANCH BOUNDARY WAS COMPLETED IN JANUARY, 2018. ONCE THE CCR LANDFILL BOUNDARY IS APPROVED, ALL PINS ASSOCIATED WITH THE LANDFILL WILL BE SET.

ADJACENT PROPERTY OWNERS		
17	19	21
NOF 0848001 MICHAEL E. HOUSE D.B. 895, p. 388 P.B. 26, p. 121	NOF 0848003 JAMES E. BLACK D.B. 627, p. 696 P.B. 26, p. 121	NOF 0848005 DONALD H. OGLETREE D.B. 393, p. 247 P.B. 26, p. 121
18	20	
NOF 0848002 JAMES BLACK D.B. 482, p. 124 P.B. 26, p. 121	NOF 0848004 ORCHARD HILLS DEVELOPMENT D.B. 314, p. 557 P.B. 26, p. 7	
NOF 0848060 MARY BELL VAUGHN D.B. 890, p. 545 GPC MAP NO. P273-20	NOF 0848061 JOEL F. MANN D.B. 820, p. 139 GPC MAP NO. P360-8	



SUBJECT PROPERTY INFORMATION	
TAX PARCEL:	083 021
CURRENT OWNER:	GEORGIA POWER COMPANY
DEED REFERENCE:	D.B. 5M, p. 733
PLAT REFERENCE:	P.B. 26, p. 7, GPC MAP NO. M-3-20, GPC MAP NO. M-3-21
TAX PARCEL:	086 002
CURRENT OWNER:	GEORGIA POWER COMPANY
DEED REFERENCE:	D.B. 3K, p. 510, D.B. 3B, p. 597, D.B. 3E, p. 75, 83, 96
PLAT REFERENCE:	GPC MAP NO. M-3-8, GPC MAP NO. M-153, GPC MAP NO. M-153

**LEGAL DESCRIPTION - PLANT HARLEE BRANCH CCR LANDFILL PERMIT BOUNDARY 220.57 ACRES**

After the parcel lying and being in Lots 189, 190, 203 and 204, District 2, Georgia Militia District 312, Putnam County, Georgia, containing 220.57 acres, as shown on a plat prepared by Hollie S. Hall, Georgia RLS 3368, dated May 15, 2019, and being more particularly described as follows:

From the POINT OF COMMENCEMENT, which is a 3" by 3" concrete monument located on the southeasterly right-of-way of the Central of Georgia Railroad, having Georgia State Plane, West Zone, NAD83(2011) coordinates in US survey feet of north 1161977.303 and east 2554747.745, travel N24°59'46"E a distance of 2238.21 feet to a 1/2" rebar set on the easterly right-of-way of the Central of Georgia Railroad, having Georgia State Plane, West Zone, NAD83(2011) coordinates in US survey feet of north 1164005.874 and east 2555693.520, which is the POINT OF BEGINNING.

From the POINT OF BEGINNING, travel N8°28'53"E a distance of 885.92 feet along said easterly right-of-way to a 1/2" rebar set; then along a northeastward-curving arc having a chord N55°20'43"E a chord length of 816.71 feet, a radius of 558.06 feet, and an arc length of 916.19 feet to a 1/2" rebar set on the southeasterly right-of-way of the Central of Georgia Railroad; then N12°32'41"E a distance of 20.00 feet to a 1/2" rebar set on the southeasterly right-of-way of the Central of Georgia Railroad; then along a southeastward-curving arc having a chord S72°48'42"E a chord length of 93.59 feet, a radius of 578.06 feet, and an arc length of 93.70 feet to a point on said southeasterly right-of-way, then S67°05'33"E a distance of 242.34 feet to a 1/2" rebar set; then S67°05'33"E a distance of 242.34 feet to a 1/2" rebar set; then S60°17'54"E a distance of 467.52 feet to a 1/2" rebar set; then S67°14'19"E a distance of 1951.80 feet to a 1/2" rebar set on the northerly line of the Georgia Transmission Company (formerly known as Ogletree Power Company) Plant Harlee Branch-Bonaire 230KV Transmission Line #1, having Georgia State Plane, West Zone, NAD83(2011) coordinates in US survey feet of north 1164255.301 and east 2559020.235; then along said northerly line of the Georgia Transmission Company (formerly known as Ogletree Power Company) Plant Harlee Branch-Bonaire 230KV Transmission Line #1 travel S10°15'57"W a distance of 1696.11 feet to a point on the northerly line of the Georgia Transmission Company (formerly known as Ogletree Power Company) Plant Harlee Branch-Bonaire 230KV Transmission Line #1, then continuing along said northerly line of the Georgia Transmission Company (formerly known as Ogletree Power Company) Plant Harlee Branch-Bonaire 230KV Transmission Line #1 travel S7°10'57"W a distance of 1612.02 feet to a 1/2" rebar set on the northerly line of the Georgia Transmission Company (formerly known as Ogletree Power Company) Plant Harlee Branch-Bonaire 230KV Transmission Line #1; then continuing along said northerly line travel N82°49'40"W a distance of 50.01 feet to a 1/2" rebar set; then leaving said northerly line travel N90°00'00"W a distance of 1101.54 feet to a 1/2" rebar set; then N38°11'13"W a distance of 102.67 feet to a 1/2" rebar set; then N75°27'33"E a distance of 84.40 feet to a 1/2" rebar set; then N22°49'16"E a distance of 62.69 feet to a 1/2" rebar set; then N62°57'25"W a distance of 97.43 feet to a 1/2" rebar set; then N21°45'04"E a distance of 99.95 feet to a 1/2" rebar set; then N69°49'52"E a distance of 173.27 feet to a 1/2" rebar set; then S53°13'16"E a distance of 441.71 feet to a 1/2" rebar set; then S88°21'01"W a distance of 173.28 feet to a 1/2" rebar set; then S88°59'41"E a distance of 51.74 feet to a 1/2" rebar set; then N10°32'18"W a distance of 510.60 feet to a 1/2" rebar set; then N63°13'50"E a distance of 258.11 feet to a 1/2" rebar set; then N24°32'20"W a distance of 658.49 feet to a 1/2" rebar set; then N31°14'29"W a distance of 861.31 feet to the POINT OF BEGINNING.



**JORDAN ENGINEERING**

144 N. WARREN ST. MONTICELLO, GA 31064  
(706) 468-0999 www.jordan-eng.com

Engineering • Surveying • Soils Classification

T:\Working2\Plants\Branch\2019040178 Plant Branch - CCR Landfill Boundary Survey

Georgia Power Company

**PROPERTY BOUNDARY SURVEY PLANT HARLEE BRANCH CCR LANDFILL PERMIT BOUNDARY**

LAND LOTS 189, 190, 203 & 204 2nd DISTRICT, 312 G.M.D., PUTNAM COUNTY, GEORGIA

DR.	TR.	Checked
HSJ	TRJ	ROJ/HSJ
SCALE: 1" = 300'		DATE: 06.27.2019
DRAWING NUMBER	SHEET NUMBER	
P478-12	SHEET 1 OF 1	






## **Attachment B**

---

### **Revised Cross Section and Figures**



\\CADD\GEORGIA POWER\PLANT BRANCH\GW6364.01\LANDFILL\FIGURES\GW6364-FIG01.R1



**LEGEND**

**BH-SERIES\*** BORINGS AND TEMPORARY PIEZOMETERS INSTALLED BY SCS (2007 - 2009).

**BRGW-SERIES** MONITORING WELLS INSTALLED BY SCS (2014).

**PZ-SERIES** PIEZOMETERS INSTALLED BY GOLDER (2016).

**PB-SERIES** BORINGS AND PIEZOMETERS INSTALLED BY GEOSYNTEC (2018 - 2019).

NOTES:  
1. \* BH-SERIES TEMPORARY PIEZOMETERS WERE ABANDONED IN 2009.  
2. THE GEOLOGIC LAYERS MODEL THAT KRIGGED LITHOLOGIC CONTACT DATA FROM BORINGS WITHIN AND IN THE NEAR VICINITY OF THE SITE.

GROUNDWATER LEVEL MEASUREMENTS (31 JANUARY 2019)

ESTIMATED SEASONAL HIGH GROUNDWATER ELEVATION AFTER REMOVAL OF CCR (BASED ON CURRENT AND HISTORICAL GROUNDWATER ELEVATION RANGES, SITE TOPOGRAPHY, AND SURFACE WATER ELEVATIONS)

EXISTING CCR

REGOLITH - RESIDUAL SOILS AND SAPROLITE CONSISTING OF A THIN SURFICIAL LAYER OF CLAYEY SILT TO SILTY CLAY UNDERLAIN BY SANDY CLAY AND SILTY OR CLAYEY SAND. SAPROLITE IS STIFF AND MICACEOUS, WITH RELICT ROCK STRUCTURES.

PARTIALLY WEATHERED ROCK (PWR) - HIGHLY WEATHERED TO DECOMPOSED BEDROCK WITH SIMILAR CHARACTERISTICS TO THE SAPROLITE; SPT BLOW COUNTS EXCEEDING 50 BLOWS PER 6 INCHES.

FRACTURED GNEISS BEDROCK - WELL BANDED FOLIATED FELDSPATHIC BIOTITE GNEISS WITH LOW-ANGLE FRACTURES AND SOME WEATHERING.




GNEISS BEDROCK - WELL BANDED AND FOLIATED FELDSPATHIC BIOTITE GNEISS WITH VERY FEW TO NO JOINTS OR FRACTURES.

0 150 300  
SCALE IN FEET (HORIZONTAL)

0 30 60  
SCALE IN FEET (VERTICAL)









- LEGEND**
- BH-SERIES\*** BORINGS AND TEMPORARY PIEZOMETERS INSTALLED BY SCS (2007 - 2009).
  - BRGW-SERIES** MONITORING WELLS INSTALLED BY SCS (2014).
  - PZ-SERIES** PIEZOMETERS INSTALLED BY GOLDER (2016).
  - PB-SERIES** BORINGS AND PIEZOMETERS INSTALLED BY GEOSYNTEC (2018 - 2019).
- NOTES:
- \* BH-SERIES TEMPORARY PIEZOMETERS WERE ABANDONED IN 2009.
  - THE GEOLOGIC LAYERS WERE DEVELOPED USING A 3-DIMENSIONAL EVS MODEL THAT KRIGGED LITHOLOGIC CONTACT DATA FROM BORINGS WITHIN AND IN THE NEAR VICINITY OF THE SITE.

- GROUNDWATER LEVEL MEASUREMENTS (31 JANUARY 2019)
- ESTIMATED SEASONAL HIGH GROUNDWATER ELEVATION AFTER REMOVAL OF CCR (BASED ON CURRENT AND HISTORICAL GROUNDWATER ELEVATION RANGES, SITE TOPOGRAPHY, AND SURFACE WATER ELEVATIONS)
- DIKE MATERIAL
- CCR
- REGOLITH - RESIDUAL SOILS AND SAPROLITE CONSISTING OF A THIN SURFICIAL LAYER OF CLAYEY SILT TO SILTY CLAY UNDERLAIN BY SANDY CLAY AND SILTY OR CLAYEY SAND
- SAPROLITE IS STIFF AND MICACEOUS, WITH RELICT ROCK STRUCTURES.
- PARTIALLY WEATHERED ROCK (PWR) - HIGHLY WEATHERED TO DECOMPOSED BEDROCK WITH SIMILAR CHARACTERISTICS TO THE SAPROLITE; SPT BLOW COUNTS EXCEEDING 50 BLOWS PER 6 INCHES.
- FRACTURED GNEISS BEDROCK - WELL BANDED FOLIATED FELDSPATHIC BIOTITE GNEISS WITH LOW-ANGLE FRACTURES AND SOME WEATHERING.
- GNEISS BEDROCK - WELL BANDED AND FOLIATED FELDSPATHIC BIOTITE GNEISS WITH VERY FEW TO NO JOINTS OR FRACTURES.







LEGEND

MONITORING WELL (NOTE 1)

GEOSYNTEC BORING/TEMPORARY  
PIEZOMETER (NOTE 1)

PIEZOMETER (NOTE 1)

CCR PERMIT BOUNDARY

OVERHEAD POWER TRANSMISSION LINES

POWER TRANSMISSION LINE EASEMENT

PROPERTY BOUNDARY

LIMIT OF WASTE

ASH POND BOUNDARY

GROUNDWATER ELEVATION  
ISO-CONTOUR (DASHED WHERE  
INFERRED)

ACCESS ROAD

EXISTING GROUND ELEVATION (FEET)

POWER POLE

TRAILER OR BUILDING

REPRESENTATIVE HYDRAULIC  
GRADIENTS

- NOTES:
1.

WATER LEVEL MEASUREMENTS RECORDED ON JANUARY 31, 2019.  
ELEVATION PROVIDED IN FEET ABOVE MEAN SEA LEVEL (FT MSL).
2.

PZ-12D AND PB-4D NOT USED TO DEVELOP THE POTENTIOMETRIC SURFACE  
MAP AS WATER LEVEL READINGS APPEARED TO BE ANOMALOUS.  
BRGWA-12S WAS DRY AT TIME OF GAUGING.



POTENTIOMETRIC SURFACE MAP - 31 JANUARY 2019


PLANT BRANCH CCR LANDFILL  
PUTNAM COUNTY, GEORGIA

Geosyntec  
consultants

1255 ROBERTS BOULEVARD NW, SUITE 200 KENNESAW, GEORGIA 30144-3694		PHONE: 678.202.9500 WWW.GEOSYNTEC.COM	
PROJ. NO.	GW6364	DWG.	6364-F2-7
SCALE	1" = 250'	EDIT	11.15.19
DATE	NOVEMBER 2019	FIGURE	2 - 7









## **Attachment C**


---

### **CPT Logs**

Project #: 18-1101-0072  
Date: Dec. 17, 2018

Latitude: 33.1979  
Longitude: -83.3174

Elevation: 415.0262  
Filename: 18-1102-0072ccpt 1A.cpt




# Cone Penetration Test SCPT 2(1)

Project #: 18-1101-0072  
Date: Dec. 13, 2018

Latitude: 33.1994  
Longitude: -83.3156

Elevation: 446.5223  
Filename: 18-1102-0072acpt 2(1)A.cpt




- |                                   |  |                                    |
|-----------------------------------|--|------------------------------------|
| 1 - Sensitive, Fine Grained Soils | 4 - Silt Mixtures-Clay Silt to Silty Clay  | 7 - Gravelly Sand to Sand          |
| 2 - Organic Soils, Peats          | 5 - Sand Mixtures-Silty Sand to Silty Silt | 8 - Very Stiff Clay to Clayey Sand |
| 3 - Clays-Clay to Silty Clay      | 6 - Sands-Clean Sand to Silty Sand         | 9 - Very Stiff Fine Grained Soils  |

# Cone Penetration Test SCPT 2(1)

Project #: 18-1101-0072  
Date: Dec. 13, 2018

Latitude: 33.1994  
Longitude: -83.3156

Elevation: 446.5223  
Filename: 18-1102-0072acpt 2(1)A.cpt



1 - Sensitive, Fine Grained Soils  
2 - Organic Soils, Peats  
3 - Clays-Clay to Silty Clay


4 - Silt Mixtures-Clay Silt to Silty Clay  
5 - Sand Mixtures-Silty Sand to Sandy Silt  
6 - Sands-Clean Sand to Silty Sand

7 - Gravelly Sand to Sand  
8 - Very Stiff Clay to Clayey Sand  
9 - Very Stiff Fine Grained Soils

Project #: 18-1101-0072  
Date: Dec. 14, 2018

Latitude: 33.1953  
Longitude: -83.3162

Elevation: 429.4619  
Filename: 18-1102-0072bcpt 3A.cpt



- |                                   |  |                                    |
|-----------------------------------|--|------------------------------------|
| 1 - Sensitive, Fine Grained Soils | 4 - Silt Mixtures-Clay Silt to Silty Clay  | 7 - Gravelly Sand to Sand          |
| 2 - Organic Soils, Peats          | 5 - Sand Mixtures-Silty Sand to Sandy Silt | 8 - Very Stiff Clay to Clayey Sand |
| 3 - Clays-Clay to Silty Clay      | 6 - Sands-Clean Sand to Silty Sand         | 9 - Very Stiff Fine Grained Soils  |

Project #: 18-1101-0072


Date: Dec. 17, 2018

Latitude: 33.1958

Longitude: -83.3158

Elevation: 406.1679

Filename: 18-1102-0072ccpt 4A.cpt



1 - Sensitive, Fine Grained Soils

2 - Organic Soils, Peats

3 - Clays-Clay to Silty Clay

4 - Silt Mixtures-Clay Silt to Silty Clay

5 - Sand Mixtures-Silty Sand to Sandy Silt

6 - Sands-Clean Sand to Silty Sand

7 - Gravelly Sand to Sand

8 - Very Stiff Clay to Clayey Sand


9 - Very Stiff Fine Grained Soils



**Project #:** 18-1101-0072  
**Date:** Dec. 17, 2018

**Latitude:** 33.1958  
**Longitude:** -83.3158

**Elevation:** 406.1679  
**Filename:** 18-1102-0072ccpt 4A.cpt




- |                                   |  |                                    |
|-----------------------------------|--|------------------------------------|
| 1 - Sensitive, Fine Grained Soils | 4 - Silt Mixtures-Clay Silt to Silty Clay  | 7 - Gravelly Sand to Sand          |
| 2 - Organic Soils, Peats          | 5 - Sand Mixtures-Silty Sand to Sandy Silt | 8 - Very Stiff Clay to Clayey Sand |
| 3 - Clays-Clay to Silty Clay      | 6 - Sands-Clean Sand to Silty Sand         | 9 - Very Stiff Fine Grained Soils  |

Project #: 18-1101-0072  
Date: Dec. 13, 2018

Latitude: 33.1943  
Longitude: -83.3118

Elevation: 392.0603  
Filename: 18-1102-0072acpt 5A.cpt




- |                                   |  |                                    |
|-----------------------------------|--|------------------------------------|
| 1 - Sensitive, Fine Grained Soils | 4 - Silt Mixtures-Clay Silt to Silty Clay  | 7 - Gravelly Sand to Sand          |
| 2 - Organic Soils, Peats          | 5 - Sand Mixtures-Silty Sand to Sandy Silt | 8 - Very Stiff Clay to Clayey Sand |
| 3 - Clays-Clay to Silty Clay      | 6 - Sands-Clean Sand to Silty Sand         | 9 - Very Stiff Fine Grained Soils  |

Project #: 18-1101-0072  
Date: Dec. 13, 2018

Latitude: 33.1943  
Longitude: -83.3118

Elevation: 392.0603  
Filename: 18-1102-0072acpt 5A.cpt




- |                                   |  |                                    |
|-----------------------------------|--|------------------------------------|
| 1 - Sensitive, Fine Grained Soils | 4 - Silt Mixtures-Clay Silt to Silty Clay  | 7 - Gravelly Sand to Sand          |
| 2 - Organic Soils, Peats          | 5 - Sand Mixtures-Silty Sand to Sandy Silt | 8 - Very Stiff Clay to Clayey Sand |
| 3 - Clays-Clay to Silty Clay      | 6 - Sands-Clean Sand to Silty Sand         | 9 - Very Stiff Fine Grained Soils  |

Project #: 18-1101-0072  
Date: Dec. 13, 2018

Latitude: 33.1966  
Longitude: -83.3145

Elevation: 424.8687  
Filename: 18-1102-0072acpt 6A.cpt




- |                                   |  |                                    |
|-----------------------------------|--|------------------------------------|
| 1 - Sensitive, Fine Grained Soils | 4 - Silt Mixtures-Clay Silt to Silty Clay  | 7 - Gravelly Sand to Sand          |
| 2 - Organic Soils, Peats          | 5 - Sand Mixtures-Silty Sand to Sandy Silt | 8 - Very Stiff Clay to Clayey Sand |
| 3 - Clays-Clay to Silty Clay      | 6 - Sands-Clean Sand to Silty Sand         | 9 - Very Stiff Fine Grained Soils  |

**Project #:** 18-1101-0072  
**Date:** Dec. 13, 2018

**Latitude:** 33.1966  
**Longitude:** -83.3145

**Elevation:** 424.8687  
**Filename:** 18-1102-0072acpt 6A.cpt




- |                                   |  |                                    |
|-----------------------------------|--|------------------------------------|
| 1 - Sensitive, Fine Grained Soils | 4 - Silt Mixtures-Clay Silt to Silty Clay  | 7 - Gravelly Sand to Sand          |
| 2 - Organic Soils, Peats          | 5 - Sand Mixtures-Silty Sand to Sandy Silt | 8 - Very Stiff Clay to Clayey Sand |
| 3 - Clays-Clay to Silty Clay      | 6 - Sands-Clean Sand to Silty Sand         | 9 - Very Stiff Fine Grained Soils  |

Project #: 18-1101-0072  
Date: Dec. 17, 2018

Latitude: 33.1967  
Longitude: -83.318

Elevation: 405.8398  
Filename: 18-1102-0072ccpt 7A.cpt



- |                                   |  |                                    |
|-----------------------------------|--|------------------------------------|
| 1 - Sensitive, Fine Grained Soils | 4 - Silt Mixtures-Clay Silt to Silty Clay  | 7 - Gravelly Sand to Sand          |
| 2 - Organic Soils, Peats          | 5 - Sand Mixtures-Silty Sand to Sandy Silt | 8 - Very Stiff Clay to Clayey Sand |
| 3 - Clays-Clay to Silty Clay      | 6 - Sands-Clean Sand to Silty Sand         | 9 - Very Stiff Fine Grained Soils  |

Project #: 18-1101-0072


Date: Dec. 13, 2018

Latitude:

Longitude:

Elevation: 424.8687

Filename: 18-1102-0072acpt 8(1)A.cpt



1 - Sensitive, Fine Grained Soils

2 - Organic Soils, Peats

3 - Clays-Clay to Silty Clay

4 - Silt Mixtures-Clay Silt to Silty Clay

5 - Sand Mixtures-Silty Sand to Sandy Silt

6 - Sands-Clean Sand to Silty Sand

7 - Gravelly Sand to Sand


8 - Very Stiff Clay to Clayey Sand

9 - Very Stiff Fine Grained Soils

Project #: 18-1101-0072  
Date: Dec. 14, 2018

Latitude: 33.1937  
Longitude: -83.3134

Elevation: 415.0262  
Filename: 18-1102-0072bcpt 9A.cpt




- |                                   |  |                                    |
|-----------------------------------|--|------------------------------------|
| 1 - Sensitive, Fine Grained Soils | 4 - Silt Mixtures-Clay Silt to Silty Clay  | 7 - Gravelly Sand to Sand          |
| 2 - Organic Soils, Peats          | 5 - Sand Mixtures-Silty Sand to Sandy Silt | 8 - Very Stiff Clay to Clayey Sand |
| 3 - Clays-Clay to Silty Clay      | 6 - Sands-Clean Sand to Silty Sand         | 9 - Very Stiff Fine Grained Soils  |



Project #: 18-1101-0072  
Date: Dec. 17, 2018

Latitude:  
Longitude:

Elevation: 405.8398  
Filename: 18-1102-0072ccpt 10A.cpt




- |                                   |  |                                    |
|-----------------------------------|--|------------------------------------|
| 1 - Sensitive, Fine Grained Soils | 4 - Silt Mixtures-Clay Silt to Silty Clay  | 7 - Gravelly Sand to Sand          |
| 2 - Organic Soils, Peats          | 5 - Sand Mixtures-Silty Sand to Sandy Silt | 8 - Very Stiff Clay to Clayey Sand |
| 3 - Clays-Clay to Silty Clay      | 6 - Sands-Clean Sand to Silty Sand         | 9 - Very Stiff Fine Grained Soils  |

Project #: 18-1101-0072  
Date: Dec. 13, 2018

Latitude: 33.1967  
Longitude: -83.3124


Elevation: 419.9475  
Filename: 18-1102-0072acpt 11(1)A.cpt



**Project #:** 18-1101-0072  
**Date:** Dec. 13, 2018

**Latitude:** 33.1967  
**Longitude:** -83.3124

**Elevation:** 419.9475  
**Filename:** 18-1102-0072acpt 11(1)A.cpt




- |                                   |  |                                    |
|-----------------------------------|--|------------------------------------|
| 1 - Sensitive, Fine Grained Soils | 4 - Silt Mixtures-Clay Silt to Silty Clay  | 7 - Gravelly Sand to Sand          |
| 2 - Organic Soils, Peats          | 5 - Sand Mixtures-Silty Sand to Sandy Silt | 8 - Very Stiff Clay to Clayey Sand |
| 3 - Clays-Clay to Silty Clay      | 6 - Sands-Clean Sand to Silty Sand         | 9 - Very Stiff Fine Grained Soils  |

Project #: 18-1101-0072  
Date: Dec. 14, 2018

Latitude: 33.1933  
Longitude: -83.3167

Elevation: 333.6614  
Filename: 18-1102-0072bcpt 12A.cpt





- |                                   |  |                                    |
|-----------------------------------|--|------------------------------------|
| 1 - Sensitive, Fine Grained Soils | 4 - Silt Mixtures-Clay Silt to Silty Clay  | 7 - Gravelly Sand to Sand          |
| 2 - Organic Soils, Peats          | 5 - Sand Mixtures-Silty Sand to Sandy Silt | 8 - Very Stiff Clay to Clayey Sand |
| 3 - Clays-Clay to Silty Clay      | 6 - Sands-Clean Sand to Silty Sand         | 9 - Very Stiff Fine Grained Soils  |

Project #: 18-1101-0072  
Date: Dec. 14, 2018

Latitude: 33.1933  
Longitude: -83.3167



Elevation: 333.6614  
Filename: 18-1102-0072bcpt 12A.cpt



**Project #:** 18-1101-0072  
**Date:** Dec. 14, 2018

**Latitude:** 33.191  
**Longitude:** -83.3158

**Elevation:** 359.9081  
**Filename:** 18-1102-0072bcpt 13A.cpt




# Cone Penetration Test SCPT 13(1)

Project #: 18-1101-0072  
Date: Dec. 14, 2018

Latitude: 33.191  
Longitude: -83.3158

Elevation: 370.0787  
Filename: 18-1102-0072bcpt 13(1)A.cpt




- |                                   |  |                                    |
|-----------------------------------|--|------------------------------------|
| 1 - Sensitive, Fine Grained Soils | 4 - Silt Mixtures-Clay Silt to Silty Clay  | 7 - Gravelly Sand to Sand          |
| 2 - Organic Soils, Peats          | 5 - Sand Mixtures-Silty Sand to Sandy Silt | 8 - Very Stiff Clay to Clayey Sand |
| 3 - Clays-Clay to Silty Clay      | 6 - Sands-Clean Sand to Silty Sand         | 9 - Very Stiff Fine Grained Soils  |

# Cone Penetration Test SCPT 13(2)

Project #: 18-1101-0072  
Date: Dec. 14, 2018

Latitude: 33.191  
Longitude: -83.3158

Elevation: 378.937  
Filename: 18-1102-0072bcpt 13(2)A.cpt



- |                                   |  |                                    |
|-----------------------------------|--|------------------------------------|
| 1 - Sensitive, Fine Grained Soils | 4 - Silt Mixtures-Clay Silt to Silty Clay  | 7 - Gravelly Sand to Sand          |
| 2 - Organic Soils, Peats          | 5 - Sand Mixtures-Silty Sand to Sandy Silt | 8 - Very Stiff Clay to Clayey Sand |
| 3 - Clays-Clay to Silty Clay      | 6 - Sands-Clean Sand to Silty Sand         | 9 - Very Stiff Fine Grained Soils  |




# Cone Penetration Test SCPT 13(3)

Project #: 18-1101-0072  
Date: Dec. 14, 2018

Latitude: 33.191  
Longitude: -83.3159

Elevation: 387.7952  
Filename: 18-1102-0072bcpt 13(3)A.cpt




- |                                   |  |                                    |
|-----------------------------------|--|------------------------------------|
| 1 - Sensitive, Fine Grained Soils | 4 - Silt Mixtures-Clay Silt to Silty Clay  | 7 - Gravelly Sand to Sand          |
| 2 - Organic Soils, Peats          | 5 - Sand Mixtures-Silty Sand to Sandy Silt | 8 - Very Stiff Clay to Clayey Sand |
| 3 - Clays-Clay to Silty Clay      | 6 - Sands-Clean Sand to Silty Sand         | 9 - Very Stiff Fine Grained Soils  |

Project #: 18-1101-0072  
Date: Dec. 14, 2018

Latitude: 33.1929  
Longitude: -83.3145

Elevation: 430.7742  
Filename: 18-1102-0072bcpt 14A.cpt



- |                                   |  |                                    |
|-----------------------------------|--|------------------------------------|
| 1 - Sensitive, Fine Grained Soils | 4 - Silt Mixtures-Clay Silt to Silty Clay  | 7 - Gravelly Sand to Sand          |
| 2 - Organic Soils, Peats          | 5 - Sand Mixtures-Silty Sand to Sandy Silt | 8 - Very Stiff Clay to Clayey Sand |
| 3 - Clays-Clay to Silty Clay      | 6 - Sands-Clean Sand to Silty Sand         | 9 - Very Stiff Fine Grained Soils  |

Response to SAR Comments – Proposed CCR Landfill  
Georgia Power – Plant Branch – Putnam County, Georgia  
Georgia Environmental Protection Division  
January 2020

## **Attachment D**

---

### **Geologic and Hydrogeologic Summary Report (Golder 2018)**

# GEOLOGIC AND HYDROGEOLOGIC SUMMARY REPORT

---

PLANT BRANCH

PUTNAM COUNTY, GEORGIA

FOR



Georgia  
Power

OCTOBER 2018



GOLDER

# Table of Contents

<b>CERTIFICATION .....</b>	<b>1</b>
<b>1.0 INTRODUCTION .....</b>	<b>2</b>
<b>2.0 BACKGROUND INFORMATION.....</b>	<b>2</b>
2.1 Site Description and Physiography .....	2
2.2 Regional Geologic and Hydrogeologic Setting .....	2
2.2.1 Regional Geology .....	3
2.2.2 Regional Hydrogeology.....	3
<b>3.0 SITE GEOLOGIC CONDITIONS .....</b>	<b>4</b>
3.1 Geologic Mapping Methodology.....	4
3.2 Residual Soil and Saprolite .....	4
3.3 Lithologic Units .....	5
3.4 Geologic Structure .....	5
3.4.1 Foliation and Faults.....	5
3.4.2 Joints .....	6
3.5 Lineament Analysis .....	6
3.5.1 Methodology.....	6
3.5.2 Discussion of Lineaments .....	7
3.5.3 Discontinuity Mapping and Lineament analysis Correlation .....	7
<b>4.0 CONCEPTUAL SITE HYROGEOLOGIC MODEL .....</b>	<b>8</b>
4.1 Uppermost Groundwater Aquifer .....	8
4.2 Bedrock Aquifer System.....	9
4.3 Conceptual Site Hydrogeologic Model Summary .....	9
<b>5.0 REFERNCES .....</b>	<b>10</b>

## Table of Contents - continued

### FIGURES & TABLES

<b>Figure 1</b>	<b>Existing Conditions</b>
<b>Figure 2</b>	<b>Geologic Map</b>
<b>Figure 3</b>	<b>Estimated Top of Rock Map</b>
<b>Figure 4</b>	<b>Geologic Cross Sections</b>
<b>Figure 5</b>	<b>Discontinuity Data from Geologic Mapping</b>
<b>Figure 6</b>	<b>Remote Sensing Lineament Map / Comparison of Measured Discontinuities and Lineaments</b>
<b>Figure 7</b>	<b>Potentiometric Surface Elevation Contour Map – June 25, 2018</b>
<b>Table 1</b>	<b>Summary of Historical Groundwater Elevations</b>

## Certification

This *Geological and Hydrogeological Report*, Georgia Power Company - Plant Scherer has been prepared in compliance with applicable Georgia Solid Waste Management Rule by a qualified groundwater scientist or engineer with Golder Associates Inc. References to the appropriate 391-3-4 Rules are incorporated throughout this document.

I hereby certify that, I, Rachel P. Kirkman, a "Qualified Groundwater Scientist," in accordance with the Rules of Solid Waste Management, this *Geological and Hydrogeological Report* was prepared under my direct supervision. This technical report of geologic and hydrogeologic units was developed to meet compliance of Georgia Environmental Protection Division Rule 391-3-4-.10(9)(c)(6)(ii).

**Golder Associates Inc.**



Dawn L. Prell, CPG  
Hydrogeologist, Senior Consultant

10/23/2018

Date



Rachel P. Kirkman, PG  
Registered Professional Geologist, No. 1756

10/23/2018

Date

dlp/rpk

Golder and the G logo are trademarks of Golder Associates Corporation

[https://golderassociates.sharepoint.com/sites/11952g/shared documents/200 reports/geologic hydrogeologic report/hydrogeo report branch\\_10.2018\\_final.docx](https://golderassociates.sharepoint.com/sites/11952g/shared%20documents/200%20reports/geologic%20hydrogeologic%20report/hydrogeo%20report%20branch_10.2018_final.docx)

## 1.0 INTRODUCTION

Georgia Environmental Protection Division (EPD) Rule 391-3-4-.10 of the Georgia Solid Waste Management Regulations provides the requirements for permitting and closure of CCR regulated facilities in Georgia (GA). A technical report of geologic and hydrogeologic units within the disposal site is required for inactive surface impoundments as specified in Georgia EPD Rule 391-3-4-.10(9)(c)(6)(ii). This report describes geologic and hydrogeologic information for Georgia Power's Plant Branch (Plant Branch).

## 2.0 BACKGROUND INFORMATION

### 2.1 Site Description and Physiography

Plant Branch is located in Putnam County, GA, and is owned and operated by Georgia Power Company (GPC). The Plant occurs approximately 8 miles north of Milledgeville, GA and is located north and west of Lake Sinclair. The plant is primarily surrounded by agricultural, residential, and light commercial land use. The property occupies approximately 3,200 acres and is bounded on the south and east by Lake Sinclair, which is an approximate 15,330-acre hydroelectric reservoir that was created in 1953 by GPC's impoundment of the Oconee River. A site location map is included as Figure 1, Existing Conditions

Plant Branch is no longer active and is in the process of decommissioning. While active, the Plant consisted of four coal-fired units that were equipped with flue gas desulfurization (FGD) equipment (i.e., scrubbers). Prior to plant decommissioning, bottom ash, fly ash, and small quantities of FGD wastes were managed onsite within five ash ponds, namely Ponds A, B, C, D, and E ranging in size from one acre to approximately 311 acres. The largest of the ash ponds (E;) has been developed on-site through impoundment of natural, unnamed tributaries that merged and drained in a general west-to-east direction to Beaverdam Creek, which is now an embayment of Lake Sinclair. The pond is maintained at an elevation of approximately 426 feet by a large earthen embankment, at the base of which a series of wells collect pore fluids for recirculation back into the pond.

The site occurs within the Piedmont Physiographic Province of central Georgia, which is characterized by gently rolling hills and narrow valleys, with locally pronounced linear ridges. Overall, the property slopes gently east and south towards Beaverdam Creek and Lake Sinclair. Ash pond E is located in the generally topographically highest area on the property, with radial surface water drainage downslope of the pond to the northeast and east, toward Beaverdam Creek, and to the south toward Lake Sinclair. Several topographically isolated hilltops occur west of Pond E, forming a topographic and surface water (and presumably groundwater) divide between the pond and the embayment to the west of the pond, as shown on Figure 1. Topographic relief across the site is less than 150 feet, with a natural topographic high of nearly 485 feet above mean sea level (ft msl) occurring along the topographic ridge west of Pond E, and with a topographic low where Beaverdam Creek discharges into Lake Sinclair at less than 350 feet.

### 2.2 Regional Geologic and Hydrogeologic Setting

The following section and subsections include a general description of regional geologic and hydrogeologic characteristics of formations that occur beneath the site. Information presented in this section is based on published literature, discussion with local geologic experts, and experience working in this geologic terrain. This information is intended to serve as a framework for site specific conditions presented in Section 3.0

Plant Branch is located on the Lake Sinclair West, GA USGS 7.5-minute topographic quadrangle. The Piedmont/Blue Ridge geologic province contains some of the oldest rocks in the Southeastern United States.



Since their origin, approximately 276 to 1100 million years ago (Ma), these late Precambrian (Neoproterozoic) to late Paleozoic (Permian) rocks have undergone repeated cycles of igneous intrusions and extrusions, metamorphism, folding, faulting, shearing, and silicification. The latest regional metamorphism and associated deformation has been attributed to the collision of the North America plate with the Eurasian plate approximately 200 to 230 Ma. More recent deformation and emplacement of mafic dikes is associated with the rifting of the North American craton during the Mesozoic and Cenozoic Eras.

The metamorphic and igneous rocks that underlie the area have been subjected to physical and chemical weathering which has created a landscape dissected by creeks and streams forming a dendritic drainage pattern. These rocks are deeply weathered due to the humid climate and bedrock is typically overlain by a variably thick blanket of residual soils and saprolite. The overall depth of weathering in the Piedmont/Blue Ridge is generally about 20 to 60 feet; however, the depth of weathering along discontinuities and/or very feldspathic rock units may extend to depths greater than 100 feet. Because of such variations in rock types and structure, the depth of weathering can vary significantly over short horizontal distances.

### 2.2.1 Regional Geology

The Lake Sinclair West, GA quadrangle occurs within the Carolina Terrane, which represents a former island arc sequence that docked onto the North American plate during early mountain building of the Appalachians. This terrane is characterized by the presence of metasedimentary and metavolcanic rocks that are locally interlayered with mafic and ultramafic bodies and subsequently intruded by granitic sills and diabase dikes.

Typically, up to four different joint sets formed in this area due to tectonic stresses imposed upon the bedrock. Dip joints form parallel to dip direction of foliation/compositional layering and are typically perpendicular to fold axes, representing extension in the maximum principal stress direction or direction of compression. These joints are commonly near vertical. Strike joints develop parallel to the strike of foliation/compositional layering and fold axes, typically forming from tension along fold hinges. The dip direction and angle of these joints is orthogonal to the dip direction and angle of compositional layering. Oblique joints develop diagonal ( $\pm 30^\circ$ ) to the principal stress direction and represent conjugate sets formed from shear (Refer to Figure 2.2.1, inset).




Figure 2.2.1 Schematic diagram showing the typical joint patterns

### 2.2.2 Regional Hydrogeology

Groundwater in the Piedmont/Blue Ridge geologic province can occur as perched water within residual soils, as an unconfined regional aquifer within residual soils and transitionally weathered materials and as a series of confined to semi-confined, discrete but locally interconnected aquifer systems within the bedrock. Perched groundwater occurs above the local or regional groundwater table and is locally developed above lithologies with relatively lower permeability which temporarily retard the natural downward infiltration of groundwater. This groundwater is unconfined, recharged by precipitation, and is laterally discontinuous and temporally transient.

The regional groundwater table is laterally consistent and generally occurs within overburden overlying fresh bedrock. In general, this overburden consists of residual soils and a transitionally weathered zone typical of Piedmont settings. Due to chemical weathering, saprolitic-soil retains relict structural features of the parent rock such as foliation and compositional layering while having the texture of a soil. Saprolitic rock is similar to the saprolitic soil but less decomposed. This saprolitic material is generally more permeable than the overlying residuum, and the underlying fresh rock, and serves to concentrate ground water along a tabular zone of enhanced permeability. Although weathering generally increases porosity and permeability within this zone, some processes taking place in this zone, such as the growth of clay minerals, mineral deposition in fractures, and development of iron oxide 'hardpan,' can significantly decrease the permeability. This tabular zone of enhanced permeability is referred to as the transitionally weathered zone, which is characterized by heterogeneously interlayered, fresh to completely weathered (saprolitic) rock.

Groundwater within the overburden (comprised of both residual soils and transitionally weathered rock) is generally unconfined, the surface of which is generally a subdued reflection of topography. It is recharged by precipitation stored in residual soils and typically discharges into major streams and rivers. During drought, the water levels within the overburden are overall lower. In areas where bedrock is relatively shallow and when water levels are seasonally depressed, the regional groundwater table also occurs within the upper zones of weathered bedrock.

Bedrock aquifer systems are recharged by groundwater that is stored in the overburden. This groundwater slowly infiltrates underlying bedrock aquifer systems by moving through preferentially weathered discontinuities in the bedrock mass, such as foliation/compositional layering, joints, and faults. The occurrence and characteristics of discontinuities (e.g., size, orientation, dilation, infilling, spacing, and persistence) are dependent on the lithology of the rock and the type of stresses applied to them. These discontinuities are locally enlarged along individual planes as well as at the intersection of planes due to physical and chemical weathering, providing preferential pathways for enhanced groundwater flow. Groundwater can move readily, both vertically and horizontally, through these isolated areas of enhanced porosity and permeability, and depending upon the size, concentration, and interconnection of these secondary openings, the bedrock can either be dry or host to high-yield wells.

## 3.0 SITE GEOLOGIC CONDITIONS

### 3.1 Geologic Mapping Methodology

Geologic mapping was performed by Petrologic Solutions, Inc. (Petrologic) within and around the site using the Lake Sinclair West, GA USGS 7.5-minute topographic quadrangle as a base map. Figure 2, Geologic Map presents interpretation of structural and lithologic features encountered during mapping of the area. Information recorded at each map station includes: lithology and mineralogy; orientation and characteristics of structural discontinuities including, shearing, faulting, jointing, and compositional bedding; and depth and type of weathering characteristics of the rock. Map station locations were recorded using a hand-held, Wide Area Augmentation System (WAAS)-enabled Global Positioning System (GPS).

### 3.2 Residual Soil and Saprolite

To develop a better understanding of subsurface conditions, available boring and monitoring well installation logs were reviewed. Revised interpretations were made, primarily related to depth to bedrock and the material that constitutes bedrock, considering criteria such as blow counts, rock core recovery, and rock quality designation (RQD) values. These data were used as the basis a top of rock contour map, presented as Figure 3, Estimated

Top of Rock, and for five geologic cross sections, presented as Figures 4A through 4D, Geologic Cross Sections Schematic.

Based on this review, residual soils, primarily sandy silt, silty sand, sandy clay and silty clay, occur as a variably-thick blanket overlying bedrock across most of the site, as illustrated on Figure 4. The thickness of residual soils encountered in the borings is variable, ranging from a minimum of 11 feet to as much as 74 feet. Saprolitic rock is also considered to be partially weathered rock (PWR), which is defined by Standard Penetration Test (SPT) blow counts that exceed 50 blows/foot. Where data were available to determine the thickness of PWR, it is relatively thin (i.e., 10 feet or less), if present, with the exception of a few locations where the thickness exceeds 20 feet.

The criterion used for identifying top of bedrock was largely based on the depth at which a significant thickness of fresh, relatively competent (i.e., RQD >50%) bedrock was encountered. Observations made in nearby borings, experience working in the Piedmont, and professional judgment were also used in interpreting top of rock elevations. These elevations were used to develop the top of rock contour map and are presented on Figure 3. The cross sections were also used to bolster three-dimensional interpretation of the surface. As shown on Figure 3, the top of rock surface generally follows topography which has been largely uniformly weathered.

Material overlying the top of rock surface, including residual soils, saprolite, and partially/transitionally weathered rock, is collectively referred to as overburden in this report.

### 3.3 Lithologic Units

Based on the detailed geologic mapping performed by Petrologic, graphically represented on Figure 2, and data review, the Plant property is primarily underlain by a fine- to medium-grained, poorly jointed biotite-quartz-feldspar gneiss that has been deeply and uniformly weathered. The gneiss is well banded and well foliated with a planar, northeast-trending fabric and weathering develops a relatively thick, clay-rich, vermiculitic soil. The gneiss is locally interlayered with a zone of highly concentrated hornblende gneiss/amphibolite that trends northeast across the southern portion of Pond E, as shown on Figures 2 and 3.

Three small mafic intrusive masses were observed around Pond E as well: two occur southeast of the pond and the third occurs northwest of the pond. These discontinuous masses are resistant to weathering, standing out in relief relative to the surrounding differentially-weathered biotite gneiss. The intrusives consist of spheroidally-weathered, medium-grained, equigranular diabase that is well jointed and massive. Weathering of the diabase yields a massive, fat-clay with relict feldspar phenocrysts.

The southern end of the site is underlain by migmatitic gneiss with large amphibole crystals and discontinuous pods of amphibolite as observed along with entrance road on the southern end of the property. Exposures of this unit are chaotically folded. Based on lack of exposure, contact relationship between the migmatitic gneiss and biotite gneiss was not determined.

### 3.4 Geologic Structure

#### 3.4.1 Foliation and Faults

Bedrock discontinuity orientations were statistically analyzed using lower hemisphere equal area stereonet, presented as Figure 5, Discontinuity Data from Geologic Mapping, to determine dominant orientations for each discontinuity type (i.e., joints, foliation, and layering). Average foliation orientation for the site is N31E, 47SE. Two domains of foliation, however, were observed on site during geologic mapping. The central and northwestern portion of the property is characterized by foliation that strikes generally northeast and dips to the southeast.

Foliation measured in the southeastern portion of the property primarily strikes to the northeast but dips to the northwest, indicating that a fold axis might occur near the central portion of the site. Although no indication of folding was observed in exposures on or adjacent to the site during geologic mapping, the site is deeply weathered which may have prevented direct observation of structural features in this area, as indicated by the variation in foliation dip direction.

### 3.4.2 Joints

Because the evaluation of joints is visual and judgmental, an effort is made for consistency in describing the relative frequency of occurrence using the following designations: Abundant (A); Common (C); and Scarce (S). These designations are relative to one another but are used consistently in descriptions made throughout the study area. An effort is made to record all of the different joint sets and, if an exposure is large, several same (or similar) joints may be recorded at the same Map Station. This deliberate method of visual evaluation in the field is more scientifically relevant and efficient than saturation-measurement of joints.

Most of the rocks and saprolite observed on site were poorly jointed, which may be related to the highly feldspathic and deeply weathered nature of the biotite gneiss. The mafic intrusives observed within the gneiss are relatively resistant to weathering, well-jointed, and are exfoliated in outcrop. Orientation of the few joints measured during mapping show clusters of poles representing two joint sets, as graphically shown on the equal area stereonet of all joints measured in all lithologies on Figure 5.


The dominant joint set observed on site is oriented northwest-southeast, and based on foliation measurement, this joint set likely represents orientation of the extensional dip joint. As shown on Figure 5, the average strike and dip of this joint set is N46W, 84SW. The second joint set shown on Figure 5 is orientated north-south, which based on foliation measurements, corresponds to a conjugate joint set. As shown on Figure 5, the average strike and dip of this joint set is N1W, 54NE.

Locally, some of the joints contain clay infilling; however, most of the joints do not contain any infilling in surface exposures. The plane-surface morphology of each joint was noted in the field descriptions. Most of the joints are planar and smooth with little to no evidence of high fluid flow based on field mapping.

## 3.5 Lineament Analysis

### 3.5.1 Methodology

Subsurface geologic discontinuities such as lithologic contacts between resistant or non-resistant units, fracture zones, jointing, shear planes, and faults often have ground surface expressions that can be identified through analysis of photographic and topographic images. The discontinuities expressed as lineaments at ground surface commonly have enhanced porosity and permeability in the rock mass due to differential weathering. Groundwater in igneous and metamorphic rocks generally moves along discontinuities in the bedrock, enhancing the differential weathering processes.



**Figure 3.5.1:** Block diagram shows how lineament/fracture trace is a surface manifestation of an underlying bedrock fracture zone.

Because discontinuity zones are typically less resistant to weathering, they are often expressed as natural topographic lows, such as straight stream valley segments, swales, aligned depressions and gaps in ridges or as linear tonal or vegetative alignments due to variations in soil thickness and moisture (Figure 3.5.1, inset). These surface manifestations are referred to as fracture traces or lineaments and were identified for this project by remote-sensing techniques using topographic maps, aerial photographs, and shaded relief maps generated from 10-meter digital elevation model (DEM) data.

Lineament analyses were conducted on USGS topographic maps, USGS Digital Elevation Models (DEM), and USGS low-altitude aerial photographs (verified with National High-Altitude Photography Program (NHAP) high-altitude aerial photographs). Linear features or linear groups of features were identified and traced on digital overlays of the maps, presented as Figure 6, Remote Sensing Lineament Map / Comparison of Measured Discontinuities and Lineaments. Lineaments arise from a number of sources. Many lineaments observed on the small-scale imagery or maps are related to fence, property, and section lines. However, many lineaments are related to local and regional geologic anomalies. Rectilinear segments of streams may be associated with local weakness in the underlying bedrock related to persistent joint sets. Faults tend to be long linear features that are often difficult to detect at ground surface, but generally form photographic and topographic lineaments.

### 3.5.2 Discussion of Lineaments

Based on evaluation of a total of 148 lineaments identified on the topographic maps, aerial photographs, and DEM, graphically shown on Figures 6, two major groups of lineament orientations were identified within and around the site and both are consistent in orientation with measured discontinuities in the bedrock:

- L1: N40 to 50W
- L2: N30 to 50E

These lineaments are considered to be the ground surface expression of preferential weathering related to discontinuities in the bedrock. Structural weaknesses in rocks are reflected by the fractures formed, which subsequently can be weathered to form lineaments. These fractures are caused by application of directional stresses to the rock body. Generally, the stress is due to regional tectonics and/or unloading due to weathering and erosion.

### 3.5.3 Discontinuity Mapping and Lineament analysis Correlation

Figure 6 shows a comparison of measured discontinuities and lineaments for this study. Based on this evaluation, the project area appears to be characterized by several persistent lineament sets whose orientations are consistent with the structural stresses experienced in this area. Based on geologic mapping, it appears that L1 is related in orientation to the dip joint, which is oriented perpendicular to the northeast-trending foliation; and L2 is related in orientation to the strike direction of the northeast-trending foliation.

Because lineament orientations correlate with known regional tectonic fabrics, it is likely that most are true manifestations of subsurface fracture zones or low-resistance stratigraphic layers within the rock formations underlying the site.

## 4.0 CONCEPTUAL SITE HYDROGEOLOGIC MODEL

### 4.1 Uppermost Groundwater Aquifer

Boring logs and monitoring/piezometer installation logs were used to evaluate hydrostratigraphy of the site. Material types identified included residual soils, saprolitic soil, saprolitic rock (or PWR if blow counts were provided), transitionally weathered rock, and competent bedrock. Based on review of site cross sections (Figures 4A-D), residual soils, primarily sandy silt, silty sand, sandy clay and silty clay, occur as a variably-thick blanket overlying bedrock across most of the site. The thickness of the soil encountered in the borings is variable, ranging from 11 feet to as much as 74 feet. Thickness of saprolitic soils and/or saprolitic rock range in thickness across the site but were generally encountered at or near ground surface. The saturated thickness of the overburden material ranges from 0 to over 60 feet. Based on review of the logs, the screen/filter pack interval for most of the piezometers and monitoring wells installed on site provides connection to overburden that is saturated, indicating that the site is underlain by a regional groundwater aquifer that occurs within the overburden. A potentiometric map for the site is presented as Figure 7, Potentiometric Surface Elevation Contour Map – June 25, 2018.

Localized groundwater flow directions within this aquifer are influenced by topographic and top of rock variations on site. As illustrated on Figure 7, the water table surface is a subdued reflection of topography at the site, with groundwater generally flowing east from the Pond E and southeast toward Lake Juliette. This pond was impounded on a topographic high within a former tributary that flowed eastward into Beaverdam Creek. A series of topographically high hilltops occur west of Pond E and also appear to influence groundwater flow. Piezometer locations PZ-2I/S through PZ-5I/S exhibit groundwater elevations between approximately 438 and 452 feet, or around 12 to 26 feet higher than Pond E. These piezometer locations in turn are located east of the topographic divide between Pond E and the intermittent to permanently flowing creek to the west. Thus, these hilltops likely represent an upgradient groundwater divide on the property west of the ash pond.

Recharge to the uppermost aquifer is primarily through precipitation and this aquifer is considered to be hydraulically unconfined. Out of 11 well clusters, data indicate that there is generally a downward gradient in topographically higher areas and an upward gradient in the topographic lows. As shown on Figure 7, groundwater appears to be supporting surface water flow in these tributaries, as indicated by the local overlap in topographic and groundwater contours of similar elevation.

Based on review of the potentiometric contours, horizontal hydraulic gradient is also variable and reflects topography at the site. The horizontal gradient appears to be steeper around the downgradient perimeter of the ponds, particularly along embankments where groundwater flow lines are influenced by the constructed slopes for the dams. Generally, the majority of groundwater flow across the site occurs laterally in the transitionally weathered rock zone. Because the site is underlain by clay-rich residual soils and relatively massive bedrock, groundwater is expected to move laterally more than vertically within the transitionally weathered rock, which is considered to have a higher hydraulic conductivity relative to the overlying clay-rich and underlying massive bedrock material.

As indicated on Figure 2 and described in Section 3, the site is developed on biotite gneiss with local mafic lithologic variations represented by amphibolite/hornblende gneiss and diabase. Weathering of different parent rocks with variable geochemical characteristics may yield overburden with variable geochemical characteristics.



## 4.2 Bedrock Aquifer System

Bedrock aquifer systems also occur beneath the site. Recharge to these aquifer systems comes from water stored in the overburden. This material functions as a sponge, slowly allowing groundwater to infiltrate the bedrock through areas of enhanced permeability. This rate of infiltration is very slow, as indicated by dating of groundwater in other areas in the Piedmont exceeding 60 years.

Relatively thick clay-rich overburden is present across most of the site which may retard recharge from the uppermost aquifer into the underlying bedrock aquifer systems. Additionally, boring logs indicate that some areas, in particular topographic highs, correlate with bedrock that is resistant to weathering and massive (i.e. few discontinuities); consequently, bedrock aquifer systems are likely not well developed or interconnected in these areas. Preferential groundwater flow, however, is anticipated within the bedrock along discontinuities and potentially around diabase dikes.

Table 1, Summary of Historical Groundwater Elevations presents a summary of the historical groundwater elevations in recent monitoring history (August 2016 to present). Based on review of Table 1, groundwater elevations at the site have shown a maximum variability of up to 5 feet. On average historic groundwater elevations typically show a seasonal variability of up to 2 feet. Maximum groundwater elevations for the Pond E area are in the range of 444 feet mean sea level (msl; observed at upgradient well BRGWA-2S/I) while minimum groundwater elevations observed at Pond E are in the range of 364 feet msl (observed at BRGWC-17S and BRGWC-35S). Conversely, maximum groundwater elevations observed in the southern portion of the site is 395 ft msl (observed at BRGWA-23S) with a minimum elevation of 344 ft msl (observed at BRGWC-50).

## 4.3 Conceptual Site Hydrogeologic Model Summary

A regional, unconfined aquifer system is present at the site, consisting of residual soils and transitionally weathered rock. Interconnected fractures in the transition zone transmit groundwater stored in the overburden soils to underlying bedrock, following the conceptual model for groundwater flow in the Piedmont (LeGrand, 2004). Overall, groundwater recharge is thought to occur in the uplands and groundwater discharge near onsite surface water bodies. The water level trends noted at Plant Branch are comparable to similar hydrogeologic settings in the Piedmont region of southeastern US (e.g., Chapman and others, 2007). Additionally, the relationship between groundwater levels and the site topography is consistent with the slope-aquifer conceptual model for groundwater flow in the Piedmont (Robinson and others, 1996; LeGrand, 2004). Other attributes of the site-specific hydrogeologic model include:

- 1) The site is directly underlain by up to a 60-foot thick blanket of overburden, which is comprised of residual soils and transitionally weathered rock. Based on slug tests, the overburden is considered to have an average hydraulic conductivity of  $10^{-4}$  cm/s.
- 2) Bedrock beneath the overburden is primarily characterized by poorly-jointed, feldspathic biotite gneiss with a localized zone of highly concentrated layers of amphibolite/hornblende gneiss interlayered with the biotite gneiss. Isolated diabase intrusive masses are also present on site. Lineaments identified around the site are consistent in orientation with structural features observed during geologic mapping, indicating that development of surface lineations is likely controlled by preferential weathering related to discontinuities in bedrock.
- 3) The top of rock surface generally mimics site topography.

- 4) The uppermost aquifer occurs within the overburden at the site. Data from boring logs, water level measurements, well development, well purging, and groundwater quality data suggest that the overburden aquifer is hydraulically connected to the bedrock aquifer, consistent with the conceptual models described for the Piedmont of Georgia. However, the degree of hydraulic connection between the overburden and the underlying bedrock aquifer system is not known due to limited data available in the bedrock aquifer.
- 5) The potentiometric surface for the uppermost aquifer is generally eastward from the topographically high area upgradient of Pond E. In general, groundwater flow is to the east, south, and west from Ponds B, C, and D.
- 6) Groundwater in the uppermost aquifer appears to be supporting base flow of creeks on site (many groundwater contours cross topographic contours of similar elevation at headwaters of creek). Additionally, vertical gradients in paired wells are generally downward in topographically high areas and generally upward in topographically low areas.
- 7) In general, the geochemistry for the site is likely fairly uniform with the exception of local mafic units within the gneiss. These differing rock types are interlayered such that they are not likely to result in significant geochemical variation in the overburden and groundwater chemistry.

## 5.0 REFERENCES

### Publicly Available Information:

Lake Sinclair West, GA United States Geologic Survey (USGS) 7.5 minute topographic quadrangle (2014)

Chapman, Melinda, J., Schlegel, M., Huffman, B.A., and McSwain, K.B., 2007, Hydraulic gradients in recharge and discharge areas and apparent ground- water-age dates from the characterizations of multiple regolith-fractured bedrock ground-water research stations in North Carolina. Proceedings of the 2007 Georgia Water Resources Conference, March 27-29, 2007, Athens, GA., 4p.

LeGrand, H.E., 2004, A Master Conceptual Model for Hydrogeological Site Characterization in the Piedmont and Mountain Region of North Carolina – A Guidance Manual. North Carolina Department of Environment and Natural Resources, Division of Water Quality, Groundwater Section

Robinson, J.L., Journey, C.A., and Atkins, J.B., 1996, Ground-Water Resources of the Coosa River Basin in Georgia and Alabama – Subarea 6 of the Apalachicola-Chattahoochee-Flint and Alabama-Coosa-Tallapoosa River Basins. U.S. Geological Survey Open-File Report 96-177.

Watson, T., 1984, Hydrogeology of Greene, Morgan and Putnam Counties. Georgia Geologic Survey IC 60.

### Internal Reports:

- 2009 Site Acceptability Report related to the feasibility of on-site gypsum disposal.



**Available boring logs from previous site investigations:**

- 2009 SCS:BH-1 to BH-19
- 2014 SCS:Piezometer locations PZ-1 to PZ-21 (total 38 single, paired, or clustered piezometers at the 21 locations)
- 2017 and 2018 Golder piezometer installation reports (PZ-23S, PZ-23I, PZ-24S, PZ-25I, PZ-26I, PZ-27S, PZ-28I, PZ-29I, PZ-30I, PZ-31S, PZ-32S, PZ-33S, PZ-34S, PZ-35S, PZ-36S, PZ-37S, PZ-38S, PZ-39, PZ-40, PZ-41, PZ-42, PZ-43, PZ-44, PZ-45, PZ-46, PZ-47, PZ-48, PZ-49, PZ-50, PZ-51I/S, and PZ-52I).

**Field and Laboratory data:**

- Hydraulic conductivity (SCS 2007 field slug tests): B-4, B-6, B-7, B-8, B-12, B-14
- Hydraulic conductivity (SCS 2014): PZ-1D, PZ-1I, PZ-1S, PZ-2S, PZ-2I, PZ-2S, PZ-4I, PZ-5I, PZ-5S, PZ-6S, PZ-7S, PZ-8S, PZ-10S, PZ-11S, PZ-14I, PZ-14S, PZ-15I, PZ-15S, PZ-16I, PZ-17I, PZ-18I, PZ-19I, P-19S, PZ-20I, PZ-21I,
- Hydraulic conductivity (Golder 2017 and 2018): PZ-23S, PZ-23I, PZ-24S, PZ-25I, PZ-26I, PZ-27S, PZ-28I, PZ-29I, PZ-30I, PZ-31S, PZ-32S, PZ-33S, PZ-34S, PZ-35S, PZ-36S, PZ-37S, PZ-38S, PZ-40, PZ-41, and PZ-42



## FIGURES & TABLES



**[golder.com](http://golder.com)**

## FIGURES & TABLES





LEGEND

	APPROXIMATE PROPERTY BOUNDARY
	EXISTING BORING LOCATIONS
	EXISTING PIEZOMETER LOCATIONS
	EXISTING MONITORING WELL LOCATIONS
	ESTIMATED EXTENT OF SURFACE IMPOUNDMENTS
	CROSS-SECTION LINES

NOTES

1. TOPOGRAPHIC CONTOUR INTERVAL = 10 FEET

REFERENCES

- BORING/WELL/PIEZOMETER LOCATIONS AND PROPERTY LINE PROVIDED BY SOUTHERN COMPANY SERVICES, INC. AND GOLDER ASSOCIATES.
- TOPOGRAPHY PROVIDED BY GEORGIA POWER LAND DEPARTMENT, DATE OF SURVEY 3-15-2018.

CLIENT



CONSULTANT



YYYY-MM-DD	2018-10-15
DESIGNED	DLP
PREPARED	DJC
REVIEWED	RPK
APPROVED	DLP

PROJECT




GEOLOGIC AND HYDROGEOLOGIC SUMMARY REPORT  
PLANT BRANCH

TITLE

EXISTING CONDITIONS PLAN

PROJECT NO.	CONTROL	REV.	FIGURE
166625418	166625418A001.dwg	0	01





LEGEND

	APPROXIMATE PROPERTY BOUNDARY		DIABASE DIKE
	ESTIMATED EXTENT OF SURFACE IMPOUNDMENTS		BIOTITE GNEISS
	INTERPRETED GEOLOGIC CONTACT		BIOTITE GNEISS WITH INTERLAYERED AMPHIBOLITE
	JOINTS		
	FOLIATION		
	GEOLOGIC MAP STATION		

REFERENCES

1. PROPERTY LINE PROVIDED BY SOUTHERN COMPANY SERVICES, INC.
2. TOPOGRAPHY OBTAINED BY NATIONAL OCEANIC AND ATMOSPHERIC ADMINISTRATION WEBSITE, [www.coast.noaa.gov](http://www.coast.noaa.gov), JUNE 2016.
3. GEOLOGIC MAPPING CONDUCTED BY PETROLOGIC SOLUTIONS, INC.

CLIENT



CONSULTANT



YYYY-MM-DD	2018-10-23
DESIGNED	DLP
PREPARED	DJC
REVIEWED	RPK
APPROVED	DLP

PROJECT

GEOLOGIC AND HYDROGEOLOGIC SUMMARY REPORT  
PLANT BRANCH

TITLE

GEOLOGIC MAP



PROJECT NO.  
166625418

REV.  
0

FIGURE  
02




Path: \\drift\cas\Projects\166625418-Plant Branch\PRODUCT\IONA-GEOLOGIC AND HYDROGEOLOGIC REPORT\1 File Name: 166625418A002.dwg



Well-ID	Top of Rock Elevation (ft msl)
BRGWA-2S	~ 405
BRGWA-2I	405.0
BRGWA-5S	~ 400
BRGWA-5I	399.0
BRGWA-6S	< 410
BRGWA-12S	~ 371
BRGWA-12I	371.0
BRGWC-17S	~ 358
BRGWA-23S	385.0
BRGWC-25I	339.0
BRGWC-27I	< 340
BRGWC-29I	< 329
BRGWC-30I	333.0
BRGWC-32S	< 358
BRGWC-33S	388.1
BRGWC-34S	< 364.0
BRGWC-35S	< 333.7
BRGWC-36S	< 354
BRGWC-37S	< 376
BRGWC-38S	< 391
BRGWC-45	< 329.7
BRGWC-47	316.87*
BRGWC-50	318.8
BRGWC-52I	330.9
PZ-1S	~ 401
PZ-1I	401.0
PZ-1D	~ 401
PZ-3S	443.0
PZ-3I	441.0
PZ-3D	443.0
PZ-4S	~ 451
PZ-4I	451.0
PZ-7S	< 408
PZ-8S	< 405
PZ-9S	< 422
PZ-10S	< 397
PZ-11S	< 371
PZ-12D	371.0
PZ-13S	< 377
PZ-14S	~ 390
PZ-14I	390.0
PZ-15S	~ 338
PZ-15I	338.0
PZ-16S	~ 358
PZ-16I	358.5
PZ-17I	358.0
PZ-18S	~ 338
PZ-18I	338.0
PZ-19S	~ 343
PZ-19I	343.0
PZ-20S	~ 352
PZ-20I	352.0
PZ-21S	~ 350*
PZ-21I	350*
PZ-22S	385.6
PZ-23I	387.9
PZ-24S	< 309
PZ-26I	352.6*
PZ-28I	342.4
PZ-31S	< 334
PZ-39	385.6
PZ-40S	< 313
PZ-41S	< 309
PZ-42S	< 326.5
PZ-43	~ 347*
PZ-44	329.5
PZ-46	343.1
PZ-48	352.8
PZ-49	375.1*
PZ-51S	< 327.6
PZ-51I	319.8
BH-1	< 343
BH-2	< 346
BH-3	< 351
BH-4	363.0
BH-5	< 347
BH-6	< 345
BH-7	363.0
BH-8	< 335
BH-9	385.0
BH-10	< 354
BH-11	< 359
BH-12	< 361
BH-13	363.0
BH-14	345.0
BH-15	346.0
BH-16	377.0
BH-17	371.0
BH-18	379.0
BH-19	< 387

\* anomalous, not used for bedrock contouring



LEGEND

---	APPROXIMATE PROPERTY BOUNDARY
BH-05	EXISTING BORING LOCATIONS
PZ-6S	EXISTING PIEZOMETER LOCATIONS
BRGWC-12I	EXISTING MONITORING WELL LOCATIONS
---	ESTIMATED EXTENT OF SURFACE IMPOUNDMENTS
---	ESTIMATED TOP OF ROCK SURFACE CONTOUR (feet MSL)

NOTES

- TOPOGRAPHIC CONTOUR INTERVAL = 10 FEET
- TOP OF ROCK SURFACE CONTOUR INTERVAL = 20 FEET
- BEDROCK CONTOURS BASED ON LINEAR INTERPOLATION BETWEEN AND EXTRAPOLATION FROM KNOWN DATA, AND TOPOGRAPHIC CONTOURS. THEREFORE, CONTOURS MAY NOT REFLECT ACTUAL CONDITIONS.

REFERENCES

- BORING/WELL/PIEZOMETER LOCATIONS AND PROPERTY LINE PROVIDED BY SOUTHERN COMPANY SERVICES, INC. AND GOLDER ASSOCIATES.
- TOPOGRAPHY PROVIDED BY GEORGIA POWER LAND DEPARTMENT, DATE OF SURVEY 3-15-2018.

CLIENT



CONSULTANT



YYYY-MM-DD	2018-10-15
DESIGNED	DLP
PREPARED	DJC
REVIEWED	RPK
APPROVED	DLP

PROJECT

GEOLOGIC AND HYDROGEOLOGIC SUMMARY REPORT  
PLANT BRANCH



TITLE

ESTIMATED TOP OF ROCK MAP

PROJECT NO. 166625418	CONTROL 166625418A002.dwg	REV. 0	FIGURE 03
--------------------------	------------------------------	-----------	--------------

IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM: ANSI D





Path: \\detroit\cas\Projects\166625418-Plant Branch\PRODUCT\TMA-GEOL\GIC AND HYDRO\GEOLOGIC REPORT\1 File Name: 166625418A003.dwg

LEGEND

EXISTING GRADE

ESTIMATED GROUNDWATER SURFACE (5-28-16)

ESTIMATED TOP OF ROCK SURFACE

OVERBURDEN/RESIDUUM

DIABASE DIKE


BIOTITE GNEISS

BIOTITE GNEISS WITH INTERLAYERED AMPHIBOLITE

- REFERENCES
1. BORING/WELL/PIEZOMETER LOCATIONS PROVIDED BY SOUTHERN COMPANY SERVICES, INC. AND GOLDER ASSOCIATES.

2. GEOLOGIC UNITS TAKEN FROM RECENT MAPPING (PETROLOGIC, INC.).

3. GEOLOGIC UNITS TAKEN FROM PETROLOGIC SOLUTION INC.'S GEOLOGIC MAPPING INCLUDED IN THIS REPORT.



CLIENT

CONSULTANT

PROJECT

GEOLOGIC AND HYDROGEOLOGIC SUMMARY REPORT  
PLANT BRANCH

TITLE

**GEOLOGIC CROSS-SECTIONS SCHEMATIC  
(1 OF 4)**

PROJECT NO.

166625418

CONTROL

166625418A003.dwg

REV.

0

FIGURE


**04-A**

YYYY-MM-DD	2018-10-16
DESIGNED	DLP
PREPARED	DJC
REVIEWED	RPK
APPROVED	DLP

IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM: ANSI D



Path: \\detroit\cas\Projects\166625418-Plant Branch\PRODUCT\01\GEOLOGIC AND HYDROGEOLOGIC REPORT\1 File Name: 166625418A003.dwg



LEGEND

EXISTING GRADE

ESTIMATED GROUNDWATER SURFACE (5-28-16)

ESTIMATED TOP OF ROCK SURFACE

OVERBURDEN/RESIDUUM

DIABASE DIKE

BIOTITE GNEISS

BIOTITE GNEISS WITH INTERLAYERED AMPHIBOLITE

- REFERENCES
1. BORING/WELL/PIEZOMETER LOCATIONS PROVIDED BY SOUTHERN COMPANY SERVICES, INC. AND GOLDER ASSOCIATES.

2. GEOLOGIC UNITS TAKEN FROM RECENT MAPPING (PETROLOGIC, INC.).


3. GEOLOGIC UNITS TAKEN FROM PETROLOGIC SOLUTION INC.'S GEOLOGIC MAPPING INCLUDED IN THIS REPORT.




CLIENT		
CONSULTANT		
	YYYY-MM-DD	2018-10-16
	DESIGNED	DLP
	PREPARED	DJC
	REVIEWED	RPK
	APPROVED	DLP

PROJECT		
GEOLOGIC AND HYDROGEOLOGIC SUMMARY REPORT PLANT BRANCH		
TITLE		
GEOLOGIC CROSS-SECTIONS SCHEMATIC (2 OF 4)		
PROJECT NO.	CONTROL	REV.
166625418	166625418A003.dwg	0
		FIGURE
		04-B

IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM: ANSI D



C - C'



C - C'

LEGEND

- EXISTING GRADE
- ESTIMATED GROUNDWATER SURFACE (5-28-16)
- ESTIMATED TOP OF ROCK SURFACE
- OVERBURDEN/RESIDUUM
- DIABASE DIKE
- BIOTITE GNEISS
- BIOTITE GNEISS WITH INTERLAYERED AMPHIBOLITE

REFERENCES

- BORING/WELL/PIEZOMETER LOCATIONS PROVIDED BY SOUTHERN COMPANY SERVICES, INC. AND GOLDER ASSOCIATES.
- GEOLOGIC UNITS TAKEN FROM RECENT MAPPING (PETROLOGIC, INC.).
- GEOLOGIC UNITS TAKEN FROM PETROLOGIC SOLUTION INC.'S GEOLOGIC MAPPING INCLUDED IN THIS REPORT.



CLIENT



CONSULTANT



YYYY-MM-DD	2018-10-16
DESIGNED	DLP
PREPARED	DJC
REVIEWED	RPK
APPROVED	DLP

PROJECT

GEOLOGIC AND HYDROGEOLOGIC SUMMARY REPORT  
PLANT BRANCH

TITLE

**GEOLOGIC CROSS-SECTIONS SCHEMATIC  
(3 OF 4)**



PROJECT NO.  
166625418

CONTROL  
166625418A003.dwg

REV.  
0

FIGURE  
04-C





**LEGEND**

	EXISTING GRADE
	ESTIMATED GROUNDWATER SURFACE (5-28-16)
	ESTIMATED TOP OF ROCK SURFACE
	OVERBURDEN/RESIDUUM
	DIABASE DIKE
	BIOTITE GNEISS
	BIOTITE GNEISS WITH INTERLAYERED AMPHIBOLITE

- REFERENCES**
1. BORING/WELL/PIEZOMETER LOCATIONS PROVIDED BY SOUTHERN COMPANY SERVICES, INC. AND GOLDER ASSOCIATES.
  2. GEOLOGIC UNITS TAKEN FROM RECENT MAPPING (PETROLOGIC, INC.).
  3. GEOLOGIC UNITS TAKEN FROM PETROLOGIC SOLUTION INC.'S GEOLOGIC MAPPING INCLUDED IN THIS REPORT.




CLIENT		
CONSULTANT		
	YYYY-MM-DD	2018-10-16
	DESIGNED	DLP
	PREPARED	DJC
	REVIEWED	RPK
	APPROVED	DLP

PROJECT		
GEOLOGIC AND HYDROGEOLOGIC SUMMARY REPORT PLANT BRANCH		
TITLE		
GEOLOGIC CROSS-SECTIONS SCHEMATIC (4 OF 4)		
PROJECT NO.	CONTROL	REV.
166625418	166625418A003.dwg	0

Path: \\detroit\cap\Projects\166625418-Plant Branch\PRODUCT\TMA-GEOLOGIC AND HYDROGEOLOGIC REPORT\1 File Name: 166625418A003.dwg

IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM: ANSI D


Plant Branch



Foliation Data

NOTE(S)  
1. DISCONTINUITY DATA COLLECTED BY PETROLOGIC SOLUTIONS, INC.

Plant Branch



Joint Data

NOT TO SCALE

CLIENT



CONSULTANT



YYYY-MM-DD	2017/09/25
DESIGNED	CCP
PREPARED	SEP
REVIEWED	DLP
APPROVED	RPK

PROJECT

GEOLOGIC AND HYDROGEOLOGIC REPORT  
PLANT BRANCH

TITLE

DISCONTINUITY DATA FROM GEOLOGIC MAPPING

PROJECT NO.

REV.

----


FIGURE

05










Well/Piezometer/Boring Identification	Groundwater Elevation (feet AMSL) 06/25/2018
BRGWA-2S	442.82
BRGWA-2I	442.74
BRGWA-5S	436.30
BRGWA-5I	436.32
BRGWA-6S	438.12
BRGWA-12S	387.01
BRGWA-12I	386.99
BRGWC-17S	363.66
BRGWA-23S	390.08
BRGWC-24S	339.79
BRGWC-25I	348.57
BRGWC-27I	362.54
BRGWC-29I	343.48
BRGWC-30I	347.63
BRGWC-32S	370.65
BRGWC-33S	409.35
BRGWC-34S	389.32
BRGWC-35S	364.39
BRGWC-36S	383.30
BRGWC-37S	395.88
BRGWC-38S	412.15
PZ-1S	432.68
PZ-1I	431.88
PZ-1D	430.39
PZ-3S	DRY
PZ-3I	439.21
PZ-3D	440.36
PZ-4S	DRY
PZ-4I	450.89
PZ-7S	429.93
PZ-8S	431.38
PZ-9S	451.84
PZ-10S	411.72
PZ-11S	376.47
PZ-12D	360.34
PZ-13S	388.25
PZ-14S	417.41
PZ-14I	417.12
PZ-15S	405.82
PZ-15I	406.34
PZ-16S	374.43
PZ-16I	374.49
PZ-17I	366.44
PZ-18S	346.43
PZ-18I	346.07
PZ-19S	361.13
PZ-19I	360.95
PZ-20S	355.46
PZ-20I	355.63
PZ-21S	353.73
PZ-21I	353.56
PZ-23I	390.02
PZ-26I	348.83
PZ-28I	350.36
PZ-31S	351.77
PZ-39	385.77
PZ-40S	340.66
PZ-41S	340.04
PZ-42S	341.06
PZ-43	353.78
PZ-44	358.83
PZ-45	374.86
PZ-46	375.52
PZ-47	385.68
PZ-48	390.09
PZ-49	376.47
PZ-50	343.70

- LEGEND**
- ESTIMATE GROUNDWATER SURFACE CONTOUR (feet MSL)
  - PROPERTY BOUNDARY
  - APPROXIMATE ASH POND BOUNDARY
  - APPROXIMATE SURFACE WATER LIMITS
  - MONITORING WELL (ELEVATION feet AMSL)
  - PIEZOMETER (ELEVATION feet AMSL)

- NOTES**
- GROUNDWATER SURFACE CONTOUR INTERVAL = 10 FEET
  - GROUNDWATER CONTOURS BASED ON LINEAR INTERPOLATION BETWEEN AND EXTRAPOLATION FROM KNOWN DATA, AND TOPOGRAPHIC CONTOURS. THEREFORE, CONTOURS MAY NOT REFLECT ACTUAL CONDITIONS.
  - PZ-8S\*, PZ-10S\*, PZ-11S\*, PZ-12D\*, AND PZ-49\* DATA NOT USED FOR CONTOURING.
  - AMSL=ABOVE MEAN SEA LEVEL.

- REFERENCE**
- SERVICE LAYER CREDITS: ESRI, HERE, GARMIN, © OPENSTREETMAP CONTRIBUTORS, AND THE GIS USER COMMUNITY  
SOURCE: ESRI, DIGITALGLOBE, GEOEYE, EARTHSTAR GEOGRAPHICS, CNES/AIRBUS DS, USDA, USGS, AEROGRIID, IGN, AND THE GIS USER COMMUNITY
  - COORDINATE SYSTEM: NAD 1983 STATE PLAN GEORGIA WEST (U.S. FEET).
  - BORING/PIEZOMETER LOCATIONS AND PROPERTY LINE PROVIDED BY SOUTHERN COMPANY SERVICES.



CLIENT  
GEORGIA POWER COMPANY  
PLANT BRANCH

PROJECT  
GROUNDWATER MONITORING PLAN

TITLE  
PIEZOMETRIC SURFACE ELEVATION CONTOUR MAP  
JUNE 25, 2018

CONSULTANT	YYYY-MM-DD	2018-08-20
	PREPARED	DJC
	DESIGN	DLP
	REVIEW	DLP
	APPROVED	RPK



PROJECT No. 1666254	CONTROL 1666254H001-GIS.mxd	Rev. 0	FIGURE 7
------------------------	--------------------------------	-----------	-------------

Service Layer Credits: Esri, HERE, Garmin, © OpenStreetMap contributors, and the GIS user community  
Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community



TABLE 1  
Summary of Historical Groundwater Elevations  
Georgia Power Company- Plant Branch  
Milledgeville, Georgia

Well-ID	Top of Casing Elevation (feet msl) <sup>[1]</sup>	GROUNDWATER ELEVATIONS (FEET MSL)								
		8/30/2016	11/21/2016	2/17/2017	6/12/2017	9/25/2017	2/7/2018	2/13/2018	6/25/2018	9/18/2018
POND BCD										
BRGWA-12S	439.69	391.26	341.94	389.54	388.88	388.42	387.14	387.43	387.01	DRY
BRGWA-12I	439.43	390.64	341.60	389.57	388.80	388.47	425.03	387.40	386.99	386.50
BRGWA-23S	428.42	395.74	361.06	394.05	392.90	392.61	390.71	390.74	390.08	389.57
BRGWC-25I	357.46	348.30	338.59	349.86	349.53	349.01	349.60	349.75	348.57	347.66
BRGWC-27I	367.99	363.35	357.29	364.60	364.91	364.63	364.40	364.23	362.54	360.67
BRGWC-29I	353.30	343.46	333.29	344.15	344.30	343.72	343.73	344.06	343.48	343.05
BRGWC-30I	352.33	347.85	343.69	348.42	348.13	348.36	348.11	348.16	347.63	347.61
BRGWC-32S	406.51	372.01	335.50	370.37	371.86	372.10	371.12	371.05	370.65	369.37
BRGWC-45	384.61	NA	NA	NA	NA	NA	373.67	373.55	374.86	372.77
BRGWC-47	411.32	NA	NA	NA	NA	NA	385.72	385.59	385.68	384.27
BRGWC-50	381.53	NA	NA	NA	NA	NA	343.47	346.10	343.70	343.45
BRGWC-52I	383.83	NA	NA	NA	NA	NA	NA	NA	NA	344.57
POND E										
BRGWA-2S	458.02	439.6	419.5	442.40	443.20	442.31	443.65	443.75	442.82	440.63
BRGWA-2I	457.85	439.7	419.6	442.15	443.00	442.14	443.45	443.61	442.74	440.63
BRGWA-5S	448.53	436.0	422.5	436.76	436.18	435.44	435.91	435.87	436.30	435.22
BRGWA-5I	448.44	435.9	422.5	436.74	436.17	435.49	435.91	435.86	436.32	435.24
BRGWA-6S	463.63	438.5	411.0	439.65	437.92	437.74	435.11	437.60	438.12	436.36
BRGWC-17S	370.25	364.7	358.8	364.60	364.17	364.11	364.05	364.39	363.66	363.95
BRGWC-33S	416.92	408.7	400.9	410.10	409.30	408.84	409.32	409.39	409.35	408.87
BRGWC-34S	392.06	389.3	386.7	389.68	389.52	389.36	389.59	389.67	389.32	389.36
BRGWC-35S	366.54	364.4	362.2	364.44	364.40	364.34	364.44	364.51	364.39	364.37
BRGWC-36S	386.00	384.3	382.4	384.20	383.94	383.80	383.42	383.47	383.30	383.30
BRGWC-37S	447.23	400.6	352.9	398.18	399.72	396.98	395.84	395.82	395.88	395.79
BRGWC-38S	432.33	412.2	391.0	413.61	412.05	411.47	411.78	411.69	412.15	410.79

Note:

1. feet msl = feet mean sea level




**[golder.com](http://golder.com)**



## **Attachment E**

---

### **Slug Test Data Plots**



### PZ-32S FALLING

Data Set: G:\...\PZ-32S Falling.aqt

Date: 09/19/16

Time: 14:31:25

### PROJECT INFORMATION

Company: Golder Associates

Client: Southern Company Services

Project: 1660939

Location: Plant Branch

Test Well: PZ-32S Falling

Test Date: 08/16/16

### AQUIFER DATA

Saturated Thickness: 20. ft

Anisotropy Ratio ( $K_z/K_r$ ): 1.

### WELL DATA (PZ-32S Falling)

Initial Displacement: 2.139 ft

Total Well Penetration Depth: 10.5 ft

Casing Radius: 0.08333 ft

Static Water Column Height: 10.5 ft

Screen Length: 9.5 ft

Well Radius: 0.08333 ft

Gravel Pack Porosity: 0.15


### SOLUTION

Aquifer Model: Unconfined

$K = 0.3795$  ft/day

Solution Method: Bouwer-Rice

$y_0 = 1.925$  ft



### PZ-32S RISING

Data Set: G:\...\PZ-32S Rising.aqt

Date: 09/19/16

Time: 14:33:30

### PROJECT INFORMATION

Company: Golder Associates

Client: Southern Company Services

Project: 1660939

Location: Plant Branch

Test Well: PZ-32S Rising

Test Date: 08/16/16

### AQUIFER DATA

Saturated Thickness: 20. ft

Anisotropy Ratio (Kz/Kr): 1.

### WELL DATA (PZ-32S Rising)

Initial Displacement: 1.612 ft

Static Water Column Height: 10.5 ft

Total Well Penetration Depth: 11. ft

Screen Length: 10. ft

Casing Radius: 0.08333 ft

Well Radius: 0.08333 ft

Gravel Pack Porosity: 0.15


### SOLUTION

Aquifer Model: Unconfined

Solution Method: Bouwer-Rice

K = 0.6744 ft/day

y0 = 1.507 ft



### WELL TEST ANALYSIS

Data Set: N:\...11-1.aqt

Date: 11/13/19

Time: 16:19:15

### PROJECT INFORMATION

Company: SCS

Test Well: Branch PZ-11S

### AQUIFER DATA

Saturated Thickness: 12. ft

Anisotropy Ratio ( $K_z/K_r$ ): 1.

### WELL DATA (PZ-11S Rising Head 1)

Initial Displacement: 0.8 ft

Total Well Penetration Depth: 21.7 ft

Casing Radius: 0.167 ft

Static Water Column Height: 12. ft

Screen Length: 10. ft

Well Radius: 0.42 ft

Gravel Pack Porosity: 0.

### SOLUTION


Aquifer Model: Unconfined

$K = 7.615$  ft/day

Solution Method: Bouwer-Rice

$y_0 = 29.3$  ft





#### B-6 SLUG IN

Data Set: T:\ESEE MAJOR PROJECTS\PROJECTS\Branch\2007\SAR\Slug Tests\B6 Slug In.aqt  
 Date: 01/17/08 Time: 14:47:20

#### PROJECT INFORMATION

Company: Georgia Power  
 Location: Plant Branch  
 Test Well: B-6  
 Test Date: 12/18/07

#### AQUIFER DATA


Saturated Thickness: 100. ft Anisotropy Ratio ( $K_z/K_r$ ): 1.

#### WELL DATA (B6 Slug In)

Initial Displacement: 1.545 ft Static Water Column Height: 35.3 ft  
 Total Well Penetration Depth: 19.2 ft Screen Length: 10. ft  
 Casing Radius: 0.083 ft Wellbore Radius: 0.333 ft  
 Gravel Pack Porosity: 0.2

#### SOLUTION

Aquifer Model: Confined Solution Method: Bouwer-Rice  
 $K = 0.0001332$  cm/sec  $y_0 = 1.055$  ft



#### B-6 SLUG OUT

Data Set: T:\ESEE MAJOR PROJECTS\PROJECTS\Branch\2007\SAR\Slug Tests\B6 Slug Out.aqt

Date: 01/17/08

Time: 14:47:26

#### PROJECT INFORMATION

Company: Georgia Power

Location: Plant Branch

Test Well: B-6

Test Date: 12/18/07

#### AQUIFER DATA

Saturated Thickness: 100. ft

Anisotropy Ratio ( $K_z/K_r$ ): 1.

#### WELL DATA (B6 Slug Out)

Initial Displacement: 1.545 ft

Static Water Column Height: 35.3 ft

Total Well Penetration Depth: 19.2 ft

Screen Length: 10. ft

Casing Radius: 0.083 ft

Wellbore Radius: 0.333 ft

Gravel Pack Porosity: 0.2


#### SOLUTION

Aquifer Model: Confined

Solution Method: Bouwer-Rice

$K = 0.0001705$  cm/sec

$y_0 = 0.4654$  ft



### B-8 SLUG IN

Data Set: T:\ESEE MAJOR PROJECTS\PROJECTS\Branch\2007\SAR\Slug Tests\B8 Slug In.aqt  
 Date: 01/29/08 Time: 14:35:14

### PROJECT INFORMATION

Company: Georgia Power  
 Location: Plant Branch  
 Test Well: B-8  
 Test Date: 12/18/07

### AQUIFER DATA

Saturated Thickness: 100. ft Anisotropy Ratio ( $K_z/K_r$ ): 1.


### WELL DATA (B8 Slug In)

Initial Displacement: 1.545 ft Static Water Column Height: 29.7 ft  
 Total Well Penetration Depth: 29.7 ft Screen Length: 10. ft  
 Casing Radius: 0.083 ft Wellbore Radius: 0.333 ft  
 Gravel Pack Porosity: 0.2

### SOLUTION

Aquifer Model: Confined Solution Method: Bouwer-Rice  
 $K = 0.0002775$  cm/sec  $y_0 = 1.271$  ft





#### B-8 SLUG OUT

Data Set: T:\ESEE MAJOR PROJECTS\PROJECTS\Branch\2007\SAR\Slug Tests\B8 Slug Out.aqt

Date: 01/29/08

Time: 14:39:08

#### PROJECT INFORMATION

Company: Georgia Power

Location: Plant Branch

Test Well: B-8

Test Date: 12/18/07

#### AQUIFER DATA

Saturated Thickness: 100. ft

Anisotropy Ratio ( $K_z/K_r$ ): 1.

#### WELL DATA (B8 Slug Out)

Initial Displacement: 1.545 ft

Static Water Column Height: 29.7 ft

Total Well Penetration Depth: 29.7 ft

Screen Length: 10. ft

Casing Radius: 0.083 ft

Wellbore Radius: 0.333 ft

Gravel Pack Porosity: 0.2


#### SOLUTION

Aquifer Model: Confined

Solution Method: Bouwer-Rice

$K = 0.0005172$  cm/sec

$y_0 = 1.054$  ft



### B-12 SLUG OUT

Data Set: T:\ESEE MAJOR PROJECTS\PROJECTS\Branch\2007\SAR\Slug Tests\B12 Slug Out.aqt  
 Date: 01/29/08 Time: 14:52:04

### PROJECT INFORMATION

Company: Georgia Power  
 Location: Plant Branch  
 Test Well: B-12  
 Test Date: 12/18/07

### AQUIFER DATA


Saturated Thickness: 100. ft Anisotropy Ratio ( $K_z/K_r$ ): 1.

### WELL DATA (B12 Slug Out)

Initial Displacement: 1.545 ft Static Water Column Height: 19.3 ft  
 Total Well Penetration Depth: 19.3 ft Screen Length: 10. ft  
 Casing Radius: 0.083 ft Wellbore Radius: 0.333 ft  
 Gravel Pack Porosity: 0.2

### SOLUTION

Aquifer Model: Confined Solution Method: Bouwer-Rice  
 $K = 0.0001422$  cm/sec  $y_0 = 0.4445$  ft



#### B-12 SLUG IN

Data Set: T:\ESEE MAJOR PROJECTS\PROJECTS\Branch\2007\SAR\Slug Tests\B12 Slug In.aqt  
 Date: 01/29/08 Time: 15:02:18

#### PROJECT INFORMATION

Company: Georgia Power  
 Location: Plant Branch  
 Test Well: B-12  
 Test Date: 12/18/07

#### AQUIFER DATA

Saturated Thickness: 100. ft Anisotropy Ratio ( $K_z/K_r$ ): 1.


#### WELL DATA (B12 Slug In)

Initial Displacement: 1.545 ft Static Water Column Height: 19.3 ft  
 Total Well Penetration Depth: 19.3 ft Screen Length: 10. ft  
 Casing Radius: 0.083 ft Wellbore Radius: 0.333 ft  
 Gravel Pack Porosity: 0.2

#### SOLUTION

Aquifer Model: Confined Solution Method: Bouwer-Rice  
 $K = 0.0001409$  cm/sec  $y_0 = 0.9951$  ft





#### WELL TEST ANALYSIS

Data Set: \...\PB-13S-Test1 Bouwer-Rice.aqt

Date: 02/07/19

Time: 17:40:23

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-13S

Test Date: 1/29/2019

#### AQUIFER DATA

Saturated Thickness: 79.92 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

#### WELL DATA (PB-13S)

Initial Displacement: 17.36 ft

Static Water Column Height: 43.82 ft

Total Well Penetration Depth: 43.82 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


#### SOLUTION

Aquifer Model: Unconfined

Solution Method: Bouwer-Rice

$K = 0.838$  ft/day

$y_0 = 16.16$  ft



#### WELL TEST ANALYSIS

Data Set: \...\PB-13S-Test1 Hvorslev.aqt

Date: 02/07/19

Time: 17:41:34

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-13S

Test Date: 1/29/2019

#### AQUIFER DATA

Saturated Thickness: 79.92 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

#### WELL DATA (PB-13S)

Initial Displacement: 17.36 ft

Static Water Column Height: 43.82 ft

Total Well Penetration Depth: 43.82 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


#### SOLUTION

Aquifer Model: Unconfined

Solution Method: Hvorslev

$K = 0.9759$  ft/day

$y_0 = 16.16$  ft



#### WELL TEST ANALYSIS

Data Set: \...\PB-13S-Test1 KGS.aqt

Date: 02/07/19

Time: 17:44:49

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-13S

Test Date: 1/29/2019

#### AQUIFER DATA

Saturated Thickness: 79.92 ft

#### WELL DATA (PB-13S)

Initial Displacement: 17.36 ft

Static Water Column Height: 43.82 ft

Total Well Penetration Depth: 43.82 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft

#### SOLUTION

Aquifer Model: Unconfined


Solution Method: KGS Model

Kr = 0.9507 ft/day

Ss = 2.081E-6 ft<sup>-1</sup>

Kz/Kr = 0.1





#### WELL TEST ANALYSIS

Data Set: \...\PB-13S-Test2 Bouwer-Rice.aqt

Date: 02/07/19

Time: 17:48:26

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-13S

Test Date: 1/29/2019

#### AQUIFER DATA

Saturated Thickness: 79.92 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

#### WELL DATA (PB-13S)

Initial Displacement: 23.15 ft

Static Water Column Height: 43.82 ft

Total Well Penetration Depth: 43.82 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


#### SOLUTION

Aquifer Model: Unconfined

Solution Method: Bouwer-Rice

$K = 0.9462$  ft/day

$y_0 = 21.67$  ft



#### WELL TEST ANALYSIS

Data Set: \...\PB-13S-Test2 Hvorslev.aqt

Date: 02/07/19

Time: 17:50:29

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-13S

Test Date: 1/29/2019

#### AQUIFER DATA

Saturated Thickness: 79.92 ft

Anisotropy Ratio (Kz/Kr): 0.1

#### WELL DATA (PB-13S)

Initial Displacement: 23.15 ft

Static Water Column Height: 43.82 ft

Total Well Penetration Depth: 43.82 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


#### SOLUTION

Aquifer Model: Unconfined

Solution Method: Hvorslev

K = 1.102 ft/day

y0 = 21.67 ft



#### WELL TEST ANALYSIS

Data Set: \...\PB-13S-Test2 KGS.aqt

Date: 02/07/19

Time: 17:52:25

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-13S

Test Date: 1/29/2019

#### AQUIFER DATA

Saturated Thickness: 79.92 ft

#### WELL DATA (PB-13S)

Initial Displacement: 23.15 ft

Total Well Penetration Depth: 43.82 ft

Casing Radius: 0.08 ft

Static Water Column Height: 43.82 ft

Screen Length: 10. ft

Well Radius: 0.08 ft

#### SOLUTION

Aquifer Model: Unconfined


Solution Method: KGS Model

Kr = 1.061 ft/day

Kz/Kr = 0.1

Ss = 2.396E-6 ft<sup>-1</sup>





### PZ-23S RISING

Data Set: G:\...\PZ-23S Rising.aqt

Date: 09/19/16

Time: 15:29:33

### PROJECT INFORMATION

Company: Golder Associates

Client: Southern Company Services

Project: 1660939

Location: Plant Branch

Test Well: PZ-23S Rising

Test Date: 08/15/16

### AQUIFER DATA

Saturated Thickness: 100. ft

Anisotropy Ratio (Kz/Kr): 1.

### WELL DATA (PZ-23S Rising)

Initial Displacement: 1.943 ft

Static Water Column Height: 7.65 ft

Total Well Penetration Depth: 10. ft

Screen Length: 10. ft

Casing Radius: 0.08333 ft

Well Radius: 0.08333 ft

Gravel Pack Porosity: 0.15


### SOLUTION

Aquifer Model: Unconfined

Solution Method: Bouwer-Rice

K = 0.1208 ft/day

y0 = 1.76 ft



### PZ-31S FALLING

Data Set: G:\...\PZ-31S Falling.aqt

Date: 09/19/16

Time: 14:25:55

### PROJECT INFORMATION

Company: Golder Associates

Client: Southern Company Services

Project: 1660939

Location: Plant Branch

Test Well: PZ-31S Falling

Test Date: 08/15/16

### AQUIFER DATA

Saturated Thickness: 100. ft

Anisotropy Ratio (Kz/Kr): 1.

### WELL DATA (PZ-31S Falling)

Initial Displacement: 1.901 ft

Static Water Column Height: 15.14 ft

Total Well Penetration Depth: 15.64 ft

Screen Length: 10. ft

Casing Radius: 0.08333 ft

Well Radius: 0.08333 ft

Gravel Pack Porosity: 0.15


### SOLUTION

Aquifer Model: Unconfined

Solution Method: Bouwer-Rice

K = 6.101 ft/day

y0 = 3.24 ft



### PZ-31S RISING

Data Set: G:\...\PZ-31S Rising.aqt

Date: 09/19/16

Time: 14:28:41

### PROJECT INFORMATION

Company: Golder Associates

Client: Southern Company Services

Project: 1660939

Location: Plant Branch

Test Well: PZ-31S Rising

Test Date: 08/15/16

### AQUIFER DATA

Saturated Thickness: 100. ft

Anisotropy Ratio (Kz/Kr): 1.

### WELL DATA (PZ-31S Rising)

Initial Displacement: 0.968 ft

Static Water Column Height: 15.14 ft

Total Well Penetration Depth: 15.64 ft

Screen Length: 10. ft

Casing Radius: 0.08333 ft

Well Radius: 0.08333 ft

Gravel Pack Porosity: 0.15


### SOLUTION

Aquifer Model: Unconfined

Solution Method: Bouwer-Rice

K = 21.56 ft/day

y0 = 2.32 ft



#### WELL TEST ANALYSIS

Data Set: \...\PB-1S-Test2 Bouwer-Rice.aqt

Date: 02/07/19

Time: 11:53:40

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-1S

Test Date: 1/30/2019

#### AQUIFER DATA

Saturated Thickness: 42.44 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

#### WELL DATA (PB-1S)

Initial Displacement: 10.17 ft

Static Water Column Height: 14.44 ft

Total Well Penetration Depth: 14.44 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft

#### SOLUTION


Aquifer Model: Unconfined

Solution Method: Bouwer-Rice

$K = 2.27$  ft/day

$y_0 = 10.83$  ft





#### WELL TEST ANALYSIS

Data Set: \...\PB-1S-Test2 Hvorslev.aqt

Date: 02/07/19

Time: 11:54:10

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-1S

Test Date: 1/30/2019

#### AQUIFER DATA

Saturated Thickness: 42.44 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

#### WELL DATA (PB-1S)

Initial Displacement: 10.17 ft

Static Water Column Height: 14.44 ft

Total Well Penetration Depth: 14.44 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


#### SOLUTION

Aquifer Model: Unconfined

Solution Method: Hvorslev

$K = 3.055$  ft/day

$y_0 = 11.18$  ft



### WELL TEST ANALYSIS

Data Set: \...\PB-1S-Test1 Bouwer-Rice.aqt

Date: 02/07/19

Time: 11:55:16

### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-1S

Test Date: 1/30/2019

### AQUIFER DATA

Saturated Thickness: 42.44 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

### WELL DATA (PB-1S)

Initial Displacement: 11.03 ft

Static Water Column Height: 14.44 ft

Total Well Penetration Depth: 14.44 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


### SOLUTION

Aquifer Model: Unconfined

Solution Method: Bouwer-Rice

$K = 2.207$  ft/day

$y_0 = 15.03$  ft



### WELL TEST ANALYSIS

Data Set: \...\PB-1S-Test1 Hvorslev.aqt

Date: 02/07/19

Time: 11:55:44

### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-1S

Test Date: 1/30/2019

### AQUIFER DATA

Saturated Thickness: 42.44 ft

Anisotropy Ratio (Kz/Kr): 0.1

### WELL DATA (PB-1S)

Initial Displacement: 11.03 ft

Static Water Column Height: 14.44 ft

Total Well Penetration Depth: 14.44 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


### SOLUTION

Aquifer Model: Unconfined

Solution Method: Hvorslev

K = 2.954 ft/day

y0 = 15.17 ft



#### WELL TEST ANALYSIS

Data Set: \\...\PB-1S-Test1 KGS.aqt

Date: 02/08/19

Time: 13:34:18

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-1S

Test Date: 1/30/2019

#### AQUIFER DATA

Saturated Thickness: 42.44 ft

#### WELL DATA (PB-1S)

Initial Displacement: 11.03 ft

Static Water Column Height: 14.44 ft

Total Well Penetration Depth: 14.44 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft

#### SOLUTION

Aquifer Model: Unconfined


Solution Method: KGS Model

Kr = 2.085 ft/day

Ss = 1.387E-7 ft<sup>-1</sup>

Kz/Kr = 0.1





#### WELL TEST ANALYSIS

Data Set: \\...\PB-1S-Test2 KGS.aqt

Date: 02/08/19

Time: 13:36:19

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-1S

Test Date: 1/30/2019

#### AQUIFER DATA

Saturated Thickness: 42.44 ft

#### WELL DATA (PB-1S)

Initial Displacement: 10.17 ft

Total Well Penetration Depth: 14.44 ft

Casing Radius: 0.08 ft

Static Water Column Height: 14.44 ft

Screen Length: 10. ft

Well Radius: 0.08 ft

#### SOLUTION


Aquifer Model: Unconfined

Solution Method: KGS Model

Kr = 2.504 ft/day

Ss = 2.866E-7 ft<sup>-1</sup>

Kz/Kr = 0.1



#### WELL TEST ANALYSIS

Data Set: \...\PB-4S-Test1 Bouwer-Rice.aqt

Date: 02/07/19

Time: 12:00:47

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-4S

Test Date: 1/28/2019

#### AQUIFER DATA

Saturated Thickness: 72.42 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

#### WELL DATA (PB-4S)

Initial Displacement: 11.61 ft

Static Water Column Height: 16.92 ft

Total Well Penetration Depth: 16.92 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


#### SOLUTION

Aquifer Model: Unconfined

Solution Method: Bouwer-Rice

$K = 3.462$  ft/day

$y_0 = 28.67$  ft



#### WELL TEST ANALYSIS

Data Set: \...\PB-4S-Test1 Hvorslev.aqt

Date: 02/07/19

Time: 12:01:49

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-4S

Test Date: 1/28/2019

#### AQUIFER DATA

Saturated Thickness: 72.42 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

#### WELL DATA (PB-4S)

Initial Displacement: 11.61 ft

Static Water Column Height: 16.92 ft

Total Well Penetration Depth: 16.92 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft

#### SOLUTION


Aquifer Model: Unconfined

Solution Method: Hvorslev

$K = 4.577$  ft/day

$y_0 = 30.34$  ft





#### WELL TEST ANALYSIS

Data Set: \...\PB-4S-Test2 Bouwer-Rice.aqt

Date: 02/07/19

Time: 12:09:56

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-4S

Test Date: 1/28/2019

#### AQUIFER DATA

Saturated Thickness: 72.42 ft

Anisotropy Ratio (Kz/Kr): 0.1

#### WELL DATA (PB-4S)

Initial Displacement: 8.79 ft

Static Water Column Height: 16.92 ft

Total Well Penetration Depth: 16.92 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


#### SOLUTION

Aquifer Model: Unconfined

Solution Method: Bouwer-Rice

K = 2.395 ft/day

y0 = 10.7 ft



#### WELL TEST ANALYSIS

Data Set: \...\PB-4S-Test2 Hvorslev.aqt

Date: 02/07/19

Time: 12:11:10

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-4S

Test Date: 1/28/2019

#### AQUIFER DATA

Saturated Thickness: 72.42 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

#### WELL DATA (PB-4S)

Initial Displacement: 8.79 ft

Static Water Column Height: 16.92 ft

Total Well Penetration Depth: 16.92 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


#### SOLUTION

Aquifer Model: Unconfined

Solution Method: Hvorslev

$K = 3.123$  ft/day

$y_0 = 11.03$  ft



#### WELL TEST ANALYSIS

Data Set: \...\PB-4S-Test1 KGS.aqt

Date: 02/08/19

Time: 16:03:21

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-4S

Test Date: 1/28/2019

#### AQUIFER DATA

Saturated Thickness: 72.42 ft

#### WELL DATA (PB-4S)

Initial Displacement: 11.61 ft

Total Well Penetration Depth: 16.92 ft

Casing Radius: 0.08 ft

Static Water Column Height: 16.92 ft

Screen Length: 10. ft

Well Radius: 0.08 ft

#### SOLUTION

Aquifer Model: Unconfined


Solution Method: KGS Model

Kr = 2.282 ft/day

Ss = 4.733E-7 ft<sup>-1</sup>

Kz/Kr = 0.1





#### WELL TEST ANALYSIS

Data Set: \...\PB-4S-Test2 KGS.aqt

Date: 02/08/19

Time: 16:05:53

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-4S

Test Date: 1/28/2019

#### AQUIFER DATA

Saturated Thickness: 72.42 ft

#### WELL DATA (PB-4S)

Initial Displacement: 8.79 ft

Total Well Penetration Depth: 16.92 ft

Casing Radius: 0.08 ft

Static Water Column Height: 16.92 ft

Screen Length: 10. ft

Well Radius: 0.08 ft

#### SOLUTION


Aquifer Model: Unconfined

Solution Method: KGS Model

Kr = 2.308 ft/day

Ss = 2.819E-7 ft<sup>-1</sup>

Kz/Kr = 0.1



#### WELL TEST ANALYSIS

Data Set: \...\PB-7S-Test2 Bouwer-Rice.aqt

Date: 02/07/19

Time: 14:45:26

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-7S

Test Date: 1/28/2019

#### AQUIFER DATA

Saturated Thickness: 12.48 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

#### WELL DATA (PB-7S)

Initial Displacement: 1.46 ft

Static Water Column Height: 8.78 ft

Total Well Penetration Depth: 10. ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


#### SOLUTION

Aquifer Model: Unconfined

Solution Method: Bouwer-Rice

$K = 0.497$  ft/day

$y_0 = 0.5622$  ft



#### WELL TEST ANALYSIS

Data Set: \...\PB-7S-Test2 Hvorslev.aqt

Date: 02/07/19

Time: 14:48:27

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-7S

Test Date: 1/28/2019

#### AQUIFER DATA

Saturated Thickness: 12.48 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

#### WELL DATA (PB-7S)

Initial Displacement: 1.46 ft

Static Water Column Height: 8.78 ft

Total Well Penetration Depth: 10. ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft

#### SOLUTION


Aquifer Model: Unconfined

Solution Method: Hvorslev

$K = 0.5739$  ft/day

$y_0 = 0.5189$  ft





### WELL TEST ANALYSIS

Data Set: \...\PB-7S-Test4 Bouwer-Rice.aqt

Date: 02/07/19

Time: 14:56:02

### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-7S

Test Date: 1/28/2019

### AQUIFER DATA

Saturated Thickness: 12.48 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

### WELL DATA (PB-7S)

Initial Displacement: 1.69 ft

Static Water Column Height: 8.78 ft

Total Well Penetration Depth: 10. ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


### SOLUTION

Aquifer Model: Unconfined

Solution Method: Bouwer-Rice

$K = 0.5073$  ft/day

$y_0 = 0.5319$  ft



#### WELL TEST ANALYSIS

Data Set: \...\PB-7S-Test4 Hvorslev.aqt

Date: 02/07/19

Time: 14:57:41

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-7S

Test Date: 1/28/2019

#### AQUIFER DATA

Saturated Thickness: 12.48 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

#### WELL DATA (PB-7S)

Initial Displacement: 1.69 ft

Static Water Column Height: 8.78 ft

Total Well Penetration Depth: 10. ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


#### SOLUTION

Aquifer Model: Unconfined

Solution Method: Hvorslev

$K = 0.6487$  ft/day

$y_0 = 0.5201$  ft



#### WELL TEST ANALYSIS

Data Set: \...\PB-7S-Test2 KGS.aqt

Date: 02/07/19

Time: 15:04:39

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-7S

Test Date: 1/28/2019

#### AQUIFER DATA

Saturated Thickness: 12.48 ft

#### WELL DATA (PB-7S)

Initial Displacement: 1.46 ft

Static Water Column Height: 8.78 ft

Total Well Penetration Depth: 10. ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft

#### SOLUTION

Aquifer Model: Unconfined


Solution Method: KGS Model

Kr = 0.7604 ft/day

Ss = 0.008013 ft<sup>-1</sup>

Kz/Kr = 0.1





#### WELL TEST ANALYSIS

Data Set: \\...\PB-7S-Test4 KGS.aqt

Date: 02/08/19

Time: 10:15:31

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-7S

Test Date: 1/28/2019

#### AQUIFER DATA

Saturated Thickness: 12.48 ft

#### WELL DATA (PB-7S)

Initial Displacement: 1.69 ft

Static Water Column Height: 8.78 ft

Total Well Penetration Depth: 10. ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft

#### SOLUTION


Aquifer Model: Unconfined

Solution Method: KGS Model

Kr = 0.8449 ft/day

Ss = 0.008013 ft<sup>-1</sup>

Kz/Kr = 0.1



### WELL TEST ANALYSIS

Data Set: \...\PB-8S-Test2 Bouwer-Rice.aqt

Date: 02/07/19

Time: 15:36:04

### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-8S

Test Date: 1/29/2019

### AQUIFER DATA

Saturated Thickness: 63.95 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

### WELL DATA (PB-8S)

Initial Displacement: 6.249 ft

Static Water Column Height: 14.45 ft

Total Well Penetration Depth: 14.45 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


### SOLUTION

Aquifer Model: Unconfined

Solution Method: Bouwer-Rice

$K = 0.1208$  ft/day

$y_0 = 3.44$  ft



#### WELL TEST ANALYSIS

Data Set: \...\PB-8S-Test2 Hvorslev.aqt

Date: 02/07/19

Time: 15:37:30

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-8S

Test Date: 1/29/2019

#### AQUIFER DATA

Saturated Thickness: 63.95 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

#### WELL DATA (PB-8S)

Initial Displacement: 6.249 ft

Static Water Column Height: 14.45 ft

Total Well Penetration Depth: 14.45 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


#### SOLUTION

Aquifer Model: Unconfined

Solution Method: Hvorslev

$K = 0.1464$  ft/day

$y_0 = 3.233$  ft



#### WELL TEST ANALYSIS

Data Set: \...\PB-8S-Test2 KGS.aqt

Date: 02/07/19

Time: 15:49:43

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-8S

Test Date: 1/29/2019

#### AQUIFER DATA

Saturated Thickness: 63.95 ft

#### WELL DATA (PB-8S)

Initial Displacement: 6.249 ft

Static Water Column Height: 14.45 ft

Total Well Penetration Depth: 14.45 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft

#### SOLUTION

Aquifer Model: Unconfined


Solution Method: KGS Model

Kr = 0.1504 ft/day

Ss = 0.001564 ft<sup>-1</sup>

Kz/Kr = 0.1





### WELL TEST ANALYSIS

Data Set: \...\PB-10S-Test1 Bouwer-Rice.aqt

Date: 02/07/19

Time: 16:22:42

### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-10S

Test Date: 1/29/2019

### AQUIFER DATA

Saturated Thickness: 57.78 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

### WELL DATA (PB-10S)

Initial Displacement: 12.81 ft

Static Water Column Height: 24.38 ft

Total Well Penetration Depth: 24.38 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


### SOLUTION

Aquifer Model: Unconfined

Solution Method: Bouwer-Rice

$K = 1.561$  ft/day

$y_0 = 11.57$  ft



### WELL TEST ANALYSIS

Data Set: \...\PB-10S-Test1 Hvorslev.aqt

Date: 02/07/19

Time: 16:23:52

### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-10S

Test Date: 1/29/2019

### AQUIFER DATA

Saturated Thickness: 57.78 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

### WELL DATA (PB-10S)

Initial Displacement: 12.81 ft

Static Water Column Height: 24.38 ft

Total Well Penetration Depth: 24.38 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


### SOLUTION

Aquifer Model: Unconfined

Solution Method: Hvorslev

$K = 1.935$  ft/day

$y_0 = 11.57$  ft



#### WELL TEST ANALYSIS

Data Set: \...\PB-10S-Test1 KGS.aqt

Date: 02/07/19

Time: 16:25:52

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-10S

Test Date: 1/29/2019

#### AQUIFER DATA

Saturated Thickness: 57.78 ft

#### WELL DATA (PB-10S)

Initial Displacement: 12.81 ft

Static Water Column Height: 24.38 ft

Total Well Penetration Depth: 24.38 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft

#### SOLUTION


Aquifer Model: Unconfined

Solution Method: KGS Model

Kr = 1.835 ft/day

Ss = 1.187E-5 ft<sup>-1</sup>

Kz/Kr = 0.1



### WELL TEST ANALYSIS

Data Set: \...\PB-10S-Test2 Bouwer-Rice.aqt

Date: 02/07/19

Time: 17:03:22

### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-10S

Test Date: 1/29/2019

### AQUIFER DATA

Saturated Thickness: 57.78 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

### WELL DATA (PB-10S)

Initial Displacement: 13.43 ft

Static Water Column Height: 24.38 ft

Total Well Penetration Depth: 24.38 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft

### SOLUTION


Aquifer Model: Unconfined

Solution Method: Bouwer-Rice

$K = 1.423$  ft/day

$y_0 = 12.54$  ft





### WELL TEST ANALYSIS

Data Set: \...\PB-10S-Test2 Hvorslev.aqt

Date: 02/07/19

Time: 17:04:59

### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-10S

Test Date: 1/29/2019

### AQUIFER DATA

Saturated Thickness: 57.78 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

### WELL DATA (PB-10S)

Initial Displacement: 13.43 ft

Static Water Column Height: 24.38 ft

Total Well Penetration Depth: 24.38 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


### SOLUTION

Aquifer Model: Unconfined

Solution Method: Hvorslev

$K = 1.764$  ft/day

$y_0 = 12.54$  ft



### WELL TEST ANALYSIS

Data Set: \...\PB-10S-Test2 KGS.aqt

Date: 02/07/19

Time: 17:07:10

### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-10S

Test Date: 1/29/2019

### AQUIFER DATA

Saturated Thickness: 57.78 ft

### WELL DATA (PB-10S)

Initial Displacement: 13.43 ft

Static Water Column Height: 24.38 ft

Total Well Penetration Depth: 24.38 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft

### SOLUTION


Aquifer Model: Unconfined

Solution Method: KGS Model

Kr = 1.69 ft/day

Ss = 3.614E-6 ft<sup>-1</sup>

Kz/Kr = 0.1



#### PZ-30I FALLING

Data Set: G:\...\PZ-30I Falling.aqt

Date: 09/19/16

Time: 14:21:41

#### PROJECT INFORMATION

Company: Golder Associates

Client: Southern Company Services

Project: 1660939

Location: Plant Branch

Test Well: PZ-30I Falling

Test Date: 08/15/16

#### AQUIFER DATA

Saturated Thickness: 100. ft

Anisotropy Ratio ( $K_z/K_r$ ): 1.

#### WELL DATA (PZ-30I Falling)

Initial Displacement: 1.879 ft

Static Water Column Height: 15.45 ft

Total Well Penetration Depth: 15.95 ft

Screen Length: 10. ft

Casing Radius: 0.08333 ft

Well Radius: 0.08333 ft

Gravel Pack Porosity: 0.15


#### SOLUTION

Aquifer Model: Unconfined

Solution Method: Bouwer-Rice

$K = 2.587$  ft/day

$y_0 = 2.043$  ft



### PZ-30I RISING

Data Set: G:\...\PZ-30I Rising.aqt

Date: 09/19/16

Time: 14:23:53

### PROJECT INFORMATION

Company: Golder Associates

Client: Southern Company Services

Project: 1660939

Location: Plant Branch

Test Well: PZ-30I Rising

Test Date: 08/15/16

### AQUIFER DATA

Saturated Thickness: 100. ft

Anisotropy Ratio (Kz/Kr): 1.

### WELL DATA (PZ-30I Rising)

Initial Displacement: 1.678 ft

Static Water Column Height: 15.45 ft

Total Well Penetration Depth: 15.45 ft

Screen Length: 9.5 ft

Casing Radius: 0.08333 ft

Well Radius: 0.08333 ft

Gravel Pack Porosity: 0.15

### SOLUTION


Aquifer Model: Unconfined

Solution Method: Bouwer-Rice

K = 5.607 ft/day

y0 = 2.067 ft





### WELL TEST ANALYSIS

Data Set: N:\...\181-1.aqt  
Date: 11/13/19

Time: 16:21:04

### PROJECT INFORMATION

Company: SCS  
Test Well: BRANCH 181

### AQUIFER DATA

Saturated Thickness: 21.7 ft

Anisotropy Ratio ( $K_z/K_r$ ): 1.

### WELL DATA (PZ-181 RISING HEAD 1)


Initial Displacement: 3. ft  
Total Well Penetration Depth: 21.7 ft  
Casing Radius: 0.167 ft

Static Water Column Height: 21.7 ft  
Screen Length: 10. ft  
Well Radius: 0.42 ft  
Gravel Pack Porosity: 0.

### SOLUTION

Aquifer Model: Unconfined  
 $K =$  6.67 ft/day

Solution Method: Bouwer-Rice  
 $y_0 =$  6.063 ft



### B-14 SLUG OUT

Data Set: T:\ESEE MAJOR PROJECTS\PROJECTS\Branch\2007\SAR\Slug Tests\B14 Slug Out.aqt

Date: 01/29/08

Time: 14:59:40

### PROJECT INFORMATION

Company: Georgia Power

Location: Plant Branch

Test Well: B-14

Test Date: 12/18/07

### AQUIFER DATA

Saturated Thickness: 100. ft

Anisotropy Ratio ( $K_z/K_r$ ): 1.

### WELL DATA (B14 Slug Out)

Initial Displacement: 1.545 ft

Static Water Column Height: 26.5 ft

Total Well Penetration Depth: 26.5 ft

Screen Length: 10. ft

Casing Radius: 0.083 ft

Wellbore Radius: 0.333 ft

Gravel Pack Porosity: 0.2


### SOLUTION

Aquifer Model: Confined

Solution Method: Bouwer-Rice

$K = 0.0007795$  cm/sec

$y_0 = 1.549$  ft



#### B-14 SLUG IN

Data Set: T:\ESEE MAJOR PROJECTS\PROJECTS\Branch\2007\SAR\Slug Tests\B14 Slug In.aqt

Date: 01/29/08

Time: 15:02:01

#### PROJECT INFORMATION

Company: Georgia Power

Location: Plant Branch

Test Well: B-14

Test Date: 12/18/07

#### AQUIFER DATA

Saturated Thickness: 100. ft

Anisotropy Ratio ( $K_z/K_r$ ): 1.

#### WELL DATA (B14 Slug In)

Initial Displacement: 1.545 ft

Static Water Column Height: 19.3 ft

Total Well Penetration Depth: 19.3 ft

Screen Length: 10. ft

Casing Radius: 0.083 ft

Wellbore Radius: 0.333 ft

Gravel Pack Porosity: 0.2


#### SOLUTION

Aquifer Model: Confined

Solution Method: Bouwer-Rice

$K = 0.0006892$  cm/sec

$y_0 = 1.407$  ft



### PZ-23I RISING

Data Set: G:\...\PZ-23I Rising.aqt  
 Date: 09/19/16

Time: 13:07:36

### PROJECT INFORMATION

Company: Golder Associates  
 Client: Southern Company Services  
 Project: 1660939  
 Location: Plant Branch  
 Test Well: PZ-23I Rising  
 Test Date: 08/12/16

### AQUIFER DATA

Saturated Thickness: 100. ft

Anisotropy Ratio (Kz/Kr): 1.

### WELL DATA (PZ-23I Rising)

Initial Displacement: 7.907 ft  
 Total Well Penetration Depth: 27.21 ft  
 Casing Radius: 0.08333 ft


Static Water Column Height: 27.21 ft  
 Screen Length: 10. ft  
 Well Radius: 0.08333 ft  
 Gravel Pack Porosity: 0.15

### SOLUTION

Aquifer Model: Unconfined  
 K = 0.001593 ft/day

Solution Method: Bouwer-Rice  
 y0 = 7.568 ft





#### B-4 SLUG IN

Data Set: T:\ESEE MAJOR PROJECTS\PROJECTS\Branch\2007\SAR\Slug Tests\B4 Slug In.aqt

Date: 01/17/08

Time: 14:47:06

#### PROJECT INFORMATION

Company: Georgia Power

Location: Plant Branch

Test Well: B-4

Test Date: 12/18/07

#### AQUIFER DATA

Saturated Thickness: 100. ft

Anisotropy Ratio ( $K_z/K_r$ ): 1.

#### WELL DATA (B4 Slug In)

Initial Displacement: 1.545 ft

Static Water Column Height: 47.6 ft

Total Well Penetration Depth: 68.5 ft

Screen Length: 10. ft

Casing Radius: 0.083 ft

Wellbore Radius: 0.333 ft

Gravel Pack Porosity: 0.2


#### SOLUTION

Aquifer Model: Confined

Solution Method: Bouwer-Rice

$K = 0.000341$  cm/sec

$y_0 = 1.662$  ft



#### B-4 SLUG OUT

Data Set: T:\ESEE MAJOR PROJECTS\PROJECTS\Branch\2007\SAR\Slug Tests\B4 Slug Out.agt  
 Date: 03/04/08 Time: 13:22:39

#### PROJECT INFORMATION

Company: Georgia Power  
 Location: Plant Branch  
 Test Well: B-4  
 Test Date: 12/18/07

#### AQUIFER DATA


Saturated Thickness: 100. ft Anisotropy Ratio ( $K_z/K_r$ ): 1.

#### WELL DATA (B4 Slug Out)

Initial Displacement: 1.545 ft Static Water Column Height: 47.6 ft  
 Total Well Penetration Depth: 68.5 ft Screen Length: 10. ft  
 Casing Radius: 0.083 ft Wellbore Radius: 0.333 ft  
 Gravel Pack Porosity: 0.2

#### SOLUTION

Aquifer Model: Confined Solution Method: Bouwer-Rice  
 $K = 0.0003459$  cm/sec  $y_0 = 1.127$  ft



### B-7 SLUG IN

Data Set: T:\ESEE MAJOR PROJECTS\PROJECTS\Branch\2007\SAR\Slug Tests\B7 Slug In.aqt  
 Date: 01/17/08 Time: 14:47:32

### PROJECT INFORMATION

Company: Georgia Power  
 Location: Plant Branch  
 Test Well: B-7  
 Test Date: 12/18/07

### AQUIFER DATA


Saturated Thickness: 100. ft Anisotropy Ratio ( $K_z/K_r$ ): 1.

### WELL DATA (B7 Slug In)

Initial Displacement: 1.545 ft Static Water Column Height: 27. ft  
 Total Well Penetration Depth: 11. ft Screen Length: 10. ft  
 Casing Radius: 0.083 ft Wellbore Radius: 0.333 ft  
 Gravel Pack Porosity: 0.2

### SOLUTION

Aquifer Model: Confined Solution Method: Bouwer-Rice  
 $K = 9.258E-5$  cm/sec  $y_0 = 0.8788$  ft



### B-7 SLUG OUT

Data Set: T:\ESEE MAJOR PROJECTS\PROJECTS\Branch\2007\SAR\Slug Tests\B7 Slug Out.aqt  
 Date: 01/17/08 Time: 14:47:38

### PROJECT INFORMATION

Company: Georgia Power  
 Location: Plant Branch  
 Test Well: B-7  
 Test Date: 12/18/07

### AQUIFER DATA

Saturated Thickness: 100. ft Anisotropy Ratio ( $K_z/K_r$ ): 1.


### WELL DATA (B7 Slug Out)

Initial Displacement: 1.545 ft Static Water Column Height: 27. ft  
 Total Well Penetration Depth: 11. ft Screen Length: 10. ft  
 Casing Radius: 0.083 ft Wellbore Radius: 0.333 ft  
 Gravel Pack Porosity: 0.2

### SOLUTION

Aquifer Model: Confined Solution Method: Bouwer-Rice  
 $K = 0.000108$  cm/sec  $y_0 = 0.2556$  ft





### WELL TEST ANALYSIS

Data Set: \...\PB-2D-Test1 Bouwer-Rice.aqt

Date: 02/07/19

Time: 11:41:37

### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-2D

Test Date: 1/30/2019

### AQUIFER DATA

Saturated Thickness: 21.21 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

### WELL DATA (PB-2D)

Initial Displacement: 0.69 ft

Static Water Column Height: 19.31 ft

Total Well Penetration Depth: 19.31 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


### SOLUTION

Aquifer Model: Unconfined

Solution Method: Bouwer-Rice

$K = 0.001595$  ft/day

$y_0 = 0.4781$  ft



### WELL TEST ANALYSIS

Data Set: \...\PB-2D-Test1 Hvorslev.aqt

Date: 02/07/19

Time: 11:52:23

### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-2D

Test Date: 1/30/2019

### AQUIFER DATA

Saturated Thickness: 21.21 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

### WELL DATA (PB-2D)

Initial Displacement: 0.69 ft

Static Water Column Height: 19.31 ft

Total Well Penetration Depth: 19.31 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


### SOLUTION

Aquifer Model: Unconfined

Solution Method: Hvorslev

$K = 0.002708$  ft/day

$y_0 = 0.4767$  ft



#### WELL TEST ANALYSIS

Data Set: \...\PB-4D-Test5 Bouwer-Rice.aqt

Date: 02/07/19

Time: 11:38:30

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-4D

Test Date: 1/30/2019

#### AQUIFER DATA

Saturated Thickness: 88.01 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

#### WELL DATA (PB-4D)

Initial Displacement: 1.158 ft

Static Water Column Height: 84.91 ft

Total Well Penetration Depth: 84.91 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


#### SOLUTION

Aquifer Model: Unconfined

Solution Method: Bouwer-Rice

$K = 0.01452$  ft/day

$y_0 = 2.136$  ft



### WELL TEST ANALYSIS

Data Set: \...\PB-4D-Test5 Hvorslev.aqt

Date: 02/07/19

Time: 11:39:54

### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-4D

Test Date: 1/30/2019

### AQUIFER DATA

Saturated Thickness: 88.01 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

### WELL DATA (PB-4D)

Initial Displacement: 1.158 ft

Static Water Column Height: 84.91 ft

Total Well Penetration Depth: 84.91 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft

### SOLUTION


Aquifer Model: Unconfined

Solution Method: Hvorslev

$K = 0.01516$  ft/day

$y_0 = 2.023$  ft





### WELL TEST ANALYSIS

Data Set: \...\PB-8D-Test3 Hvorslev.aqt

Date: 02/07/19

Time: 15:15:48

### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-8D

Test Date: 1/29/2019

### AQUIFER DATA

Saturated Thickness: 87.45 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

### WELL DATA (PB-8D)

Initial Displacement: 4.164 ft

Static Water Column Height: 84.15 ft

Total Well Penetration Depth: 84.15 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


### SOLUTION

Aquifer Model: Unconfined

Solution Method: Hvorslev

$K = 0.02077$  ft/day

$y_0 = 4.224$  ft



### WELL TEST ANALYSIS

Data Set: \...\PB-8D-Test3 Bouwer-Rice.aqt

Date: 02/07/19

Time: 15:17:11

### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-8D

Test Date: 1/29/2019

### AQUIFER DATA

Saturated Thickness: 87.45 ft

Anisotropy Ratio (Kz/Kr): 0.1

### WELL DATA (PB-8D)

Initial Displacement: 4.164 ft

Static Water Column Height: 84.15 ft

Total Well Penetration Depth: 84.15 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


### SOLUTION

Aquifer Model: Unconfined

Solution Method: Bouwer-Rice

K = 0.01984 ft/day

y0 = 4.248 ft



#### WELL TEST ANALYSIS

Data Set: \\...\PB-8D-Test3 KGS.aqt

Date: 02/07/19

Time: 15:25:15

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-8D

Test Date: 1/29/2019

#### AQUIFER DATA

Saturated Thickness: 87.45 ft

#### WELL DATA (PB-8D)

Initial Displacement: 4.164 ft

Static Water Column Height: 84.15 ft

Total Well Penetration Depth: 84.15 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft

#### SOLUTION


Aquifer Model: Unconfined

Solution Method: KGS Model

Kr = 0.02011 ft/day

Ss = 1.144E-12 ft<sup>-1</sup>

Kz/Kr = 0.1



### WELL TEST ANALYSIS

Data Set: \...\PB-10D-Test1 Bouwer-Rice.aqt

Date: 02/07/19

Time: 15:58:23

### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-10D

Test Date: 1/29/2019

### AQUIFER DATA

Saturated Thickness: 79.25 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

### WELL DATA (PB-10D)

Initial Displacement: 2.02 ft

Static Water Column Height: 76.9 ft

Total Well Penetration Depth: 76.9 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft

### SOLUTION


Aquifer Model: Unconfined

Solution Method: Bouwer-Rice

$K = 0.0004809$  ft/day

$y_0 = 1.277$  ft





#### WELL TEST ANALYSIS

Data Set: \...\PB-10D-Test1 Hvorslev.aqt

Date: 02/07/19

Time: 16:04:14

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-10D

Test Date: 1/29/2019

#### AQUIFER DATA

Saturated Thickness: 79.25 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

#### WELL DATA (PB-10D)

Initial Displacement: 2.02 ft

Static Water Column Height: 76.9 ft

Total Well Penetration Depth: 76.9 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


#### SOLUTION

Aquifer Model: Unconfined

Solution Method: Hvorslev

$K = 0.0005599$  ft/day

$y_0 = 1.286$  ft



#### WELL TEST ANALYSIS

Data Set: \...\PB-10D-Test1 KGS.aqt

Date: 02/07/19

Time: 16:16:04

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-10D

Test Date: 1/29/2019

#### AQUIFER DATA

Saturated Thickness: 79.25 ft

#### WELL DATA (PB-10D)

Initial Displacement: 2.02 ft

Total Well Penetration Depth: 76.9 ft

Casing Radius: 0.08 ft

Static Water Column Height: 76.9 ft

Screen Length: 10. ft

Well Radius: 0.08 ft

#### SOLUTION


Aquifer Model: Unconfined

Solution Method: KGS Model

Kr = 0.007202 ft/day

Ss = 0.001564 ft<sup>-1</sup>

Kz/Kr = 0.1



### WELL TEST ANALYSIS

Data Set: \...\PB-13D-Test1 Bouwer-Rice.aqt

Date: 02/07/19

Time: 17:14:20

### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-13D

Test Date: 1/30/2019

### AQUIFER DATA

Saturated Thickness: 92.42 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

### WELL DATA (PB-13D)

Initial Displacement: 10.13 ft

Static Water Column Height: 89.72 ft

Total Well Penetration Depth: 89.72 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft


### SOLUTION

Aquifer Model: Unconfined

Solution Method: Bouwer-Rice

$K = 0.2806$  ft/day

$y_0 = 8.644$  ft



#### WELL TEST ANALYSIS

Data Set: \\...\PB-13D-Test1 Hvorslev.aqt

Date: 02/07/19

Time: 17:28:39

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-13D

Test Date: 1/30/2019

#### AQUIFER DATA

Saturated Thickness: 92.42 ft

Anisotropy Ratio ( $K_z/K_r$ ): 0.1

#### WELL DATA (PB-13D)

Initial Displacement: 10.13 ft

Static Water Column Height: 89.72 ft

Total Well Penetration Depth: 89.72 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft

#### SOLUTION


Aquifer Model: Unconfined

Solution Method: Hvorslev

$K = 0.2946$  ft/day

$y_0 = 8.643$  ft





#### WELL TEST ANALYSIS

Data Set: \...\PB-13D-Test1 KGS.aqt

Date: 02/07/19

Time: 17:30:35

#### PROJECT INFORMATION

Company: Geosyntec Consultants

Client: Georgia Power Company

Project: GW6364

Location: Milledgeville, Georgia

Test Well: PB-13D

Test Date: 1/30/2019

#### AQUIFER DATA

Saturated Thickness: 92.42 ft

#### WELL DATA (PB-13D)

Initial Displacement: 10.13 ft

Static Water Column Height: 89.72 ft

Total Well Penetration Depth: 89.72 ft

Screen Length: 10. ft

Casing Radius: 0.08 ft

Well Radius: 0.08 ft

#### SOLUTION

Aquifer Model: Unconfined

Solution Method: KGS Model

Kr = 0.2327 ft/day

Ss = 0.0002057 ft<sup>-1</sup>

Kz/Kr = 0.1

Response to SAR Comments – Proposed CCR Landfill  
Georgia Power – Plant Branch – Putnam County, Georgia  
Georgia Environmental Protection Division  
January 2020

## **Attachment F**

---

### **Soil Laboratory Test Results**

Bin 39110  
5131 Maner Road  
Smyrna, Georgia 30080  
Tel 404.799.2100  
Fax 404.799.2141



February 11, 2006

Ms. Rhonda Tinsley  
Southern Company Services  
SCG Earth Sciences & Env Engr  
42 Inverness Center Parkway  
Birmingham, AL 35242

RE: Branch Kd Sorption and Cation Exchange Capacity Analytical Results

The Environmental Laboratory has completed the analysis of your samples and reports the results on the attached pages. Our laboratory maintains current NELAC accreditation for those analytes listed under the scope of accreditation. Analytes not listed in this scope are currently not maintained under an accreditation program. The analytes of this report that are listed under our NELAC scope of accreditation meet all requirements of the NELAC standard unless otherwise noted by data qualifiers. For internal clients, the scope and effective dates of our accreditation can be found at:

<http://environmental.southernco.com/gpc/environmental-lab/chem.html>

Please note the attached results from TestAmerica Laboratories, Inc. All results relate only to the contents of the samples as submitted. Samples will be disposed of after 30 days unless otherwise instructed. This report should only be reproduced in full with all associated records.

If you have any questions, please advise.

Respectively Submitted,

Robert S. Dickerson  
Project Manager

Georgia Power Company  
Environmental Laboratory  
5131 Maner Road  
Smyrna, GA 30080  
(404) 799-2100  
(404) 799-2141 (FAX)

Certificate of Analysis

Rhonda Tinsley  
Southern Company Services  
SCG Earth Sciences & Env Engr  
42 Inverness Center parkway  
Birmingham, AL 35242

REPORT SUMMARY				
SAMPLE #	SAMPLE DESCRIPTION	DATE COLLECTED	TEST METHOD	QC HBN
28330001	BH #4 0-6', Water		EPA 6010B	261953
28330002	BH #4 0-6', Water		EPA 6010B	261953
28330003	BH #4 0-6', Water		EPA 6010B	261953
28330004	BH #5 0-10', Water		EPA 6010B	261953
28330005	BH #5 0-10', Water		EPA 6010B	261953
28330006	BH #5 0-10', Water		EPA 6010B	261953
28330007	BH #7 0-6', Water		EPA 6010B	261953
28330008	BH #7 0-6', Water		EPA 6010B	261953
28330009	BH #7 0-6', Water		EPA 6010B	261953
28330010	BH #11 0-7', Water		EPA 6010B	261953
28330011	BH #11 0-7', Water		EPA 6010B	261953
28330012	BH #11 0-7', Water		EPA 6010B	261953
28330013	BH #12 0-8', Water		EPA 6010B	261953
28330014	BH #12 0-8', Water		EPA 6010B	261953
28330015	BH #12 0-8', Water		EPA 6010B	261953
28330016	BH #13 0-10', Water		EPA 6010B	262013
28330017	BH #13 0-10', Water		EPA 6010B	261953

February 06, 2008

Georgia Power Company  
Environmental Laboratory  
5131 Maner Road  
Smyrna, GA 30080  
(404) 799-2100  
(404) 799-2141 (FAX)  
Certificate of Analysis

Rhonda Tinsley  
Southern Company Services  
SCG Earth Sciences & Env Engr  
42 Inverness Center parkway  
Birmingham, AL 35242

Workorder Kd Sorption - Branch

SAMPLE #	SAMPLE DESCRIPTION	DATE COLLECTED	TEST METHOD	QC HBN
28330018	BH #13 0-10', Water		EPA 6010B	261953

ND - Not detectable at specified reporting limit.

This document may be reproduced only in its entirety. Our analysis is based upon the sample received and does not guarantee the uniformity of the lot.

February 06, 2008



Georgia Power Company  
Environmental Laboratory  
5131 Maner Road  
Smyrna, GA 30080  
(404) 799-2100  
(404) 799-2141 (FAX)

Certificate of Analysis

Rhonda Tinsley  
Southern Company Services  
SCG Earth Sciences & Env Engr  
42 Inverness Center parkway  
Birmingham, AL 35242

Sample Information

Sample ID:	28330001	Matrix:	Water	Analysis Request:	23337
Location:	Branch	Sample Date/Time:		Workorder ID:	28330
Description:	Branch Soil	Received Date/Time:	01/18/08 09:00	Purchase Order:	
Field ID:	BH #4 0-6'	Collector:	Rhonda Tinsley		

INORGANICS

Analyte	Date	Prep	Prep	Analytical	Result	Reporting	Units	Analyst	Date
	Prepared	Method	By	Method		Limit			Analyzed
Selenium	02/01/08	EPA 3010	ECS	EPA 6010B	0.013	0.0080	mg/L	CKP	02/05/08

February 06, 2008

ND - Not detectable at specified reporting limit.

This document may be reproduced only in its entirety. Our analysis is based upon the sample received and does not guarantee the uniformity of the lot.

Georgia Power Company  
Environmental Laboratory  
5131 Maner Road  
Smyrna, GA 30080  
(404) 799-2100  
(404) 799-2141 (FAX)

Certificate of Analysis

Rhonda Tinsley  
Southern Company Services  
SCG Earth Sciences & Env Engr  
42 Inverness Center parkway  
Birmingham, AL 35242

Sample Information

Sample ID:	28330002	Matrix:	Water	Analysis Request:	23337
Location:	Branch	Sample Date/Time:		Workorder ID:	28330
Description:	Branch Soil	Received Date/Time:	01/18/08 09:00	Purchase Order:	
Field ID:	BH #4 0-6'	Collector:	Rhonda Tinsley		

INORGANICS

Analyte	Date	Prep	Prep	Analytical	Result	Reporting	Units	Analyst	Date
	Prepared	Method	By	Method		Limit			Analyzed
Selenium	02/01/08	EPA 3010	ECS	EPA 6010B	0.021	0.0080	mg/L	CKP	02/05/08

February 06, 2008

ND - Not detectable at specified reporting limit.

This document may be reproduced only in its entirety. Our analysis is based upon the sample received and does not guarantee the uniformity of the lot.

Georgia Power Company  
Environmental Laboratory  
5131 Maner Road  
Smyrna, GA 30080  
(404) 799-2100  
(404) 799-2141 (FAX)

## Certificate of Analysis

Rhonda Tinsley  
Southern Company Services  
SCG Earth Sciences & Env Engr  
42 Inverness Center parkway  
Birmingham, AL 35242

## Sample Information

Sample ID:	28330003	Matrix:	Water	Analysis Request:	23337
Location:	Branch	Sample Date/Time:		Workorder ID:	28330
Description:	Branch Soil	Received Date/Time:	01/18/08 09:00	Purchase Order:	
Field ID:	BH #4 0-6'	Collector:	Rhonda Tinsley		

## INORGANICS

Analyte	Date	Prep	Prep	Analytical	Result	Reporting	Units	Analyst	Date
	Prepared	Method	By	Method		Limit			Analyzed
Selenium	02/01/08	EPA 3010	ECS	EPA 6010B	0.026	0.0080	mg/L	CKP	02/05/08

February 06, 2008

ND - Not detectable at specified reporting limit.

This document may be reproduced only in its entirety. Our analysis is based upon the sample received and does not guarantee the uniformity of the lot.

Georgia Power Company  
Environmental Laboratory

5131 Maner Road

Smyrna, GA 30080

(404) 799-2100

(404) 799-2141 (FAX)

## Certificate of Analysis

Rhonda Tinsley  
Southern Company Services  
SCG Earth Sciences & Env Engr  
42 Inverness Center parkway  
Birmingham, AL 35242

## Sample Information

Sample ID: 28330004  
Location: Branch  
Description: Branch Soil  
Field ID: BH #5 0-10'

Matrix: Water  
Sample Date/Time:  
Received Date/Time: 01/18/08 09:00  
Collector: Rhonda Tinsley

Analysis Request: 23337  
Workorder ID: 28330  
Purchase Order:

## INORGANICS

Analyte	Date Prepared	Prep Method	Prep By	Analytical Method	Result	Reporting Limit	Units	Analyst	Date Analyzed
Selenium	02/01/08	EPA 3010	ECS	EPA 6010B	ND	0.0080	mg/L	CKP	02/05/08

February 06, 2008

ND - Not detectable at specified reporting limit.

This document may be reproduced only in its entirety. Our analysis is based upon the sample received and does not guarantee the uniformity of the lot.

Georgia Power Company  
Environmental Laboratory  
5131 Maner Road  
Smyrna, GA 30080  
(404) 799-2100  
(404) 799-2141 (FAX)

Certificate of Analysis

Rhonda Tinsley  
Southern Company Services  
SCG Earth Sciences & Env Engr  
42 Inverness Center parkway  
Birmingham, AL 35242

Sample Information

Sample ID:	28330005	Matrix:	Water	Analysis Request:	23337
Location:	Branch	Sample Date/Time:		Workorder ID:	28330
Description:	Branch Soil	Received Date/Time:	01/18/08 09:00	Purchase Order:	
Field ID:	BH #5 0-10'	Collector:	Rhonda Tinsley		

INORGANICS

Analyte	Date Prepared	Prep Method	Prep By	Analytical Method	Result	Reporting Limit	Units	Analyst	Date Analyzed
Selenium	02/01/08	EPA 3010	ECS	EPA 6010B	0.0085	0.0080	mg/L	CKP	02/05/08

February 06, 2008

ND - Not detectable at specified reporting limit.

This document may be reproduced only in its entirety. Our analysis is based upon the sample received and does not guarantee the uniformity of the lot.



Georgia Power Company  
Environmental Laboratory  
5131 Maner Road  
Smyrna, GA 30080  
(404) 799-2100  
(404) 799-2141 (FAX)

Certificate of Analysis

Rhonda Tinsley  
Southern Company Services  
SCG Earth Sciences & Env Engr  
42 Inverness Center parkway  
Birmingham, AL 35242

Sample Information

Sample ID:	28330006	Matrix:	Water	Analysis Request:	23337
Location:	Branch	Sample Date/Time:		Workorder ID:	28330
Description:	Branch Soil	Received Date/Time:	01/18/08 09:00	Purchase Order:	
Field ID:	BH #5 0-10'	Collector:	Rhonda Tinsley		

INORGANICS

Analyte	Date Prepared	Prep Method	Prep By	Analytical Method	Result	Reporting Limit	Units	Analyst	Date Analyzed
Selenium	02/01/08	EPA 3010	ECS	EPA 6010B	ND	0.0080	mg/L	CKP	02/05/08

February 06, 2008

ND - Not detectable at specified reporting limit.

This document may be reproduced only in its entirety. Our analysis is based upon the sample received and does not guarantee the uniformity of the lot.

Georgia Power Company  
Environmental Laboratory  
5131 Maner Road  
Smyrna, GA 30080  
(404) 799-2100  
(404) 799-2141 (FAX)

Certificate of Analysis

Rhonda Tinsley  
Southern Company Services  
SCG Earth Sciences & Env Engr  
42 Inverness Center parkway  
Birmingham, AL 35242

Sample Information

Sample ID:	28330007	Matrix:	Water	Analysis Request:	23337
Location:	Branch	Sample Date/Time:		Workorder ID:	28330
Description:	Branch Soil	Received Date/Time:	01/18/08 09:00	Purchase Order:	
Field ID:	BH #7 0-6'	Collector:	Rhonda Tinsley		

INORGANICS

Analyte	Date Prepared	Prep Method	Prep By	Analytical Method	Result	Reporting Limit	Units	Analyst	Date Analyzed
Selenium	02/01/08	EPA 3010	ECS	EPA 6010B	ND	0.0080	mg/L	CKP	02/05/08

February 06, 2008

ND - Not detectable at specified reporting limit.

This document may be reproduced only in its entirety. Our analysis is based upon the sample received and does not guarantee the uniformity of the lot.

Georgia Power Company  
Environmental Laboratory  
5131 Maner Road  
Smyrna, GA 30080  
(404) 799-2100  
(404) 799-2141 (FAX)

Certificate of Analysis

Rhonda Tinsley  
Southern Company Services  
SCG Earth Sciences & Env Engr  
42 Inverness Center parkway  
Birmingham, AL 35242

Sample Information

Sample ID:	28330008	Matrix:	Water	Analysis Request:	23337
Location:	Branch	Sample Date/Time:		Workorder ID:	28330
Description:	Branch Soil	Received Date/Time:	01/18/08 09:00	Purchase Order:	
Field ID:	BH #7 0-6'	Collector:	Rhonda Tinsley		

INORGANICS

Analyte	Date	Prep	Prep	Analytical	Result	Reporting	Units	Analyst	Date
	Prepared	Method	By	Method		Limit			Analyzed
Selenium	02/01/08	EPA 3010	ECS	EPA 6010B	ND	0.0080	mg/L	CKP	02/05/08

February 06, 2008

ND - Not detectable at specified reporting limit.

This document may be reproduced only in its entirety. Our analysis is based upon the sample received and does not guarantee the uniformity of the lot.

Georgia Power Company  
Environmental Laboratory  
5131 Maner Road  
Smyrna, GA 30080  
(404) 799-2100  
(404) 799-2141 (FAX)

Certificate of Analysis

Rhonda Tinsley  
Southern Company Services  
SCG Earth Sciences & Env Engr  
42 Inverness Center parkway  
Birmingham, AL 35242

Sample Information

Sample ID:	28330009	Matrix:	Water	Analysis Request:	23337
Location:	Branch	Sample Date/Time:		Workorder ID:	28330
Description:	Branch Soil	Received Date/Time:	01/18/08 09:00	Purchase Order:	
Field ID:	BH #7 0-6'	Collector:	Rhonda Tinsley		

INORGANICS

Analyte	Date Prepared	Prep Method	Prep By	Analytical Method	Result	Reporting Limit	Units	Analyst	Date Analyzed
Selenium	02/01/08	EPA 3010	ECS	EPA 6010B	0.017	0.0080	mg/L	CKP	02/05/08

February 06, 2008

ND - Not detectable at specified reporting limit.

This document may be reproduced only in its entirety. Our analysis is based upon the sample received and does not guarantee the uniformity of the lot.

Georgia Power Company  
Environmental Laboratory  
5131 Maner Road  
Smyrna, GA 30080  
(404) 799-2100  
(404) 799-2141 (FAX)

Certificate of Analysis

Rhonda Tinsley  
Southern Company Services  
SCG Earth Sciences & Env Engr  
42 Inverness Center parkway  
Birmingham, AL 35242

Sample Information

Sample ID:	28330010	Matrix:	Water	Analysis Request:	23337
Location:	Branch	Sample Date/Time:		Workorder ID:	28330
Description:	Branch Soil	Received Date/Time:	01/18/08 09:00	Purchase Order:	
Field ID:	BH #11 0-7'	Collector:	Rhonda Tinsley		

INORGANICS

Analyte	Date	Prep	Prep	Analytical	Result	Reporting	Units	Analyst	Date
	Prepared	Method	By	Method		Limit			Analyzed
Selenium	02/01/08	EPA 3010	ECS	EPA 6010B	0.012	0.0080	mg/L	CKP	02/05/08

February 06, 2008

ND - Not detectable at specified reporting limit.

This document may be reproduced only in its entirety. Our analysis is based upon the sample received and does not guarantee the uniformity of the lot.



Georgia Power Company  
Environmental Laboratory  
5131 Maner Road  
Smyrna, GA 30080  
(404) 799-2100  
(404) 799-2141 (FAX)

Certificate of Analysis

Rhonda Tinsley  
Southern Company Services  
SCG Earth Sciences & Env Engr  
42 Inverness Center parkway  
Birmingham, AL 35242

Sample Information

Sample ID:	28330011	Matrix:	Water	Analysis Request:	23337
Location:	Branch	Sample Date/Time:		Workorder ID:	28330
Description:	Branch Soil	Received Date/Time:	01/18/08 09:00	Purchase Order:	
Field ID:	BH #11 0-7'	Collector:	Rhonda Tinsley		

INORGANICS

Analyte	Date	Prep	Prep	Analytical	Result	Reporting	Units	Analyst	Date
	Prepared	Method	By	Method		Limit			Analyzed
Selenium	02/01/08	EPA 3010	ECS	EPA 6010B	0.014	0.0080	mg/L	CKP	02/05/08

February 06, 2008

ND - Not detectable at specified reporting limit.

This document may be reproduced only in its entirety. Our analysis is based upon the sample received and does not guarantee the uniformity of the lot.

Georgia Power Company  
Environmental Laboratory  
5131 Maner Road  
Smyrna, GA 30080  
(404) 799-2100  
(404) 799-2141 (FAX)

Certificate of Analysis

Rhonda Tinsley  
Southern Company Services  
SCG Earth Sciences & Env Engr  
42 Inverness Center parkway  
Birmingham, AL 35242

Sample Information

Sample ID:	28330012	Matrix:	Water	Analysis Request:	23337
Location:	Branch	Sample Date/Time:		Workorder ID:	28330
Description:	Branch Soil	Received Date/Time:	01/18/08 09:00	Purchase Order:	
Field ID:	BH #11 0-7'	Collector:	Rhonda Tinsley		

INORGANICS

Analyte	Date Prepared	Prep Method	Prep By	Analytical Method	Result	Reporting Limit	Units	Analyst	Date Analyzed
Selenium	02/01/08	EPA 3010	ECS	EPA 6010B	0.0086	0.0080	mg/L	CKP	02/05/08

February 06, 2008

ND - Not detectable at specified reporting limit.

This document may be reproduced only in its entirety. Our analysis is based upon the sample received and does not guarantee the uniformity of the lot.

Georgia Power Company  
Environmental Laboratory  
5131 Maner Road  
Smyrna, GA 30080  
(404) 799-2100  
(404) 799-2141 (FAX)

Certificate of Analysis

Rhonda Tinsley  
Southern Company Services  
SCG Earth Sciences & Env Engr  
42 Inverness Center parkway  
Birmingham, AL 35242

Sample Information

Sample ID:	28330013	Matrix:	Water	Analysis Request:	23337
Location:	Branch	Sample Date/Time:		Workorder ID:	28330
Description:	Branch Soil	Received Date/Time:	01/18/08 09:00	Purchase Order:	
Field ID:	BH #12 0-8'	Collector:	Rhonda Tinsley		

INORGANICS

Analyte	Date Prepared	Prep Method	Prep By	Analytical Method	Result	Reporting Limit	Units	Analyst	Date Analyzed
Selenium	02/01/08	EPA 3010	ECS	EPA 6010B	0.015	0.0080	mg/L	CKP	02/05/08

February 06, 2008

ND - Not detectable at specified reporting limit.

This document may be reproduced only in its entirety. Our analysis is based upon the sample received and does not guarantee the uniformity of the lot.

Georgia Power Company  
Environmental Laboratory  
5131 Maner Road  
Smyrna, GA 30080  
(404) 799-2100  
(404) 799-2141 (FAX)

Certificate of Analysis

Rhonda Tinsley  
Southern Company Services  
SCG Earth Sciences & Env Engr  
42 Inverness Center parkway  
Birmingham, AL 35242

Sample Information

Sample ID:	28330014	Matrix:	Water	Analysis Request:	23337
Location:	Branch	Sample Date/Time:		Workorder ID:	28330
Description:	Branch Soil	Received Date/Time:	01/18/08 09:00	Purchase Order:	
Field ID:	BH #12 0-8'	Collector:	Rhonda Tinsley		

INORGANICS

Analyte	Date Prepared	Prep Method	Prep By	Analytical Method	Result	Reporting Limit	Units	Analyst	Date Analyzed
Selenium	02/01/08	EPA 3010	ECS	EPA 6010B	ND	0.0080	mg/L	CKP	02/05/08

February 06, 2008

ND - Not detectable at specified reporting limit.

This document may be reproduced only in its entirety. Our analysis is based upon the sample received and does not guarantee the uniformity of the lot.

Georgia Power Company  
Environmental Laboratory  
5131 Maner Road  
Smyrna, GA 30080  
(404) 799-2100  
(404) 799-2141 (FAX)

Certificate of Analysis

Rhonda Tinsley  
Southern Company Services  
SCG Earth Sciences & Env Engr  
42 Inverness Center parkway  
Birmingham, AL 35242

Sample Information

Sample ID:	28330015	Matrix:	Water	Analysis Request:	23337
Location:	Branch	Sample Date/Time:		Workorder ID:	28330
Description:	Branch Soil	Received Date/Time:	01/18/08 09:00	Purchase Order:	
Field ID:	BH #12 0-8'	Collector:	Rhonda Tinsley		

INORGANICS

Analyte	Date Prepared	Prep Method	Prep By	Analytical Method	Result	Reporting Limit	Units	Analyst	Date Analyzed
Selenium	02/01/08	EPA 3010	ECS	EPA 6010B	ND	0.0080	mg/L	CKP	02/05/08

February 06, 2008

ND - Not detectable at specified reporting limit.

This document may be reproduced only in its entirety. Our analysis is based upon the sample received and does not guarantee the uniformity of the lot.



Georgia Power Company  
Environmental Laboratory  
5131 Maner Road  
Smyrna, GA 30080  
(404) 799-2100  
(404) 799-2141 (FAX)

Certificate of Analysis

Rhonda Tinsley  
Southern Company Services  
SCG Earth Sciences & Env Engr  
42 Inverness Center parkway  
Birmingham, AL 35242

Sample Information

Sample ID:	28330016	Matrix:	Water	Analysis Request:	23337
Location:	Branch	Sample Date/Time:		Workorder ID:	28330
Description:	Branch Soil	Received Date/Time:	01/18/08 09:00	Purchase Order:	
Field ID:	BH #13 0-10'	Collector:	Rhonda Tinsley		

INORGANICS

Analyte	Date Prepared	Prep Method	Prep By	Analytical Method	Result	Reporting Limit	Units	Analyst	Date Analyzed
Selenium	02/04/08	EPA 3010	CKP	EPA 6010B	0.066	0.0080	mg/L	CKP	02/05/08

February 06, 2008

ND - Not detectable at specified reporting limit.

This document may be reproduced only in its entirety. Our analysis is based upon the sample received and does not guarantee the uniformity of the lot.

Georgia Power Company  
Environmental Laboratory  
5131 Maner Road  
Smyrna, GA 30080  
(404) 799-2100  
(404) 799-2141 (FAX)

Certificate of Analysis

Rhonda Tinsley  
Southern Company Services  
SCG Earth Sciences & Env Engr  
42 Inverness Center parkway  
Birmingham, AL 35242

Sample Information

Sample ID:	28330017	Matrix:	Water	Analysis Request:	23337
Location:	Branch	Sample Date/Time:		Workorder ID:	28330
Description:	Branch Soil	Received Date/Time:	01/18/08 09:00	Purchase Order:	
Field ID:	BH #13 0-10'	Collector:	Rhonda Tinsley		

INORGANICS

Analyte	Date Prepared	Prep Method	Prep By	Analytical Method	Result	Reporting Limit	Units	Analyst	Date Analyzed
Selenium	02/01/08	EPA 3010	ECS	EPA 6010B	0.090	0.0080	mg/L	CKP	02/05/08

February 06, 2008

ND - Not detectable at specified reporting limit.

This document may be reproduced only in its entirety. Our analysis is based upon the sample received and does not guarantee the uniformity of the lot.

Georgia Power Company  
Environmental Laboratory  
5131 Maner Road  
Smyrna, GA 30080  
(404) 799-2100  
(404) 799-2141 (FAX)

Certificate of Analysis

Rhonda Tinsley  
Southern Company Services  
SCG Earth Sciences & Env Engr  
42 Inverness Center parkway  
Birmingham, AL 35242

Sample Information

Sample ID:	28330018	Matrix:	Water	Analysis Request:	23337
Location:	Branch	Sample Date/Time:		Workorder ID:	28330
Description:	Branch Soil	Received Date/Time:	01/18/08 09:00	Purchase Order:	
Field ID:	BH #13 0-10'	Collector:	Rhonda Tinsley		

INORGANICS

Analyte	Date	Prep	Prep	Analytical	Result	Reporting	Units	Analyst	Date
	Prepared	Method	By	Method		Limit			Analyzed
Selenium	02/01/08	EPA 3010	ECS	EPA 6010B	0.11	0.0080	mg/L	CKP	02/05/08

February 06, 2008

ND - Not detectable at specified reporting limit.

This document may be reproduced only in its entirety. Our analysis is based upon the sample received and does not guarantee the uniformity of the lot.

Georgia Power Company  
Environmental Laboratory  
5131 Maner Road  
Smyrna, GA 30080  
(404) 799-2100  
(404) 799-2141 (FAX)

Certificate of Analysis

Rhonda Tinsley  
Southern Company Services  
SCG Earth Sciences & Env Engr  
42 Inverness Center parkway  
Birmingham, AL 35242

Method Blank Report

Client ID: Southern Company Services  
Workorder ID: Kd Sorption - Branch  
Laboratory ID: 52946  
Sample ID: MB for HBN 261953 [DIGM/2255]  
Matrix: Water

---

Parameter	Date Prepared	Analytical Method	Date Analyzed	Result	Reporting Limit	Units
INORGANICS						
Selenium	02/01/08	EPA 6010B	02/05/08	ND	0.0080	mg/L

February 06, 2008

ND - Not detectable at specified reporting limit.

This document may be reproduced only in its entirety. Our analysis is based upon the sample received and does not guarantee the uniformity of the lot.

Georgia Power Company  
Environmental Laboratory  
5131 Maner Road  
Smyrna, GA 30080  
(404) 799-2100  
(404) 799-2141 (FAX)

Certificate of Analysis

Terri Hartsfield  
Southern Company Services  
SCG Earth Sciences & Env Engr  
42 Inverness Center Parkway  
Birmingham, AL 35242

Method Blank Report

Client ID: Southern Company Services  
Workorder ID: Kd Sorption - Branch  
Laboratory ID: 53000  
Sample ID: MB for HBN 262013 [DIGM/2257]  
Matrix: Water

---

Parameter	Date Prepared	Analytical Method	Date Analyzed	Result	Reporting Limit	Units
INORGANICS						
Selenium	02/04/08	EPA 6010B	02/05/08	ND	0.0080	mg/L

February 06, 2008

ND - Not detectable at specified reporting limit.

This document may be reproduced only in its entirety. Our analysis is based upon the sample received and does not guarantee the uniformity of the lot.



## ENV-474

## ASTM D 4646 Standard Test Method for 24-h Batch-Type Measurement of Contaminant Sorption by Soils and Sediments

2/11/2008 11:01

Workorder 28330 (Branch)

Sample	Initial Concentration (mg/L)	Final Concentration (mg/L)	Initial Concentration (mg/L)	Final Concentration (mg/L)	Distribution Ratio
28330001-003	3387.9	2934.0	2913.9	2913.8	1.01
28330004-006	4025.0	3510.1	3457.2	3456.0	0.46
28330007-009	3115.1	2707.8	2697.2	2698.2	0.48

Date		Location		Time		Sample	
Sample	Location	Time	Sample	Time	Sample	Time	Sample
28330001	A	70.4	9	5.0	5.0	1/31/08 11:40	2/1/08 11:10
28330002	B	70.4	23	5.0	5.0	1/31/08 11:40	2/1/08 11:10
28330003	C	70.4	24	5.0	5.0	1/31/08 11:40	2/1/08 11:10
28330004	A	70.4	100	5.0	5.0	1/31/08 11:40	2/1/08 11:10
28330005	B	70.4	101	5.0	5.0	1/31/08 11:40	2/1/08 11:10
28330006	C	70.4	102	5.0	5.0	1/31/08 11:40	2/1/08 11:10
28330007	A	70.4	103	5.0	5.0	1/31/08 11:40	2/1/08 11:10
28330008	B	70.4	104	5.0	5.0	1/31/08 11:40	2/1/08 11:10
28330009	C	70.4	105	5.0	5.0	1/31/08 11:40	2/1/08 11:10
Control	A	0	1A	7.0	7.0	1/31/08 11:40	2/1/08 11:10
Control	B	0	1A	7.0	7.0	1/31/08 11:40	2/1/08 11:10
Control	C	0	1A	7.0	7.0	1/31/08 11:40	2/1/08 11:10

Distribution Ratio		Selenium (mg/L) Initial	Selenium (mg/L) Final	ES of Oxidized Phase (%)	Distribution Ratio (mg/L)	Average (mg/L)	Std Dev (mg/L)
28330001	A	0.986	0.013	69.7	1504		
28330002	B	0.986	0.021	69.7	923	1056	398
28330003	C	0.986	0.026	69.7	742		
28330004	A	0.986	0.008	70.1	2443		
28330005	B	0.986	0.009	70.1	2298	2395	84
28330006	C	0.986	0.008	70.1	2443		
28330007	A	0.986	0.008	70.1	2443		
28330008	B	0.986	0.008	70.1	2443	2443	0
28330009	C	0.986	0.008	70.1	2443		
Control	A	0.986	0.942				
Control	B	0.986	0.942				
Control	C	0.986	0.942				

Average Blank +/- Std Dev 0.942 0.012

Selenium concentrations by ICP with MDL of 0.008 ug/mL. Results below MDL are entered as the MDL value.

Volume (mL) 1400

Horizon Batch#	Date	Analyst	Reviewed Date
261953/262013	2/5/08	CKP/ECS	RSD 02/06/08

## ENV-474

## ASTM D 4646 Standard Test Method for 24-h Batch-Type Measurement of Contaminant Sorption by Soils and Sediments

2/11/2008 11:01

Workorder

28330 (Branch)

Sample ID	Initial Weight (g)	Final Weight (g)	Initial Volume (mL)	Final Volume (mL)	Concentration (mg/L)
28330010-012	3708.7	3343.1	3269.4	3263.1	0.65
28330013-015	3770.2	3296.3	3188.8	3177.0	0.34
28330016-018	1735.7	1455.1	1455.9	1455.9	0.47

Sample ID	Weight (grams)	Extraction Volume (mL)	Initial pH	Final pH	Time Start	Time End
28330010 A	70.4	106	5.0	5.0	1/31/08 11:40	2/1/08 11:10
28330011 B	70.4	107	5.0	5.0	1/31/08 11:40	2/1/08 11:10
28330012 C	70.4	108	5.0	5.0	1/31/08 11:40	2/1/08 11:10
28330013 A	70.4	109	5.0	5.0	1/31/08 11:40	2/1/08 11:10
28330014 B	70.4	110	5.0	5.0	1/31/08 11:40	2/1/08 11:10
28330015 C	70.4	111	5.0	5.0	1/31/08 11:40	2/1/08 11:10
28330016 A	70.4	115	5.0	5.0	2/1/08 11:15	2/2/08 11:35
28330017 B	70.4	113	5.0	5.0	1/31/08 11:40	2/1/08 11:10
28330018 C	70.4	114	5.0	5.0	1/31/08 11:40	2/1/08 11:10
Control A	0	1A	7.0	7.0	1/31/08 11:40	2/1/08 11:10
Control B	0	1A	7.0	7.0	1/31/08 11:40	2/1/08 11:10
Control C	0	1A	7.0	7.0	1/31/08 11:40	2/1/08 11:10

Distribution Ratio	Selenium (ug/mL)	Selenium (ug/mL)	pH	Distribution Ratio	Average	Std Dev
Initial	Final	Given	Final	(mL/g)	(mL/g)	(mL/g)
28330010 A	0.986	0.012	69.9	1625		
28330011 B	0.986	0.014	69.9	1390	1763	459
28330012 C	0.986	0.009	69.9	2275		
28330013 A	0.986	0.015	70.2	1292		
28330014 B	0.986	0.008	70.2	2440	2057	663
28330015 C	0.986	0.008	70.2	2440		
28330016 A	0.986	0.066	70.1	279		
28330017 B	0.986	0.090	70.1	199	212	61
28330018 C	0.986	0.110	70.1	159		
Control A	0.986	0.942				
Control B	0.986	0.942				
Control C	0.986	0.942				

Average Blank +/- Std Dev	0.942	0.012
---------------------------	-------	-------

Selenium concentrations by ICP with MDL of 0.008 ug/mL. Results below MDL are entered as the MDL value.

Volume (mL) 1400

Horizon Batch #	Date	Analyst	Reviewed/Date
261953/262013	2/5/08	CKP/ECS	RSD 02/06/08

## ANALYTICAL REPORT


Job Number: 680-33710-1

Job Description: Branch

For:

Georgia Power - Environmental Lab  
5131 Maner Road, Bin 39110  
Smyrna, GA 30080

Attention: Mr. Robert S Dickerson



---

Abbie Page

Project Manager I

[abbie.page@testamericainc.com](mailto:abbie.page@testamericainc.com)

02/07/2008

The test results in this report meet all NELAP requirements for parameters for which accreditation is required or available. Any exceptions to NELAP requirements are noted in this report. Pursuant to NELAP, this report may not be reproduced, except in full, without the written approval of the laboratory. All questions regarding this report should be directed to the TestAmerica Project Manager who signed this report.

**Job Narrative**  
**680-J33710-1**

**Comments**

No additional comments.

**Receipt**

The Chain-of-Custody (COC) was not properly filled out. No sampling dates and times were provided. Client confirmed via telephone that all samples were collected on 1/23/08.

All other samples were received in good condition within temperature requirements.

**Metals**

No analytical or quality issues were noted.

## METHOD / ANALYST SUMMARY

Client: Georgia Power - Environmental Lab

Job Number: 680-33710-1

Method	Analyst	Analyst ID
SW846 9081	Smith, Tim J	TJS



## SAMPLE SUMMARY

Client: Georgia Power - Environmental Lab

Job Number: 680-33710-1

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received	
680-33710-1	28330001	Solid	01/23/2008 0000	01/24/2008 0903	4 0-6"
680-33710-2	28330004	Solid	01/23/2008 0000	01/24/2008 0903	5 0-10'
680-33710-3	28330007	Solid	01/23/2008 0000	01/24/2008 0903	7 0-6'
680-33710-4	28330010	Solid	01/23/2008 0000	01/24/2008 0903	11 0-7'
680-33710-5	28330013	Solid	01/23/2008 0000	01/24/2008 0903	12 0-8'
680-33710-6	28330016	Solid	01/23/2008 0000	01/24/2008 0903	13 0-10'

**Analytical Data**

Client: Georgia Power - Environmental Lab

Job Number: 680-33710-1

**General Chemistry****Client Sample ID: 28330001**

Lab Sample ID: 680-33710-1

Client Matrix: Solid

% Moisture: 14.3

Date Sampled: 01/23/2008 0000

Date Received: 01/24/2008 0903

Analyte	Result	Qual	Units	MDL	RL	Dil	Method
Cation Exchange Capacity	18	B	meq/100gm	0.025	0.025	1.0	9081
	Anly Batch: 360-28582	Date Analyzed	02/06/2008	1414			DryWt Corrected: Y
	Prep Batch: 360-28511	Date Prepared:	02/05/2008	0921			

**Client Sample ID: 28330004**

Lab Sample ID: 680-33710-2

Client Matrix: Solid

% Moisture: 14.1

Date Sampled: 01/23/2008 0000

Date Received: 01/24/2008 0903

Analyte	Result	Qual	Units	MDL	RL	Dil	Method
Cation Exchange Capacity	17	B	meq/100gm	0.025	0.025	1.0	9081
	Anly Batch: 360-28582	Date Analyzed	02/06/2008	1420			DryWt Corrected: Y
	Prep Batch: 360-28511	Date Prepared:	02/05/2008	0921			

**Client Sample ID: 28330007**

Lab Sample ID: 680-33710-3

Client Matrix: Solid

% Moisture: 13.8

Date Sampled: 01/23/2008 0000

Date Received: 01/24/2008 0903

Analyte	Result	Qual	Units	MDL	RL	Dil	Method
Cation Exchange Capacity	18	B	meq/100gm	0.025	0.025	1.0	9081
	Anly Batch: 360-28582	Date Analyzed	02/06/2008	1422			DryWt Corrected: Y
	Prep Batch: 360-28511	Date Prepared:	02/05/2008	0921			

**Client Sample ID: 28330010**

Lab Sample ID: 680-33710-4

Client Matrix: Solid

% Moisture: 22.1

Date Sampled: 01/23/2008 0000

Date Received: 01/24/2008 0903

Analyte	Result	Qual	Units	MDL	RL	Dil	Method
Cation Exchange Capacity	22	B	meq/100gm	0.028	0.028	1.0	9081
	Anly Batch: 360-28582	Date Analyzed	02/06/2008	1425			DryWt Corrected: Y
	Prep Batch: 360-28511	Date Prepared:	02/05/2008	0921			

**Client Sample ID: 28330013**

Lab Sample ID: 680-33710-5

Client Matrix: Solid

% Moisture: 20.5

Date Sampled: 01/23/2008 0000

Date Received: 01/24/2008 0903

Analyte	Result	Qual	Units	MDL	RL	Dil	Method
Cation Exchange Capacity	14	B	meq/100gm	0.027	0.027	1.0	9081
	Anly Batch: 360-28582	Date Analyzed	02/06/2008	1428			DryWt Corrected: Y
	Prep Batch: 360-28511	Date Prepared:	02/05/2008	0921			

**Analytical Data**

Client: Georgia Power - Environmental Lab

Job Number: 680-33710-1

---

**General Chemistry**

Client Sample ID: 28330016

Lab Sample ID: 680-33710-6

Date Sampled: 01/23/2008 0000

Client Matrix: Solid

% Moisture: 17.6

Date Received: 01/24/2008 0903

Analyte	Result	Qual	Units	MDL	RL	Dil	Method
Cation Exchange Capacity	19	B	meq/100gm	0.026	0.026	1.0	9081
	Anly Batch: 360-28582	Date Analyzed	02/06/2008	1430			DryWt Corrected: Y
	Prep Batch: 360-28511	Date Prepared:	02/05/2008	0921			

## DATA REPORTING QUALIFIERS

Client: Georgia Power - Environmental Lab

Job Number: 680-33710-1

Lab Section	Qualifier	Description
General Chemistry		
	B	Compound was found in the blank and sample.
	F	Duplicate RPD exceeds the control limit

## Quality Control Results

Client: Georgia Power - Environmental Lab

Job Number: 680-33710-1

### Method Blank - Batch: 360-28511

Lab Sample ID: MB 360-28511/1-A  
Client Matrix: Solid  
Dilution: 1.0  
Date Analyzed: 02/06/2008 1348  
Date Prepared: 02/05/2008 0921

Analysis Batch: 360-28582  
Prep Batch: 360-28511  
Units: meq/100gm

### Method: 9081 Preparation: 9081

Instrument ID: Varian 720 ES ICP  
Lab File ID: N/A  
Initial Weight/Volume: 100 mL  
Final Weight/Volume: 100 mL

Analyte	Result	Qual	MDL	RL
Cation Exchange Capacity	1.0		0.022	0.022

### Duplicate - Batch: 360-28511

Lab Sample ID: 680-33710-1  
Client Matrix: Solid  
Dilution: 1.0  
Date Analyzed: 02/06/2008 1417  
Date Prepared: 02/05/2008 0921

Analysis Batch: 360-28582  
Prep Batch: 360-28511  
Units: meq/100gm

### Method: 9081 Preparation: 9081

Instrument ID: Varian 720 ES ICP  
Lab File ID: N/A  
Initial Weight/Volume: 4.49 g  
Final Weight/Volume: 100 mL

Analyte	Sample Result/Qual	Result	RPD	Limit	Qual
Cation Exchange Capacity	18	23.0	24	20	F

Calculations are performed before rounding to avoid round-off errors in calculated results.



5131 Marier Road, Bin 39110  
Smyrna, Georgia 30080



**GEORGIA POWER**  
A SOUTHERN COMPANY

Phone: (404) 799-2100 Fax: (404) 799-2141  
Company: 8-530-2100 Fax: 8-530-2141

Sample Delivery Group No. 29330

[illegible]

**\* Note: Attach copy of original Analysis Request**

TRANSFERRED BY (Signature)		RECEIVED BY (Signature)		TELEPHONE	
				1415	
DATE		TIME		DATE	
1/23/08				1/23/08	
707454 MA		WHITE—Laboratory		CANA	
		707454 MA		PINK—Laboratory	

## Login Sample Receipt Check List

Client: Georgia Power - Environmental Lab

Job Number: 680-33710-1

Login Number: 33710

List Source: TestAmerica Savannah

Creator: Hall, Karl I

List Number: 1

Question	T / F / NA	Comment
Radioactivity either was not measured or, if measured, is at or below background	True	
The cooler's custody seal, if present, is intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	False	sample date of 1/23/08 provided by R. Dickerson
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	N/A	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	

## Login Sample Receipt Check List

Client: Georgia Power - Environmental Lab

Job Number: 680-33710-1

Login Number: 33710

Creator: Tremblay, Kara R

List Number: 1

List Source: TestAmerica Westfield

List Creation: 01/25/08 10:13 AM

Question	T / F / NA	Comment
Radioactivity either was not measured or, if measured, is at or below background	N/A	
The cooler's custody seal, if present, is intact.	N/A	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	0.8 C
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	N/A	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	

---

**MOISTURE DENSITY TEST DATA**

---

Client: SCS - Rhonda Tinsley & Gary McWhorter  
Project: Plant Branch Gypsum Storage  
Project Number: EWO -

---

**Specimen Data**

---

Source:

Sample No.: BH4

Elev. or Depth: 0.0 - 6.0

Sample Length(in./cm.):

Location:

Description: (lab#17)

Liquid Limit:

Plasticity Index:

Natural Moisture:

Date: 01/08/08

USCS Classification:

AASHTO Classification:

Testing Remarks:

Percent retained on 3/4 in. sieve:

Percent passing No. 200 sieve:      Specific gravity:

---


**Test Data And Results For Curve 17**

---

Type of test: ASTM D 698-91 Procedure C Standard

Mold Dia.: 6.00 in.    Hammer Wt.: 5.5 lb.    Drop: 12 in.

Layers: three    Blows per Layer: 56



Max dry den= 102.4 pcf    Opt moisture= 22.1 %

Oversize Correction Not Applied

---

**MOISTURE DENSITY TEST DATA**

---

Client: SCS - Rhonda Tinsley & Gary McWhorter  
Project: Plant Branch Gypsum Storage  
Project Number: EWO -

---

**Specimen Data**

---

Source:

Sample No.: BH5

Elev. or Depth: 0.0 - 10.0

Sample Length(in./cm.):

Location:

Description: (lab#18)

Liquid Limit:

Plasticity Index:

Natural Moisture:

Date: 01/18/08

USCS Classification:

AASHTO Classification:

Testing Remarks:

Percent retained on 3/4 in. sieve:

Percent passing No. 200 sieve:      Specific gravity:

---


**Test Data And Results For Curve 18**

---

Type of test: ASTM D 698-91 Procedure C Standard

Mold Dia.: 6.00 in.    Hammer Wt.: 5.5 lb.    Drop: 12 in.

Layers: three    Blows per Layer: 56



POINT NO.	1	2	3	4
WM + WS	3628.0	3706.5	3809.0	3797.5
WM	1985.5	1985.5	1985.5	1985.5
WW+T	300.00	300.00	300.00	300.00
WD+T	257.50	251.90	245.40	239.40
TARE	0.00	0.00	0.00	0.00
MOIST	16.5	19.1	22.2	25.3

MOISTURE	16.5	19.1	22.2	25.3
DRY DEN	93.3	95.6	98.7	95.6

Max dry den= 98.7 pcf    Opt moisture= 22.2 %

Oversize Correction Not Applied

---

**MOISTURE DENSITY TEST DATA**

---

Client: SCS - Rhonda Tinsley & Gary McWhorter  
Project: Plant Branch Gypsum Storage  
Project Number: EWO -

---

---

**Specimen Data**

---

Source:

Sample No.: BH7

Elev. or Depth: 0.0 - 6.0

Sample Length(in./cm.):

Location:

Description: (lab19)

Liquid Limit:

Plasticity Index:

Natural Moisture:

Date: 01/18/08

USCS Classification:

AASHTO Classification:

Testing Remarks:

Percent retained on 3/4 in. sieve:

Percent passing No. 200 sieve:      Specific gravity:

---

---


**Test Data And Results For Curve 19**

---

Type of test: ASTM D 698-91 Procedure C Standard

Mold Dia.: 6.00 in.    Hammer Wt.: 5.5 lb.    Drop: 12 in.

Layers: three    Blows per Layer: 56



POINT NO.	1	2	3	4
WM + WS	3750.5	3798.0	3814.5	3792.5
WM	1985.5	1985.5	1985.5	1985.5
WW+T	300.00	300.00	300.00	300.00
WD+T	252.30	249.60	245.40	239.70
TARE	0.00	0.00	0.00	0.00
MOIST	18.9	20.2	22.2	25.2

MOISTURE	18.9	20.2	22.2	25.2
DRY DEN	98.2	99.7	99.0	95.5

Max dry den= 99.9 pcf    Opt moisture= 20.7 %

Oversize Correction Not Applied



# MOISTURE DENSITY TEST DATA

Client: SCS - Rhonda Tinsley & Gary McWhorter  
Project: Plant Branch Gypsum Storage  
Project Number: EWO -

## Specimen Data

Source:

Sample No.: BH11

Elev. or Depth: 0.0 - 7.0

Sample Length(in./cm.):

Location:

Description: (lab20)

Liquid Limit:

Plasticity Index:

Natural Moisture:

Date: 01/18/08

USCS Classification:

AASHTO Classification:

Testing Remarks:

Percent retained on 3/4 in. sieve:


Percent passing No. 200 sieve: Specific gravity:

## Test Data And Results For Curve 20

Type of test: ASTM D 698-91 Procedure C Standard

Mold Dia.: 6.00 in. Hammer Wt.: 5.5 lb. Drop: 12 in.

Layers: three Blows per Layer: 56



POINT NO.	1	2	3	4
WM + WS	3703.5	3763.0	3814.0	3798.5
WM	1985.5	1985.5	1985.5	1985.5
WW+T	300.00	300.00	300.00	300.00
WD+T	255.30	251.30	244.00	238.20
TARE	0.00	0.00	0.00	0.00
MOIST	17.5	19.4	23.0	25.9

MOISTURE	17.5	19.4	23.0	25.9
DRY DEN	96.7	98.5	98.4	95.2

Max dry den= 99.1 pcf Opt moisture= 21.1 %

Oversize Correction Not Applied

# MOISTURE DENSITY TEST DATA

Client: SCS - Rhonda Tinsley & Gary McWhorter  
Project: Plant Branch Gypsum Storage  
Project Number: EWO -

## Specimen Data

Source:

Sample No.: BH12

Elev. or Depth: 0.0 - 8.0

Sample Length(in./cm.):

Location:

Description: (lab21)

Liquid Limit:

Plasticity Index:

Natural Moisture:

Date: 01/18/08

USCS Classification:

AASHTO Classification:

Testing Remarks:

Percent retained on 3/4 in. sieve:


Percent passing No. 200 sieve: Specific gravity:

## Test Data And Results For Curve 21

Type of test: ASTM D 698-91 Procedure C Standard

Mold Dia.: 6.00 in. Hammer Wt.: 5.5 lb. Drop: 12 in.

Layers: three Blows per Layer: 56



POINT NO.	1	2	3	4
WM + WS	3613.5	3706.0	3771.5	3804.5
WM	1985.5	1985.5	1985.5	1985.5
WW+T	300.00	300.00	300.00	300.00
WD+T	264.80	259.80	255.20	247.40
TARE	0.00	0.00	0.00	0.00
MOIST	13.3	15.5	17.6	21.3

MOISTURE	13.3	15.5	17.6	21.3
DRY DEN	95.0	98.6	100.5	99.2

Max dry den= 100.6 pcf Opt moisture= 18.1 %

Oversize Correction Not Applied

# MOISTURE DENSITY TEST DATA

Client: SCS - Rhonda Tinsley & Gary McWhorter  
Project: Plant Branch Gypsum Storage  
Project Number: EWO -

## Specimen Data

Source:

Sample No.: BH13

Elev. or Depth: 0.0 - 10.0

Sample Length(in./cm.):

Location:

Description: (lab22)

Liquid Limit:

Plasticity Index:

Natural Moisture:

Date: 01/18/08

USCS Classification:

AASHTO Classification:

Testing Remarks:

Percent retained on 3/4 in. sieve:


Percent passing No. 200 sieve: Specific gravity:

## Test Data And Results For Curve 22

Type of test: ASTM D 698-91 Procedure C Standard

Mold Dia.: 6.00 in. Hammer Wt.: 5.5 lb. Drop: 12 in.

Layers: three Blows per Layer: 56




POINT NO.	1	2	3	4
WM + WS	3640.5	3775.0	3834.5	3822.5
WM	1985.5	1985.5	1985.5	1985.5
WW+T	300.00	300.00	300.00	300.00
WD+T	263.00	256.60	250.90	244.40
TARE	0.00	0.00	0.00	0.00
MOIST	14.1	16.9	19.6	22.7

MOISTURE	14.1	16.9	19.6	22.7
DRY DEN	96.0	101.2	102.3	99.0

Max dry den= 102.5 pcf Opt moisture= 18.8 %

Oversize Correction Not Applied

# Particle Size Distribution Report



% COBBLES	% GRAVEL	% SAND	% SILT	% CLAY
0.0	0.0	45.0	16.2	38.8

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
#4	100.0		
#8	99.9		
#10	99.9		
#16	97.4		
#30	86.7		
#40	79.5		
#50	74.3		
#100	63.1		
#200	55.0		

\* (no specification provided)

## Soil Description

Dark Reddish Brown Sandy lean clay

## Atterberg Limits

PL= 24

LL= 47

PI= 23

## Coefficients

D<sub>85</sub>= 0.555

D<sub>60</sub>= 0.123

D<sub>50</sub>= 0.0320

D<sub>30</sub>= 0.0015

D<sub>15</sub>=

D<sub>10</sub>=

C<sub>u</sub>=

C<sub>c</sub>=

## Classification

USCS= CL

AASHTO=

## Remarks

Specific Gravity - 2.67

Moisture Content - 15.2%

Sample No.: 1

Location: Boring #13

Source of Sample:

Date: 01/18/08

Elev./Depth: 4.5 - 6.0

**SOUTHERN COMPANY**


Client: SCS - Rhonda Tinsley

Project: Plant Branch SAR

Project No: EWO -

Lab# 1

# LIQUID AND PLASTIC LIMITS TEST REPORT



SOIL DATA								
SYMBOL	SOURCE	SAMPLE NO.	DEPTH (ft.)	NATURAL WATER CONTENT (%)	PLASTIC LIMIT (%)	LIQUID LIMIT (%)	PLASTICITY INDEX (%)	USCS
•		1	4.5 - 6.0	15.2%	24	47	23	CL

LIQUID AND PLASTIC LIMITS TEST REPORT

**SOUTHERN COMPANY**


Client: SCS - Rhonda Tinsley

Project: Plant Branch SAR

Project No.: EWO -


Lab# 1

# Particle Size Distribution Report





# Particle Size Distribution Report



% COBBLES	% GRAVEL	% SAND	% SILT	% CLAY
0.0	0.0	79.8	13.5	6.7

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
#4	100.0		
#8	99.6		
#10	99.5		
#16	95.6		
#30	78.7		
#40	66.4		
#50	53.1		
#100	32.6		
#200	20.2		

\* (no specification provided)

## Soil Description

Light Gray Silty sand

## Atterberg Limits

PL= NP

LL= NP

PI= NP

## Coefficients

D<sub>85</sub>= 0.735

D<sub>60</sub>= 0.360

D<sub>50</sub>= 0.275

D<sub>30</sub>= 0.135

D<sub>15</sub>= 0.0337

D<sub>10</sub>= 0.0132

C<sub>u</sub>= 27.25

C<sub>c</sub>= 3.83

## Classification

USCS= SM

AASHTO=

## Remarks

Specific Gravity - 2.65

Moisture Content - 2.5

Sample No.: 2  
Location: Boring #16

Source of Sample:

Date: 01/18/08  
Elev./Depth: 8.5 - 10.0

**SOUTHERN COMPANY**

Client: SCS - Rhonda Tinsley  
Project: Plant Branch SAR

Project No: EWO -

Lab# 3

Grain size distribution curve for a soil sample. The graph plots Percent Finer (Y-axis, 0 to 100) against Grain Size in mm (X-axis, logarithmic scale from 500 to 0.001). The curve shows a well-graded soil with a maximum grain size of approximately 2.0 mm and a minimum grain size of approximately 0.075 mm. Key sieve sizes are marked on the top X-axis: 6 in., 3 in., 2 in., 1 1/2 in., 1 in., 3/4 in., 1/2 in., 3/8 in., #4, #10, #20, #30, #40, #60, #100, #140, and #200.


Grain Size (mm)	Percent Finer (%)
2.0	100
1.0	99
0.85	98
0.75	95
0.60	88
0.50	83
0.425	78
0.355	70
0.300	63
0.250	62
0.200	59
0.150	56
0.106	50
0.075	47
0.060	44
0.0475	40
0.0375	34

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
#8	100.0		
#10	99.8		
#16	98.0		
#30	87.9		
#40	82.7		
#50	78.0		
#100	69.8		
#200	62.9		

### Moisture Content - 10.3

Lab# 4

# LIQUID AND PLASTIC LIMITS TEST REPORT



SOIL DATA								
SYMBOL	SOURCE	SAMPLE NO.	DEPTH (ft.)	NATURAL WATER CONTENT (%)	PLASTIC LIMIT (%)	LIQUID LIMIT (%)	PLASTICITY INDEX (%)	USCS
•		1	4.5 - 6.0	10.3%	36	57	21	MH

LIQUID AND PLASTIC LIMITS TEST REPORT

**SOUTHERN COMPANY**

Client: SCS - Rhonda Tinsley

Project: Plant Branch SAR

Project No.: EWO -

Lab# 4

The graph illustrates the grain size distribution of a soil sample. The y-axis represents the percentage of soil finer than a given grain size, ranging from 0 to 100. The x-axis represents the grain size in millimeters, on a logarithmic scale from 500 mm to 0.001 mm. The curve shows that approximately 95% of the soil is finer than 10 mm, and about 25% is finer than 0.075 mm (No. 200 sieve).


Grain Size (mm)	Percent Finer (%)
500	100
10	95
4.75	92
2.5	86
1.18	81
0.85	67
0.6	59
0.425	53
0.25	36
0.15	24
0.106	22
0.075	19
0.053	15
0.0375	11
0.025	7
0.018	6
0.0125	4
0.0085	1

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
0.75 in.	100.0		
.375 in.	94.8		
#4	90.8		
#8	86.3		
#10	85.3		
#16	80.3		
#30	67.0		
#40	58.7		
#50	52.3		
#100	35.7		
#200	23.8		

Moisture Content - 20.6

Lab# 5

# Particle Size Distribution Report



% COBBLES	% GRAVEL	% SAND	% SILT	% CLAY
0.0	0.0	60.3	26.7	13.0

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
#4	100.0		
#8	99.0		
#10	97.8		
#16	91.6		
#30	77.4		
#40	69.6		
#50	63.1		
#100	49.5		
#200	39.7		

\* (no specification provided)

**Soil Description**  
 Light Grayish Brown Silty sand

**Atterberg Limits**  
 PL= NP      LL= NP      PI= NP

**Coefficients**  
 D<sub>85</sub>= 0.837      D<sub>60</sub>= 0.255      D<sub>50</sub>= 0.154  
 D<sub>30</sub>= 0.0314      D<sub>15</sub>= 0.0090      D<sub>10</sub>= 0.0025  
 C<sub>u</sub>= 100.10      C<sub>c</sub>= 1.51

**Classification**  
 USCS= SM      AASHTO=

**Remarks**  
 Specific Gravity - 2.59  
 Moisture Content - 22.7

Sample No.: 6  
Location: Boring #6

Source of Sample:

Date: 01/18/08  
Elev./Depth: 29.5 - 31.0


**SOUTHERN COMPANY**

Client: SCS - Rhonda Tinsley  
Project: Plant Branch SAR

Project No: EWO -

Lab# 6

# Particle Size Distribution Report





# Particle Size Distribution Report



% COBBLES	% GRAVEL	% SAND	% SILT	% CLAY
0.0	0.6	33.2	26.1	40.1

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
.375 in.	100.0		
#4	99.4		
#8	99.2		
#10	99.0		
#16	96.2		
#30	88.3		
#40	83.8		
#50	79.2		
#100	71.2		
#200	66.2		

\* (no specification provided)

**Soil Description**  
 Light Reddish Brown Sandy elastic silt

**Atterberg Limits**  
 PL= 42      LL= 66      PI= 24

**Coefficients**  
 D<sub>85</sub>= 0.466      D<sub>60</sub>= 0.0233      D<sub>50</sub>= 0.0122  
 D<sub>30</sub>=      D<sub>15</sub>=      D<sub>10</sub>=  
 C<sub>u</sub>=      C<sub>c</sub>=

**Classification**  
 USCS= MH      AASHTO=

**Remarks**  
 Specific Gravity - 2.67  
 Moisture Content - 15.0

Sample No.: 1  
Location: Boring #5

Source of Sample:

Date: 01/18/08  
Elev./Depth: 3.5 - 5.0


**SOUTHERN COMPANY**

Client: SCS - Rhonda Tinsley  
Project: Plant Branch SAR

Project No: EWO -

Lab# 8

# LIQUID AND PLASTIC LIMITS TEST REPORT



SOIL DATA								
SYMBOL	SOURCE	SAMPLE NO.	DEPTH (ft.)	NATURAL WATER CONTENT (%)	PLASTIC LIMIT (%)	LIQUID LIMIT (%)	PLASTICITY INDEX (%)	USCS
•		1	3.5 - 5.0	15.0%	42	66	24	MH

LIQUID AND PLASTIC LIMITS TEST REPORT

**SOUTHERN COMPANY**

Client: SCS - Rhonda Tinsley

Project: Plant Branch SAR

Project No.: EWO -

Lab# 8

# Particle Size Distribution Report



% COBBLES	% GRAVEL	% SAND	% SILT	% CLAY
0.0	0.0	45.4	32.7	21.9

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
#4	100.0		
#8	99.9		
#10	99.6		
#16	95.6		
#30	85.5		
#40	79.7		
#50	73.2		
#100	61.9		
#200	54.6		

\* (no specification provided)

## Soil Description

Light Brown Sandy silt

## Atterberg Limits

PL= NP

LL= NP

PI= NP

## Coefficients

D<sub>85</sub>= 0.582  
D<sub>30</sub>= 0.0105  
C<sub>u</sub>=

D<sub>60</sub>= 0.131  
D<sub>15</sub>=  
C<sub>c</sub>=

D<sub>50</sub>= 0.0322  
D<sub>10</sub>=

## Classification

USCS= ML

AASHTO=

## Remarks

Specific Gravity - 2.64  
Moisture Content - 16.2

Sample No.: 3  
Location: Boring #5

Source of Sample:

Date: 01/18/08  
Elev./Depth: 13.5 - 15.0


**SOUTHERN COMPANY**

Client: SCS - Rhonda Tinsley  
Project: Plant Branch SAR

Project No: EWO -

Lab# 9

# Particle Size Distribution Report



% COBBLES	% GRAVEL	% SAND	% SILT	% CLAY
0.0	0.1	42.4	23.7	33.8

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
.375 in.	100.0		
#4	99.9		
#8	99.5		
#10	99.3		
#16	97.3		
#30	86.6		
#40	80.2		
#50	73.8		
#100	63.7		
#200	57.5		

\* (no specification provided)

**Soil Description**  
Brown Sandy elastic silt

**Atterberg Limits**  
 PL= 34      LL= 56      PI= 22

**Coefficients**  
 D<sub>85</sub>= 0.551      D<sub>60</sub>= 0.108      D<sub>50</sub>= 0.0233  
 D<sub>30</sub>= 0.0030      D<sub>15</sub>=      D<sub>10</sub>=  
 C<sub>u</sub>=      C<sub>c</sub>=

**Classification**  
 USCS= MH      AASHTO=

**Remarks**  
 Specific Gravity - 2.66  
 Moisture Content - 12.7

Sample No.: 2  
Location: Boring #5

Source of Sample:

Date: 01/18/08  
Elev./Depth: 8.5 - 10.0


**SOUTHERN COMPANY**

Client: SCS - Rhonda Tinsley  
Project: Plant Branch SAR

Project No: EWO -

Lab# 10

# LIQUID AND PLASTIC LIMITS TEST REPORT



## SOIL DATA

SYMBOL	SOURCE	SAMPLE NO.	DEPTH (ft.)	NATURAL WATER CONTENT (%)	PLASTIC LIMIT (%)	LIQUID LIMIT (%)	PLASTICITY INDEX (%)	USCS
•		2	8.5 - 10.0	12.7%	34	56	22	MH

LIQUID AND PLASTIC LIMITS TEST REPORT

**SOUTHERN COMPANY**


**Client:** SCS - Rhonda Tinsley

**Project:** Plant Branch SAR

**Project No.:** EWO -


**Lab#** 10

# Particle Size Distribution Report





# LIQUID AND PLASTIC LIMITS TEST REPORT



## SOIL DATA

SYMBOL	SOURCE	SAMPLE NO.	DEPTH (ft.)	NATURAL WATER CONTENT (%)	PLASTIC LIMIT (%)	LIQUID LIMIT (%)	PLASTICITY INDEX (%)	USCS
•		1	4.5 - 6.0	10.2%	22	43	21	SC

LIQUID AND PLASTIC LIMITS TEST REPORT

**SOUTHERN COMPANY**

Client: SCS - Rhonda Tinsley

Project: Plant Branch SAR

Project No.: EWO -

Lab# 11

# Particle Size Distribution Report



% COBBLES	% GRAVEL	% SAND	% SILT	% CLAY
0.0	0.0	36.5	20.8	42.7

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
#4	100.0		
#8	99.9		
#10	99.7		
#16	97.3		
#30	91.4		
#40	87.3		
#50	83.6		
#100	67.4		
#200	63.5		

\* (no specification provided)

## Soil Description

Dark Reddish Brown Sandy elastic silt

## Atterberg Limits

PL= 41

LL= 65

PI= 24

## Coefficients

D<sub>85</sub>= 0.333

D<sub>60</sub>= 0.0293

D<sub>50</sub>= 0.0107

D<sub>30</sub>=

D<sub>15</sub>=

D<sub>10</sub>=

C<sub>u</sub>=

C<sub>c</sub>=

## Classification

USCS= MH

AASHTO=

## Remarks

Specific Gravity - 2.70

Moisture Content - 20.0

Sample No.: 2

Location: Boring #6

Source of Sample:

Date: 01/18/08

Elev./Depth: 9.5 - 11.0

**SOUTHERN COMPANY**


Client: SCS - Rhonda Tinsley

Project: Plant Branch SAR

Project No: EWO -

Lab# 12

# LIQUID AND PLASTIC LIMITS TEST REPORT



## SOIL DATA

SYMBOL	SOURCE	SAMPLE NO.	DEPTH (ft.)	NATURAL WATER CONTENT (%)	PLASTIC LIMIT (%)	LIQUID LIMIT (%)	PLASTICITY INDEX (%)	USCS
•		2	9.5 - 11.0	20.0%	41	65	24	MH

LIQUID AND PLASTIC LIMITS TEST REPORT

**SOUTHERN COMPANY**


Client: SCS - Rhonda Tinsley

Project: Plant Branch SAR

Project No.: EWO -

Lab# 12

# Particle Size Distribution Report



% COBBLES	% GRAVEL	% SAND	% SILT	% CLAY
0.0	0.0	60.4	27.4	12.2

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
#4	100.0		
#8	100.0		
#10	100.0		
#16	98.4		
#30	87.1		
#40	79.3		
#50	70.2		
#100	52.0		
#200	39.6		

\* (no specification provided)

**Soil Description**  
Light Brown Silty sand

**Atterberg Limits**  
 PL= NP      LL= NP      PI= NP

**Coefficients**  
 D<sub>85</sub>= 0.544      D<sub>60</sub>= 0.206      D<sub>50</sub>= 0.137  
 D<sub>30</sub>= 0.0413      D<sub>15</sub>= 0.0086      D<sub>10</sub>=  
 C<sub>u</sub>=      C<sub>c</sub>=

**Classification**  
 USCS= SM      AASHTO=

**Remarks**  
 Specific Gravity - 2.62  
 Moisture Content - 7.2

Sample No.: 1  
Location: Boring #7

Source of Sample:

Date: 01/18/08  
Elev./Depth: 4.5 - 6.0


**SOUTHERN COMPANY**

Client: SCS - Rhonda Tinsley  
Project: Plant Branch SAR

Project No: EWO -

Lab# 13

# Particle Size Distribution Report



% COBBLES	% GRAVEL	% SAND	% SILT	% CLAY
0.0	5.5	60.9	26.1	7.5

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
.375 in.	100.0		
#4	94.5		
#8	90.9		
#10	89.0		
#16	79.9		
#30	67.1		
#40	61.0		
#50	55.9		
#100	44.2		
#200	33.6		

\* (no specification provided)

**Soil Description**  
Light Reddish Brown Silty sand

**Atterberg Limits**  
 PL= 29      LL= 37      PI= 8

**Coefficients**  
 D<sub>85</sub>= 1.55      D<sub>60</sub>= 0.398      D<sub>50</sub>= 0.210  
 D<sub>30</sub>= 0.0601      D<sub>15</sub>= 0.0143      D<sub>10</sub>= 0.0077  
 C<sub>u</sub>= 51.97      C<sub>c</sub>= 1.18

**Classification**  
 USCS= SM      AASHTO=

**Remarks**  
 Specific Gravity - 2.58  
 Moisture Content - 6.3

Sample No.: 2  
Location: Boring #7

Source of Sample:

Date: 01/18/08  
Elev./Depth: 9.5 - 11.0


**SOUTHERN COMPANY**

Client: SCS - Rhonda Tinsley  
Project: Plant Branch SAR

Project No: EWO -

Lab# 14

# LIQUID AND PLASTIC LIMITS TEST REPORT



## SOIL DATA

SYMBOL	SOURCE	SAMPLE NO.	DEPTH (ft.)	NATURAL WATER CONTENT (%)	PLASTIC LIMIT (%)	LIQUID LIMIT (%)	PLASTICITY INDEX (%)	USCS
•		2	9.5 - 11.0	6.3%	29	37	8	SM

LIQUID AND PLASTIC LIMITS TEST REPORT

**SOUTHERN COMPANY**

Client: SCS - Rhonda Tinsley


Project: Plant Branch SAR

Project No.: EWO -

Lab# 14



# Particle Size Distribution Report



% COBBLES	% GRAVEL	% SAND	% SILT	% CLAY
0.0	0.0	48.4	31.1	20.5

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
#4	100.0		
#8	100.0		
#10	100.0		
#16	98.6		
#30	87.5		
#40	82.1		
#50	76.0		
#100	63.5		
#200	51.6		

\* (no specification provided)

## Soil Description

Light Reddish Brown Sandy silt

## Atterberg Limits

PL= NP

LL= NP

PI= NP

## Coefficients

D<sub>85</sub>= 0.511

D<sub>60</sub>= 0.125

D<sub>50</sub>= 0.0637

D<sub>30</sub>= 0.0155

D<sub>15</sub>=

D<sub>10</sub>=

C<sub>u</sub>=

C<sub>c</sub>=

## Classification

USCS= ML

AASHTO=

## Remarks

Specific Gravity - 2.63

Permeability - 7.1x10<sup>-5</sup>

Dry Density - 89.8pcf & 16.0% Moisture

Sample No.: UD  
Location: Boring #6

Source of Sample:

Date: 01/18/08  
Elev./Depth: 9.0 - 11.0

**SOUTHERN COMPANY**

Client: SCS - Rhonda Tinsley  
Project: Plant Branch SAR

Project No: EWO -

Lab# 15

# Particle Size Distribution Report

