GEORGIA
DEPARTMENT OF NATURAL RESOURCES
ENVIRONMENTAL PROTECTION DIVISION

Jeffrey W. Cown, Director

EPD Director's Office
2 Martin Luther King, Jr. Drive
Suite 1456, East Tower
Atlanta, Georgia 30334
404-656-4713

CATEGORICAL EXCLUSION DETERMINATION
Force Main and Screening Upgrades
City of Adel (Cook County)
GEFA Loan No. CW-HRF-2026-010

The Georgia Environmental Protection Division (EPD) has conducted a review of the above project in accordance with the State's Environmental Review Process (SERP). EPD has determined that this project is eligible for a categorical exclusion. Accordingly, no further environmental review is planned. The proposed project consists of replacing the force main connecting the City's influent lift station to the headworks and replacing the manual bar screen. Existing buildings will not be impacted as a result of this project. All construction will be located on City-owned property and/or existing right-of-ways.

The project will be located in the 100-year floodplain as indicated by the Federal Emergency Management Agency (FEMA) map. However, the scope of work taking place within the floodplain consists of replacement of sewer lines and will not impact the floodplain.

This project is eligible for a categorical exclusion because it meets the following specific criteria, outlined in the SERP: rehabilitation of existing facilities. Furthermore: the project will not create a new or relocate an existing discharge to surface or ground waters; the project will not substantially increase the volume of discharge or loading of pollutants; the project will not provide capacity to serve a population 30% greater than the existing population; the project will not have a significant effect on the quality of the human environment; the action will not directly or indirectly affect cultural resources, habitats of endangered or threatened species, or environmentally important natural resource areas; and the action is cost-effective and should cause no significant public controversy.

This determination is effective immediately. This exclusion may be revoked at any time if: 1) the project is altered and no longer meets the requirements of a categorical exclusion, 2) new evidence shows that serious environmental issues exist, or 3) a local, State or Federal law is being or may be violated. The information which supports this decision can be viewed online via the Georgia EPD Online System (GEOS) at *https://geos.epd.georgia.gov/GA/GEOS/Public/Client/GA_GEOS/Public/Pages/PublicApplicationList.aspx* and is available for public review upon request with the Georgia EPD.

If you have any questions about this determination, please contact Ethan Rhine of my staff at *ethan.rhine@dnr.ga.gov* or (678) 672-6037.

Issuance Date: 10/15/2026

Jeffrey W. Cown

Jeffrey W. Cown, Director
Environmental Protection Division

EXISTING LIFT STATION #18

PROPOSED BAR SCREEN IMPROVEMENTS

EXISTING CITY OF ADEL WPCP

±5,420 L.F. 24" C-900 PVC FORCE MAIN

±95 L.F. HORIZONTAL DIRECTIONAL DRILL

Bear Creek

City of Adel Lake

City of Adel Lake Dam

200

Memorial

SCALE 1" = 500'

LIFT STATION #18 FORCE MAIN IMPROVEMENTS

FOR THE

CITY OF ADEL

COOK COUNTY, GEORGIA

Carter & Sloope

CONSULTING ENGINEERS

MACON ◆ MOULTRIE ◆ ATHENS ◆ CANTON

6310 PEAKE ROAD . MACON, GA 31210 . 478.477.3923 TEL . 478.477.4691 FAX

GA. COA LICENSE# PEF001004 EXPIRES 6/30/2022