

PERMIT AMENDMENT NO. 4911-063-0150-S-01-2
ISSUANCE DATE:



GEORGIA
DEPARTMENT OF NATURAL RESOURCES

ENVIRONMENTAL PROTECTION DIVISION

Air Quality – Permit Amendment

In accordance with The Georgia Air Quality Act, O.C.G.A. Section 12-9-1, et seq and the Rules, Chapter 391-3-1, adopted pursuant to or in effect under that Act, Permit No. 4911-063-0150-S-01-0 issued on August 14, 2019 to:

Facility Name: Hartsfield-Jackson Atlanta International Airport Resiliency Facility
Facility Address: 6000 North Terminal Parkway
Atlanta, Georgia 30320 Clayton County
Mailing Address: 241 Ralph McGill Blvd. NE, Bin 10221
Atlanta, Georgia 30308
Facility AIRS Number: 04-13-063-0150

for the following: Operation of one hundred 625 kW Tier 4 diesel engine generators for airport in case of power outage.

is hereby amended as follows: Modification of Permit Condition 2.1 which limits the hours of operation of all engines combined such that the total hours of operation do not exceed 308,829 hours during any consecutive twelve-month period to 500 hours of operation for each engine during any consecutive twelve-month period.

Reason for Amendment: Application Number 28964 dated July 27, 2023.

This Permit is further subject to and conditioned upon the terms, conditions, limitations, standards, or schedules contained in or specified on the attached 1 page(s).

This Permit Amendment is hereby made a part of Permit No. 4911-063-0150-S-01-0 and compliance herewith is hereby ordered. Except as amended hereby, the above referenced Permit remains in full force and effect.



Jeffrey W. Cown, Director
Environmental Protection Division

**State of Georgia
Department of Natural Resources
Environmental Protection Division**

**Permit Amendment No.
4911-063-0150-S-01-2**

Page 1 of 1

2. Allowable Emissions

- 2.1 The Permittee shall limit the hours of operation of each engine such that the total hours of operation do not exceed 500 hours during any consecutive twelve-month period in order to limit potential emissions of NO_x to less than 100 tons during any consecutive twelve-month period.
[391-3-1-.03(2)(c) and 40 CFR 70 Avoidance]

7. Notification, Reporting and Record Keeping Requirements

- 7.3 The Permittee shall use the monthly operating time data required by Condition 7.1 to calculate monthly the twelve-month rolling total of the operating time of each generator for each consecutive twelve-month period. The Permittee shall notify the Division in writing within 15 days if any twelve-month rolling total of the hours of operation of an engine exceeds 500 hours. This notification shall include an explanation of how the Permittee intends to maintain NO_x emissions to below 100 tons during any consecutive twelve-month period.
[391-3-1-.03(2)(c) and 40 CFR 70 Avoidance]