

BART EXEMPTION MODELING PROTOCOL

PCS NITROGEN FERTILIZER

AUGUSTA, GEORGIA

Submitted to:

GEORGIA ENVIRONMENTAL PROTECTION DIVISION

Prepared for:



Prepared by:

**MACTEC Engineering and Consulting, Inc.
Kennesaw, Georgia**

Project No. 6306-06-0034

May 2006

1.	INTRODUCTION	1-1
1.1	OBJECTIVES.....	1-1
1.2	LOCATION OF SOURCE VS. RELEVANT CLASS I AREAS	1-1
1.3	SOURCE IMPACT EVALUATION CRITERIA	1-2
2.	SOURCE DESCRIPTION.....	2-1
2.1	UNIT SPECIFIC SOURCE DATA.....	2-1
2.2	BOUNDARY CONDITIONS	2-1
3.	GEOGRAPHICAL AND METEOROLOGICAL DATA	3-1
3.1	MODELING DOMAIN AND TERRAIN	3-1
3.2	LAND USE	3-1
3.3	METEOROLOGICAL DATA BASE	3-1
3.3.1	MM5 Simulations.....	3-1
3.3.2	Measurements and Observations.....	3-1
3.4	AIR QUALITY DATA BASE	3-1
3.4.1	Ozone Concentrations – Measured or Modeled	3-1
3.4.2	Ammonia Concentrations – Measured or Modeled.....	3-2
3.4.3	Concentrations of Other Pollutants – Measured or Modeled	3-2
3.5	NATURAL CONDITIONS AT CLASS I AREAS.....	3-2
4.	AIR QUALITY MODELING METHODOLOGY.....	4-1
4.1	PLUME MODEL SELECTION.....	4-1
4.1.1	Major Relevant Features of CALMET	4-1
4.1.2	Major Relevant Features of CALPUFF.....	4-1
4.2	MODELING DOMAIN CONFIGURATION.....	4-1
4.3	CLAMET METEOROLOGICAL MODELING.....	4-2
4.4	CALPUFF COMPUTATIONAL DOMAIN AND RECEPTORS.....	4-2
4.5	CALPUFF MODELING OPTIONS SELECTIONS.....	4-2
4.6	LIGHT EXTINCTION AND HAZE IMPACT CALCULATIONS	4-2
4.7	MODELING PRODUCTS	4-2
5.	REVIEW PROCESS	5-1
5.1	CALMET FIELDS	5-1
5.2	CALPUFF, CALPOST, AND POSTUTIL RESULTS.....	5-1
6.	REFERENCES	6-1

LIST OF APPENDICES

A.1	VISTAS BART MODELING PROTOCOL
-----	-------------------------------

1. INTRODUCTION

MACTEC Engineering and Consulting, Inc. (MACTEC) is submitting the following Best Available Retrofit Technology (BART) Exemption Modeling protocol on behalf of the PCS Nitrogen Fertilizer (PCS) plant located in Augusta, Georgia. This modeling will follow the procedures outlined in the “Protocol for the Application of the CALPUFF Model for Analyses of Best Available Retrofit Technology (BART)” December 22, 2005 revised March 9th, 2006 as posted on the VISTAS website.

1.1 OBJECTIVES

The objective of this modeling protocol is to outline the procedures that will be utilized for conducting the BART exemption modeling for the PCS site located in Augusta, Georgia.

1.2 LOCATION OF SOURCE VS. RELEVANT CLASS I AREAS

Table 1 below provides the location of the PCS Nitrogen site and the Class I areas near the site. The distance from PCS to the nearby class I areas was determined by calculating the distance from the site to each of the receptor locations, which represent the Class I area boundary. These boundary receptors (taken from the National Park Service website) were used to determine the shortest distance between the PCS site to the nearby Class I areas. As shown in Table 1 the PCS site is within 300 km of eight class I areas. All eight Class I areas will therefore be evaluated as part of the exemption modeling.

Table 1: PCS Nitrogen Location and Distance to Class I Areas

Site/ Class I Area	LCC (Easting) - km	LCC (Northing) - km	Shortest Distance to PCS (km)
PCS	1390.6	-610.4	--
Cape Romain	1610.2	-627.0	220
Cohutta	1131.5	-484.1	288
Wolf Island	1485.8	-828.1	238
Great Smokey Mountains	1241.2	-400.0	258
Joyce Kilmer	1177.1	-429.2	280
Shining Rock Wilderness	1276.4	-416.0	225
Okefenokee	1401.4	-877.3	267
Linville Gorge	1349.5	-350.9	263

1.3 SOURCE IMPACT EVALUATION CRITERIA

The maximum 24 hour results from the CALPOST model for each modeled year will be compared to the 0.5 deciview significant impact level. If the results of this CALPOST analysis show that the site is below this level, then the site qualifies as an exemption source and no additional evaluation will be completed. If the site doesn't meet this criteria, a 98th percentile result for each year will be compared to the 0.5 dv value. For this assessment, the 98th percentile level (8th highest deciview value) for each modeled year will be compared to the 0.5 dv to determine exemption eligibility. The 4-km spacing meteorology will be used for the fine grid scale modeling.

2. SOURCE DESCRIPTION

PCS Nitrogen Fertilizer, L.P. (PCS) owns and operates a nitrogenous fertilizer manufacturing facility in Augusta, Georgia. The plant produces ammonia, nitric acid, urea, carbon dioxide, ammonium nitrate, and urea-ammonium nitrate solutions. In the ammonia plant, natural gas is reformed and mixed with atmospheric air to form ammonia in a series of reaction steps. The plant operates two nitric acid plants, which combust the ammonia in the presence of air to form NO_x, which is routed through absorption columns to form nitric acid. Ammonium nitrate is formed at the plant by mixing gaseous ammonia with nitric acid. The neutralized solution is then concentrated in prilling towers to form a solid. The plant also operates a Urea production facility which combines carbon dioxide (produced from the ammonia plant) with ammonia to form urea. The urea is then concentrated in a prill tower. The ammonia plant, nitric acid plants, ammonium nitrate operations, and urea plant were built between the eligibility dates of August 1962 to August 1977, the processes are on the list of 26 listed processes (chemical plants), and the units have the potential NO_x emissions greater than 250 tpy. All these units are therefore BART eligible. The boilers on site were not built during the BART eligibility dates, however, they are in place to support the chemical plant operations, therefore, they are noted as BART eligible sources and will be included in the modeling evaluation.

2.1 UNIT SPECIFIC SOURCE DATA

The exemption modeling will be based on the stack parameters for the regulated units as summarized in Table 2. The emission rates for the operations are based on results from continuous emission monitors (CEMs), stack tests, vendor estimates, and permit allowable emission rates. Exhaust flow rates and temperatures are based on stack tests where available and engineering design where testing data is not available. As per the common VISTAS modeling protocol (page 42), the modeling evaluation will not include building downwash, because all Class I areas being evaluated are greater than 50 km away from the site.

2.2 BOUNDARY CONDITIONS

Model options and switches will be used as set in the example models as provided on the Earth Tech website.

Table 2: BART Modeling Data
PCS Nitrogen - Augusta, Georgia

STATIONARY SOURCE NAME/LOCATION	COUNTY NAME OR FIPS COUNTY CODE	STATIONARY SOURCE ID(1)	2-DIGIT SIC	STACK ID	STACK HEIGHT FT	UTM COORDINATES EASTING	UTM COORDINATES NORTHING	ELEVATION FT ABOVE MSL	STACK DIAMETER FT	EXIT VELOCITY FT/SEC	EXIT TEMP DEGREES F
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5103	102	566465.3264	3776240.826		3.2	53	85
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5104	97	566465.3264	3776240.826		2.5	59	85
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5105	119	566465.3264	3776240.826		6.24	80	120
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5101	117	566465.3264	3776240.826		2	64.2	210
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5109	200	566465.3264	3776240.826		8.66	83.85	70-100
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5106	216	566465.3264	3776240.826		4	81	70-100
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5107	95	566465.3264	3776240.826		5	50	60-120
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5110	95	566465.3264	3776240.826		6	40.4	65-105
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5102	95	566465.3264	3776240.826		2.6	64.15	209
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5111	272	566465.3264	3776240.826		4.62	49.4	120-150
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5113	272	566465.3264	3776240.826		8.65	87	100-120
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5118	137.5	566465.3264	3776240.826		3.17	104	97
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5119	69	566465.3264	3776240.826		5	104	344
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28			566465.3264	3776240.826				
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5121	126	566465.3264	3776240.826		5	12.4	300
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5121	126	566465.3264	3776240.826		5	12.4	300
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5124	104	566465.3264	3776240.826		5	4.2	330
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5124	104	566465.3264	3776240.826		5	4.2	330
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5172	108	566465.3264	3776240.826		13.9	42	360
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5172	108	566465.3264	3776240.826		13.9	42	360
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5172	108	566465.3264	3776240.826		13.9	42	360
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5176	100	566465.3264	3776240.826		0.25	17.6	300
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5115	285	566465.3264	3776240.826		1.5	436.9	
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5177	285	566465.3264	3776240.826		1.7	2	105
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5178	285	566465.3264	3776240.826		0.5	44.2	137
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5129	272	566465.3264	3776240.826		11.5	4.7	226
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5130	285	566465.3264	3776240.826		1.67	2	105
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5135	95	566465.3264	3776240.826		4	16	80
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28			566465.3264	3776240.826				
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5113	285	566465.3264	3776240.826		3.5	201	150
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28			566465.3264	3776240.826				
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5131	90	566465.3264	3776240.826		1	181.4	106
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5117	45	566465.3264	3776240.826		1.3	263.4	80
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5132	18	566465.3264	3776240.826		0.3	5.7	82
PCS Nitrogen Fertilizer, LP - Augusta	245	0002	28	5136	66	566465.3264	3776240.826				100

Table 2: BART Modeling Data
PCS Nitrogen - Augusta, Georgia

EMISSION UNIT ID(2)	EMISSION UNIT DESCRIPTION	PROCESS CODE(3)	SCC CODE	EMISSION PROCESS DESCRIPTION	MAX. HEAT INPUT RATE FUEL-FIRED BOILERS (MMBtu/hr)	CATEGORY CODE(4)	NOX(TPY) POTENTIAL	ACTUAL	MAX 24-HR EMISSION RATE FOR 2002-2004	POTENTIAL	ACTUAL	MAX 24-HR EMISSION RATE FOR 2002-2004
A1A03	C001 AN Plant Prill Drying System	1	30102706			10	0.00	0.00	0.00	31.60	20.70	30.10
A1A04	C001 AN Plant Prill Cooling System	1	30102706			10	0.00	0.00	0.00	78.50	52.20	75.70
A1A05	C001 AN Plant Prill Tower	1	30102701			10	0.00	0.00	0.00	14.10	20.70	21.40
AN01	C001 AN Neutralizer	1	30102704			10	0.00	0.00	0.00	36.60	29.30	35.80
A2A01	C002 AN Plant Prill Tower-Outside	1	30102701			10	0.00	0.00	0.00	12.70	8.40	12.70
A2A02	C002 AN Plant Prill Tower-Biniks	1	30102701			10	0.00	0.00	0.00	3.90	2.40	3.90
A2A03	C002 AN Plant Prill Cooler	1	30102706			10	0.00	0.00	0.00	17.00	11.20	17.00
A2A04	C002 AN Plant Prill Dryer	1	30102706			10	0.00	0.00	0.00	6.80	4.00	6.80
AN02	C002 AN Neutralizer	1	30102704			10	0.00	0.00	0.00	31.40	20.70	31.40
A2U01	C002 Urea Plant Prill Tower-Inner	1	30104003			10	0.00	0.00	0.00	7.70	5.90	7.70
UN01	C002 Urea Plant Prill Tower-Outer	1	30104003			10	0.00	0.00	0.00	35.70	28.10	32.70
N2N01	C002 Nitric Acid Plant	1	30101301			10	2242.00	1876.60	1876.50	0.00	0.00	0.00
N2N02	C002 Nitric Acid Plant	1	30101302			10	602.30	274.00	440.70	0.00	0.00	0.00
N2N03	C002 Nitric Acid Plant	1	30101302			10	0.70	0.70	0.70	0.00	0.00	0.00
N2S11	Nitric Acid Tank TKG28B	1	30101309			10						
N2S12	Nitric Acid Tank TKG28A	1	30101309			10						
N2S13	Nitric Acid Tank TKG27B	1	30101309			10						
N2S14	Nitric Acid Tank TKG27A	1	30101309			10						
N2S15	Nitric Acid Tank TKG231	1	30101309			10						
N2S16	Nitric Acid Tank TKG27C	1	30101309			10						
N2S17	Nitric Acid Tank TKG01	1	30101309			10						
N2S18	Nitric Acid Tank TKG20	1	30101309			10						
A3B01	Boller H 6531**	1	10206031	Natural Gas	181.00	10	124.30	62.2	124.30	6.40	2.70	6.40
A3B01	Boller H 6531**	1	10206031	Oil	181.00	10	126.80	0.50	45.20	12.30	0.00	6.10
A3B02	Boller Boiler**	2	10206031	Natural Gas	181.00	10						
A3B03	A3B/CSE Boller H 6532**	1	10206031	Natural Gas	181.00	10	34.80	2.60	34.80	6.40	0.80	6.40
A3B03	A3B/CSE Boller H 6532**	2	30516002	Oil	181.00	10	0.00	0.00	0.00	0.00	0.00	0.00
A3B03	Primary Reducer	2	30103036	Natural Gas	387.00	10	39.70	37.20	39.70	10.20	9.50	10.20
A3B03	Primary Reducer	2	30103036	waste gas	387.00	10	32.40	46.10	32.40	8.80	8.80	8.80
A3B03	Combustion Furnace	2	21203201	Natural Gas	387.00	10	352.80	330.40	352.80	0.00	0.00	0.00
A3B03	NHS Storage Pans	1	21203201	Natural Gas	387.00	10	0.10	0.10	0.10	0.00	0.00	0.00
A3B03	Solution Regenerator	1	30103036			10	0.00	0.00	0.00	0.00	0.00	0.00
A3B03	Urea Plant Low P Vent	1	30104020			10	0.00	0.00	0.00	0.00	0.00	0.00
A3B03	Urea Plant High P Vent	1	30104020			10	0.00	0.00	0.00	0.00	0.00	0.00
A3B03	Dial Washer	1	30104003			10	0.00	0.00	0.00	5.40	3.90	4.60
A3B03	Urea Process Tanks	1	30104020			10	0.00	0.00	0.00	0.00	0.00	0.00
A3B03	Pond Evaporator	1	30104003			10	0.00	0.00	0.00	0.00	0.00	0.00
A3B03	Urea Warehouse	1	30105001			10	0.00	0.00	0.00	0.00	0.00	0.00
A3B03	Startup Vent for Ammonia Plant	1	30105001			10	0.00	0.00	0.00	0.00	0.00	0.00
AN02	Startup Vent for Ammonia Plant	1	30105001			10	0.00	0.00	0.00	0.00	0.00	0.00
AC01	ACI Plant	1	30106008			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U07	Urea Compressor	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
AC02	ACI Skids	1	30106008			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank	1	30104001			10	0.00	0.00	0.00	0.00	0.00	0.00
A2U08	Formaldehyde Tank</											

* As a worst case assumption all PM emissions will be modeled as PM fine

*** The installation dates for the boilers do not fall within the BART eligibility window, however, they are included in the modeling because they support the operations of other modeled sources,

Table 2: BART Modeling Data
PCS Nitrogen - Augusta, Georgia

EMISSIION UNIT ID (2)	EMISSIION UNIT DESCRIPTION	SO2 (TPY)			VOCs (TPY)			NH3 (TPY)			PM2.5 (TPY)			MAX 24-HR EMISSION RATE FOR 2002-2004	POTENTIAL	ACTUAL	MAX 24-HR EMISSION RATE FOR 2002-2004	POTENTIAL	ACTUAL
		POTENTIAL	ACTUAL	MAX 24-HR EMISSION RATE FOR 2002-2004	POTENTIAL	ACTUAL	MAX 24-HR EMISSION RATE FOR 2002-2004	POTENTIAL	ACTUAL	POTENTIAL	ACTUAL	POTENTIAL	ACTUAL						
IA103	C001 AN Plant Prill Drying System	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			26.40		
IA104	C001 AN Plant Prill Cooling System	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			36.50		
IA105	C001 AN Plant Prill Tower	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			22.30		
AN101	C001 AN Neutralizer	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			193.80		
AJ201	C002 AN Plant Prill Tower-Outside	0.00	0.00000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			15.00		
AJ201	C002 AN Plant Prill Tower-Brinks	0.00	0.00000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			54.40		
AJ202	C002 AN Plant Prill Cooler	0.00	0.00000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			35.70		
AJ204	C002 AN Plant Prill Dryer	0.00	0.00000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			72.00	109.60	
AN02	C002 AN Neutralizer	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			41.70	58.70	
UJ201	C002 Urea Plant Prill Tower-Inner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			343.00	519.00	
UJ201	C002 Urea Plant Prill Tower-Outer	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			77.70	97.30	
NI101	C001 Nitric Acid Plant	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			79.30	99.40	
NI201	C002 Nitric Acid Plant	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			513.00	490.20	522.40
NI201	Nitric Acid Tank TK628B	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
NI202	Nitric Acid Tank TK628A																		
NI203	Nitric Acid Tank TK627B																		
NI204	Nitric Acid Tank TK627A																		
NI205	Nitric Acid Tank TK6281																		
NI206	Nitric Acid Tank TK627G																		
NI207	Nitric Acid Tank TK661																		
NI208	Nitric Acid Tank TK620																		
AJ301	Boiler H 6531	0.10	0.10	0.10	4.60	1.90	4.60	0.00	0.00	4.60	0.00	0.00	0.00	0.00			0.00	0.00	
AJ301	Boiler H 6531	46.40	0.20	24.10	2.10	0.00	0.00	0.00	0.00	1.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ302	Rondit Boiler																		
AJ303	ABCECE Boiler H 6532	0.10	0.00	0.10	4.60	0.30	4.60	0.00	0.00	4.60	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	
AJ303	ABCECE Boiler H 6532	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										

Table 2: BART Modeling Data
PCS Nitrogen - Augusta, Georgia

EMISSION UNIT ID (2)	EMISSION UNIT DESCRIPTION	NOx			PM10			SO2			VOC		
		NEI PRIMARY CONTROL DEVICE CODE	CONTROL SYSTEM DESCRIPTION	TOTAL CAPTURE & CONTROL EFFICIENCY (%)	NEI PRIMARY CONTROL DEVICE CODE	CONTROL SYSTEM DESCRIPTION	TOTAL CAPTURE & CONTROL EFFICIENCY (%)	NEI PRIMARY CONTROL DEVICE CODE	CONTROL SYSTEM DESCRIPTION	TOTAL CAPTURE & CONTROL EFFICIENCY (%)	NEI PRIMARY CONTROL DEVICE CODE	CONTROL SYSTEM DESCRIPTION	TOTAL CAPTURE & CONTROL EFFICIENCY (%)
A103	CD01 AN Plant Pail Drying System												
A104	CD01 AN Plant Pail Cooling System												
A105	CD01 AN Plant Pail Tower				85	Wet Cyclone	86						
AN01	CD01 AN Neutralizer				85	Wet Cyclone	86						
A201	CD02 AN Plant Pail Tower-Outside				53	Venturi Scrubber	95						
A202	CD02 AN Plant Pail Tower-Brines				1	Scrubber	93						
A203	CD02 AN Plant Pail Cooler				1	Scrubber	90						
A204	CD02 AN Plant Pail Drier				1	Scrubber	98						
AN02	CD02 AN Neutralizer				1	Scrubber	98						
U201	CD03 Urea Plant Pail Tower-Inner												
U202	CD03 Urea Plant Pail Tower-Outer												
U203	CD03 Urea Plant Pail Tower-Cooler												
U204	CD03 Urea Plant Pail Tower-Heater												
U205	CD03 Urea Plant Pail Tower-Stripper												
U206	CD03 Urea Plant Pail Tower-Stripper												
U207	CD03 Urea Plant Pail Tower-Stripper												
U208	CD03 Urea Plant Pail Tower-Stripper												
U209	CD03 Urea Plant Pail Tower-Stripper												
U210	CD03 Urea Plant Pail Tower-Stripper												
U211	CD03 Urea Plant Pail Tower-Stripper												
U212	CD03 Urea Plant Pail Tower-Stripper												
U213	CD03 Urea Plant Pail Tower-Stripper												
U214	CD03 Urea Plant Pail Tower-Stripper												
U215	CD03 Urea Plant Pail Tower-Stripper												
U216	CD03 Urea Plant Pail Tower-Stripper												
U217	CD03 Urea Plant Pail Tower-Stripper												
U218	CD03 Urea Plant Pail Tower-Stripper												
U219	CD03 Urea Plant Pail Tower-Stripper												
U220	CD03 Urea Plant Pail Tower-Stripper												
U221	CD03 Urea Plant Pail Tower-Stripper												
U222	CD03 Urea Plant Pail Tower-Stripper												
U223	CD03 Urea Plant Pail Tower-Stripper												
U224	CD03 Urea Plant Pail Tower-Stripper												
U225	CD03 Urea Plant Pail Tower-Stripper												
U226	CD03 Urea Plant Pail Tower-Stripper												
U227	CD03 Urea Plant Pail Tower-Stripper												
U228	CD03 Urea Plant Pail Tower-Stripper												
U229	CD03 Urea Plant Pail Tower-Stripper												
U230	CD03 Urea Plant Pail Tower-Stripper												
U231	CD03 Urea Plant Pail Tower-Stripper												
U232	CD03 Urea Plant Pail Tower-Stripper												
U233	CD03 Urea Plant Pail Tower-Stripper												
U234	CD03 Urea Plant Pail Tower-Stripper												
U235	CD03 Urea Plant Pail Tower-Stripper												
U236	CD03 Urea Plant Pail Tower-Stripper												
U237	CD03 Urea Plant Pail Tower-Stripper												
U238	CD03 Urea Plant Pail Tower-Stripper												
U239	CD03 Urea Plant Pail Tower-Stripper												
U240	CD03 Urea Plant Pail Tower-Stripper												
U241	CD03 Urea Plant Pail Tower-Stripper												
U242	CD03 Urea Plant Pail Tower-Stripper												
U243	CD03 Urea Plant Pail Tower-Stripper												
U244	CD03 Urea Plant Pail Tower-Stripper												
U245	CD03 Urea Plant Pail Tower-Stripper												
U246	CD03 Urea Plant Pail Tower-Stripper												
U247	CD03 Urea Plant Pail Tower-Stripper												
U248	CD03 Urea Plant Pail Tower-Stripper												
U249	CD03 Urea Plant Pail Tower-Stripper												
U250	CD03 Urea Plant Pail Tower-Stripper												
U251	CD03 Urea Plant Pail Tower-Stripper												
U252	CD03 Urea Plant Pail Tower-Stripper												
U253	CD03 Urea Plant Pail Tower-Stripper												
U254	CD03 Urea Plant Pail Tower-Stripper												
U255	CD03 Urea Plant Pail Tower-Stripper												
U256	CD03 Urea Plant Pail Tower-Stripper												
U257	CD03 Urea Plant Pail Tower-Stripper												
U258	CD03 Urea Plant Pail Tower-Stripper												
U259	CD03 Urea Plant Pail Tower-Stripper												
U260	CD03 Urea Plant Pail Tower-Stripper												
U261	CD03 Urea Plant Pail Tower-Stripper												
U262	CD03 Urea Plant Pail Tower-Stripper												
U263	CD03 Urea Plant Pail Tower-Stripper												
U264	CD03 Urea Plant Pail Tower-Stripper												
U265	CD03 Urea Plant Pail Tower-Stripper												
U266	CD03 Urea Plant Pail Tower-Stripper												
U267	CD03 Urea Plant Pail Tower-Stripper												
U268	CD03 Urea Plant Pail Tower-Stripper												
U269	CD03 Urea Plant Pail Tower-Stripper												
U270	CD03 Urea Plant Pail Tower-Stripper												
U271	CD03 Urea Plant Pail Tower-Stripper												
U272	CD03 Urea Plant Pail Tower-Stripper												
U273	CD03 Urea Plant Pail Tower-Stripper												
U274	CD03 Urea Plant Pail Tower-Stripper												
U275	CD03 Urea Plant Pail Tower-Stripper												
U276	CD03 Urea Plant Pail Tower-Stripper												
U277	CD03 Urea Plant Pail Tower-Stripper												
U278	CD03 Urea Plant Pail Tower-Stripper												
U279	CD03 Urea Plant Pail Tower-Stripper												
U280	CD03 Urea Plant Pail Tower-Stripper												
U281	CD03 Urea Plant Pail Tower-Stripper												
U282	CD03 Urea Plant Pail Tower-Stripper												
U283	CD03 Urea Plant Pail Tower-Stripper												
U284	CD03 Urea Plant Pail Tower-Stripper												
U285	CD03 Urea Plant Pail Tower-Stripper												
U286	CD03 Urea Plant Pail Tower-Stripper												
U287	CD03 Urea Plant Pail Tower-Stripper												
U288	CD03 Urea Plant Pail Tower-Stripper												
U289	CD03 Urea Plant Pail Tower-Stripper												
U290	CD03 Urea Plant Pail Tower-Stripper												
U291	CD03 Urea Plant Pail Tower-Stripper												
U292	CD03 Urea Plant Pail Tower-Stripper												
U293	CD03 Urea Plant Pail Tower-Stripper												
U294	CD03 Urea Plant Pail Tower-Stripper												
U295	CD03 Urea Plant Pail Tower-Stripper												
U296	CD03 Urea Plant Pail Tower-Stripper												
U297	CD03 Urea Plant Pail Tower-Stripper												
U298	CD03 Urea Plant Pail Tower-Stripper												
U299	CD03 Urea Plant Pail Tower-Stripper												
U300	CD03 Urea Plant Pail Tower-Stripper												

Table 2: BART Modeling Data
PCS Nitrogen - Augusta, Georgia

EMISSION UNIT ID (2)	EMISSION UNIT DESCRIPTION	NH3		PM2.5		DATES		LOCATION							
		NEI PRIMARY CONTROL DEVICE CODE	CONTROL SYSTEM DESCRIPTION	TOTAL CAPTURE & CONTROL EFFICIENCY (%)	NEI PRIMARY CONTROL DEVICE CODE	CONTROL SYSTEM DESCRIPTION	TOTAL CAPTURE & CONTROL EFFICIENCY (%)	IN EXISTENCE <8/17/77?	BEGAN OPERATION >8/18/27(s)	EXPECTED BART CLASSIFICATION (s)	LATITUDE (Decimal Degrees)	LONGITUDE (Decimal Degrees)	UTMX	UTMY	UTM Zone
A103	G001 AN Plant Pail Drying System							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
A104	G001 AN Plant Pail Cooling System							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
A105	G001 AN Plant Pail Tower							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
AN01	G001 AN Neutralizer							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
A201	G002 AN Plant Pail Tower-Outside							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
A201	G002 AN Plant Pail Tower-Brinks							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
A202	G002 AN Plant Pail Cooler							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
A204	G002 AN Plant Pail Dryer							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
AN02	G002 AN Neutralizer							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
U201	G002 Urea Plant Pail Tower-Inner							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
U201	G002 Urea Plant Pail Tower-Outer							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
N101	G001 Nitric Acid Plant							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
N201	G002 Nitric Acid Plant							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
NS11	Nitric Acid Tank T4628B							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
NS12	Nitric Acid Tank T4628A							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
NS13	Nitric Acid Tank T4627B							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
NS14	Nitric Acid Tank T4627A							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
NS15	Nitric Acid Tank T4627C							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
NS16	Nitric Acid Tank T4601							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
NS17	Nitric Acid Tank T4620							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
NS18	Nitric Acid Tank T4620							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
AB01	Boiler H 6531							No	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
AB01	Boiler H 6531							No	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
AB02	Boiler H 6531							No	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
AB03	AB03CE Boiler H 6532							No	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
AB03	AB03CE Boiler H 6532							No	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
AM01	Primary Reforiner							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
AM01	Primary Reforiner							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
GT01	Combustion Turbine							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
FL01	NH3 Storage Flare							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
AM04	Solution Regenerator							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
U202	Urea Plant Low P Vent							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
U203	Urea Plant High P Vent							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
U204	Urea Washer							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
U205	Urea Process Tanks							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
A205	Pond Evaporator							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
U206	Urea Warehouse							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
AM02	Startup Vent for Ammonia Plant							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
AC11	ACI Plant							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
U207	Urea Compressor							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
AC12	ACI Sinks							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
U108	Formaldehyde Tank							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17
A203	G2 AN HD Cooler							Yes	Yes	Bart eligible	33.445	81.930278	566465.3264	3779240.826	17

3. GEOGRAPHICAL AND METEOROLOGICAL DATA

3.1 MODELING DOMAIN AND TERRAIN

The modeling data to be utilized for the modeling evaluation is the CALMET data provided by VISTAS via Georgia EPD. The modeling domain consists of the area which includes the site, all eight class I areas being evaluated, with an additional 50 km buffer around this area. The area around the site is primarily flat terrain.

3.2 LAND USE

The area immediately around the site is industrial, but is primarily rural outside a few kilometers from the site.

3.3 METEOROLOGICAL DATA BASE

All met data will be run as provided by VISTAS.

3.3.1 MM5 Simulations

As provided by VISTAS.

3.3.2 Measurements and Observations

None.

3.4 AIR QUALITY DATA BASE

3.4.1 Ozone Concentrations – Measured or Modeled

The ozone concentrations will be modeled using the three years of ozone data as provided by Earth Tech on their website. The OZONE.DAT file to be used in each year of the model runs will be extracted from the corresponding year data taken from the Earth Tech website. The CALPRO GUI will be used to extract the data by providing the domain being used for the CALPUFF model.

3.4.2 Ammonia Concentrations – Measured or Modeled

Ammonia emissions will be modeled from the site.

3.4.3 Concentrations of Other Pollutants – Measured or Modeled

Per the “Federal Land Managers’ Air Quality Related Values Workgroup (FLAG) Phase I report (December 2000)” the background SO₄ concentration (BKSO₄) will be calculated based on the reported hygroscopic value for each of the Class I areas divided by 3. The hygroscopic value for all eight class I areas is 0.9, therefore a 0.3 value will be used for the BKSO₄ variable for all months. The soil background (BKSOIL) concentration will be set to the non-hygroscopic value as per the FLAG document. This value is 8.5 for all eight of the Class I areas. Per the FLAG document all other background concentrations will be modeled at 0 except for ammonia as noted in 3.4.2.

3.5 NATURAL CONDITIONS AT CLASS I AREAS

The relative humidity to be used for each site is based on data taken from the FLAG document. Table 3 below provides the monthly relative humidity that will be used for each of the eight Class I areas.

Table 3: Relative Humidity Factor Data

Month	Cape Romain	Cohutta	Wolf Island	Great Smokey Mountains	Joyce Kilmer	Shining Rock Wilderness	Okefenokee	Linville Gorge
January	2.9	3	3.1	3	3	2.9	3.2	2.9
February	2.9	3	3.1	3	3	2.9	3.2	2.9
March	3.3	3.1	3.3	3.1	3.1	3.1	3.4	3.1
April	3.3	3.1	3.3	3.1	3.1	3.1	3.4	3.1
May	3.3	3.1	3.3	3.1	3.1	3.1	3.4	3.1
June	3.9	3.6	3.9	3.6	3.6	3.7	3.9	3.7
July	3.9	3.6	3.9	3.6	3.6	3.7	3.9	3.7
August	3.9	3.6	3.9	3.6	3.6	3.7	3.9	3.7
September	3.3	3.3	3.6	3.2	3.2	3.2	3.6	3.1
October	3.3	3.3	3.6	3.2	3.2	3.2	3.6	3.1
November	3.3	3.3	3.6	3.2	3.2	3.2	3.6	3.1
December	2.9	3	3.1	3	3	2.9	3.2	2.9

4. AIR QUALITY MODELING METHODOLOGY

4.1 PLUME MODEL SELECTION

The modeling will be completed using the VISTAS recommended CALPUFF version for BART modeling as posted on the Earth Tech website. The modeling will be completed using the 12-km meteorological data files provided by VISTAS (via Georgia EPD). The sample CALPUFF model and CALPOSTL input files posted on the Earth Tech website will be used for the modeling assessment.

4.1.1 Major Relevant Features of CALMET

The CALMET data as provided by VISTAS will be used in the analysis.

4.1.2 Major Relevant Features of CALPUFF

The modeling will utilize the MESOPUFF II module for chemical mechanism portion of the model. The integrated puff sampling methodology option will be chosen. For running the CALPOST processor, the visibility Method 6 option will be used using the monthly relative humidity values identified above. The species modeled in the visibility analysis will include SO₂, NO_x, NH₃, and PM which will be modeled as fine particulate.

4.2 MODELING DOMAIN CONFIGURATION

The domain consists of the area which includes the site, all eight class I areas, with an additional 50 km buffer around this area. Table 4 provides the coordinates of the area bounded by the modeling domain.

Table 4: Modeling Domain Coordinates

Location	km	km
Southwest Corner	1037.973	-1001.974
Southeast Corner	1709.973	-1001.974
Northeast Corner	1709.973	-269.974
Northwest Corner	1037.973	-269.974

4.3 CLAMET METEOROLOGICAL MODELING

No CALMET modeling will be completed as VISTAS has provided the meteorological data to be used in the CALPUFF modeling. The CALMET modeling has already been completed by Earth Tech.

4.4 CALPUFF COMPUTATIONAL DOMAIN AND RECEPTORS

The computational domain is the same as the modeling domain as indicated above. The CALPUFF model will include the Class I receptors for each site as taken from the National Park Service Website. The website conversion program will be used to convert the receptor set into Lambert Conformal Coordinates (LCC) for use in the CALPUFF model.

4.5 CALPUFF MODELING OPTIONS SELECTIONS

All modeling option selections will be made as outlined in the Earth Tech provided sample CALPUFF modeling file as provided on the Earth Tech website which includes the VISTAS recommend version for BART modeling.

4.6 LIGHT EXTINCTION AND HAZE IMPACT CALCULATIONS

The light extinction and haze impact calculations will be completed by the CALPUFF model.

4.7 MODELING PRODUCTS

The output of the CALPOSTL modeling will be summarized in tables for presentation of the modeling results.

5. REVIEW PROCESS

5.1 CALMET FIELDS

As provided by VISTAS.

5.2 CALPUFF, CALPOST, AND POSTUTIL RESULTS

The initial run results will be based on the highest change in light extinction (deciviews) from natural conditions over the three-year period for each Class I area considered. Predicted concentrations exceeding the “contribution” threshold of 0.5 deciviews will trigger a finer grid CALPUFF modeling analysis. In the finer grid (4 km) modeling analysis the predicted visibility impairment that is compared to the threshold is based on the BART guidance of the 98th percentile change in deciviews value rather than the more conservative highest value used in the initial analysis.

6. REFERENCES

Protocol for the Application of the CALPUFF Model for Analyses of Best Available Retrofit Technology (BART)” December 22, 2005 revised March 9th, 2006.

Federal Land Managers’ Air Quality Related Values Workgroup (FLAG) Phase I report (December 2000).

APPENDICES

A.1 VISTAS BART MODELING PROTOCOL