



INITIAL DEMONSTRATION OF FUGITIVE EMISSIONS CONTROL SYSTEM PERFORMANCE

GLOBAL DISTRIBUTION CENTER

**Becton, Dickinson and Company
14201 Lochridge Blvd.
Covington, GA 30014**

**Ramboll US Corporation
1600 Parkwood Circle
Suite 310
Atlanta, Georgia 30339**

February 2021

TABLE OF CONTENTS

EXECUTIVE SUMMARY	1
1. BACKGROUND	2
2. TESTING ACTIVITES	3
3. ANALYTICAL LABORATORY RESULTS AND PERFORMANCE ASSESMENT	4
4. CONCLUSIONS	5

FIGURES

Figure 1: Site Location Map

TABLES

Table 1: System Airflow Rates
Table 2: System Ethylene Oxide Sample Results
Table 3: Performance Assessment

APPENDICES

Appendix A: Stack Testing Scope
Appendix B: Testing Subcontractor Final Report
Appendix C: Laboratory Analytical Report

EXECUTIVE SUMMARY

In fulfillment of obligations first set in a Consent Order with the Georgia Environmental Protection Division on October 28, 2019, amended on January 15, 2020, Becton, Dickinson and Company has installed a dry bed fugitive emission control system at its Covington, Georgia, Global Distribution Center facility for the reduction of potential emissions of ethylene oxide.

In accordance with the Test Plan, approved by EPD on December 16, 2020, the system has been tested to assess its performance and effectiveness. The testing has found that the emissions to the atmosphere of ethylene oxide from the system are consistent with the levels expected from the dry bed system outlet. The emission rate measured from the system outlet on December 31, 2020 was 123.8 pounds-per-year, if annualized over 8,760 hours.

It should be noted that this is the first known instance of applying emission controls for the reduction of potential fugitive emissions of ethylene oxide from a facility solely engaged in warehousing and distribution activities.

1. BACKGROUND

Becton, Dickinson and Company (BD) operates a medical products warehouse facility, referred to as the Global Distribution Center (GDC) at 14201 Lochridge Boulevard in Covington, Georgia (see **Figure 1**). BD uses the nearly 600,000 square foot warehouse facility to store products sterilized with ethylene oxide (EO) prior to distribution to medical facilities.

As a condition of a Consent Order with the Georgia Environmental Protection Division (EPD) dated October 28, 2019, BD has installed a system for the capture and control potential fugitive emissions of EO that may exist in the GDC. The new equipment includes three discrete systems comprised of 50 Advanced Air Technologies Model DR490 "Dry Bed Scrubbers." Details regarding the dry bed scrubber system were presented in the air permit application for its installation that was submitted to the EPD on October 31, 2019.

BD developed a test plan for the fugitive emissions control system. **Appendix A** provides the test plan methodology. The testing for the overall system was conducted on December 31, 2020. Both Ray Shen and Marcus Cureton from the EPD Stationary Source Compliance, Source Monitoring Unit were present to observe the testing activities.

2. TESTING ACTIVITIES

The testing program for assessing the effectiveness of the dry bed fugitive emission control system for fugitive releases captured in the warehouse facility was based on two primary elements:

1. Measurement of the airflow rate at three zones of the inlet ducts (Zone 2, Zone 3, and Zone 5) to the dry bed system and the stack outlet utilizing EPA standard methods 1, 2, and 4; and,
2. Measurement of the concentration of EO in three zones of the inlet ducts and the outlet stack.

Measurement of the airflow rates was conducted by Advanced Industrial Resources (AIR) of Acworth, Georgia, a qualified stack testing contractor.

Ramboll personnel oversaw and coordinated the EO sample collection during the testing. Air samples were collected in 6-liter Summa canisters individually tested and certified by the analytical laboratory to be free of EO. The samples were analyzed for EO via EPA Method TO-15 modified to achieve sub-part-per-billion (ppb) detection limits for EO.

The Test Plan presented in **Appendix A** was followed for the flow measurement and sample collection. As outlined in the Test Plan, a duplicate sample was collected at the system stack outlet to allow for assessment of precision and repeatability of analyses. The original and duplicate samples were collected simultaneously over a 4-hour duration from two separate segments of tubing introduced side-by-side in the sampling port.

3. ANALYTICAL LABORATORY RESULTS AND PERFORMANCE ASSESMENT

The collected samples were transferred to Eurofins Air Toxics, LLC (Eurofins), an independent laboratory in Folsom, California, with recognized expertise with EO analytical methods, for analysis using a modified EPA Method TO-15 with gas chromatography and mass spectrophotometer (GC/MS) in the Selective Ion Monitoring (SIM) acquisition mode to obtain detection limits sufficiently low for use in testing the dry bed system performance.

A duplicate sample collected from the system stack outlet was analyzed upon receipt at the laboratory to demonstrate the repeatability and precision of the sampling and analytical method.

Table 1 presents the airflow rate and moisture results from the EPA Method 1, 2, and 4 tests performed by AIR. AIR's complete report is provided as **Appendix B**. **Table 2** presents the EO concentration results from Eurofins. The complete laboratory report is provided as **Appendix C**, including results from the quality control assessments described above.

The testing and analytical work met quality assurance and quality control criteria set forth in the test plan. The measured EO concentrations in each sample were above the detection limits of the laboratory method – there were no “non-detect” results.

Table 3 combines the air flow and EO concentration data for an assessment of the performance of the dry bed fugitive emissions control system.

Performance Assessment

The dry bed fugitive emission control system at the GDC facility captures and treats fugitive EO releases from the warehouse where products sterilized with EO are stored prior to distribution to medical facilities. Total fugitive emission concentrations from three zones of the inlet ducts (Zone 2, Zone 3, and Zone 5) in the warehouse area ranged between 110 micrograms per cubic meter ($\mu\text{g}/\text{m}^3$) to 1,100 $\mu\text{g}/\text{m}^3$. The exhaust mass rate from the system stack was only 0.014 pounds per hour (lb/hour), or 123.8 pounds per year (lb/year) if annualized over 8,760 hours.


As shown in **Table 3**, the system is achieving a control device effectiveness of 92.95 percent reduction in fugitive ethylene oxide emissions from the warehouse facility.

4. CONCLUSIONS

The following conclusions can be drawn from this testing as an initial assessment of the performance of the dry bed fugitive emission control system at the GDC Covington facility:

1. Post-control-device emissions of EO from the system are 0.014 lb/hour.
2. The system is reducing EO emissions from the warehouse facility at a control device efficiency of 92.95 percent.
3. The Summa canister testing and analytical approach applied for this testing successfully allowed monitoring of EO concentrations that allowed calculation of control efficiency from the dry bed treatment systems and achieved all stability and precision objectives.

FIGURE



Map Scale: 1:24,000 | Map Center: 83°49'4"W 33°36'24"N

SITE LOCATION

FIGURE 1



KEY MAP (not to scale)

0 1,000 2,000 Feet

BD BARD GLOBAL DISTRIBUTION FACILITY
14201 LOCHRIDGE BOULEVARD
COVINGTON, GEORGIA

RAMBOLL US CONSULTING, INC.
A RAMBOLL COMPANY

RAMBOLL

TABLES

TABLE 1
System Air Flow Rates
Becton, Dickinson and Company
General Distribution Center
Covington, Georgia Facility

Sample ID	Sample Location	Pre-Test Flow Rate (dscfm)	Pre-Test Average Temperature (°F)	Post-Test Flow Rate (dscfm)	Post-Test Average Temperature (°F)	Average Flow Rate (dscfm)	Average Temperature (°F)
Emission Control System Testing - December 31, 2020							
SYS-S2 20201231	Zone 2 Inlet	44,496	63	44,729	64	44,613	64
SYS-S3 20201231	Zone 3 Inlet	33,275	63	34,237	63	33,756	63
SYS-S5 20201231	Zone 5 Inlet	14,717	71	14,464	71	14,591	71
SYS-STACK 20201231	SYS1 Out	104,347	68	102,327	72	103,337	70
Notes: Notes In : Pre and Post-Test average temperatures and airflow rates provided by Advanced Industrial Resources, Inc. (AIR). dscfm - dry standard cubic feet per minute dscfm In - dry standard cubic feet per							

TABLE 2
System Ethylene Oxide Sample Results
Becton, Dickinson and Company
General Distribution Center
Covington, Georgia Facility

Sample ID	Sample Location	Date	Start Time	Stop Time	Duration (hours)	Vacuum ¹		EO Concentration (µg/m ³)
						Initial (In. Hg)	Final (In. Hg)	
Emission Control System Testing - December 31, 2020								
SYS-S2 20201231	Zone 2 Inlet	12/31/2020	9:52	13:52	4:00	28.0	8.3	210
SYS-S3 20201231	Zone 3 Inlet	12/31/2020	9:52	13:52	4:00	26.5	7.8	1100
SYS-S5 20201231	Zone 5 Inlet	12/31/2020	9:52	13:52	4:00	28.0	6.5	110
SYS-STACK 20201231 ²	SYS1 Out	12/31/2020	9:52	13:52	4:00	27.5	6.5	36.5
Notes: ¹ Vacuum readings recorded in the field from the regulator gauge. ² The listed EO concentration is the average of duplicate samples - SYS-STACK 20201231 (36 µg/m ³) & SYS-STACK DUP 20201231 (37 µg/m ³). In. Hg - inches of mercury µg/m ³ - micrograms per cubic meter EO - Ethylene Oxide								

TABLE 3
Performance Assessment
Becton, Dickinson and Company
General Distribution Center
Covington, Georgia Facility

Sample ID	Sample Location	EO Concentration ($\mu\text{g}/\text{m}^3$)	Duct Flow (dscfm)	EO Rate (lb/hr)
Emission Control System Testing - December 31, 2020				
SYS-S2 20201231	Zone 2 Inlet	210	44,613	0.035
SYS-S3 20201231	Zone 3 Inlet	1100	33,756	0.139
SYS-S5 20201231	Zone 5 Inlet	110	14,591	0.006
SYS-STACK 20201231	SYS1 Out	36.5	103,337	0.014
Total Inlet			92,959	0.180
Flow-weighted average inlet ($\mu\text{g}/\text{m}^3$)				517.49
Notes: EO - Ethylene Oxide $\mu\text{g}/\text{m}^3$ - micrograms per cubic meter dscfm - dry standard cubic feet per meter lb/hr - pounds per hour				
			System Testing December 31, 2020	
Annual EO Input to Treatment System (lb/yr)			1579	
Annual Post-Treatment Emissions (lb/yr)			123.8	
Concentration-based percent removal			92.95	
Mass-based percent removal			92.16	

APPENDIX A

STACK TESTING SCOPE

Test Plan
for the
Performance Testing of the Fugitive Emissions Control System
at

Becton, Dickinson and Company
Global Distribution Center
14201 Lochridge Boulevard
Covington, Georgia 30014

Proposed Test Date:
31 December 2020

Submitted By:
Becton, Dickinson and Company

Table of Contents

	Page
I. Introduction	1
II. Process and Control Equipment Description and Operating Conditions	1
III. Dry Bed Validation Testing Plan	2
IV. Plant Entry and Safety	3

I. Introduction

Becton Dickinson (BD) is providing this test plan for the fugitive emissions control system proposed in the air permit application for the BD General Distribution Center (GDC) facility. Upon completion of the system installations and placement into service, the following testing will be conducted, consistent with the outline provided in Attachment F to the air permit application submitted on February 14, 2020.

The system's control efficiency for ethylene oxide (EO) will be tested and demonstrated on a concentration basis by withdrawing exhaust air from the ductwork at the inlet and outlet side of a dry bed system into Summa canisters in accordance with EPA Method TO-15.

Testing is scheduled to be performed December 31, 2020 at the BD GDC facility in Covington, Georgia. The purpose of the testing is to determine removal efficiency of EO by the dry bed fugitive emissions control system.

The services of a reputable contractor will be obtained to conduct the required testing. Mr. John LaMontagne, of BD, and other BD personnel, will provide on-site coordination of the testing.

II. Process and Control Equipment Description and Operating Conditions

The equipment being tested is for the control of fugitive emissions of EO at an existing warehousing distribution center facility where products that have been sterilized with EO are stored.

Testing for this equipment is specific to the emission control systems being installed to capture and treat fugitive emissions of EO. The new equipment to be tested includes a system comprised of multiple Advanced Air Technologies Model DR490 "Dry Bed Scrubbers." The collection system will capture potential emissions from three main zones of the facility where sterilized products are stored.

III. Dry Bed Validation Testing Plan

Analytical Methods

The samples will be collected in Summa canisters and analyzed using EPA Method TO-15 with GC/MS in the Selective Ion Monitoring (SIM) acquisition mode to determine the concentration of EO. Analysis will be performed by Eurofins Air Toxics, an independent laboratory. Results will be reported in units of micrograms per cubic meter ($\mu\text{g}/\text{m}^3$).

To accommodate the conditions relating to canister placement, sampling probes will be connected using flexible tubing (Teflon FEP, 1/4" OD), with the length not to exceed 5 feet.

A duplicate sample will be collected at the discharge stack from the combined duct of the dry bed system and submitted to the laboratory to be analyzed to evaluate the precision and repeatability of sample collection.

Initial Efficiency Assessment

The initial performance testing will be performed during the commissioning phase of system installation as follows:

- Sample duration – 4 hours.
- Three inlet sample locations from each of the three main ducts originating at three separate zones inside the facility.
- Outlet sample location at the discharge stack outside the facility.
- Samples will be collected at a single point within each corresponding stack or duct.
- Outlet stack airflow rate and moisture will be measured simultaneously by EPA Methods 1, 2, and 4.
- Velocity traverses of the inlet ducts will be performed periodically during the testing.

Control efficiency will be calculated based on the reduction in concentration of EO across the dry beds. Mass emission rate of EO (lb/hr) will be determined using the measured outlet concentration and airflow rate.

IV. Plant Entry and Safety

General safety rules must be adhered to when inside the GDC facility. Visitors must first sign in at the reception area at 14201 Lochridge Boulevard prior to admission to the GDC.

Entry to the GDC is restricted. John LaMontagne is responsible for this project. He can be reached at (770) 784-6186 (work) or (770) 652-2049 (cell).

APPENDIX B

TESTING SUBCONTRACTOR FINAL REPORT



ADVANCED INDUSTRIAL RESOURCES, INC.

***DRY BED SYSTEM
INITIAL DEMONSTRATION
AT
BECTON, DICKINSON AND COMPANY
GLOBAL DISTRIBUTION CENTER
PROJECT ID: KR-10629***

PREPARED FOR:



**BECTON, DICKINSON AND COMPANY
14201 LOCHRIDGE BLVD
COVINGTON, GA 30014**

PREPARED BY:

**ADVANCED INDUSTRIAL RESOURCES, INC.
3407 NOVIS POINTE
ACWORTH, GEORGIA 30101**

**TEST DATE:
DECEMBER 31, 2020**

TABLE OF CONTENTS

<u>1.0</u>	<u>INTRODUCTION</u>	<u>1</u>
1.1	SUMMARY OF TEST PROGRAM	1
1.2	KEY PERSONNEL	1
<u>2.0</u>	<u>PLANT AND SAMPLING LOCATION DESCRIPTIONS</u>	<u>2</u>
2.1	PROCESS DESCRIPTION AND OPERATION	2
2.2	SAMPLING LOCATIONS	2
<u>3.0</u>	<u>SUMMARY AND DISCUSSION OF TEST RESULTS</u>	<u>4</u>
3.1	OBJECTIVES	4
3.2	FIELD TEST CHANGES AND PROBLEMS	4
3.3	PRESENTATION OF RATA TEST RESULTS	4
<u>4.0</u>	<u>SAMPLING AND ANALYTICAL PROCEDURES</u>	<u>5</u>
<u>5.0</u>	<u>QUALITY ASSURANCE ACTIVITIES</u>	<u>6</u>
5.1	INTERNAL QUALITY ASSURANCE	6
5.1.1	SAMPLING TRAIN LEAK CHECKS	6
5.1.2	PROBE NOZZLE DIAMETER CHECKS	7
5.1.3	PITOT TUBE FACE PLANE ALIGNMENT CHECK	7
5.1.4	METERING SYSTEM CALIBRATION	7
5.1.5	TEMPERATURE GAUGE CALIBRATION	7
5.1.6	DATA REDUCTION CHECKS	8
<u>6.0</u>	<u>DATA QUALITY OBJECTIVES</u>	<u>9</u>

LIST OF APPENDICES

APPENDIX A

TEST RESULTS

APPENDIX B

EXAMPLE CALCULATIONS AND NOMENCLATURE

APPENDIX C

FIELD DATA

APPENDIX D

CALIBRATION DATA

1.0 INTRODUCTION

1.1 SUMMARY OF TEST PROGRAM

Becton, Dickinson and Company (BD) operates a medical products warehouse facility (Global Distribution Center (GDC)) located at 14201 Lochridge Blvd, Covington, GA 30014. Products already sterilized with ethylene oxide (EO) gas are shipped to this facility from various sterilization plants in preparation for distribution to medical facilities. The warehouse recently installed three (3) dry bed systems designed to control fugitive ethylene oxide emissions from the interior of the facility.

A performance test of the dry bed systems was conducted on December 31st, 2020 by Ramboll US Consulting, Inc. (Ramboll) and Advanced Industrial Resources, Inc. (AIR) in accordance with approved USEPA Methods (i.e., 40 CFR 60 Appendix A, Methods 1, 2, 4, and 18). The purpose of the performance test was to establish the newly installed control systems' ethylene oxide removal efficiencies. Testing was conducted by quantifying the inlet loading of ethylene oxide to the dry bed systems and simultaneously quantifying the emission rate of ethylene oxide at the outlet of the respective dry bed systems. U.S. EPA Methods 1, 2, 4, and 18 were used to conduct testing

1.2 KEY PERSONNEL

The key personnel who coordinated the test program and their telephone numbers are:

Keith A. Cole, P.E., <i>Ramboll</i> , Sr. Managing Consultant	678-388-1648
Derek Stephens, <i>AIR</i> , VP/QA Director	404-843-2100
Stephen Wilson, <i>AIR</i> , Chief Operations Officer	404-403-6079
Scott Wilson, <i>AIR</i> , Program Director	800-224-5007

2.0 PLANT AND SAMPLING LOCATION DESCRIPTIONS

2.1 PROCESS & CONTROL EQUIPMENT DESCRIPTION

BD operates a medical products warehouse facility in Covington, Georgia. Products already sterilized with ethylene oxide (EO) gas are shipped to this facility from various sterilization plants in preparation for distribution to medical facilities around the country. The warehouse recently installed three (3) dry bed systems designed to control fugitive ethylene oxide emissions from the interior of the facility.

2.2 SAMPLING LOCATION

Each sampling location has a circular cross section with at least two (2) sampling ports oriented 90 degrees from one another. The sampling locations are located at least two (2) equivalent diameters downstream from the nearest upstream flow disturbance and at least one-half (0.5) equivalent diameters upstream from the nearest downstream flow disturbance. In accordance with EPA Method 1, a minimum of sixteen (16) total traverse points (≥ 8 per port) were used to measure velocities within the respective ducts via EPA Method 2. The centroids of the respective ducts were used to collect the ethylene oxide samples. The following table summarizes the sampling location diameters, up- and down-stream flow disturbance distances, and quantity of traverse points used to conduct Method 2 velocity measurements.

Source	Stack diameter (Ds)	Downstream flow disturbance distance (A)		Downstream flow disturbance distance (B)		Traverse Points (per port)
	inches	inches	equiv. diameter	inches	equiv. diameter	
Outlet	75.0	576	7.7	265	3.5	16 (8)
Zone 2 Inlet	68.0	48	0.7	140	2.1	24 (12)
Zone 3 Inlet	56.0	18.0	0.3	18.0	0.3	16 (8)
Zone 5 Inlet	37.5	85.0	2.3	72.0	1.3	16 (8)

3.0 SUMMARY AND DISCUSSION OF TEST RESULTS

3.1 OBJECTIVES

The purpose of the initial performance test was to establish the newly installed control systems' EO removal efficiencies. Testing was conducted by quantifying the inlet loading of ethylene oxide to three separate dry bed systems and simultaneously quantifying the emission rate of ethylene oxide at the collective outlet of the combined system.

3.2 FIELD TEST CHANGES AND PROBLEMS

No problems were encountered during testing that required deviation from the planned test protocol.

3.3 PRESENTATION OF TEST RESULTS

Volumetric flow rates and associated data are presented in Appendix A. Actual raw field data sheets are presented in Appendix C.

4.0 SAMPLING AND ANALYTICAL PROCEDURES

Testing was performed in accordance with 40 *CFR* 60 Appendix A. Specifically:

- EPA Method 1 was used for the qualification of the location of sampling ports and for the determination of the number and positions of stack traverse points, as applicable to sample traverses for EPA Method 2.
- EPA Method 2 was employed for the determination of the stack gas velocity and volumetric flow rate during sampling using Type “S” Pitot tubes. EPA Method 2 was conducted prior to and at the conclusion of the single ethylene oxide sample period and the average of the two (2) traverses, per sample location, were used to determine the volumetric flow rate used for calculating the mass rate (lb/hr) of ethylene oxide. The pre- and post-test velocity traverses for each sample location varied by less than 10%.
- EPA Method 3 was used for the calculation of the density and dry molecular weight of the effluent stack gas. The gas streams were assumed to be at ambient conditions (20.9% O₂, 0.0% CO₂).
- EPA Method 4 was employed for the determination of the stack gas moisture content of the respective system exhaust stacks. A single test run was conducted on each stack which lasted the duration of the test run (240 min.). Wet bulb/dry bulb measurements were conducted on the inlet ducts to determine moisture content.

5.0 QUALITY ASSURANCE ACTIVITIES

5.1 INTERNAL QUALITY ASSURANCE

The quality assurance/quality control (QA/QC) measures associated with the sampling and analysis procedures given in the noted EPA reference methodologies, in Subparts A of 40 *CFR* 60 and 40 *CFR* 63, and in the *EPA QA/QC Handbook*, Volume III (EPA 600/R-94/038c) were employed, as applicable. Such measures include, but are not limited to, the procedures detailed below.

5.1.1 SAMPLING TRAIN LEAK CHECKS

Determinations of the leakage rate of the Method 4 sampling trains were made before and after each sampling run using the procedure detailed in Section 8.13.2 of EPA Method 4. Before the sampling run, after the sampling trains had been assembled and probe and filter box temperatures had time enough to settle at their appropriate operating values, the probe inlet was plugged and the system was evacuated to a pressure of 15 inches of Hg below ambient pressure. The volumetric leakage rate was measured by the dry gas meter over the course of one (1) minute. The leakage rate was less than 0.020 cfm for each run, thereby meeting the maximum allowable leakage rate.

After the sampling run, before the train was disassembled the probe inlet was plugged and the system depressurized to a vacuum equal to or greater than the maximum value reached during the sampling run. The dry gas meter measured the volumetric leakage rate over the course of one (1) minute. The leakage rate was determined to be less than 0.020 cfm, thereby meeting the maximum allowable leakage rate.

The Type "S" Pitot tube assemblies were also checked for leaks before and after sampling runs using the procedure in Section 8.1 of EPA Method 2. The impact opening of the Pitot tubes were blown through until a pressure of at least 3 inches of water registered on the manometer. The impact opening was quickly plugged and held for at least 15 seconds, during which time the manometer reading held. The same operation was performed on the static pressure side of the Pitot tubes, except suction was used to obtain the pressure differential.

5.1.2 PROBE NOZZLE DIAMETER CHECKS

No probe nozzles were used during this test program.

5.1.3 PITOT TUBE FACE PLANE ALIGNMENT CHECK

Before field testing, each Type S Pitot tube was examined in order to verify that the face planes of the tube were properly aligned, per Method 2 of 40 *CFR* 60, Appendix A. The external tubing diameter and base-to-face plane distances were measured in order to verify the use of 0.84 as the baseline (isolated) Pitot coefficient. At that time the entire probe assembly (i.e., the sampling probe, nozzle, thermocouple, and Pitot tube) was inspected in order to verify that its components met the interference-free alignment specifications given in EPA Method 2. Because the specifications were met, then the baseline Pitot coefficient was used for the entire probe assembly.

After field testing, the face plane alignment of each Pitot tube was checked. No damage to the tube orifices was noted.

5.1.4 METERING SYSTEM CALIBRATION

Every three months each dry gas meter (DGM) console is calibrated at five orifice settings according to Method 5 of 40 *CFR* 60, Appendix A. From the calibration data, calculations of the values of Y_m and $\Delta H_@$ are made, and an average of each set of values is obtained. The limit of total variation of Y_m values is ± 0.02 , and the limit for $\Delta H_@$ values is ± 0.20 .

After field testing, the calibration of the DGM console was checked by performing three calibration runs at a single intermediate orifice setting that is representative of the range used during field-testing. Each DGM was within the limit of acceptable relative variation from Y_m of 5.0%.

5.1.5 TEMPERATURE GAUGE CALIBRATION

After field testing, the temperature measuring instruments on each sampling train was calibrated against standardized mercury-in-glass reference thermometers. Each indicated temperature was within the limit of acceptable variation between the absolute reference temperature and the absolute indicated temperature of 1.5%.

5.1.6 DATA REDUCTION CHECKS

AIR ran an independent check (using a validated computer program) of the calculations with predetermined data before the field test, and the *AIR* Team Leader conducted spot checks on-site to assure that data was being recorded accurately. After the test, *AIR* checked the data input to assure that the raw data had been transferred to the computer accurately. Flow rates, temperatures and moisture levels were relatively constant (variation <5%) during the three test runs, which indicates that data recording and Method 2 and 4 sampling and calculation errors are not likely.

6.0 DATA QUALITY OBJECTIVES

The data quality objectives (DQOs) process is generally a seven-step iterative planning approach to ensure development of sampling designs for data collection activities that support decision making. The seven steps are as follows: (1) defining the problem; (2) stating decisions and alternative actions; (3) identifying inputs into the decision; (4) defining the study boundaries; (5) defining statistical parameters, specifying action levels, and developing action logic; (6) specifying acceptable error limits; and (7) selecting resource-effective sampling and analysis plan to meet the performance criteria. The first five steps are primarily focused on identifying qualitative criteria such as the type of data needed and defining how the data will be used. The sixth step defines quantitative criteria and the seventh step is used to develop a data collection design. In regards to emissions sampling, these steps have already been identified for typical monitoring parameters.

Monitoring methods presented in 40 *CFR* 60 Appendix A indicate the following regarding DQOs: Adherence to the requirements of this method will enhance the quality of the data obtained from air pollutant sampling methods. At a minimum, each method provides the following types of information: summary of method; equipment and supplies; reagents and standards; sample collection, preservation, storage, and transportation; quality control; calibration and standardization; analytical procedures, data analysis and calculations; and alternative procedures. These test methods have been designed and tested according to DQOs for emissions testing and analysis.

APPENDIX A

TEST RESULTS

Advanced Industrial Resources
 BD Bard - Covington, Georgia
 Flow Summary

Dry Bed System									
Inlets					Outlet				
Source	Pre	Post	Average	Units	Source	Pre	Post	Average	Units
Zone 2 Inlet	44,496	44,729	44,612	dscfm	Outlet	104,347	102,327	103,337	dscfm
Zone 3 Inlet	33,275	34,237	33,756	dscfm	Total	104,347	102,327	103,337	dscfm
Zone 5 Inlet	14,717	14,464	14,591	dscfm					
Total	92,488	93,430	92,959	dscfm					

APPENDIX B

EXAMPLE CALCULATIONS

AND

NOMENCLATURE

EXAMPLE CALCULATIONS

$$A_n = D_n^2 \pi / 4$$

$$A_s = D_s^2 \pi / 4$$

$$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$$

$$c_{\text{analyte}} = (m_{\text{analyte}} / V_{m(std)}) (35.31466 \text{ ft}^3/\text{m}^3)$$

$$'c_{\text{analyte}} = (m_{\text{analyte}} / V_{m(std)}) (0.015432 \text{ gr/mg})$$

$$c_{\text{analyte}} = 'c_{\text{analyte}} \text{ MW}_{\text{analyte}} / 24.04 \text{ l/mol}$$

$$CC = t_{0.975} (S_d / n^{1/2})$$

$$d = 1/n (S_{di})$$

$$DE = (E_{\text{Inlet}} - E_{\text{Outlet}}) / E_{\text{Inlet}} \times 100\%$$

$$E_{\text{analyte}} = (m_{\text{analyte}} / V_{m(std)}) Q_{sd} (60 \text{ min/hr}) (2.2046 \times 10^{-6} \text{ lb./mg})$$

$$E_{\text{analyte}} = c_{\text{analyte}} Q_{sd} (60 \text{ min/hr}) (2.2046 \times 10^{-6} \text{ lb./mg})$$

$$I = 100 T_s (K_3 V_{lc} + Y_m V_m P_m / T_m) / (60 \theta v_s P_s A_n)$$

$$\text{where } K_3 = 0.002669 (\text{in. Hg ft}^3) / (\text{mL } ^\circ\text{R})$$

$$K_I = [(2.0084 \times 10^7 \Delta H_{@}) A_n (1 - B_{ws})]^2 (M_d / M_s) (T_m / T_s) (P_s / P_m)$$

$$M_d = 0.44 (\% \text{ CO}_2) + 0.32 (\% \text{ O}_2) + 0.28 (\% \text{ N}_2 + \% \text{ CO})$$

$$M_s = M_d (1 - B_{ws}) + M_w B_{ws}$$

$$P = Q_{sd} / \text{F-Factor} \times 60 \times (20.9 - \text{O}_2) / 20.9$$

$$P_m = P_{\text{bar}} + \Delta H / 13.6$$

$$P_s = P_{\text{bar}} + p_g / 13.6$$

$$Q_a = (60 \text{ s/min}) v_s A_s$$

$$Q_{sd} = (60 \text{ s/min}) (1 - B_{ws}) v_s A_s (T_{std} / T_s) (P_s / P_{std})$$

$$RA = [\text{Abs}(d) + \text{Abs}(CC)] / RM$$

$$S_d = [(S_{di}^2 - (S_{di})^2/n)/(n-1)]^{1/2}$$

$$T_m = t_m + 460^\circ$$

$$T_s = t_s + 460^\circ$$

$$V_{m(std)} = V_m Y_m (T_{std} / T_m) (P_m / P_{std})$$

$$V_{w(std)} = (V_{lc} \rho_w R T_{std}) / (M_w P_{std})$$

$$v_s = K_p C_p [\Delta p]^{1/2} [T_s / (P_s M_s)]^{1/2}$$

NOMENCLATURE

Symbol	Units	Description
Abs(x)	dimensionless	Absolute value of parameter x
A_n	ft ²	Area of the nozzle
A_s	ft ²	Area of the stack
B_{ws}	dimensionless	Volume proportion of water in the stack gas stream
C_p	dimensionless	Type S pitot tube coefficient
C_{analyte}	mg/dscm	Concentration of analyte in dry stack gas, standardized
'C_{analyte}	gr./dscf	Concentration of analyte in dry stack gas, standardized
'C_{analyte}	ppm	Concentration of analyte in dry stack gas, standardized
CC	dimensionless	One-tailed 2.5% error confidence coefficient
d	ppm	Arithmetic mean of differences
d_i	ppm	Difference between individual CEM and reference method concentration value
D_n	inches	Internal diameter of the nozzle at the entrance orifice
D_s	inches	Internal diameter of the stack at sampling location
DE	percent	Destruction efficiency
UH	inches H ₂ O	Average pressure differential across the meter orifice
UH_@	inches H ₂ O	Orifice pressure differential that corresponds to 0.75 cfm of air at 68 °F and 29.92 inches of Hg
U_p	inches H ₂ O	Velocity head of stack gas
E_{analyte}	lb./hour	Emission rate of analyte, time basis
I	percent	Isokinetic sampling ratio expressed as percentage
K_I	dimensionless	K-factor, ratio of DH to DP, ideal
K_p	ft[(lb/lb-mol)(in. Hg)] ^{1/2}	Type S pitot tube constant,
	s[(°R)(in. H ₂ O)] ^{1/2}	= 85.49
L_p	cfm	Measured post-test leakage rate of the sampling train
M_d	lb./lb.-mole	Molecular weight of gas at the DGM
M_s	lb./lb.-mole	Molecular weight of gas at the stack

NOMENCLATURE

Symbol	Units	Description
M_w	lb./lb.-mole	Molecular weight of water,
		= 18.0
m_{analyte}	mg	Mass of analyte in the sample
n	dimensionless	Number of data points
P	MMBtu	Fuel firing rate
P_{bar}	inches Hg	Barometric pressure at measurement site
P_{input}	tons/hour	Process dry mass input rate
p_g	inches H ₂ O	Gauge (static) pressure of stack gas
P_m	inches Hg	Absolute pressure of meter gases
P_s	inches Hg	Absolute pressure of stack gases
P_{std}	inches Hg	Standard absolute pressure
		= 29.92
Q_a	cfm	Volumetric flow rate of actual stack gas
Q_{sd}	dscfm	Volumetric flow rate of dry stack gas, standardized
R	(in. Hg)(ft ³)	Ideal gas constant,
	(lb-mole)(°R)	= 21.85
RA	percent	Relative accuracy
RE	percent	Removal efficiency
RM	ppm	Average reference method concentration
r_w	lb/mL	Density of water,
		= 0.002201
r_a	g/mL	Density of acetone,
		= 0.7899
S_d	dimensionless	Standard deviation
T_m	°R	Absolute temperature of dry gas meter
T_s	°R	Absolute temperature of stack gas
T_{std}	°R	Standard absolute temperature,
		= 528
t_{0.975}	dimensionless	2.5 percent error t-value
t_m	°F	Temperature of DGM
t_s	°F	Temperature of stack gas
t₁	minutes	Total sampling time

NOMENCLATURE

Symbol	Units	Description
V_{lc}	mL	Total volume of liquid collected
V_m	dcf	Volume of gas sample as measured by the DGM
$V_{m(std)}$	dscf	Volume of gas sample as measured by the DGM, standardized
$V_{w(std)}$	scf	Volume of water vapor in the gas sample, standardized
v_s	ft./sec	Velocity of stack gas
Y_m	dimensionless	DGM calibration coefficient
Y_c	dimensionless	DGM calibration check value
Y_w	dimensionless	Reference (wet) gas meter calibration coefficient
% CO ₂	percent	Percent CO ₂ by volume, dry basis
% O ₂	percent	Percent O ₂ by volume, dry basis
% N ₂	percent	Percent N ₂ by volume, dry basis

APPENDIX C

FIELD DATA

Advanced Industrial Resources

Moisture Measurements & Calculations

<u>Input values:</u>		Run Number			
		outlet	Inlet 2	Inlet 3	Inlet 5
T _{db}	F	68	63	63	71
T _{wb}	F	54	52	52	60
P _g	in H ₂ O	0.71	0.00	0.00	1.30
P _{bar}	in Hg	20.9	20.9	20.9	20.9
O ₂	%	20.9	20.9	20.9	20.9
CO ₂	%	0.0	0.0	0.0	0.0

<u>Calculated values:</u>					
P	in Hg	20.95	20.90	20.90	21.00
MW _{air}	lb/mol	28.84	28.84	28.84	28.84
p _{sat}	in Hg	0.42	0.39	0.39	0.52
p	in Hg	0.31	0.31	0.31	0.44
H	lb H ₂ O/lb air	0.0094	0.0093	0.0093	0.0132
B_{ws}		0.015	0.015	0.015	0.021

Note: % O₂ and % CO₂ are not important variables. Use 21% and 0% if values have not been measured.

Advanced Industrial Resources
BD Bard - Covington, Georgia
Moisture Measurements & Calculations
Outlet

Test Team: JL, LS
EPA Methods: 4
Test Date: December 31, 2021
Console ID: C-018

Measured values:

P_{bar} (in. Hg): 29.45
p_g (in. H₂O): 0.71
Y_m 1.029
Probe Assembly ID:

Moisture Run Run #1
Used for flow runs: 1, 2 & 3
Water recovery (ml): 9
Start 0
Stop 172.795
Sample volume (cf): 172.795
Meter temperature (F): 63.0

Calculations:

Moisture volume, V_w = 0.42 scf = ml x 0.04715
Sample volume, V_s = 177.00 scf = V_m x Y_m x {528 / (T_m + 460)} x {(P_{bar} + P_g / 13.6) / 29.92}
Moisture content, B_{ws} = 0.24 % = V_w / (V_w + V_s)

OUTLET

Advanced Industrial Resources
BD Bard - Covington, Georgia
Flow Measurements & Calculations

Outlet
Pre-Test

Test Team:	JL, LS	Measured values:	
EPA Methods:	1,2	D_s (in.):	75.00
Test Date:	December 31, 2020	P_{bar} (in. Hg):	29.95
Console ID:	C-018	p_g (in. H₂O):	0.71
Y_m	1.029	O₂ (%):	20.90
Probe Assembly ID:	P7-02	CO₂ (%):	0.00
Cp:	0.84	B_{ws} (%):	2.4
		Test Time:	

Point	Δp (" H ₂ O)	$(\Delta p)^{1/2}$	t _s (°F)
1	1.50	1.225	68
2	1.55	1.245	69
3	1.40	1.183	68
4	1.40	1.183	69
5	1.20	1.095	68
6	1.10	1.049	68
7	0.88	0.938	69
8	0.86	0.927	69
9	0.84	0.917	68
10	0.84	0.917	67
11	0.82	0.906	67
12	0.81	0.900	68
13	1.40	1.183	68
14	1.55	1.245	67
15	1.45	1.204	67
16	1.20	1.095	68
17	1.00	1.000	68
18	0.90	0.949	69
19	0.87	0.933	69
20	0.85	0.922	68
21	0.86	0.927	67
22	0.84	0.917	67
23	0.83	0.911	67
24	0.80	0.894	68
Average	1.07	1.028	68

Calculations:

Molar weight, M_s =	28.58 lb/mol	$= \{ (\%O_2 \times 32) + (\%CO_2 \times 44) + (\%N_2 \times 28) \} \times (1 - B_{ws}/100) / (100 + B_{ws}/100 \times 18)$
Velocity, v_s =	57.91 ft/sec	$= 85.49 C_p \times (\Delta p)^{1/2} \times \{ (t_s + 460) / (P_{bar} + p_g / 13.6) / M_s \}^{1/2}$
Flow Rate, Q_{s,ds} =	104,347 dscfm	$= v_s \pi D_s^2 / 4 / 144 \times 60 \times (t_{std} + 460) / (t_s + 460) \times (P_{bar} + p_g / 13.6) / 29.92 \times (1 - B_{ws}/100)$
Flow Rate, Q_{s,act} =	106,603 acfm	$= v_s \pi D_s^2 / 4 / 144 \times 60$
Flow Rate, Q_{s,std} =	106,904 scfm	$= v_s \pi D_s^2 / 4 / 144 \times 60 \times (t_{std} + 460) / (t_s + 460) \times (P_{bar} + p_g / 13.6) / 29.92$

Advanced Industrial Resources
BD Bard - Covington, Georgia
Flow Measurements & Calculations
Outlet
Post-Test

Test Team:	JL LS	Measured values:	
EPA Methods:	1, 2, 3A & 4	D_s (in.):	75.00
Test Date:	December 31, 2020	P_{bar} (in. Hg):	29.95
Console ID:	C-018	p_g (in. H₂O):	0.71
Y_m	1.029	O₂ (%):	20.90
Probe Assembly ID:	P7-02	CO₂ (%):	0.00
Cp:	0.84	B_{ws} (%):	2.4
		Test Time:	

Point	Δp (in H ₂ O)	$(\Delta p)^{1/2}$	t _s (°F)
1	1.35	1.162	71
2	1.30	1.140	71
3	1.40	1.183	72
4	1.15	1.072	72
5	1.10	1.049	72
6	0.97	0.985	71
7	0.90	0.949	72
8	0.86	0.927	72
9	0.84	0.917	72
10	0.85	0.922	72
11	0.82	0.906	72
12	0.81	0.900	72
13	1.35	1.162	71
14	1.50	1.225	71
15	1.40	1.183	72
16	1.25	1.118	72
17	1.05	1.025	72
18	0.94	0.970	71
19	0.86	0.927	71
20	0.85	0.922	72
21	0.84	0.917	72
22	0.83	0.911	71
23	0.81	0.900	71
24	0.81	0.900	71
Average	1.04	1.011	72

Calculations:			
Molar weight, M_s =	28.58 lb/mol	$= \{ (\%O_2 \times 32) + (\%CO_2 \times 44) + (\%N_2 \times 28) \} \times (1 - B_{ws}/100) / (100 + B_{ws}/100 \times 18)$	
Velocity, v_s =	57.18 ft/sec	$= 85.49 C_p \times (\Delta p)^{1/2} \times \{ (t_s + 460) / (P_{bar} + p_g / 13.6) / M_s \}^{1/2}$	
Flow Rate, Q_{s,ds} =	102,327 dscfm	$= v_s \pi D_s^2 / 4 / 144 \times 60 \times (t_{std} + 460) / (t_s + 460) \times (P_{bar} + p_g / 13.6) / 29.92 \times (1 - B_{ws} / 100)$	
Flow Rate, Q_{s,act} =	105,257 acfm	$= v_s \pi D_s^2 / 4 / 144 \times 60$	
Flow Rate, Q_{s,std} =	104,834 scfm	$= v_s \pi D_s^2 / 4 / 144 \times 60 \times (t_{std} + 460) / (t_s + 460) \times (P_{bar} + p_g / 13.6) / 29.92$	

Advanced Industrial Resources, Inc.

Field Data Sheet

Client: Ramboll GDL
 Location: Covington, GA
 Source: Outlet
 Test Team: SS
 EPA Methods: 1, 2
 D_s (in.): 75
 % O₂: 21
 % CO₂: 0
 Start Run: 0915
 End Run: 0928
 Run Number: Pre-test

Test Date: 12/31/20
 Console ID: C-18
 Y_m / ΔH_@: 1.029/1.883
 Sampling Box ID: —
 Probe Assembly ID: P7-02
 D_n (in.): —
 Assumed B_{ws}: —
 P_{bar} (in. Hg): 29.45
 p_g (in. H₂O): 0.71
 Minutes/Point: —
 K-Factor: —

		Inches H ₂ O		Temperature Readings (°F)							
Point	Meter (dcf)	Δp	ΔH	t _s	Probe	Filter Box	Last Impinger	t _m		Filter Exit (M5 or CPM)	Vacuum (in. Hg)
								Inlet	Outlet		
1		1.50		68							
2		1.53		69							
3		1.40		68							
4		1.40		69							
5		1.20		69							
6		1.10		68							
7		0.88		68							
8		0.86		69							
9		0.84		69							
10		0.84		68							
11		0.82		67							
12		0.81		68							
Change Ports											
1		1.40		68							
2		1.55		67							
3		1.45		67							
4		1.20		68							
5		1.00		68							
6		0.90		69							
7		0.87		69							
8		0.85		68							
9		0.86		67							
10		0.84		67							
11		0.83		67							
12		0.80		68							
End											

Moisture Collected (g)			
	Initial	Final	Net
Body:			
Silica Gel:	200.0		
Gel Number:		Total:	

Silica Gel Desc. (initial): _____
 Silica Gel Desc. (final): _____
 Test Team Leader Review: _____
 Data Entry Review: AW

Pre-Run Leak Checks (dcfm @ "Hg)
 Sampling Line: _____
 Pitot A: ✓
 Pitot B: ✓

Post-Run Leak Checks (dcfm @ "Hg)
 Sampling Line: _____
 Pitot A: ✓
 Pitot B: ✓

Reagent 1: _____ Lot No: _____
 Reagent 2: _____ Lot No: _____

Advanced Industrial Resources, Inc.

Field Data Sheet

Client: Ramboll - GDC
 Location: Covington, GA
 Source: Outlet
 Test Team: SS
 EPA Methods: 1,2
 D_s (in.): 75
 % O₂: 21
 % CO₂: 0
 Start Run: 1355
 End Run: 1405
 Run Number: Post-test

Test Date: 12/31/20
 Console ID: C-18
 Y_m / ΔH_@: 1.029 / 1.883
 Sampling Box ID: —
 Probe Assembly ID: P7-02
 D_n (in.): —
 Assumed B_{w3}: —
 P_{bar} (in. Hg): 29.45
 p_g (in. H₂O): 0.72
 Minutes/Point: —
 K-Factor: —

		Inches H ₂ O		Temperature Readings (°F)							
Point	Meter (dcf)	Δp	ΔH	t _s	Probe	Filter Box	Last Impinger	t _m		Filter Exit (MS or CPM)	Vacuum (in. Hg)
								Inlet	Outlet		
1		1.35		71							
2		1.30		71							
3		1.40		72							
4		1.15		72							
5		1.10		72							
6		0.97		71							
7		0.90		72							
8		0.86		72							
9		0.84		72							
10		0.85		72							
11		0.82		72							
12		0.81		72							
Change Ports											
1		1.35		71							
2		1.50		71							
3		1.40		72							
4		1.25		72							
5		1.05		72							
6		0.94		71							
7		0.86		71							
8		0.85		72							
9		0.84		72							
10		0.83		71							
11		0.81		71							
12		0.81		71							
End											

Moisture Collected (g)			
	Initial	Final	Net
Body:			
Silica Gel:	200.0		
Gel Number:		Total:	

Silica Gel Desc. (initial): _____
 Silica Gel Desc. (final): _____
 Test Team Leader Review: _____
 Data Entry Review: SS

Pre-Run Leak Checks (dcfm @ "Hg)
 Sampling Line: _____ @ _____
 Pitot A: ✓
 Pitot B: ✓

Post-Run Leak Checks (dcfm @ "Hg)
 Sampling Line: _____ @ _____
 Pitot A: ✓
 Pitot B: ✓

Reagent 1: _____ Lot No: _____
 Reagent 2: _____ Lot No: _____

Advanced Industrial Resources, Inc.

Field Data Sheet

Client: Ramboll-GDC
 Location: Covington, GA
 Source: Outlet
 Test Team: SS
 EPA Methods: 1-4
 D_s (in.): 75
 % O₂: 21
 % CO₂: 0
 Start Run: 0952
 End Run: 1352
 Run Number: ①

Test Date: 12/31/20
 Console ID: C-18
 Y_m / ΔH_@: 1.029 / 1.883
 Sampling Box ID: —
 Probe Assembly ID: —
 D_n (in.): —
 Assumed B_{ws}: —
 P_{bar} (in. Hg): 29.45
 P_g (in. H₂O): 0.71
 Minutes/Point: 10
 K-Factor: —

Point	Meter (def)	Inches H ₂ O		Temperature Readings (°F)							Filter Exit (M5 or CPM)	Vacuum (in. Hg)
		Δp	ΔH	t _s	Probe	Filter Box	Last Impinger	t _m				
1	0.000		1.88		N/A	N/A	40	46	46	N/A		3
2	7.18						41	48	48			3
3	14.35						41	52	52			3
4	21.58						41	55	55			3
5	28.83						42	57	57			3
6	36.04						42	59	59			3
7	43.21						43	61	61			3
8	50.44						43	61	61			3
9	57.56						43	62	62			3
10	64.92						43	63	63			3
11	72.05						44	63	63			3
12	79.23						44	63	63			3
Change Ports												
1	86.40						44	63	63			3
2	93.64						44	63	63			3
3	100.81						45	63	63			3
4	108.10						45	63	63			3
5	115.23						45	64	64			3
6	122.41						46	64	64			3
7	129.66						46	64	64			3
8	136.83						46	64	64			3
9	144.05						45	64	64			3
10	151.26						45	64	64			3
11	158.52						45	64	64			3
12	165.61						45	64	64			3
End	172.795											

Moisture Collected (g)

	Initial	Final	Net
Body:	200	206	6
Silica Gel:	200.0	203	3
Gel Number:		Total:	9

Pre-Run Leak Checks (dcfm @ "Hg)
 Sampling Line: 0.003 @ 8"
 Pitot A: ✓
 Pitot B: ✓

Post-Run Leak Checks (dcfm @ "Hg)
 Sampling Line: 0.003 @ 8"
 Pitot A: ✓
 Pitot B: ✓

Silica Gel Desc. (initial): Blue
 Silica Gel Desc. (final): Amber
 Test Team Leader Review: —
 Data Entry Review: —

Reagent 1: — Lot No: —
 Reagent 2: — Lot No: —

Advanced Industrial Resources, Inc.
Cyclonic Flow Absence Verification Field Data
EPA Method 1

Client: Ramboll, GDC
 Location: Covington, GA
 Source: Outlet
 Test Team: SS
 Probe ID: P7-02
 C_p: 0.84

Date: 12/31/20
 D_s (in.): 75
 A_s (ft²): 30.68
 D_n (in.): —
 A_n (ft²): —

t_m (°F): 60
 Console ID: C-18
 Y_m: 1.029
 ΔH_@: 1.883
 Assumed B_{ws}: —
 P_{bar} (in. Hg): 29.45

Point	Δp (in. H ₂ O)	α (degrees)
1	0.0	0
2	0.0	5
3	0.0	0
4	0.0	0
5	0.0	0
6	0.0	5
7	0.0	5
8	0.0	0
9	0.0	0
10	0.0	0
11	0.0	0
12	0.0	5
Change Ports		
1	0.0	0
2	0.0	5
3	0.0	5
4	0.0	0
5	0.0	0
6	0.0	0
7	0.0	0
8	0.0	0
9	0.0	5
10	0.0	0
11	0.0	0
12	0.0	0

Test Team Leader Review: _____
 Data Entry Review: _____

Advanced Industrial Resources, Inc.

Source Description Sheets

Client: Ramboll GDC
 Location: Covington, GA
 Source: Outlet


Date: 12/31/20
 Test Team: SS,

D_n (in.): —
 A_n (ft²): —
 D_s (in.): 75
 A_s (ft²): 30.68
 Length A (in.): 576
 Length B (in.): 245
 t_{amb} (°F): 50
 Assumed B_{ws} : —
 P_{bar} (in. Hg): 29.45
 P_g (in. H₂O): 0.71
 % O₂: 21
 % CO₂: 0
 Console ID: C-18
 Y : 1.029
 $\Delta H_{@}$: 1.883
 C_p : 0.84
 K-Factor: —

Point	Δp (in. H ₂ O)	t_s (°F)
1	1.50	68
2	1.55	69
3	1.40	68
4	1.40	69
5	1.20	69
6	1.10	68
7	0.88	68
8	0.86	69
9	0.84	69
10	0.84	68
11	0.82	67
12	0.81	68

Change Ports		
1	1.40	68
2	1.55	67
3	1.45	67
4	1.20	68
5	1.00	68
6	0.90	69
7	0.87	69
8	0.85	68
9	0.86	67
10	0.84	67
11	0.83	67
12	0.80	68

Sketch of Stack



Test Team Leader Review: _____
 Data Entry Review: _____

ZONE 2

INLET

Advanced Industrial Resources
BD Bard - Covington, Georgia
Flow Measurements & Calculations
Zone 2 Inlet
Pre-Test

Test Team:	GE/ RB	Measured values:	D_s (in.):	68.00
EPA Methods:	1,2	P_{bar} (in. Hg):	29.45	
Test Date:	December 31, 2020	p_g (in. H₂O):	-2.60	
Console ID:	C-02	O₂ (%):	21.00	
Y_m	0.999	CO₂ (%):	0.00	
Probe Assembly ID:	P7-01	B_{ws} (%):	1.46	
Cp:	0.84	Test Time:	9:40	

Point	Δp (" H ₂ O)	$(\Delta p)^{1/2}$	t _s (°F)
1	0.26	0.510	63
2	0.33	0.574	63
3	0.35	0.592	63
4	0.35	0.592	63
5	0.33	0.574	63
6	0.25	0.500	63
7	0.21	0.458	63
8	0.24	0.490	63
9	0.20	0.447	63
10	0.20	0.447	63
11	0.27	0.520	63
12	0.23	0.480	63
13	0.44	0.663	63
14	0.25	0.500	63
15	0.24	0.490	63
16	0.22	0.469	63
17	0.23	0.480	63
18	0.23	0.480	63
19	0.35	0.592	63
20	0.37	0.608	63
21	0.37	0.608	63
22	0.34	0.583	63
23	0.33	0.574	63
24	0.32	0.566	63
Average	0.29	0.533	63

Calculations:			
Molar weight, M_s =	28.68 lb/mol	$= \{ (\%O_2 \times 32) + (\%CO_2 \times 44) + (\%N_2 \times 28) \} \times (1 - B_{ws}/100) / (100 + B_{ws}/100 \times 18)$	
Velocity, v_s =	30.23 ft/sec	$= 85.49 C_p \times (\Delta p)^{1/2} \times \{ (t_s + 460) / (P_{bar} + p_g / 13.6) / M_s \}^{1/2}$	
Flow Rate, Q_{s,ds} =	44,496 dscfm	$= v_s \pi D_s^2 / 4 \times 60 \times (t_{std} + 460) / (t_s + 460) \times (P_{bar} + p_g / 13.6) / 29.92 \times (1 - B_{ws}/100)$	
Flow Rate, Q_{s,act} =	45,739 acfm	$= v_s \pi D_s^2 / 4 \times 60$	
Flow Rate, Q_{s,std} =	45,156 scfm	$= v_s \pi D_s^2 / 4 \times 60 \times (t_{std} + 460) / (t_s + 460) \times (P_{bar} + p_g / 13.6) / 29.92$	

Advanced Industrial Resources
BD Bard - Covington, Georgia
Flow Measurements & Calculations
Zone 2 Inlet
Post-Test

		<u>Measured values:</u>	
Test Team:	GE/ RB	D _s (in.):	68.00
EPA Methods:	1,2	P _{bar} (in. Hg):	29.45
Test Date:	December 31, 2020	p _g (in. H ₂ O):	-2.60
Console ID:	C-002	O ₂ (%):	21.00
Y _m	0.999	CO ₂ (%):	0.00
Probe Assembly ID:	P7-01	B _{ws} (%):	1.46
Cp:	0.84	Test Time:	13:55

Point	Δp (" H ₂ O)	$(\Delta p)^{1/2}$	t _s (°F)
1	0.22	0.469	64
2	0.20	0.447	64
3	0.30	0.548	64
4	0.34	0.583	64
5	0.33	0.574	64
6	0.27	0.520	64
7	0.26	0.510	64
8	0.26	0.510	64
9	0.28	0.529	64
10	0.30	0.548	64
11	0.34	0.583	64
12	0.33	0.574	64
13	0.22	0.469	63
14	0.31	0.557	63
15	0.39	0.624	63
16	0.40	0.632	63
17	0.37	0.608	63
18	0.36	0.600	63
19	0.31	0.557	63
20	0.27	0.520	63
21	0.25	0.500	63
22	0.23	0.480	63
23	0.21	0.458	63
24	0.22	0.469	63
Average	0.29	0.536	64

<u>Calculations:</u>			
Molar weight, M _s =	28.68 lb/mol	= { (%O ₂ x 32) + (%CO ₂ x 44) + (%N ₂ x 28) } x (1-B _{ws} /100) / 100 + B _{ws} /100 * 18	
Velocity, v _s =	30.41 ft/sec	= 85.49 C _p x (Δp) ^{1/2} x { (t _s +460) / (P _{bar} +P _g /13.6) / M _s } ^{1/2}	
Flow Rate, Q _{s,ds} =	44,729 dscfm	= v _s π D _s ² / 4 x 60 x (t _{std} +460) / (t _s +460) x (P _{bar} +P _g /13.6) / 29.92 x (1-B _{ws} /100)	
Flow Rate, Q _{s,act} =	46,022 acfm	= v _s π D _s ² / 4 x 60	
Flow Rate, Q _{s,std} =	45,392 scfm	= v _s π D _s ² / 4 x 60 x (t _{std} +460) / (t _s +460) x (P _{bar} +P _g /13.6) / 29.92	

Advanced Industrial Resources

Duct Velocity & Flow Calculation Sheet

Client: Ramboll + GDC
 Location: Covington, GA.
 Source: System 2
 Test Team: GE / RB
 EPA Methods: 1, 2
 Test Date: 12-31-2020
 Console ID: C-02
 Y_m / ΔH_@: 0.999 / 1.594
 Probe Assembly ID: P7-01
 Cp: 0.84

Measured values:
 D_s (in.): 68
 P_{bar} (in. Hg): 29.45
 p_g (in. H₂O): -2.6
 t_{amb} (°F): 63
 Assumed B_{ws} (%): 1
 O₂ (%): 21
 CO₂ (%): 0
 Pre-Time: 9:40
 Post-Time: 13:55

	Pre		Post		Average	
Traverse Point	Δp (" H ₂ O)	t _s (°F)	Δp (" H ₂ O)	t _s (°F)	Δp (" H ₂ O)	t _s (°F)
1	0.26	63	0.27	64		
2	0.33	63	0.28	64		
3	0.35	63	0.30	64		
4	0.35	63	0.34	64		
5	0.33	63	0.33	64		
6	0.25	63	0.27	64		
7	0.21	63	0.26	64		
8	0.24	63	0.24	64		
9	0.20	63	0.28	64		
10	0.20	63	0.30	64		
11	0.27	63	0.34	64		
12	0.23	63	0.33	64		
13	0.44	63	0.22	63		
14	0.25	63	0.31	63		
15	0.24	63	0.39	63		
16	0.22	63	0.40	63		
17	0.23	63	0.37	63		
18	0.23	63	0.36	63		
19	0.35	63	0.31	63		
20	0.37	63	0.27	63		
21	0.37	63	0.25	63		
22	0.34	63	0.23	63		
23	0.33	63	0.21	63		
24	0.32	63	0.22	63		
Average						

Side port
bottom port

Pilot A	Pre ok	Post ok
Pilot B	ok	ok

Can 6L1220
 9:52 - 28.5
 10:27 - 26.0
 10:53 - 23.5
 11:23 - 21.0
 11:52 - 18.0
 12:20 - 15.5
 12:52 - 13.0
 13:21 - 11.0
 13:52 8.25

Calculations:

Molar weight, M_s = $\text{lb/mol} = \{(\%O_2 \times 32) + (\%CO_2 \times 44) + (\%N_2 \times 28)\} \times (1 - B_w/100) / 100 + B_w/100 \times 18$
 Velocity, v_s = $\text{ft/sec} = 85.49 C_p \times (\Delta p)^{1/2} \times \{(t_s + 460) / (P_{bar} + p_g / 13.6) / M_s\}^{1/2}$
 Flow Rate, Q_{s,ds} = $\text{dscfm} = v_s \pi D_s^2 / 4 / 144 \times 60 \times (t_{act} + 460) / (t_s + 460) \times (P_{bar} + p_g / 13.6) / 29.92$
 Flow Rate, Q_{s,act} = $\text{acfm} = v_s \pi D_s^2 / 4 / 144 \times 60$

Test Team Leader Review: _____

Data Entry Review: _____

WET DubB 52

Advanced Industrial Resources, Inc.
Cyclonic Flow Absence Verification Field Data
EPA Method 1

Client: Ramboll-GDC
 Location: Covington, GA.
 Source: System 2
 Test Team: GE SW
 Probe ID: P7.01
 C_p: 0.84

Date: 12-31-2020
 D_s (in.): 68
 A_s (ft²): 25.22
 D_n (in.): _____
 A_n (ft²): _____

④ t_m (°F): 6.02
 Console ID: C02
 Y_m: 0.999
 ΔH_@: 1.594
 Assumed B_{ws}: 1%
 P_{bar} (in. Hg): 29.45

Point	Δp (in. H ₂ O)	α (degrees)
1	0.0	2
2	0.0	2
3	0.0	2
4	0.0	0
5	0.0	0
6	0.0	0
7	0.0	0
8	0.0	0
9	0.0	0
10	0.0	0
11	0.0	0
12	0.0	0
Change Ports		
1	0.0	0
2	0.0	0
3	0.0	0
4	0.0	0
5	0.0	0
6	0.0	2
7	0.0	0
8	0.0	0
9	0.0	0
10	0.0	0
11	0.0	0
12	0.0	0

Test Team Leader Review: _____
 Data Entry Review: _____

REV021717

Advanced Industrial Resources, Inc.

Source Description Sheets


Client: Ramboll GDC
 Location: Covington GA
 Source: System 2

Date: 12-31-2020
 Test Team: GE/RB

D_n (in.): NA
 A_n (ft²): NA
 D_s (in.): 68
 A_s (ft²): 25.22
 Length A (in.): 48
 Length B (in.): 140

t_{amb} (°F): 63
 Assumed B_{ws} : 1%
 P_{bar} (in. Hg): 29.45
 P_g (in. H₂O): -2.6
 % O₂: 21
 % CO₂: 0
 Console ID: C-02
 Y: 0.999
 $\Delta H_{@}$: 1.594
 C_p : 0.84
 K-Factor: NA

Sketch of Stack



Point	Δp (in. H ₂ O)	t_s (°F)
1	0.26	63
2	0.33	63
3	0.35	63
4	0.35	63
5	0.33	63
6	0.25	63
7	0.21	63
8	0.24	63
9	0.20	63
10	0.20	63
11	0.20	63
12	0.27	63
Change Ports		
1	0.23	63
2	0.34	63
3	0.25	64 63
4	0.24	63
5	0.25	63
6	0.24	63
7	0.23	63
8	0.37	63
9	0.37	63
10	0.34	63
11	0.33	63
12	0.32	63

Test Team Leader Review: _____

Data Entry Review: _____

ZONE 3

INLET

Advanced Industrial Resources
BD Bard - Covington, Georgia
Flow Measurements & Calculations
Zone 3 Inlet
Pre-Test

Test Team:	LS KF	Measured values:	
EPA Methods:	1,2	D_s (in.):	56.00
Test Date:	December 31, 2020	P_{bar} (in. Hg):	29.45
Console ID:	C-014	p_g (in. H₂O):	-2.00
Y_m	1.010	O₂ (%):	20.90
Probe Assembly ID:	P5-04	CO₂ (%):	0.00
Cp:	0.84	B_{ws}(%):	1.5
		Test Time:	9:20

Point	Δp (" H ₂ O)	(Δp) ^{1/2}	t _s (°F)
1	0.34	0.583	63
2	0.36	0.600	63
3	0.35	0.592	63
4	0.34	0.583	63
5	0.41	0.640	63
6	0.40	0.632	63
7	0.41	0.640	63
8	0.42	0.648	63
9	0.42	0.648	63
10	0.32	0.566	63
11	0.31	0.557	63
12	0.26	0.510	63
13	0.30	0.548	63
14	0.30	0.548	63
15	0.32	0.566	63
16	0.29	0.539	63
Average	0.35	0.587	63

Calculations:			
Molar weight, M_s =	28.68 lb/mol	$= \{ (\% \text{O}_2 \times 32) + (\% \text{CO}_2 \times 44) + (\% \text{N}_2 \times 28) \} \times (1 - B_{ws}/100) / 100 + B_{ws}/100 \times 18$	
Velocity, v_s =	33.28 ft/sec	$= 85.49 C_p \times (\Delta p)^{1/2} \times \{ (t_s + 460) / (P_{bar} + p_g / 13.6) / M_s \}^{1/2}$	
Flow Rate, Q_{s,ds} =	33,275 dscfm	$= v_s \pi D_s^2 / 4 \times 144 \times 60 \times (t_{std} + 460) / (t_s + 460) \times (P_{bar} + p_g / 13.6) / 29.92 \times (1 - B_{ws} / 100)$	
Flow Rate, Q_{s,act} =	34,153 acfm	$= v_s \pi D_s^2 / 4 \times 144 \times 60$	
Flow Rate, Q_{s,std} =	33,768 scfm	$= v_s \pi D_s^2 / 4 \times 144 \times 60 \times (t_{std} + 460) / (t_s + 460) \times (P_{bar} + p_g / 13.6) / 29.92$	

Advanced Industrial Resources
BD Bard - Covington, Georgia
Flow Measurements & Calculations
Zone 3 Inlet
Post-Test

Test Team:	LS KF	Measured values:	
EPA Methods:	1,2	D_s (in.):	56.00
Test Date:	December 31, 2020	P_{bar} (in. Hg):	29.45
Console ID:	C-014	p_g (in. H₂O):	-2.00
Y_m	1.01	O₂ (%):	20.90
Probe Assembly ID:	P5-04	CO₂ (%):	0.00
Cp:	0.84	B_{ws}(%):	1.5
		Test Time:	14:06

Point	Δp (in. H ₂ O)	$(\Delta p)^{1/2}$	t _s (°F)
1	0.29	0.539	63
2	0.34	0.583	63
3	0.36	0.600	63
4	0.35	0.592	63
5	0.38	0.616	63
6	0.40	0.632	63
7	0.41	0.640	63
8	0.42	0.648	63
9	0.33	0.574	63
10	0.39	0.620	63
11	0.41	0.640	63
12	0.42	0.648	63
13	0.39	0.624	63
14	0.37	0.608	63
15	0.32	0.566	63
16	0.29	0.539	63
Average	0.37	0.604	63

Calculations:

Molar weight, M_s =	28.68 lb/mol	$= \{ (\% \text{O}_2 \times 32) + (\% \text{CO}_2 \times 44) + (\% \text{N}_2 \times 28) \} \times (1 - B_{ws}/100) / (100 + B_{ws}/100 \times 18)$
Velocity, v_s =	34.24 ft/sec	$= 85.49 C_p \times (\Delta p)^{1/2} \times \{ (t_s + 460) / (P_{bar} + p_g / 13.6) / M_s \}^{1/2}$
Flow Rate, Q_{s,ds} =	34,237 dscfm	$= v_s \pi D_s^2 / 4 \times 60 \times (t_{std} + 460) / (t_s + 460) \times (P_{bar} + p_g / 13.6) / 29.92 \times (1 - B_{ws} / 100)$
Flow Rate, Q_{s,act} =	35,140 acfm	$= v_s \pi D_s^2 / 4 \times 60$
Flow Rate, Q_{s,std} =	34,745 scfm	$= v_s \pi D_s^2 / 4 \times 60 \times (t_{std} + 460) / (t_s + 460) \times (P_{bar} + p_g / 13.6) / 29.92$

Advanced Industrial Resources

Duct Velocity & Flow Calculation Sheet

Client: <u>Ramboll - GNC</u>	Measured values:
Location: <u>Covington, GA</u>	D _s (in.): <u>56.0</u>
Source: <u>System 3 Inlet</u>	Y _m / ΔH _@ : <u>N/A</u>
Test Team: <u>RB / GR</u>	C _p : <u>0.84</u>
EPA Methods: <u>1, 2, 3, 4</u>	t _{amb} (°F): <u>63</u>
Test Date: <u>12/31/2020</u>	Assumed B _{ws} (%): <u>1</u>
Console ID: <u>C-14</u>	O ₂ (%): <u>21</u>
Probe Assembly ID: <u>P5-04</u>	CO ₂ (%): <u>0</u>

Start time: <u>9:20</u>	Start time: <u>14:06</u>	Start time: _____	Start time: _____
Stop time: _____	Stop time: <u>14:12</u>	Stop time: _____	Stop time: _____

Test #	Pre test		Post Test					
P _{bar} (in. Hg):								
p _g (in. H ₂ O):	<u>-2.0</u>		<u>-2.0</u>					
Traverse Point	Δp (" H ₂ O)	t _s (°F)	Δp (" H ₂ O)	t _s (°F)	Δp (" H ₂ O)	t _s (°F)	Δp (" H ₂ O)	t _s (°F)
1	0.34	63	0.29	63				
2	0.36	63	0.34	63				
3	0.35	63	0.36	63				
4	0.34	63	0.35	63				
5	0.41	63	0.38	63				
6	0.40	63	0.40	63				
7	0.41	63	0.41	63				
8	0.42	63	0.42	63				
9	0.42	63	0.33	63				
10	0.32	63	0.38	63				
11	0.31	63	0.41	63				
12	0.26	63	0.42	63				
13	0.30	63	0.39	63				
14	0.30	63	0.37	63				
15	0.32	63	0.32	63				
16	0.29	63	0.29	63				
Average								

Wet bulb = 52°F
 Wet bulb = 52°F

Test Team Leader Review: _____
 Data Entry Review: APL

Advanced Industrial Resources, Inc.
Cyclonic Flow Absence Verification Field Data
 EPA Method 1

Client: Ramboll-GNC
 Location: Covington, GA
 Source: System 3 Inlet
 Test Team: RLB / GE
 Probe ID: P5-04
 C_p: 0.94

Date: 12/31/2020
 D_s (in.): 56.0
 A_s (ft²): 17.10
 D_n (in.): N/A
 A_n (ft²): N/A

t_m (°F): 63
 Console ID: C-14
 Y_m: N/A
 ΔH_@: N/A
 Assumed B_{ws}: 1
 P_{bar} (in. Hg): _____

Point	Δp (in. H ₂ O)	α (degrees)
1	0.0	0
2	0.0	0
3	0.0	0
4	0.0	0
5	0.0	0
6	0.0	0
7	0.0	0
8	0.0	0
9	0.0	0
10	0.0	0
11	0.0	0
12	0.0	0
Change Ports		
1	0.0	0
2	0.0	0
3	0.0	0
4	0.0	0
5	0.0	0
6	0.0	0
7	0.0	0
8	0.0	0
9	0.0	0
10	0.0	0
11	0.0	0
12	0.0	0

Test Team Leader Review: _____
 Data Entry Review: _____

REV021717

Advanced Industrial Resources, Inc.

Source Description Sheets


Client: Ramboll-GDC
 Location: Covington, GA
 Source: System 3 Inlet

Date: 12/31/2020
 Test Team: RB/GR

D_n (in.): N/A
 A_n (ft²): N/A
 D_s (in.): 56.0
 A_s (ft²): 17.10
 Length A (in.): 180
 Length B (in.): 180

t_{amb} (°F): 63
 Assumed B_{ws} : 1
 P_{bar} (in. Hg):
 P_g (in. H₂O): -2.0
 % O₂: 21
 % CO₂: 0
 Console ID: C-14
 Y: N/A
 $\Delta H_@$: N/A
 C_p : 0.84
 K-Factor: N/A

Sketch of Stack



Point	Δp (in. H ₂ O)	t_s (°F)
1	0.34	63
2	0.36	63
3	0.35	63
4	0.34	63
5	0.41	63
6	0.40	63
7	0.41	63
8	0.42	63
9		
10		
11		
12		
Change Ports		
1	0.42	63
2	0.32	63
3	0.31	63
4	0.26	63
5	0.30	63
6	0.30	63
7	0.32	63
8	0.29	63
9		
10		
11		
12		

Test Team Leader Review: _____
 Data Entry Review: _____

ZONE 5

INLET

Advanced Industrial Resources
BD Bard - Covington, Georgia
Flow Measurements & Calculations
Zone 5 Inlet
Pre-Test

Test Team:	RB GE	Measured values:	
EPA Methods:	1,2	D_s (in.):	37.50
Test Date:	December 31, 2020	P_{bar} (in. Hg):	29.45
Console ID:	C-003	p_g (in. H₂O):	-1.30
Y_m	0.938	O₂ (%):	20.90
Probe Assembly ID:	FP-04	CO₂ (%):	0.00
Cp:	0.84	B_{ws}(%):	2.1
		Test Time:	9:22

Point	Δp (" H ₂ O)	(Δp) ^{1/2}	t _s (°F)
1	0.32	0.566	71
2	0.36	0.600	71
3	0.35	0.592	71
4	0.39	0.624	71
5	0.34	0.583	71
6	0.33	0.574	71
7	0.33	0.574	71
8	0.30	0.548	71
9	0.26	0.510	71
10	0.29	0.539	71
11	0.32	0.566	71
12	0.35	0.592	71
13	0.41	0.640	71
14	0.40	0.632	71
15	0.39	0.624	71
16	0.38	0.616	71
Average	0.35	0.586	71

Calculations:			
Molar weight, M_s =	28.61 lb/mol	$= \{ (\% \text{O}_2 \times 32) + (\% \text{CO}_2 \times 44) + (\% \text{N}_2 \times 28) \} \times (1 - B_{ws}/100) / 100 + B_{ws}/100 \times 18$	
Velocity, v_s =	33.48 ft/sec	$= 85.49 C_p \times (\Delta p)^{1/2} \times \{ (t_s + 460) / (P_{bar} + p_g / 13.6) / M_s \}^{1/2}$	
Flow Rate, Q_{s,ds} =	14,717 dscfm	$= v_s \pi D_s^2 / 4 \times 144 \times 60 \times (t_{std} + 460) / (t_s + 460) \times (P_{bar} + p_g / 13.6) / 29.92 \times (1 - B_{ws} / 100)$	
Flow Rate, Q_{s,act} =	15,406 acfm	$= v_s \pi D_s^2 / 4 \times 144 \times 60$	
Flow Rate, Q_{s,std} =	15,029 scfm	$= v_s \pi D_s^2 / 4 \times 144 \times 60 \times (t_{std} + 460) / (t_s + 460) \times (P_{bar} + p_g / 13.6) / 29.92$	

Advanced Industrial Resources
BD Bard - Covington, Georgia
Flow Measurements & Calculations
Zone 5 Inlet
Post-Test

Test Team:	RB GE	Measured values:	D_s (in.):	37.50
EPA Methods:	1,2	P_{bar} (in. Hg):	29.45	
Test Date:	December 31, 2020	p_g (in. H₂O):	-1.30	
Console ID:	C-003	O₂ (%):	20.90	
Y_m	0.938	CO₂ (%):	0.00	
Probe Assembly ID:	FP-04	B_{ws}(%):	2.1	
Cp:	0.84	Test Time:	13:24	

Point	Δp (" H ₂ O)	$(\Delta p)^{1/2}$	t _s (°F)
1	0.29	0.539	71
2	0.37	0.608	71
3	0.35	0.592	71
4	0.33	0.574	71
5	0.33	0.574	71
6	0.31	0.557	71
7	0.30	0.548	71
8	0.27	0.520	71
9	0.27	0.520	71
10	0.31	0.557	71
11	0.34	0.583	71
12	0.38	0.616	71
13	0.39	0.624	71
14	0.39	0.624	71
15	0.35	0.592	71
16	0.35	0.592	71
Average	0.33	0.576	71

Calculations:

Molar weight, M_s =	28.61 lb/mol	$= \{ (\% \text{O}_2 \times 32) + (\% \text{CO}_2 \times 44) + (\% \text{N}_2 \times 28) \} \times (1 - B_{ws}/100) / (100 + B_{ws}/100 \times 18)$
Velocity, v_s =	32.90 ft/sec	$= 85.49 C_p \times (\Delta p)^{1/2} \times \{ (t_s + 460) / (P_{bar} + p_g / 13.6) / M_s \}^{1/2}$
Flow Rate, Q_{s,ds} =	14,464 dscfm	$= v_s \pi D_s^2 / 4 \times 60 \times (t_{std} + 460) / (t_s + 460) \times (P_{bar} + p_g / 13.6) / 29.92 \times (1 - B_{ws} / 100)$
Flow Rate, Q_{s,act} =	15,141 acfm	$= v_s \pi D_s^2 / 4 \times 60$
Flow Rate, Q_{s,std} =	14,771 scfm	$= v_s \pi D_s^2 / 4 \times 60 \times (t_{std} + 460) / (t_s + 460) \times (P_{bar} + p_g / 13.6) / 29.92$

Advanced Industrial Resources

Duct Velocity & Flow Calculation Sheet

Client: Ramboll GDC
 Location: Covington, GA
 Source: S-5
 Test Team: LS, KF
 EPA Methods: 1+2
 Test Date: 12/31/20
 Console ID: C-03
 Probe Assembly ID: FP-04

Measured values:
 D_s (in.): 37.5
 $Y_m / \Delta H_{@}$: 0.938 / 1.807
 C_p : 0.84
 t_{amb} (°F): 69
 Assumed B_{ws} (%): 1%
 O_2 (%): 21%
 CO_2 (%): 0%

Start time: 09:22 Start time: 13:24 Start time: _____ Start time: _____
 Stop time: 09:29 Stop time: 13:28 Stop time: _____ Stop time: _____

	Pre-1 <u>LS</u>		Post-1; Pre-2		Post-2; Pre-3		Post-3	
P_{bar} (in. Hg):	<u>29.34 29.45</u>		<u>29.45</u>					
p_g (in. H ₂ O):	<u>-1.30</u>		<u>-1.30</u>					
Traverse Point	Δp (in. H ₂ O)	t_s (°F)	Δp (in. H ₂ O)	t_s (°F)	Δp (in. H ₂ O)	t_s (°F)	Δp (in. H ₂ O)	t_s (°F)
1	0.32	71	0.29	71				
2	0.36	71	0.37	71				
3	0.35	71	0.35	71				
4	0.39	71	0.33	71				
5	0.34	71	0.33	71				
6	0.33	71	0.31	71				
7	0.33	71	0.30	71				
8	0.30	71	0.27	71				
9	0.26	71	0.27	71				
10	0.29	71	0.31	71				
11	0.32	71	0.34	71				
12	0.35	71	0.38	71				
13	0.41	71	0.39	71				
14	0.40	71	0.39	71				
15	0.39	71	0.35	71				
16	0.33	71	0.35	71				
Average								

Wet 60 59
 Dry 71 71

Test Team Leader Review: _____
 Data Entry Review: LS

CAN No. 6L1647

Pre
 Pitot Line
 Check - o.k.

Static = 1.30

Advanced Industrial Resources, Inc.


Source Description Sheets

Client: BD Bard Rambo GDL Date: 12-31-20
 Location: COVENGTON LS Test Team: LS-KF
 Source: S-5 INLET

D_n (in.): N/A
 A_n (ft²): N/A
 D_s (in.): 30 37.5 LS
 A_s (ft²): 7.88 7.67 LS
 Length A (in.): 85
 Length B (in.): 72

t_{amb} (°F): 45
 Assumed B_{ws} : 10%
 P_{bar} (in. Hg): 29.34
 P_g (in. H₂O): 1.30
 % O₂: 21
 % CO₂: 0
 Console ID: C03
 Y : 0.938
 $\Delta H_{@}$: 1.807
 C_p : 0.84
 K-Factor: N/A

Sketch of Stack



Point	Δp (in. H ₂ O)	t_s (°F)
1	0.32	71
2	0.36	71
3	0.35	71
4	0.39	71
5	0.34	71
6	0.33	71
7	0.30	71
8	0.33	71
9		
10		
11		
12		

Change Ports		
1	0.26	71
2	0.29	71
3	0.32	71
4	0.35	71
5	0.41	71
6	0.40	71
7	0.39	71
8	0.38	71
9		
10		
11		
12		

Test Team Leader Review: _____
 Data Entry Review: _____

Advanced Industrial Resources, Inc.
Cyclonic Flow Absence Verification Field Data
 EPA Method 1

Client: B.R. Bard
 Location: Covington, LA
 Source: S-5
 Test Team: LS, KCF
 Probe ID: FP-04
 C_p: 0.84

Date: 12/31/20
 D_s (in.): 37.5
 A_s (ft²): 7.67
 D_n (in.): N/A
 A_n (ft²): N/A

t_m (°F): 606
 Console ID: 1-03
 Y_m: ~~0.999~~ 0.938 LS
 ΔH_@: 1.807
 Assumed B_{ws}: 10%
 P_{bar} (in. Hg): 29.34

Point	Δp (in. H ₂ O)	α (degrees)
1	0.0	2
2	0.0	6
3	0.0	2
4	0.0	2
5	0.0	4
6	0.0	2
7	0.0	0
8	0.0	2
9	0.0	
10	0.0	
11	0.0	
12	0.0	
Change Ports		
1	0.0	2
2	0.0	2
3	0.0	4
4	0.0	4
5	0.0	2
6	0.0	0
7	0.0	2
8	0.0	2
9	0.0	
10	0.0	
11	0.0	
12	0.0	

Test Team Leader Review: _____
 Data Entry Review: _____

APPENDIX D

CALIBRATION DATA

Advanced Industrial Resources, Inc.

Dry Gas Meter Calibration Data

Dry Gas Meter	
Console ID:	C-02
Serial Number:	

Reference Meter	
Meter ID:	M5RFM1
Calibration Factor, Y_w :	0.998

Date: 07/24/20
 Barometric Pressure, P_b (in. Hg): 29.15

Performed By: LS
 Reviewed By:

Data								
Vacuum (in. Hg)	ΔH (in. H ₂ O)	Reference Meter Volume V _w (ft ³)	Dry Gas Meter Volume V _m (ft ³)	Temperatures (°F)				Time Elapsed θ (min.)
				Reference Meter t _w	Dry Gas Meter			
					init. t _i	final t _f	avg. t _m	
3.0	0.50	5.205	5.276	72	66.0	76.0	71.0	11.90
3.0	1.00	5.009	5.066	73	77.0	84.0	80.5	8.40
3.0	2.00	6.468	6.537	74	85.0	89.0	87.0	7.75
3.0	3.00	5.283	5.324	74	88.0	90.0	89.0	5.10
3.0	4.00	7.217	7.365	74	90.0	92.0	91.0	6.10

Calculations						
ΔH (inches H ₂ O)	Y_m	Variation (dimensionless)		$\Delta H_{@}$ (inches H ₂ O)	Variation (dimensionless)	
0.50	0.981	-0.018	PASS	1.521	-0.073	PASS
1.00	0.998	-0.001	PASS	1.614	0.020	PASS
2.00	1.006	0.007	PASS	1.634	0.040	PASS
3.00	1.010	0.011	PASS	1.586	-0.008	PASS
4.00	0.999	0.000	PASS	1.615	0.021	PASS
Averages:	0.999	PASS		1.594	PASS	

Where:

Y_m is the ratio of the reading of the reference meter to that of the dry gas meter (DGM);
 variance limit: ± 0.02 .

$$Y_m = \frac{Y_w V_w P_b (t_m + 460)}{V_m (P_b + \Delta H/13.6) (t_w + 460)}$$

$\Delta H_{@}$ is the orifice pressure differential (inches H₂O) that corresponds to 0.75 cfm of air at
 68 °F and 29.92 inches of mercury; variance limit: ± 0.20 .

$$\Delta H_{@} = \frac{0.0317 \Delta H ((t_w + 460) \theta)^2}{P_b (t_m + 460) (Y_w V_w)^2}$$

Advanced Industrial Resources, Inc.

Dry Gas Meter Calibration Data

Dry Gas Meter		Reference Meter	
Console ID:	C-002	Meter ID:	MSRFM #1
Serial Number:		Calibration Factor, Y_w :	0.9980

Date:	01/05/21	Accepted Y_m :	0.999
Barometric Pressure, P_b (in. Hg):	29.80	Performed By:	LS

Data								
Vacuum (in. Hg)	ΔH (in. H ₂ O)	Net Reference Meter Volume V_w (ft ³)	Net Dry Gas Meter Volume V_m (ft ³)	Temperatures (°F)				Time Elapsed θ (min.)
				Reference Meter t_w	Dry Gas Meter			
					init. t_i	final t_f	avg. t_m	
5.0	3.00	6.287	6.314	74	94	96	95.0	6.00
5.0	3.00	6.262	6.316	75	96	97	96.5	6.00
5.0	3.00	6.209	6.274	75	97	98	97.5	6.00

Calculations						
ΔH (inches H ₂ O)	Y_m	Variation (dimensionless)		$\Delta H_{@}$ (inches H ₂ O)	Variation (dimensionless)	
3.00	1.025	0.0024	PASS	1.499	-0.017	PASS
3.00	1.022	-0.0012	PASS	1.513	-0.003	PASS
3.00	1.022	-0.0012	PASS	1.536	0.020	PASS
Averages:	1.023	PASS		1.516	PASS	

Calculations				
**Note: Avg Y_m cannot be (< or >) 5% of the Accepted Y_M	Low Tolerance	High Tolerance	% diff	Pass or Fail?
	0.949	1.049	2%	PASS

Where:

Y_m is the ratio of the reading of the reference meter to that of the dry gas meter (DGM); variance limit: ± 0.02 .

$$Y_m = \frac{Y_w V_w P_b (t_m + 460)}{V_m (P_b + \Delta H/13.6) (t_w + 460)}$$

$\Delta H_{@}$ is the orifice pressure differential (inches H₂O) that corresponds to 0.75 cfm of air at 68 °F and 29.92 inches of mercury; variance limit: ± 0.20 .

$$\Delta H_{@} = \frac{0.0317 \Delta H ((t_w + 460) \theta)^2}{P_b (t_m + 460) (Y_w V_w)^2}$$

Advanced Industrial Resources, Inc.

Dry Gas Meter Calibration Data

Dry Gas Meter	
Console ID:	C-003
Serial Number:	

Reference Meter	
Meter ID:	M5 RFM #1
Calibration Factor, Y_w :	0.998

Date: 12/11/20
 Barometric Pressure, P_b (in. Hg): 29.27

Performed By: JML
 Reviewed By:

Data								
Vacuum (in. Hg)	ΔH (in. H ₂ O)	Reference Meter Volume V _w (ft ³)	Dry Gas Meter Volume V _m (ft ³)	Temperatures (°F)				Time Elapsed θ (min.)
				Reference Meter t _w	Dry Gas Meter			
					init. t _i	final t _f	avg. t _m	
5.0	0.50	5.949	6.130	72	61.0	59.0	60.0	14.50
5.0	1.00	5.772	5.970	72	58.0	60.0	59.0	10.00
5.0	2.00	6.029	6.269	72	60.0	62.0	61.0	7.50
5.0	3.00	5.894	6.143	72	62.0	65.0	63.5	6.00
5.0	4.00	5.637	5.878	72	65.0	67.0	66.0	5.00

Calculations						
ΔH (inches H ₂ O)	Y_m	Variation (dimensionless)		$\Delta H_{@}$ (inches H ₂ O)	Variation (dimensionless)	
0.50	0.945	0.007		1.758	-0.049	
1.00	0.939	0.001		1.780	-0.027	
2.00	0.935	-0.003		1.828	0.021	
3.00	0.935	-0.003		1.828	0.021	
4.00	0.937	-0.001		1.841	0.034	
Averages:	0.938			1.807		

Where:

Y_m is the ratio of the reading of the reference meter to that of the dry gas meter (DGM);
 variance limit: ± 0.02 .

$$Y_m = \frac{Y_w V_w P_b (t_m + 460)}{V_m (P_b + \Delta H/13.6) (t_w + 460)}$$

$\Delta H_{@}$ is the orifice pressure differential (inches H₂O) that corresponds to 0.75 cfm of air at
 68 °F and 29.92 inches of mercury; variance limit: ± 0.20 .

$$\Delta H_{@} = \frac{0.0317 \Delta H ((t_w + 460) \theta)^2}{P_b (t_m + 460) (Y_w V_w)^2}$$

Advanced Industrial Resources, Inc.

Dry Gas Meter Calibration Data

Dry Gas Meter		Reference Meter	
Console ID:	C-003	Meter ID:	M5 RFM #1
Serial Number:		Calibration Factor, Y_w :	0.9980

Date:	01/05/21	Accepted Y_m :	0.938
Barometric Pressure, P_b (in. Hg):	29.27	Performed By:	LS

Data								
Vacuum (in. Hg)	ΔH (in. H ₂ O)	Net Reference Meter Volume V_w (ft ³)	Net Dry Gas Meter Volume V_m (ft ³)	Temperatures (°F)				Time Elapsed θ (min.)
				Reference Meter t_w	Dry Gas Meter			
					init. t_i	final t_f	avg. t_m	
5.0	3.00	5.895	6.164	72	64	65	64.5	6.00
5.0	3.00	5.905	6.177	72	65	66	65.5	6.00
5.0	3.00	5.894	6.186	72	66	68	67.0	6.00

Calculations						
ΔH (inches H ₂ O)	Y_m	Variation (dimensionless)		$\Delta H_{@}$ (inches H ₂ O)	Variation (dimensionless)	
3.00	0.934	-0.0008	PASS	1.824	0.006	PASS
3.00	0.935	0.0006	PASS	1.814	-0.004	PASS
3.00	0.935	0.0002	PASS	1.815	-0.002	PASS
Averages:	0.935	PASS		1.818	PASS	

Calculations				
**Note: Avg Y_m cannot be (< or >) 5% of the Accepted Y_M	Low Tolerance	High Tolerance	% diff	Pass or Fail?
	0.891	0.985	0%	PASS

Where:

Y_m is the ratio of the reading of the reference meter to that of the dry gas meter (DGM); variance limit: ± 0.02 .

$$Y_m = \frac{Y_w V_w P_b (t_m + 460)}{V_m (P_b + \Delta H/13.6) (t_w + 460)}$$

$\Delta H_{@}$ is the orifice pressure differential (inches H₂O) that corresponds to 0.75 cfm of air at 68 °F and 29.92 inches of mercury; variance limit: ± 0.20 .

$$\Delta H_{@} = \frac{0.0317 \Delta H ((t_w + 460) \theta)^2}{P_b (t_m + 460) (Y_w V_w)^2}$$

Advanced Industrial Resources, Inc.

Dry Gas Meter Calibration Data

Dry Gas Meter	
Console ID:	C-14
Serial Number:	28554

Reference Meter	
Meter ID:	MSRFM1
Calibration Factor, Y_w :	0.998

Date: 01/23/20
 Barometric Pressure, P_b (in. Hg): 29.30

Performed By: LS
 Reviewed By:

Data								
Vacuum (in. Hg)	ΔH (in. H ₂ O)	Reference Meter Volume V _w (ft ³)	Dry Gas Meter Volume V _m (ft ³)	Temperatures (°F)				Time Elapsed θ (min.)
				Reference Meter t _w	Dry Gas Meter			
					init. t _i	final t _f	avg. t _m	
5.0	0.50	5.170	5.334	51	65.0	70.0	67.5	12.75
5.0	0.75	5.082	5.264	53	71.0	76.0	73.5	10.50
5.0	1.00	5.021	5.132	53	71.0	74.0	72.5	9.10
5.0	1.20	5.038	5.113	54	75.0	77.0	76.0	8.50
5.0	1.50	5.025	5.111	55	75.0	77.0	76.0	7.50

Calculations						
ΔH (inches H ₂ O)	Y_m	Variation (dimensionless)		$\Delta H_{@}$ (inches H ₂ O)	Variation (dimensionless)	
0.50	0.997	-0.012	PASS	1.635	-0.113	PASS
0.75	1.000	-0.010	PASS	1.716	-0.032	PASS
1.00	1.011	0.001	PASS	1.763	0.016	PASS
1.20	1.022	0.013	PASS	1.829	0.081	PASS
1.50	1.017	0.008	PASS	1.796	0.048	PASS
Averages:	1.010	PASS		1.748	PASS	

Where:

Y_m is the ratio of the reading of the reference meter to that of the dry gas meter (DGM);
 variance limit: ± 0.02 .

$$Y_m = \frac{Y_w V_w P_b (t_m + 460)}{V_m (P_b + \Delta H/13.6) (t_w + 460)}$$

$\Delta H_{@}$ is the orifice pressure differential (inches H₂O) that corresponds to 0.75 cfm of air at
 68 °F and 29.92 inches of mercury; variance limit: ± 0.20 .

$$\Delta H_{@} = \frac{0.0317 \Delta H ((t_w + 460) \theta)^2}{P_b (t_m + 460) (Y_w V_w)^2}$$

Advanced Industrial Resources, Inc.

Dry Gas Meter Calibration Data

Dry Gas Meter		Reference Meter	
Console ID:	C-014	Meter ID:	MSRFM #1
Serial Number:		Calibration Factor, Y_w :	0.9980

Date:	01/05/21	Accepted Y_m :	1.010
Barometric Pressure, P_b (in. Hg):	29.05	Performed By:	LS

Data								
Vacuum (in. Hg)	ΔH (in. H ₂ O)	Net Reference Meter Volume V_w (ft ³)	Net Dry Gas Meter Volume V_m (ft ³)	Temperatures (°F)				Time Elapsed θ (min.)
				Reference Meter t_w	Dry Gas Meter			
					init. t_i	final t_f	avg. t_m	
5.0	3.00	6.035	6.098	74	88	94	91.0	6.00
5.0	3.00	6.166	6.249	74	94	100	97.0	6.17
5.0	3.00	5.986	6.091	74	100	106	103.0	6.00

Calculations						
ΔH (inches H ₂ O)	Y_m	Variation (dimensionless)		$\Delta H_{@}$ (inches H ₂ O)	Variation (dimensionless)	
3.00	1.011	-0.0076	PASS	1.681	0.002	PASS
3.00	1.019	0.0004	PASS	1.685	0.005	PASS
3.00	1.026	0.0072	PASS	1.673	-0.007	PASS
Averages:	1.019	PASS		1.680	PASS	

Calculations				
**Note: Avg Y_m cannot be (< or >) 5% of the Accepted Y_M	Low Tolerance	High Tolerance	% diff	Pass or Fail?
	0.960	1.061	1%	PASS

Where:

Y_m is the ratio of the reading of the reference meter to that of the dry gas meter (DGM); variance limit: ± 0.02 .

$$Y_m = \frac{Y_w V_w P_b (t_m + 460)}{V_m (P_b + \Delta H/13.6) (t_w + 460)}$$

$\Delta H_{@}$ is the orifice pressure differential (inches H₂O) that corresponds to 0.75 cfm of air at 68 °F and 29.92 inches of mercury; variance limit: ± 0.20 .

$$\Delta H_{@} = \frac{0.0317 \Delta H ((t_w + 460) \theta)^2}{P_b (t_m + 460) (Y_w V_w)^2}$$

Advanced Industrial Resources, Inc.

Dry Gas Meter Calibration Data

Dry Gas Meter	
Console ID:	C-18
Serial Number:	1604009

Reference Meter	
Meter ID:	M5RFM1
Calibration Factor, Y_w :	0.998

Date: 04/15/20
 Barometric Pressure, P_b (in. Hg): 28.95
 Performed By: LS
 Reviewed By:

Data								
Vacuum (in. Hg)	ΔH (in. H ₂ O)	Reference Meter Volume V _w (ft ³)	Dry Gas Meter Volume V _m (ft ³)	Temperatures (°F)				Time Elapsed θ (min.)
				Reference Meter t _w	Dry Gas Meter			
					init. t _i	final t _f	avg. t _m	
5.0	0.50	8.531	8.056	73	60.0	63.0	61.5	21.60
5.0	1.00	7.771	7.485	73	64.0	67.0	65.5	14.00
5.0	2.00	8.095	7.712	74	67.0	71.0	69.0	10.20
5.0	3.00	5.764	5.508	74	71.0	72.0	71.5	5.90
5.0	4.00	6.619	6.319	74	72.0	72.0	72.0	5.83

Calculations						
ΔH (inches H ₂ O)	Y_m	Variation (dimensionless)		$\Delta H_{@}$ (inches H ₂ O)	Variation (dimensionless)	
0.50	1.033	0.003	PASS	1.920	0.037	PASS
1.00	1.019	-0.010	PASS	1.929	0.046	PASS
2.00	1.033	0.003	PASS	1.882	-0.001	PASS
3.00	1.032	0.002	PASS	1.854	-0.029	PASS
4.00	1.031	0.002	PASS	1.829	-0.054	PASS
Averages:	1.029	PASS		1.883	PASS	

Where:

Y_m is the ratio of the reading of the reference meter to that of the dry gas meter (DGM);
 variance limit: ± 0.02 .

$$Y_m = \frac{Y_w V_w P_b (t_m + 460)}{V_m (P_b + \Delta H/13.6) (t_w + 460)}$$

$\Delta H_{@}$ is the orifice pressure differential (inches H₂O) that corresponds to 0.75 cfm of air at
 68 °F and 29.92 inches of mercury; variance limit: ± 0.20 .

$$\Delta H_{@} = \frac{0.0317 \Delta H ((t_w + 460) \theta)^2}{P_b (t_m + 460) (Y_w V_w)^2}$$

Advanced Industrial Resources, Inc.

Dry Gas Meter Calibration Data

Dry Gas Meter		Reference Meter	
Console ID:	C-18	Meter ID:	M5RFM1
Serial Number:	1604006	Calibration Factor, Y_w :	0.9980

Date:	01/05/21	Accepted Y_m :	1.029
Barometric Pressure, P_b (in. Hg):	29.15	Performed By:	LS

Data								
Vacuum (in. Hg)	ΔH (in. H ₂ O)	Net Reference Meter Volume V _w (ft ³)	Net Dry Gas Meter Volume V _m (ft ³)	Temperatures (°F)			Time Elapsed θ (min.)	
				Reference Meter t _w	Dry Gas Meter			
					init. t _i	final t _f		avg. t _m
4.0	1.80	5.293	5.072	74	64	64	64.0	7.25
4.0	1.80	5.241	5.029	74	64	65	64.5	7.20
4.0	1.80	5.271	5.061	74	65	66	65.5	7.25

Calculations						
ΔH (inches H ₂ O)	Y_m	Variation (dimensionless)		$\Delta H_{@}$ (inches H ₂ O)	Variation (dimensionless)	
1.80	1.017	-0.0002	PASS	2.007	-0.007	PASS
1.80	1.017	-0.0006	PASS	2.017	0.003	PASS
1.80	1.018	0.0007	PASS	2.018	0.004	PASS
Averages:	1.018	PASS		2.014	PASS	

Calculations				
**Note: Avg Y_m cannot be (< or >) 5% of the Accepted Y_M	Low Tolerance	High Tolerance	% diff	Pass or Fail?
	0.978	1.080	1%	PASS

Where:

Y_m is the ratio of the reading of the reference meter to that of the dry gas meter (DGM); variance limit: ± 0.02 .

$$Y_m = \frac{Y_w V_w P_b (t_m + 460)}{V_m (P_b + \Delta H/13.6) (t_w + 460)}$$

$\Delta H_{@}$ is the orifice pressure differential (inches H₂O) that corresponds to 0.75 cfm of air at 68 °F and 29.92 inches of mercury; variance limit: ± 0.20 .

$$\Delta H_{@} = \frac{0.0317 \Delta H ((t_w + 460) \theta)^2}{P_b (t_m + 460) (Y_w V_w)^2}$$

**15 POINT SECONDARY REFERENCE METER CALIBRATION**

Date: 8/15/2019

DGM Model: T-110

Customer: Advanced Industrial Resources

DGM S/N: 27979

Reference Prover: Cert.# A-610 Tape # 26727

Pb: 29.89 in Hg


Approx. Flow Rate (cfm) Q	Prover Volume (ft ³) V _w	DGM Volume (ft ³) V _{ds}	Temperature		Time (min) Φ	Flow Rate (cfm) Q	Meter Coefficient Y _{ds}	Average Meter Coefficient Y _{ds}
			Prover (°F) t _w	DGM (°F) t _{ds}				
0.40	2.000	2.020	76.2	76.2	5.148	0.382	0.990	
0.40	2.000	2.019	76.1	76.1	5.117	0.384	0.991	
0.40	2.000	2.009	76.2	76.2	5.122	0.384	0.996	0.992
0.60	2.000	2.018	76.5	76.5	3.320	0.592	0.991	
0.60	2.000	2.017	75.9	75.9	3.318	0.593	0.992	
0.60	2.000	2.017	75.9	75.9	3.308	0.595	0.992	0.991
0.80	2.000	2.017	75.9	75.9	2.438	0.807	0.992	
0.80	2.000	2.017	76.2	76.2	2.432	0.809	0.992	
0.80	2.000	2.023	75.9	75.9	2.428	0.810	0.989	0.991
1.00	2.000	2.022	76.3	76.3	1.943	1.012	0.989	
1.00	2.000	2.017	75.6	75.6	1.947	1.011	0.992	
1.00	2.000	2.016	76.2	76.2	1.942	1.013	0.992	0.991
1.20	2.000	2.007	75.5	75.5	1.622	1.214	0.997	
1.20	2.000	2.016	75.5	75.5	1.623	1.213	0.992	
1.20	2.000	2.017	75.5	75.5	1.623	1.213	0.992	0.993

AVERAGE Y_{ds} **0.992**

$$Y_{ds} = \frac{V_w(t_{ds} + t_{std})}{V_{ds}(t_w + t_{std})} * \left(\frac{P_{bar}}{P_{bar} + P_m / 13.6} \right)$$

$$Q = 17.64 \frac{P_{bar}}{(t_w + t_{std})} \frac{V_w}{\Phi}$$

Dry gas meter Serial Number 27979 was calibrated in accordance with the Code of Federal Regulations, Title 40, Part 60, Appendix A, Method 5 Section 16.1.1


Signature



15 POINT SECONDARY REFERENCE METER CALIBRATION

Date: 8/27/2019

DGM Model: T-110

Customer: Advanced Industrial Resources

DGM S/N: 356333

Reference Prover: Cert.# A-610 Tape # 26727

Pb: 29.86 in Hg


Approx. Flow Rate (cfm) Q	Prover Volume (ft ³) V _w	DGM Volume (ft ³) V _{ds}	Temperature		Time (min) Φ	Flow Rate (cfm) Q	Meter Coefficient Y _{ds}	Average Meter Coefficient Y _{ds}
			Prover (°F) t _w	DGM (°F) t _{ds}				
0.40	2.000	1.998	77.9	75.8	5.092	0.385	0.997	
0.40	2.000	1.997	77.4	75.8	5.088	0.385	0.999	
0.40	2.000	1.998	77.4	75.7	5.097	0.385	0.998	0.998
0.60	2.000	2.004	75.8	75.8	3.290	0.598	0.998	
0.60	2.000	2.003	75.8	75.8	3.288	0.598	0.999	
0.60	2.000	2.003	75.8	75.8	3.285	0.599	0.999	0.998
0.80	2.000	2.006	75.8	75.8	2.453	0.801	0.997	
0.80	2.000	2.007	75.8	75.8	2.442	0.805	0.997	
0.80	2.000	2.001	75.5	75.5	2.440	0.806	1.000	0.998
1.00	2.000	2.001	75.9	75.9	1.918	1.025	1.000	
1.00	2.000	2.006	75.9	75.9	1.925	1.021	0.997	
1.00	2.000	2.010	75.9	75.9	1.928	1.019	0.995	0.997
1.20	2.000	2.007	75.9	75.9	1.595	1.232	0.997	
1.20	2.000	2.006	75.9	75.9	1.597	1.231	0.997	
1.20	2.000	2.006	75.9	75.9	1.588	1.238	0.997	0.997

AVERAGE Y_{ds} 0.998

$$Y_{ds} = \frac{V_w(t_{ds} + t_{std})}{V_{ds}(t_w + t_{std})} * \left(\frac{P_{bar}}{P_{bar} + P_m / 13.6} \right)$$

$$Q = 17.64 \frac{P_{bar}}{(t_w + t_{std})} \frac{V_w}{\Phi}$$


Dry gas meter Serial Number 356333 was calibrated in accordance with the Code of Federal Regulations, Title 40, Part 60, Appendix A, Method 5 Section 16.1.1


Signature

Calibration Date: 10-10-2017

Calibration Technician: EW


Meter Gamma vs Flowrate



Console Model: T-200

Calibration Date: 10-10-2017

Calibration Technician: EW



Console Serial: 27979

Console Model: T-200

Advanced Industrial Resources, Inc.

Thermocouple Calibration Data

Thermometer ID: RT-01 ; RT-03

Date: 01/04/21

Bias: 0

Performed By: SS

Apparatus ID	Apparatus Description	Reference Temperature Reading		Indicated Temperature		Relative Variation
		°F	°R	°F	°R	
P7-02	Stack Temp.	32	492	33	493	0.2
P7-02	Stack Temp.	210	670	211	671	0.1
B-18	Filter Temp.	32	492	32	492	0.0
B-18	Filter Temp.	210	670	210	670	0.0
B-18	Exit Imp. Temp.	32	492	33	493	0.2
B-18	Exit Imp. Temp.	210	670	210	670	0.0
C-018	Meter In Temp.	32	492	33	493	0.2
C-018	Meter In Temp.	210	670	211	671	0.1
C-018	Meter Out Temp.	32	492	33	493	0.2
C-018	Meter Out Temp.	210	670	210	670	0.0
B-18	Filter Exit Temp.	32	492	33	493	0.2
B-18	Filter Exit Temp.	210	670	210	670	0.0
P7-02	Probe Temp.	32	492	33	493	0.2
P7-02	Probe Temp.	210	670	210	670	0.0

Thermocouple Calibration Procedure

A. References

1. Mercury-in-glass reference thermometer, calibrated against thermometric fixed points.
2. Thermometric fixed points, including ice bath and boiling water (corrected for barometric pressure)

B. Measurement

1. Compare field temperature sensors against the reference thermometer. Agreement must be within $\pm 1.5\%$ of the absolute reference temperature.

Advanced Industrial Resources, Inc.

Thermocouple Calibration Data

Thermometer ID: RT-01 ; RT-03

Date: 01/04/21

Bias: 0

Performed By: SS

Apparatus ID	Apparatus Description	Reference Temperature Reading		Indicated Temperature		Relative Variation
		°F	°R	°F	°R	
P7-01	Stack Temp.	32	492	32	492	0.0
P7-01	Stack Temp.	210	670	211	671	0.1
B-02	Filter Temp.	32	492	33	493	0.2
B-02	Filter Temp.	210	670	211	671	0.1
B-02	Exit Imp. Temp.	32	492	33	493	0.2
B-02	Exit Imp. Temp.	210	670	211	671	0.1
C-002	Meter In Temp.	32	492	32	492	0.0
C-002	Meter In Temp.	210	670	210	670	0.0
C-002	Meter Out Temp.	32	492	32	492	0.0
C-002	Meter Out Temp.	210	670	211	671	0.1
B-02	Filter Exit Temp.	32	492	33	493	0.2
B-02	Filter Exit Temp.	210	670	210	670	0.0
P7-01	Probe Temp.	32	492	33	493	0.2
P7-01	Probe Temp.	210	670	210	670	0.0

Thermocouple Calibration Procedure

A. References

1. Mercury-in-glass reference thermometer, calibrated against thermometric fixed points.
2. Thermometric fixed points, including ice bath and boiling water (corrected for barometric pressure)

B. Measurement

1. Compare field temperature sensors against the reference thermometer. Agreement must be within $\pm 1.5\%$ of the absolute reference temperature.

Advanced Industrial Resources, Inc.

Thermocouple Calibration Data

Thermometer ID: RT-01 ; RT-03

Date: 01/04/21

Bias: 0

Performed By: SS

Apparatus ID	Apparatus Description	Reference Temperature Reading		Indicated Temperature		Relative Variation
		°F	°R	°F	°R	
P5-04	Stack Temp.	32	492	33	493	0.2
P5-04	Stack Temp.	210	670	210	670	0.0
B-14	Filter Temp.	32	492	33	493	0.2
B-14	Filter Temp.	210	670	210	670	0.0
B-14	Exit Imp. Temp.	32	492	33	493	0.2
B-14	Exit Imp. Temp.	210	670	211	671	0.1
C-014	Meter In Temp.	32	492	32	492	0.0
C-014	Meter In Temp.	210	670	211	671	0.1
C-014	Meter Out Temp.	32	492	32	492	0.0
C-014	Meter Out Temp.	210	670	210	670	0.0
B-14	Filter Exit Temp.	32	492	33	493	0.2
B-14	Filter Exit Temp.	210	670	210	670	0.0
P5-04	Probe Temp.	32	492	33	493	0.2
P5-04	Probe Temp.	210	670	211	671	0.1

Thermocouple Calibration Procedure

A. References

1. Mercury-in-glass reference thermometer, calibrated against thermometric fixed points.
2. Thermometric fixed points, including ice bath and boiling water (corrected for barometric pressure)

B. Measurement

1. Compare field temperature sensors against the reference thermometer. Agreement must be within $\pm 1.5\%$ of the absolute reference temperature.

Advanced Industrial Resources, Inc.

Thermocouple Calibration Data

Thermometer ID: RT-01 ; RT-03

Date: 01/04/21

Bias: 0

Performed By: SS

Apparatus ID	Apparatus Description	Reference Temperature Reading		Indicated Temperature		Relative Variation
		°F	°R	°F	°R	
P4-01	Stack Temp.	32	492	33	493	0.2
P4-01	Stack Temp.	210	670	210	670	0.0
B-14	Filter Temp.	32	492	32	492	0.0
B-14	Filter Temp.	210	670	211	671	0.1
B-14	Exit Imp. Temp.	32	492	33	493	0.2
B-14	Exit Imp. Temp.	210	670	210	670	0.0
C-003	Meter In Temp.	32	492	33	493	0.2
C-003	Meter In Temp.	210	670	210	670	0.0
C-003	Meter Out Temp.	32	492	32	492	0.0
C-003	Meter Out Temp.	210	670	210	670	0.0
B-14	Filter Exit Temp.	32	492	33	493	0.2
B-14	Filter Exit Temp.	210	670	210	670	0.0
P4-01	Probe Temp.	32	492	32	492	0.0
P4-01	Probe Temp.	210	670	210	670	0.0

Thermocouple Calibration Procedure

A. References

1. Mercury-in-glass reference thermometer, calibrated against thermometric fixed points.
2. Thermometric fixed points, including ice bath and boiling water (corrected for barometric pressure)

B. Measurement

1. Compare field temperature sensors against the reference thermometer. Agreement must be within $\pm 1.5\%$ of the absolute reference temperature.

VERIFICATION OF CONSTRUCTION SPECIFICATIONS FOR THE
TYPE-S PITOT TUBE

Thomas R. Clark, Wade Mason, Paul Reinerma III
PEDCO Environmental, Inc.,
Cincinnati, Ohio

Revisions to EPA Reference Method 2 - Determination of Stack Gas Velocity and Volumetric Flow Rate (Type-S Pitot Tube) - promulgated August 18, 1977, exempted certain pitot tubes from calibration and included appropriate construction criteria and application guidelines.

Figure 1 summarizes procedures for determining the calibration coefficients of Type-S pitot tubes. A pitot tube may be calibrated using procedures outlined in Method 2 or assigned a baseline coefficient (C_p) of 0.84 if it meets the following criteria:

- Pitot tube meets the construction criteria of Figures 2 and 3

- The external tubing diameter (D_t) is between 0.48 and 0.95 cm (3/16 and 3/8 in.)

- The base-to-opening plane distances (P_A and P_B) are equal and range between 1.05 and 1.50 D_t

- The pitot tube is used separately, or in a pitot-probe assembly, mounted in accordance with the specifications in Figures 4 and 5

Pitot tubes that meet the construction criteria of Figures 2 and 3, but do not meet the specified limits for D_t , P_A , and P_B may be used, but must be calibrated.




Figure 1. Procedures for determining the calibration coefficients of Type-S pitot tubes.




Figure 2. Properly constructed Type-S pitot tube, shown in: (a) end view; face opening planes perpendicular to transverse axis; (b) top view; face opening plans parallel to longitudinal axis; (c) side view; both legs of equal length and centerlines coincident, when viewed from both sides. Baseline coefficient values of 0.84 may be assigned to pitot tubes constructed this way.






Figure 3. Types of face-opening misalignment that can result from field use or improper construction of Type S pitot tubes. These will not affect C_p as long as α_1 and $\alpha_2 < 10^\circ$, $\beta_2 < 5^\circ$, $z < 0.32$ cm (1/8 in.) and $w < 0.08$ cm (1/32 in.).



A. BOTTOM VIEW: SHOWING MINIMUM PITOT-NOZZLE SEPARATION.



B. SIDE VIEW: TO PREVENT PITOT TUBE FROM INTERFERING WITH GAS FLOW STREAMLINES APPROACHING THE NOZZLE, THE IMPACT PRESSURE OPENING PLANE OF THE PITOT TUBE SHALL BE EVEN WITH OR ABOVE THE NOZZLE ENTRY PLANE.

Figure 4. Required pitot tube - sampling nozzle configuration to prevent aerodynamic interference; buttonhook - type nozzle; centers of nozzle and pitot opening aligned; D_t between 0.48 and 0.95 cm (3/16 and 3/8 in.).




Figure 5. Required thermocouple and probe placement to prevent interference; D_t between 0.48 and 0.95 cm (3/16 and 3/8 in.).

The EPA has not specified a measurement technique to verify proper construction. The following procedures provide a quick and accurate method of checking construction specifications for Type-S pitot tubes. The apparatus is inexpensive and available in most hardware stores. The method can be used in the laboratory by testers and easily adapted to field use by agency personnel while witnessing tests or performing quality assurance checks.

1. Obtain a section of angle aluminum approximately 20 cm (8 in.) by 1.3 x 2.5 cm (0.5 x 1.0 in.). Mount a bull's-eye level (with ± 1 degree accuracy) to the angle aluminum, as shown in Figure 6. After mounting the bull's-eye level to the angle aluminum, level the angle aluminum and place the degree-indicating level in the parallel and perpendicular positions. The indicating level should not read more than 1 degree in either position.

2. Place the pitot tube in the angle aluminum as shown in Figure 6, and level the pitot tube as indicated by the bull's-eye level. A vise may be used to hold the angle aluminum and pitot tube in the laboratory and a C-clamp in the field.

Note: A permanently mounted pitot tube and probe assembly may require a shorter section of angle aluminum to allow proper mounting on the assembly.

3. Place a degree-indicating level in the various positions, as illustrated in Figures 7 and 8.

4. Measure distances P_A and P_B with a micrometer.






Figure 6. Type S pitot tube dimension specialization measurements.

DEGREE INDICATING LEVEL POSITION
FOR DETERMINING β_1 and β_2



DEGREE INDICATING LEVEL
POSITION FOR DETERMINING
 α_1 and α_2







Figure 7. Position of dimension measurement.



DEGREE INDICATING LEVEL POSITION
FOR DETERMINING γ , THEN CALCULATING Z.



DEGREE INDICATING LEVEL
POSITION FOR DETERMINING θ , THEN CALCULATE W.

Figure 8. Position of dimension measurement.

5. Measure the external tube diameter (D_t). Record all data on a data sheet such as Figure 9.

6. Calculate dimensions w and z using the following equations:

$$w = A \sin \theta \quad \text{Equation 1}$$

$$z = A \sin \gamma \quad \text{Equation 2}$$

where,

w = alignment dimension, cm (in.)

z = alignment dimension, cm (in.)

A = distance between tips, ($P_A + P_B$), cm (in.)

θ = angle in degrees

γ = angle in degrees.

Note: Pitot tubes with bent or damaged tubing may be difficult to check using this procedure.

If the Type-S pitot tube meets the face alignment criteria, an identification number should be assigned and permanently marked or engraved on the body of the tube.

References

1. Federal Register, Vol. 42. No. 160, August 18, 1977.

Advanced Industrial Resources, Inc.

Type-S Pitot Tube Assembly Inspection Data Sheet

Date: 1/5/2021

Pitot Tube Assembly: P5-04 Caliper ID: CP-02

Performed by: SS

Pitot tube assembly level? x yes no

Pitot tube openings damaged? yes (explain below) x no

$\alpha_1 =$ 0 $^{\circ}(<10^{\circ})$ $\beta_1 =$ 2 $^{\circ}(<5^{\circ})$

$\alpha_2 =$ 0 $^{\circ}(<10^{\circ})$ $\beta_2 =$ 1 $^{\circ}(<5^{\circ})$

$\gamma =$ 2 $^{\circ}$ $\theta =$ 0 $^{\circ}$ $A =$ 0.92 in.

$z = A \sin \gamma =$ 0.0321 in. $<1/8$ in. (0.125 in.)

$w = A \sin \theta =$ 0.0000 in. $<1/32$ in. (0.03125 in.)

$P_A =$ 0.460 in. $P_B =$ 0.460 in.

$D_t =$ 0.375 cm (in.) $P / D_t =$ 1.23 (1.05 \leq and \leq 1.50)

$P_a = P_b = P$

$X =$ 1 (>0.75 in.) (Dist. between pitot and nozzle)

$Y =$ 3.31 (>3.0 in.) (Dist. from nozzle union to pitot tube openings)

$Z =$ 1.65 (>0.75 in.) (Dist. between pitot and stack thermocouple)

Does the pitot tube assembly meet the Method 2 requirements? x yes

 no (explain below)

If the Method 2 requirements are met then a coefficient of **0.84** is assigned
to the pitot tube assembly being inspected.

Advanced Industrial Resources, Inc.

Type-S Pitot Tube Assembly Inspection Data Sheet

Date: 1/5/2021

Pitot Tube Assembly: P4-01 Caliper ID: CP-02

Performed by: SS

Pitot tube assembly level? X yes no

Pitot tube openings damaged? yes (explain below) X no

$\alpha_1 =$ 2 $^{\circ}(<10^{\circ})$ $\beta_1 =$ 1 $^{\circ}(<5^{\circ})$

$\alpha_2 =$ 2 $^{\circ}(<10^{\circ})$ $\beta_2 =$ 2 $^{\circ}(<5^{\circ})$

$\gamma =$ 2 1 $^{\circ}$ $A =$ 0.97 in.

$z = A \sin \gamma =$ 0.0338 in. $< 1/8$ in. (0.125 in.)

$w = A \sin \theta =$ 0.0169 in. $< 1/32$ in. (0.03125 in.)

$P_A =$ 0.485 in. $P_B =$ 0.485 in.

$D_t =$ 0.385 cm (in.) $P / D_t =$ 1.26 (1.05 \leq and \leq 1.50)

$P_a = P_b = P$

$X =$ 1.1 (>0.75 in.) (Dist. between pitot and nozzle)

$Y =$ 3.52 (>3.0 in.) (Dist. from nozzle union to pitot tube openings)

$Z =$ 1.27 (>0.75 in.) (Dist. between pitot and stack thermocouple)

Does the pitot tube assembly meet the Method 2 requirements? X yes

 no (explain below)

If the Method 2 requirements are met then a coefficient of **0.84** is assigned
to the pitot tube assembly being inspected.

Advanced Industrial Resources, Inc.

Type-S Pitot Tube Assembly Inspection Data Sheet

Date: 1/5/2021

Pitot Tube Assembly: P7-01 Caliper ID: CP-02

Performed by: SS

Pitot tube assembly level? x yes no

Pitot tube openings damaged? yes (explain below) x no

$\alpha_1 =$ 1 $^{\circ}(<10^{\circ})$ $\beta_1 =$ 0 $^{\circ}(<5^{\circ})$

$\alpha_2 =$ 0 $^{\circ}(<10^{\circ})$ $\beta_2 =$ 0 $^{\circ}(<5^{\circ})$

$\gamma =$ 1 $^{\circ}$ $\theta =$ 0 $^{\circ}$ $A =$ 0.93 in.

$z = A \sin \gamma =$ 0.0162 in. $<1/8$ in. (0.125 in.)

$w = A \sin \theta =$ 0.0000 in. $<1/32$ in. (0.03125 in.)

$P_A =$ 0.465 in. $P_B =$ 0.465 in.

$D_t =$ 0.375 cm (in.) $P / D_t =$ 1.24 (1.05 \leq and \leq 1.50)

$P_a = P_b = P$

$X =$ 1.11 (>0.75 in.) (Dist. between pitot and nozzle)

$Y =$ 3.71 (>3.0 in.) (Dist. from nozzle union to pitot tube openings)

$Z =$ 2.03 (>0.75 in.) (Dist. between pitot and stack thermocouple)

Does the pitot tube assembly meet the Method 2 requirements? x yes

 no (explain below)

If the Method 2 requirements are met then a coefficient of **0.84** is assigned
to the pitot tube assembly being inspected.

Advanced Industrial Resources, Inc.

Type-S Pitot Tube Assembly Inspection Data Sheet

Date: 1/5/2021

Pitot Tube Assembly: P7-02 Caliper ID: CP-02

Performed by: SS

Pitot tube assembly level? x yes no

Pitot tube openings damaged? yes (explain below) x no

$\alpha_1 =$ 0 $^{\circ}(<10^{\circ})$ $\beta_1 =$ 1 $^{\circ}(<5^{\circ})$

$\alpha_2 =$ 1 $^{\circ}(<10^{\circ})$ $\beta_2 =$ 0 $^{\circ}(<5^{\circ})$

$\gamma =$ 1 $^{\circ}$ $\theta =$ 1 $^{\circ}$ $A =$ 1 in.

$z = A \sin \gamma =$ 0.0174 in. $<1/8$ in. (0.125 in.)

$w = A \sin \theta =$ 0.0174 in. $<1/32$ in. (0.03125 in.)

$P_A =$ 0.500 in. $P_B =$ 0.500 in.

$D_t =$ 0.375 cm (in.) $P / D_t =$ 1.33 (1.05 \leq and \leq 1.50)

$P_a = P_b = P$

$X =$ 1.57 (>0.75 in.) (Dist. between pitot and nozzle)

$Y =$ 3.75 (>3.0 in.) (Dist. from nozzle union to pitot tube openings)

$Z =$ 1.2 (>0.75 in.) (Dist. between pitot and stack thermocouple)

Does the pitot tube assembly meet the Method 2 requirements? x yes

 no (explain below)

If the Method 2 requirements are met then a coefficient of **0.84** is assigned
to the pitot tube assembly being inspected.

APPENDIX C

LABORATORY ANALYTICAL REPORT

1/11/2021

Mr. Robert DeMott
Ramboll Environ
10150 Highland Manor Drive
Suite 440
Tampa FL 33610

Project Name: K&S Bard
Project #: 1690014483
Workorder #: 2101012

Dear Mr. Robert DeMott

The following report includes the data for the above referenced project for sample(s) received on 1/4/2021 at Eurofins Air Toxics LLC.

The data and associated QC analyzed by Modified TO-15 SIM are compliant with the project requirements or laboratory criteria with the exception of the deviations noted in the attached case narrative.

Thank you for choosing Eurofins Air Toxics LLC. for your air analysis needs. Eurofins Air Toxics Inc. is committed to providing accurate data of the highest quality. Please feel free to contact the Project Manager: Brian Whittaker at 916-985-1000 if you have any questions regarding the data in this report.

Regards,



Brian Whittaker
Project Manager

WORK ORDER #: 2101012

Work Order Summary

CLIENT:	Mr. Robert DeMott Ramboll 10150 Highland Manor Drive Suite 440 Tampa, FL 33610	BILL TO:	Accounts Payable Ramboll 10150 Highland Manor Drive Suite 440 Tampa, FL 33610
PHONE:	813-628-4325	P.O. #	
FAX:	813-628-4983	PROJECT #	1690014483 K&S Bard
DATE RECEIVED:	01/04/2021	CONTACT:	Brian Whittaker
DATE COMPLETED:	01/11/2021		

<u>FRACTION #</u>	<u>NAME</u>	<u>TEST</u>	<u>RECEIPT VAC./PRES.</u>	<u>FINAL PRESSURE</u>
01A	SYS-S2 20201231	Modified TO-15 SIM	8.5 "Hg	5 psi
02A	SYS-S3 20201231	Modified TO-15 SIM	7.5 "Hg	5 psi
03A	SYS-S5 20201231	Modified TO-15 SIM	7.5 "Hg	5 psi
04A	SYS-STACK 20201231	Modified TO-15 SIM	6.5 "Hg	5 psi
05A	SYS-STACK DUP 20201231	Modified TO-15 SIM	6.0 "Hg	5 psi
05AA	SYS-STACK DUP 20201231 Lab Duplicate	Modified TO-15 SIM	6.0 "Hg	5 psi
06A	Lab Blank	Modified TO-15 SIM	NA	NA
07A	CCV	Modified TO-15 SIM	NA	NA
08A	LCS	Modified TO-15 SIM	NA	NA
08AA	LCSD	Modified TO-15 SIM	NA	NA

CERTIFIED BY:



Technical Director

DATE: 01/11/21

Certification numbers: AZ Licensure AZ0775, FL NELAP – E87680, LA NELAP – 02089, NH NELAP - 209220, NJ NELAP - CA016, NY NELAP - 11291, TX NELAP - T104704434-20-16, UT NELAP – CA009332020-12, VA NELAP - 10615, WA NELAP - C935

Name of Accreditation Body: NELAP/ORELAP (Oregon Environmental Laboratory Accreditation Program)

Accreditation number: CA300005-014, Effective date: 10/18/2020, Expiration date: 10/17/2021.

Eurofins Air Toxics, LLC certifies that the test results contained in this report meet all requirements of the NELAC standards

This report shall not be reproduced, except in full, without the written approval of Eurofins Air Toxics, LLC.

180 BLUE RAVINE ROAD, SUITE B FOLSOM, CA - 95630

(916) 985-1000 . (800) 985-5955 . FAX (916) 351-8279

LABORATORY NARRATIVE
EPA TO-15 Ethylene oxide (SIM)
Ramboll Environ
Workorder# 2101012

Five 6 Liter Summa Canister (EO) samples were received on January 04, 2021. The laboratory performed analysis via EPA Method TO-15 using GC/MS in the SIM acquisition mode for the measurement of Ethylene oxide in ambient air.

Receiving Notes

There were no receiving discrepancies.

Analytical Notes

Ethylene Oxide is not included on the laboratory's NELAP scope of accreditation for TO-15 SIM. However, TO-15 method and NELAP quality requirements were met.

As per project specific client request the laboratory has reported estimated values for target compound hits that are below the Reporting Limit but greater than the Method Detection Limit. The canisters used for this project have been certified to half the Reporting Limit for Ethylene Oxide. Concentrations that are below the level at which the canister was certified may be false positives.

Dilution was performed on samples SYS-S2 20201231, SYS-S3 20201231 and SYS-S5 20201231 due to the presence of high level target species.

Definition of Data Qualifying Flags

Nine qualifiers may have been used on the data analysis sheets and indicates as follows:

B - Compound present in laboratory blank greater than reporting limit (background subtraction not performed).

J - Estimated value.

S - Saturated peak.

Q - Exceeds quality control limits.

U - Compound analyzed for but not detected above the reporting limit, LOD, or MDL value. See data page for project specific U-flag definition.

UJ- Non-detected compound associated with low bias in the CCV

N - The identification is based on presumptive evidence.

CN - See Case Narrative

File extensions may have been used on the data analysis sheets and indicates as follows:

a-File was requantified

b-File was quantified by a second column and detector

r1-File was requantified for the purpose of reissue

MODIFIED EPA METHOD TO-15 GC/MS SIM
K&S Bard

Client ID:	SYS-S2 20201231	Date/Time Analyzed:	1/6/21 07:07 PM
Lab ID:	2101012-01A	Dilution Factor:	7.48
Date/Time Collected:	12/31/20 01:52 PM	Instrument/Filename:	msd30.i / 30010614sim
Media:	6 Liter Summa Canister (EO)		

Compound	CAS#	MDL (ug/m3)	LOD (ug/m3)	Rpt. Limit (ug/m3)	Amount (ug/m3)
Ethylene Oxide	75-21-8	0.14	D	0.67	210

D: Analyte not within the DoD scope of accreditation.

MODIFIED EPA METHOD TO-15 GC/MS SIM
K&S Bard

Client ID:	SYS-S3 20201231	Date/Time Analyzed:	1/6/21 07:39 PM
Lab ID:	2101012-02A	Dilution Factor:	7.15
Date/Time Collected:	12/31/20 01:52 PM	Instrument/Filename:	msd30.i / 30010615sim
Media:	6 Liter Summa Canister (EO)		

Compound	CAS#	MDL (ug/m3)	LOD (ug/m3)	Rpt. Limit (ug/m3)	Amount (ug/m3)
Ethylene Oxide	75-21-8	0.13	D	0.64	1100

D: Analyte not within the DoD scope of accreditation.

MODIFIED EPA METHOD TO-15 GC/MS SIM
K&S Bard

Client ID:	SYS-S5 20201231	Date/Time Analyzed:	1/6/21 08:10 PM
Lab ID:	2101012-03A	Dilution Factor:	7.15
Date/Time Collected:	12/31/20 01:52 PM	Instrument/Filename:	msd30.i / 30010616sim
Media:	6 Liter Summa Canister (EO)		

Compound	CAS#	MDL (ug/m3)	LOD (ug/m3)	Rpt. Limit (ug/m3)	Amount (ug/m3)
Ethylene Oxide	75-21-8	0.13	D	0.64	110

D: Analyte not within the DoD scope of accreditation.

MODIFIED EPA METHOD TO-15 GC/MS SIM
K&S Bard

Client ID:	SYS-STACK 20201231	Date/Time Analyzed:	1/6/21 06:35 PM
Lab ID:	2101012-04A	Dilution Factor:	1.71
Date/Time Collected:	12/31/20 01:52 PM	Instrument/Filename:	msd30.i / 30010613sim
Media:	6 Liter Summa Canister (EO)		

Compound	CAS#	MDL (ug/m3)	LOD (ug/m3)	Rpt. Limit (ug/m3)	Amount (ug/m3)
Ethylene Oxide	75-21-8	0.032	D	0.15	36

D: Analyte not within the DoD scope of accreditation.

MODIFIED EPA METHOD TO-15 GC/MS SIM
K&S Bard

Client ID:	SYS-STACK DUP 20201231	Date/Time Analyzed:	1/6/21 05:25 PM
Lab ID:	2101012-05A	Dilution Factor:	1.68
Date/Time Collected:	12/31/20 01:52 PM	Instrument/Filename:	msd30.i / 30010611sim
Media:	6 Liter Summa Canister (EO)		

Compound	CAS#	MDL (ug/m3)	LOD (ug/m3)	Rpt. Limit (ug/m3)	Amount (ug/m3)
Ethylene Oxide	75-21-8	0.031	D	0.15	37

D: Analyte not within the DoD scope of accreditation.

MODIFIED EPA METHOD TO-15 GC/MS SIM
K&S Bard

Client ID:	SYS-STACK DUP 20201231 Lab Duplicate	Date/Time Analyzed:	1/6/21 06:00 PM
Lab ID:	2101012-05AA	Dilution Factor:	1.68
Date/Time Collected:	12/31/20 01:52 PM	Instrument/Filename:	msd30.i / 30010612sim
Media:	6 Liter Summa Canister (EO)		

Compound	CAS#	MDL (ug/m3)	LOD (ug/m3)	Rpt. Limit (ug/m3)	Amount (ug/m3)
Ethylene Oxide	75-21-8	0.031	D	0.15	37

D: Analyte not within the DoD scope of accreditation.

MODIFIED EPA METHOD TO-15 GC/MS SIM
K&S Bard

Client ID:	Lab Blank	Date/Time Analyzed:	1/6/21 12:08 PM
Lab ID:	2101012-06A	Dilution Factor:	1.00
Date/Time Collected:	NA - Not Applicable	Instrument/Filename:	msd30.i / 30010605sim
Media:	NA - Not Applicable		

Compound	CAS#	MDL (ug/m3)	LOD (ug/m3)	Rpt. Limit (ug/m3)	Amount (ug/m3)
Ethylene Oxide	75-21-8	0.019	D	0.090	Not Detected

D: Analyte not within the DoD scope of accreditation.

MODIFIED EPA METHOD TO-15 GC/MS SIM
K&S Bard

Client ID:	CCV	Date/Time Analyzed:	1/6/21 10:29 AM
Lab ID:	2101012-07A	Dilution Factor:	1.00
Date/Time Collected:	NA - Not Applicable	Instrument/Filename:	msd30.i / 30010602sim
Media:	NA - Not Applicable		

Compound	CAS#	%Recovery
Ethylene Oxide	75-21-8	108

D: Analyte not within the DoD scope of accreditation.

MODIFIED EPA METHOD TO-15 GC/MS SIM
K&S Bard

Client ID:	LCS	Date/Time Analyzed:	1/6/21 11:01 AM
Lab ID:	2101012-08A	Dilution Factor:	1.00
Date/Time Collected:	NA - Not Applicable	Instrument/Filename:	msd30.i / 30010603sim
Media:	NA - Not Applicable		

Compound	CAS#	%Recovery
Ethylene Oxide	75-21-8	92

D: Analyte not within the DoD scope of accreditation.

* % Recovery is calculated using unrounded analytical results.

MODIFIED EPA METHOD TO-15 GC/MS SIM
K&S Bard

Client ID:	LCSD	Date/Time Analyzed:	1/6/21 11:33 AM
Lab ID:	2101012-08AA	Dilution Factor:	1.00
Date/Time Collected:	NA - Not Applicable	Instrument/Filename:	msd30.i / 30010604sim
Media:	NA - Not Applicable		

Compound	CAS#	%Recovery
Ethylene Oxide	75-21-8	91

D: Analyte not within the DoD scope of accreditation.

* % Recovery is calculated using unrounded analytical results.

LABSAMPID	LABCODE	MATRIX	METHOD	CLIENTSAMPID	SAMPDATE	ANALDATE	ANALTIME	LABCTUD	DILUTION	REPLMT	UNITS	RESULTS	DATAFLAGS	REPLMT	(ug/n)	UNITS	(ug/n)	RESULTS	(ug/n)	DATAFLAGS	COMPOUND NAME	CASNUM	COMMENTS
2101012-01A	ATL	AIR	TO-15	SYS-S2 20201231	12/31/2020	01/06/2021	1907	msd3006JAN21	7.48	0.67	UG/M3	210		0.67	UG/M3	210					Ethylene Oxide	75-21-8	
2101012-02A	ATL	AIR	TO-15	SYS-S3 20201231	12/31/2020	01/06/2021	1939	msd3006JAN21	7.15	0.64	UG/M3	1100		0.64	UG/M3	1100					Ethylene Oxide	75-21-8	
2101012-03A	ATL	AIR	TO-15	SYS-S5 20201231	12/31/2020	01/06/2021	2010	msd3006JAN21	7.15	0.64	UG/M3	110		0.64	UG/M3	110					Ethylene Oxide	75-21-8	
2101012-04A	ATL	AIR	TO-15	SYS-STACK 20201231	12/31/2020	01/06/2021	1835	msd3006JAN21	1.71	0.15	UG/M3	36		0.15	UG/M3	36					Ethylene Oxide	75-21-8	
2101012-05A	ATL	AIR	TO-15	SYS-STACK DUP 20201231	12/31/2020	01/06/2021	1725	msd3006JAN21	1.68	0.15	UG/M3	37		0.15	UG/M3	37					Ethylene Oxide	75-21-8	
2101012-05AA	ATL	AIR	TO-15	SYS-STACK DUP 20201231 Lab	12/31/2020	01/06/2021	1800	msd3006JAN21	1.68	0.15	UG/M3	37		0.15	UG/M3	37					Ethylene Oxide	75-21-8	
2101012-06A	ATL	AIR	TO-15	Lab Blank	00:00	01/06/2021	1208	msd3006JAN21	1.00	0.090	UG/M3		ND	0.090	UG/M3		ND				Ethylene Oxide	75-21-8	
2101012-07A	ATL	AIR	TO-15	CCV	00:00	01/06/2021	1029	msd3006JAN21	1.00		%R	108			%R	108					Ethylene Oxide	75-21-8	
2101012-08A	ATL	AIR	TO-15	LCS	00:00	01/06/2021	1101	msd3006JAN21	1.00		%R	92			%R	92					Ethylene Oxide	75-21-8	
2101012-08AA	ATL	AIR	TO-15	LCSD	00:00	01/06/2021	1133	msd3006JAN21	1.00		%R	91			%R	91					Ethylene Oxide	75-21-8	