



GEORGIA

DEPARTMENT OF NATURAL RESOURCES

ENVIRONMENTAL PROTECTION DIVISION

GEORGIA ENVIRONMENTAL PROTECTION DIVISION
 UNDERGROUND STORAGE TANK MANAGEMENT PROGRAM
 CATHODIC PROTECTION EVALUATION FORM FOR
GALVANIC SYSTEM (SACRIFICIAL ANODE)

Questions on how to complete this form should be directed to the EPD,
 UST Regulatory Compliance Unit at (404) 362-2687

1. Galvanic cathodic protection systems must be tested:

- a. In accordance with the latest edition code of practice established by the National Association of Corrosion Engineers (TM0101),
 - b. By a qualified cathodic protection tester within 6 months of installation and repair of any portion of the UST system, and every 3 years.
2. Please use photocopies of the appropriate pages if you have more than 4 tanks at any one location.
 3. Please remove all pages that do not apply to the site.
 4. The UST owner is required to keep a record of the last two (2) cathodic protection evaluations from the date of test, on a form acceptable to EPD.

I. OWNER INFORMATION		II. FACILITY INFORMATION	
Owner:		Facility Name:	
Address:		Location (facility) ID#:	
City, state, Zip Code:		City, County:	
Phone Number:		Phone Number:	
III. REASON SURVEY WAS CONDUCTED (mark only one)			
<input type="checkbox"/> Installation of new tank		<input type="checkbox"/> Routine-3 year test	
<input type="checkbox"/> Re-survey after repair/modification			
Date next cathodic protection survey must be conducted by _____ (required within 6 months of installation/repair & every 3 years thereafter).			
IV. CATHODIC PROTECTION TESTER'S EVALUATION			
<ol style="list-style-type: none"> 1. If any portion of the system fails, the system fails, and "Fail" should be marked below. 2. Repairs/modifications are required to be designed and evaluated by a corrosion expert. 			
<input type="checkbox"/> Pass		<i>I certify that all structures at this facility "pass" the cathodic protection testing and in my best judgement, adequate cathodic protection has been provided to the UST system. No further action is necessary at this time.</i>	
<input type="checkbox"/> Fail		<i>I certify that one or more structures at this facility "fail" the cathodic protection testing and in my best judgement, adequate cathodic protection has <u>NOT</u> been provided to the UST system. The cathodic protection system must be repaired in accordance with a code of practice developed by a nationally recognized association or independent laboratory, and re-tested within 6 months following the repair, and signed by corrosion expert.</i>	
Name:		Name of Company:	
Certifying Organization:		Address:	
Type of Certification:		City, State, Zip Code:	
Date of Certification:		Phone Number:	
Signature:		Date survey performed:	
V. CORROSION EXPERT EVALUATION			
The survey must be conducted and/or evaluated by a corrosion expert when: a) repairs to galvanized or uncoated steel piping are conducted or b) supplemental anodes are added to the tanks and/or piping without following an accepted industry code.			
<input type="checkbox"/> Pass		<i>I certify that all structures at this facility "pass" the cathodic protection testing and in my best judgement, adequate cathodic protection has been provided to the UST system. No further action is necessary at this time</i>	
<input type="checkbox"/> Fail		<i>I certify that one or more structures at this facility "fail" the cathodic protection testing and in my best judgement, adequate cathodic protection has <u>NOT</u> been provided to the UST system. The cathodic protection system must be repaired in accordance with a code of practice developed by a nationally recognized association or independent laboratory, and re-tested within 6 months following the repair.</i>	
Corrosion Expert Name:		Name of Company:	
Corrosion Expert Certification:		Address:	
Type of Certification/Certification Number:		City, State, Zip Code:	
Signature:		Date:	Phone #:

V. Description of Cathodic Protection System Repairs and/or Comments

1. If applicable, describe the repairs in detail below and provide a sketch of the location and depth of any new anodes.
2. If repairs are made, provide the code of practice information below such as the Steel Tank Institute Standard R-972-01 "Recommended Practice for the Addition of Supplemental Anodes to STI-P3 USTs".

Association or Independent Laboratory:

Code of Practice Name:

Code of Practice Number:

Code of Practice Date:

VI. Underground Storage Tank Facility Site Drawing

1. In the space below, sketch the important parts of the facility such as tanks, manways, fill pipes, tank monitor, vapor recovery connections, piping, vents, drilled test ports, anodes, pump islands, and buildings.
2. Indicate reference cell locations using location code "R" and sequential numbers (e.g. R1, R2) and structure contact points using the location code "S" and sequential numbers (e.g. S1, S2) as used in the tables on the following pages.
3. For each tank, include Location (Facility) ID number and/or product stored. Use the letter and number designations from the tables on the following pages to indicate reference cell locations and structure contact locations used for each measurement.

VII. Underground Storage Tanks Continuity Test Results (Galvanic Systems)

1. The "Location Code" must be used to locate the reference cell and structure contact points on the drawing of the facility as discussed on page 2.
2. Record continuity test measurements using "Fixed Cell, Moving Ground Technique", or the structure-to-structure "Potential Difference Technique".
3. When using the "Fixed Cell, Moving Ground Technique", the reference cell must be placed in the soil at a location remote from the UST system (not within potential gradient of anodes or shielded by other tanks or structures) and left undisturbed until continuity testing is completed.
4. If one continuity method fails to conclusively show proper isolation, the other method may be used to try to show proper isolation.
5. Metallic structures are isolated when the "Voltage Potential" difference between two structures is greater than 10 mv, continuous when 10 mv or less.
6. All single and double wall metal tanks should be isolated from all other metallic structures to maximize the life of the tank's galvanic cathodic protection system.

Location Code	Reference Cell Location and Structure Contact Points (Check all available points)	Voltage Potential (negative millivolts)	Results/Comments (Check the one that applies)
R	*		
Tank (# _____), Grade of Product Stored _____, Size in Gallons _____			
S _____	(Tank bottom)(test lead)(_____)**	- mv	(continuous) (isolated)
S _____	Submersible pump	- mv	(continuous) (isolated)
S _____	Fill pipe	- mv	(continuous) (isolated)
S _____	Tank monitor	- mv	(continuous) (isolated)
S _____	Vapor recovery connection	- mv	(continuous) (isolated)
S _____	Vent line	- mv	(continuous) (isolated)
S _____	Other (e.g. blind riser) ***	- mv	(continuous) (isolated)
S _____	Other ***	- mv	(continuous) (isolated)
S _____	Other ***	- mv	(continuous) (isolated)
S _____	Other ***	- mv	(continuous) (isolated)
Tank (# _____), Grade of Product Stored _____, Size in Gallons _____			
S _____	(Tank bottom)(test lead)(_____)**	- mv	(continuous) (isolated)
S _____	Submersible pump	- mv	(continuous) (isolated)
S _____	Fill pipe	- mv	(continuous) (isolated)
S _____	Tank monitor	- mv	(continuous) (isolated)
S _____	Vapor recovery connection	- mv	(continuous) (isolated)
S _____	Vent line	- mv	(continuous) (isolated)
S _____	Other ***	- mv	(continuous) (isolated)
S _____	Other ***	- mv	(continuous) (isolated)
S _____	Other ***	- mv	(continuous) (isolated)
S _____	Other ***	- mv	(continuous) (isolated)
Tank (# _____), Grade of Product Stored _____, Size in Gallons _____			
S _____	(Tank bottom)(test lead)(_____)**	- mv	(continuous) (isolated)
S _____	Submersible pump	- mv	(continuous) (isolated)
S _____	Fill pipe	- mv	(continuous) (isolated)
S _____	Tank monitor	- mv	(continuous) (isolated)
S _____	Vapor recovery connection	- mv	(continuous) (isolated)
S _____	Vent line	- mv	(continuous) (isolated)
S _____	Other ***	- mv	(continuous) (isolated)
S _____	Other ***	- mv	(continuous) (isolated)
S _____	Other ***	- mv	(continuous) (isolated)
S _____	Other ***	- mv	(continuous) (isolated)
Tank (# _____), Grade of Product Stored _____, Size in Gallons _____			
S _____	(Tank bottom)(test lead)(_____)**	- mv	(continuous) (isolated)
S _____	Submersible pump	- mv	(continuous) (isolated)
S _____	Fill pipe	- mv	(continuous) (isolated)
S _____	Tank monitor	- mv	(continuous) (isolated)
S _____	Vapor recovery connection	- mv	(continuous) (isolated)
S _____	Vent line	- mv	(continuous) (isolated)
S _____	Other ***	- mv	(continuous) (isolated)
S _____	Other ***	- mv	(continuous) (isolated)
S _____	Other ***	- mv	(continuous) (isolated)
S _____	Other ***	- mv	(continuous) (isolated)

*Describe remote location of reference cell for "Fixed Cell, Moving Ground Technique". N/A for structure-to-structure "Potential Difference Technique".

**Indicate base structure contact point for both techniques. Mark all that do NOT apply. Make sure tank is not internally lined before using tank bottom.

***Describe location of any other contact points measured.

VIII. Underground Storage Tanks Structure-to-Soil Test Results (Galvanic Systems)

1. The "Location Code" must be used to locate the reference cell and structure contact points on the drawing of the facility as discussed on page 2.
2. A minimum of 3 tank voltage measurements must be taken; one while the reference cell is placed in the soil as close to the middle of the tank as possible and the others while the reference cell is placed in the soil as close as possible to each end of the tank (but not directly over anodes).
3. All single and double wall metal tanks using a galvanic cathodic protection system, must have all voltage measurements equal to or more negative than -850 mv to be protected from corrosion and pass the structure-to-soil test.

Location Code	Structure Contact Point and Reference Cell Locations	Voltage (negative millivolts)	Results/Comments (Check the one that applies)
<i>Tank (# _____)</i>			
S _____	(Tank bottom)(test lead)(_____)*		
R _____	Soil near submersible pump manway	- mv	(pass) (fail)
R _____	Soil near tank monitor manway	- mv	(pass) (fail)
R _____	Soil near vapor recovery manway	- mv	(pass) (fail)
R _____	Soil near vent riser	- mv	(pass) (fail)
R _____	Other _____ <i>e.g. blind riser</i> **	- mv	(pass) (fail)
R _____	Other _____ **	- mv	(pass) (fail)
R _____	Other _____ **	- mv	(pass) (fail)
R _____	Other _____ **	- mv	(pass) (fail)
<i>Tank (# _____)</i>			
S _____	(Tank bottom)(test lead)(_____)*		
R _____	Soil near submersible pump manway	- mv	(pass) (fail)
R _____	Soil near tank monitor manway	- mv	(pass) (fail)
R _____	Soil near vapor recovery manway	- mv	(pass) (fail)
R _____	Soil near vent riser	- mv	(pass) (fail)
R _____	Other _____ **	- mv	(pass) (fail)
R _____	Other _____ **	- mv	(pass) (fail)
R _____	Other _____ **	- mv	(pass) (fail)
R _____	Other _____ **	- mv	(pass) (fail)
<i>Tank (# _____)</i>			
S _____	(Tank bottom)(test lead)(_____)*		
R _____	Soil near submersible pump manway	- mv	(pass) (fail)
R _____	Soil near tank monitor manway	- mv	(pass) (fail)
R _____	Soil near vapor recovery manway	- mv	(pass) (fail)
R _____	Soil near vent riser	- mv	(pass) (fail)
R _____	Other _____ **	- mv	(pass) (fail)
R _____	Other _____ **	- mv	(pass) (fail)
R _____	Other _____ **	- mv	(pass) (fail)
R _____	Other _____ **	- mv	(pass) (fail)
<i>Tank (# _____)</i>			
S _____	(Tank bottom)(test lead)(_____)*		
R _____	Soil near submersible pump manway	- mv	(pass) (fail)
R _____	Soil near tank monitor manway	- mv	(pass) (fail)
R _____	Soil near vapor recovery manway	- mv	(pass) (fail)
R _____	Soil near vent riser	- mv	(pass) (fail)
R _____	Other _____ **	- mv	(pass) (fail)
R _____	Other _____ **	- mv	(pass) (fail)
R _____	Other _____ **	- mv	(pass) (fail)
R _____	Other _____ **	- mv	(pass) (fail)

*Indicate base structure contact point. Mark all that do NOT apply. Make sure tank is not internally lined before using tank bottom.

**Describe location of any other reference cell location used.

IX. Underground Metal Product Piping Continuity Test Results (Galvanic Systems)

1. The "Location Code" must be used to locate the reference cell and structure contact points on the drawing of the facility as discussed on page 2.
2. Record continuity test measurements using "Fixed Cell, Moving Ground Technique", or the structure-to-structure "Potential Difference Technique".
3. When using the "Fixed Cell, Moving Ground Technique", the reference cell must be placed in the soil at a location remote from the UST system (not within potential gradient of anodes or shielded by other tanks or structures) and left undisturbed until continuity testing is completed.
4. If one continuity method fails to conclusively show proper isolation, the other method may be used to try to show proper isolation.
5. Metallic structures are isolated when the "Voltage Potential" difference between two structures is greater than 10 mv, continuous when 10 mv or less.
6. **All single and double wall metal piping should be isolated from all other metallic structures to maximize the life of the piping's galvanic cathodic protection system.**

Location Code	Reference Cell Location and Structure Contact Points (Check all available points)	Voltage Potential (negative millivolts)	Results/Comments (Check the one that applies)
R	_____*		
Tank (# _____) Metal Piping, Type of Metal (steel) (copper)(_____) Approximate Length of Piping in Feet _____			
S _____	(Piping)(flex conn.) at submersible pump**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	Other _____***	- mv	(continuous) (isolated)
S _____	Other _____***	- mv	(continuous) (isolated)
Tank (# _____) Metal Piping, Type of Metal (steel) (copper)(_____) Approximate Length of Piping in Feet _____			
S _____	(Piping)(flex conn.) at submersible pump**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	Other _____***	- mv	(continuous) (isolated)
S _____	Other _____***	- mv	(continuous) (isolated)
Tank (# _____) Metal Piping, Type of Metal (steel) (copper)(_____) Approximate Length of Piping in Feet _____			
S _____	(Piping)(flex conn.) at submersible pump**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	Other _____***	- mv	(continuous) (isolated)
S _____	Other _____***	- mv	(continuous) (isolated)
Tank (# _____) Metal Piping, Type of Metal (steel) (copper)(_____) Approximate Length of Piping in Feet _____			
S _____	(Piping)(flex conn.) at submersible pump**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	(Piping)(flex conn.) at dispenser # _____**	- mv	(continuous) (isolated)
S _____	Other _____***	- mv	(continuous) (isolated)
S _____	Other _____***	- mv	(continuous) (isolated)

*Describe remote location of reference cell for "Fixed Cell, Moving Ground Technique". N/A for structure-to-structure "Potential Difference Technique".

**Indicate piping and/or flex connector. Mark any that do NOT apply.

***Describe location of any other contact points measured.

X. Underground Metal Product Piping Structure-to-Soil Test Results (Galvanic Systems)

1. The "Location Code" must be used to locate the reference cell and structure contact points on the drawing of the facility as discussed on page 2.
2. Piping voltage measurements should be taken with the reference cell in the soil at both ends of the piping run (but not directly over anodes), and if the run is longer than 100 feet, in the soil as close as possible to the middle of the piping run (but not directly over anodes).
3. All single and double wall metal piping using a galvanic cathodic protection system, must have all voltage measurements equal to or more negative than -850 mv to be protected from corrosion and pass the structure-to-soil test.

Location Code	Structure Contact Point and Reference Cell Locations	Voltage (negative millivolts)	Results/Comments (Check the one that applies)
<i>Tank (#) Metal Piping</i>			
S ____	Product piping at (dispenser # _____) (sub pump) (_____)*		
R ____	Soil at submersible pump	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil at middle of piping run	- mv	(pass) (fail)
R ____	Other _____**	- mv	(pass) (fail)
<i>Tank (#) Metal Piping</i>			
S ____	Product piping at (dispenser # _____) (sub pump) (_____)*		
R ____	Soil at submersible pump	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil at middle of piping run	- mv	(pass) (fail)
R ____	Other _____**	- mv	(pass) (fail)
<i>Tank (#) Metal Piping</i>			
S ____	Product piping at (dispenser # _____) (sub pump) (_____)*		
R ____	Soil at submersible pump	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil at middle of piping run	- mv	(pass) (fail)
R ____	Other _____**	- mv	(pass) (fail)
<i>Tank (#) Metal Piping</i>			
S ____	Product piping at (dispenser # _____) (sub pump) (_____)*		
R ____	Soil at submersible pump	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil under dispenser # _____	- mv	(pass) (fail)
R ____	Soil at middle of piping run	- mv	(pass) (fail)
R ____	Other _____**	- mv	(pass) (fail)

*Indicate base structure contact point. Mark all that do NOT apply.

**Describe location of any other reference cell location used.