

**Sampling Results**

Becton, Dickinson and Company  
 Global Distribution Center, Covington, Georgia

**December 20-21, 2019**

Sample ID	Label	Section	Start Date	Start Time	Stop Date	Stop Time	Duration (hours)	Initial Vacuum (inches Hg)	Final Vacuum (inches Hg)	Concentration EO (ug/m <sup>3</sup> )
GDC-S2 20191220	<b>S2</b>	2	12/20/2019	13:48	12/21/2019	11:58	22:10	29.5	9.0	<b>600</b>
GDC-S3 20191220	<b>S3</b>	3	12/20/2019	13:56	12/21/2019	12:03	22:07	30.0	10.0	<b>1100</b>
GDC-S4E 20191220	<b>S4E</b>	4 East	12/20/2019	14:02	12/21/2019	12:06	22:04	30.0	8.5	<b>110</b>
GDC-S5 20191220	<b>S5</b>	5	12/20/2019	14:12	12/21/2019	12:13	22:01	30.0	7.5	<b>730</b>
GDC-P1 20191220	<b>P1</b>	Perimeter	12/20/2019	14:43	12/21/2019	12:33	21:50	28.5	7.5	<b>1.4</b>

**December 20-21, 2019**

Section	Sample	Concentration EO (ug/m <sup>3</sup> )	Fan ID	Flow (cfm)	mass rate (lb/hr)
1	S1A		EF-26		
1	S1B		EF-18		
2	S2	600	EF-14	24,350	0.055
2	S2	600	EF-9	14,418	0.032
2	S2	600	EF-8	23,549	0.053
2	S2	600	EF-7	24,270	0.055
3	S3	1100	EF-3	23,977	0.099
4 East	S4E	110	EF-33A	16,601	0.007
4 West	S4W		EF-30		
5	S5	730	F-5-G	26,366	0.072
<b>Totals</b>				<b>153,531 (cfm)</b>	<b>0.372 (lb/hr)</b>

**NO SAMPLE COLLECTED IN SECTION 1**

**NO SAMPLE COLLECTED IN SECTION 1**

**NO SAMPLE COLLECTED IN SECTION 4W**