

**Public Comments and EPD Responses on Draft LAS Permit
Kingston Park LLC – Permit No. GAJ010583**

COMMENT RECEIVED	EPD RESPONSE
<p>Kingston Park indicates that they intend to comply with the new conditions outlined in the draft permit.</p>	<p>Comment noted.</p>
<p>Kingston Park will operate the system in accordance with the 2008 DDR with the new loading rate of 1.75 in/week until GAEPD approves a revision of that loading rate if applicable once a new soil study is completed. We anticipate that with the new wells and groundwater data we will be able to increase back to the original loading rate.</p>	<p>Part II.C.1.a of the permit requires the permittee to comply with the approved 2005 Design Development Report (DDR) and 2008 Application. Part II.C.1.b of the permit requires the permittee to submit updated information for review and approval. Once the updated DDR has been approved, the permittee may request to modify the permit based on the current site conditions and application rates.</p>
<p>Kingston Park will submit a Sludge Management plan within the thirty days of approval of the Draft Permit.</p>	<p>As stated in Part II.D. of the permit, a Sludge Management Plan (SMP) for the facility was approved in May 2020 and EPD expects the permittee to comply with the SMP and permit. The permittee does not need to submit anything further.</p>