

ENVIRONMENTAL PROTECTION DIVISION

MEMORANDUM

TO:	Sean Taylor
THROUGH:	Daniel McCain
FROM:	Ray Shen
SUBJECT:	SOURCE TEST REPORT REVIEW

Richard E. Dunn, Director

Air Protection Branch

4244 International Parkway, Suite 120 Atlanta, Georgia 30354 404-363-7000

The following test has been reviewed	and was conducted in an acceptable	fashion for the purpose intended.

COMPANY NAME		Sterilization Services of Georgia					
COMPANY ADDRESS		Atlanta, GA					
SOURCE TESTED		Chemroxx Scrubber Ou	emroxx Scrubber Outlet - Chamber 2				
POLLUTANT DETERMINED		Ethylene Oxide					
REPORT REVIEWED BY		Ray Shen	Ray Shen				
TEST WITNESSED BY		Ray Shen					
DATE(S) OF TEST		March 22, 2022					
DATE RECEIVED BY AP	B	June 2, 2022					
APPLICABLE REQUIRE	MENT	Permit 3841-121-0010-S-03-0, Condition 2.4. 40 CFR 63.362					
MAXIMUM EXPECTED OPERATING CAPACITY		8 UNITS					
OPERATING CAPACITY		0 UNITS	0 UNITS				
ALLOWABLE EMISSION RATE(S)		99.0 % DRE					
CONTROL EQUIPMENT MONITORING DATA	AND	Liquid Glycol % (Befor	re/After) = 42.8/42.8 See A	ppendix K of test report.			
TEST RUN #		1	2	3	AVERAGE		
GAS TEMPERATURE	INLET						
°F)	OUTLET	69.4	76.2	74.4			
GAS MOISTURE (%)	INLET						
	OUTLET	1.54	1.57	1.60			
GAS FLOW RATE (ACFM)	INLET						
	OUTLET	93	98	91			
GAS FLOW RATE (DSCFM)	INLET						
	OUTLET	90	93	87			
POLLUTANT	INLET				0		
CONCENTRATION (PPM)	OUTLET	12.6	18.0	15.3	15.3		
EMISSION RATE (LB/MIN)	INLET	2.20	2.36	2.26	2.27		
	OUTLET	0.000129	0.000193	0.000152	0.000158		
DESTRUCTION EFFICIE	NCY (%)	99.993					
OTHER INFORMATION			er met the min. DRE requir	ement of >99.0 %.			

40 CFR 63.362 requires testing with an empty sterilization chamber. It also requires sampling to start at 1st evacuation of sterilization chamber. Both conditions were met.

Inlet emission rate is based on the amount of EtO charged to the sterilization chamber.

Reference Number: 202200482 Printed: 10-Jun-2022