

PERMIT NO. 4924-057-0036-V-05-0

ISSUANCE DATE:



GEORGIA

DEPARTMENT OF NATURAL RESOURCES

ENVIRONMENTAL PROTECTION DIVISION

Air Quality - Part 70 Operating Permit

Facility Name: Atlanta Gas Light Company – Cherokee LNG Plant
Facility Address: 12860 East Cherokee Drive
Ball Ground, Georgia 30107-4899, Cherokee County
Mailing Address: P.O. Box 4569
Atlanta, Georgia 30302-4569
Parent/Holding Company: Atlanta Gas Light Company (AGLC)
Facility AIRS Number: 04-13-057-00036

In accordance with the provisions of the Georgia Air Quality Act, O.C.G.A. Section 12-9-1, et seq and the Georgia Rules for Air Quality Control, Chapter 391-3-1, adopted pursuant to and in effect under the Act, the Permittee described above is issued a Part 70 Permit for:

The operation of a liquified natural gas (LNG) plant.

This Permit is conditioned upon compliance with all provisions of The Georgia Air Quality Act, O.C.G.A. Section 12-9-1, et seq, the Rules, Chapter 391-3-1, adopted and in effect under that Act, or any other condition of this Permit. Unless modified or revoked, this Permit expires five years after the issuance date indicated above.

This Permit may be subject to revocation, suspension, modification or amendment by the Director for cause including evidence of noncompliance with any of the above, for any misrepresentation made in Title V Application TV-627834 signed on February 10, 2022, any other applications upon which this Permit is based, supporting data entered therein or attached thereto, or any subsequent submittal of supporting data, or for any alterations affecting the emissions from this source.

This Permit is further subject to and conditioned upon the terms, conditions, limitations, standards, or schedules contained in or specified on the attached **53** pages.



DRAFT

Jeffrey W. Cown, Director
Environmental Protection Division

Table of Contents

PART 1.0	FACILITY DESCRIPTION	1
1.1	Site Determination	1
1.2	Previous and/or Other Names	1
1.3	Overall Facility Process Description.....	1
PART 2.0	REQUIREMENTS PERTAINING TO THE ENTIRE FACILITY	3
2.1	Facility Wide Emission Caps and Operating Limits.....	3
2.2	Facility Wide Federal Rule Standards.....	3
2.3	Facility Wide SIP Rule Standards.....	3
2.4	Facility Wide Standards Not Covered by a Federal or SIP Rule and Not Instituted as an Emission Cap or Operating Limit	3
PART 3.0	REQUIREMENTS FOR EMISSION UNITS	4
3.1	Emission Units	4
3.2	Equipment Emission Caps and Operating Limits	8
3.3	Equipment Federal Rule Standards.....	10
3.4	Equipment SIP Rule Standards	14
3.5	Equipment Standards Not Covered by a Federal or SIP Rule and Not Instituted as an Emission Cap or Operating Limit	15
PART 4.0	REQUIREMENTS FOR TESTING.....	16
4.1	General Testing Requirements	16
4.2	Specific Testing Requirements	17
PART 5.0	REQUIREMENTS FOR MONITORING (Related to Data Collection)	19
5.1	General Monitoring Requirements.....	19
5.2	Specific Monitoring Requirements	19
PART 6.0	RECORD KEEPING AND REPORTING REQUIREMENTS	25
6.1	General Record Keeping and Reporting Requirements	25
6.2	Specific Record Keeping and Reporting Requirements.....	28
PART 7.0	OTHER SPECIFIC REQUIREMENTS.....	34
7.1	Operational Flexibility	34
7.2	Off-Permit Changes	34
7.3	Alternative Requirements.....	35
7.4	Insignificant Activities	35
7.5	Temporary Sources	35
7.6	Short-term Activities.....	35
7.7	Compliance Schedule/Progress Reports	35
7.8	Emissions Trading.....	35
7.9	Acid Rain Requirements	35
7.10	Prevention of Accidental Releases (Section 112(r) of the 1990 CAAA).....	35
7.11	Stratospheric Ozone Protection Requirements (Title VI of the CAAA of 1990)	37
7.12	Revocation of Existing Permits and Amendments.....	38
7.13	Pollution Prevention.....	38
7.14	Specific Conditions	38
PART 8.0	GENERAL PROVISIONS	39
8.1	Terms and References	39
8.2	EPA Authorities	39
8.3	Duty to Comply.....	39
8.4	Fee Assessment and Payment	40

Title V Permit

8.5	Permit Renewal and Expiration	40
8.6	Transfer of Ownership or Operation	40
8.7	Property Rights.....	40
8.8	Submissions.....	41
8.9	Duty to Provide Information	41
8.10	Modifications	42
8.11	Permit Revision, Revocation, Reopening and Termination.....	42
8.12	Severability	43
8.13	Excess Emissions Due to an Emergency	43
8.14	Compliance Requirements	44
8.15	Circumvention.....	46
8.16	Permit Shield.....	46
8.17	Operational Practices	46
8.18	Visible Emissions.....	47
8.19	Fuel-burning Equipment	47
8.20	Sulfur Dioxide.....	47
8.21	Particulate Emissions	48
8.22	Fugitive Dust.....	48
8.23	Solvent Metal Cleaning.....	49
8.24	Incinerators.....	49
8.25	Volatile Organic Liquid Handling and Storage	50
8.26	Use of Any Credible Evidence or Information	50
8.27	Internal Combustion Engines.....	50
8.28	Boilers and Process Heaters	52
Attachments	53
A.	List of Standard Abbreviations and List of Permit Specific Abbreviations	
B.	Insignificant Activities Checklist, Insignificant Activities Based on Emission Levels and Generic Emission Groups	
C.	List of References	

PART 1.0 FACILITY DESCRIPTION

1.1 Site Determination

There are no other facilities which could possibly be contiguous or adjacent and under common control.

1.2 Previous and/or Other Names

Not Applicable.

1.3 Overall Facility Process Description

Atlanta Gas Light Company (AGLC) operates three liquefied natural gas (LNG) peak shaving plants in Georgia, including Atlanta Gas Light Company – Cherokee LNG Plant (hereinafter facility). These plants serve the purpose of liquefaction and storage of natural gas during the spring, summer, and fall months followed by vaporization and distribution of the stored natural gas during the peak demand periods in the winter. These LNG stations operate numerous pieces of fuel-burning equipment fired exclusively by natural gas. The peak shaving LNG operation consists of three distinct operations: (1) Liquefaction, where pipeline natural gas is converted into LNG and placed into a storage tank, (2) Vaporization, where LNG is converted into a gas and inserted into the distribution system, and (3) Standby, where neither liquefaction nor vaporization are taking place.

Liquefaction

Natural gas received from the transmission pipeline is cooled to liquid phase through indirect contact with a mixed hydrocarbon refrigerant typically consisting of ethylene, isobutane, and propane. At the Cherokee facility, an 8,500-horsepower (hp) natural gas-fired turbine (ID No. T1) is used to compress the refrigerant gases before being fed to a series of heat exchangers in the “cold box” to refrigerate the vapor-phase natural gas below its boiling point at -260°F and into the liquid phase. Prior to refrigeration, carbon dioxide scrubbers cleanse the natural gas stream to avoid freezing of impurities. A 10.6-MMBtu/hr regeneration heater (ID No.: RH1) is used to regenerate these scrubbers. The regeneration heater potentially operates at all times during liquefaction operations. After refrigeration, LNG is drawn into large, insulated tanks for storage until natural gas is needed. LNG storage tanks are essentially unpressurized, cooled by the evaporation of LNG, with natural gas vapor accumulating at the top of the tank. Boil-off gas compressors, which are driven by two 628-hp engines (ID Nos. C1 and C2), draw this vapor from the tank and compress the gas to the appropriate pressure for injection into the pipeline system.

Vaporization

When consumer demand for natural gas exceeds supply from the interstate pipeline system, LNG can be pumped from the storage tanks, vaporized and injected into the distribution system. At the Cherokee plant, the LNG pumps are driven by electric motors. These pumps deliver LNG to the vaporizers that heat the LNG. Six 48.2-MMBtu/hr Vaporizer Heaters (ID Nos: VH1 through VH6), three 50.2-MMBtu/hr Vaporizer Heaters (ID Nos. VH7 through VH9), and nine 57.9-MMBtu/hr Vaporizer Heaters (ID Nos. VH10 through VH18) heat a glycol/water solution which is the heat exchange fluid that is used to change the phase of natural gas from liquid to gas and raise the gas temperature to pipeline conditions at 60°F . According to the facility, the Vaporizer Heaters only operate during vaporization mode, which occurs at most 120 hours per year at the Cherokee plant. All of the heaters above fire exclusively on natural gas.

Auxiliary Equipment

The facility operates four 1,200-hp engine powered generators (ID Nos. G1 through G4), three 1,067-hp engine powered generators (ID Nos. G5 through G7), and two generator turbines (ID Nos.: GT1 and GT2) to generate baseload electricity for on-site consumption. These generators are utilized during LNG peak shaving operations to ensure a reliable power supply for pumps and compressors during liquefaction or vaporization. In addition, the facility utilizes a 1,475-hp emergency generator (ID No.: EG1) and a 400-hp engine powered generator (ID No.: EG) designated for emergency stand-by use only when the primary generators are inoperable.

The facility operates a 1.0-MMBtu/hr steam boiler (ID No. SB1) to generate steam for auxiliary purposes at the Cherokee Plant such as deicing pipes and valves. Also, a 350-hp engine (ID No. FP1) is maintained to drive a water pump for emergency fire suppression. All of the engines mentioned above fire exclusively on natural gas.

The facility expanded the LNG storage capacity at the Cherokee LNG Plant, adding one new LNG tank, one electric powered boil-off compressor, and one electric powered refrigerant compressor. Additionally, AGLC plans to decommission three currently existing emission units: (1) compressor turbine (ID No.: T1), (2) regeneration heater (ID No.: RH1), and (3) emergency generator (ID No.: EG). The removal of these three emission units is required once construction of the new emission units is complete.

PART 2.0 REQUIREMENTS PERTAINING TO THE ENTIRE FACILITY

2.1 Facility Wide Emission Caps and Operating Limits

None applicable.

2.2 Facility Wide Federal Rule Standards

None applicable.

2.3 Facility Wide SIP Rule Standards

None applicable.

2.4 Facility Wide Standards Not Covered by a Federal or SIP Rule and Not Instituted as an Emission Cap or Operating Limit

None applicable.

Title V Permit

PART 3.0 REQUIREMENTS FOR EMISSION UNITS

Note: Except where an applicable requirement specifically states otherwise, the averaging times of any of the Emissions Limitations or Standards included in this permit are tied to or based on the run time(s) specified for the applicable reference test method(s) or procedures required for demonstrating compliance.

3.1 Emission Units

Emission Units		Applicable Requirements/Standards	Air Pollution Control Devices	
ID No.	Description		ID No.	Description
VH1	Vaporizer Heater No. 1 Stone-Johnston Corp. Model PFTA1500-4L60W Capacity: 48.4 MMBtu/hr Installed in 1987	40 CFR 52.21 Avoidance 391-3-1-.02(2)(d) 391-3-1-.02(2)(g) 391-3-1-.02(2)(yy)1	n/a	None
VH2	Vaporizer Heater No. 2 Stone-Johnston Corp. Model PFTA1500-4L60W Capacity: 48.4 Installed in 1987	40 CFR 52.21 Avoidance 391-3-1-.02(2)(d) 391-3-1-.02(2)(g) 391-3-1-.02(2)(yy)1	n/a	None
VH3	Vaporizer Heater No. 3 Stone-Johnston Corp. Model PFTA1500-4L60W Capacity: 48.4 MMBtu/hr Installed in 1987	40 CFR 52.21 Avoidance 391-3-1-.02(2)(d) 391-3-1-.02(2)(g) 391-3-1-.02(2)(yy)1	n/a	None
VH4	Vaporizer Heater No. 4 Stone-Johnston Corp. Model PFTA1500-4L60W Capacity: 48.4 MMBtu/hr Installed in 1987	40 CFR 52.21 Avoidance 391-3-1-.02(2)(d) 391-3-1-.02(2)(g) 391-3-1-.02(2)(yy)1	n/a	None
VH5	Vaporizer Heater No. 5 Stone-Johnston Corp. Model PFTA1500-4L60W Capacity: 48.4 MMBtu/hr Installed in 1987	40 CFR 52.21 Avoidance 391-3-1-.02(2)(d) 391-3-1-.02(2)(g) 391-3-1-.02(2)(yy)1	n/a	None
VH6	Vaporizer Heater No. 6 Stone-Johnston Corp. Model PFTA1500-4L60W Capacity: 48.4 MMBtu/hr Installed in 1987	40 CFR 52.21 Avoidance 391-3-1-.02(2)(d) 391-3-1-.02(2)(g) 391-3-1-.02(2)(yy)1	n/a	None
VH7	Vaporizer Heater No. 7 Stone-Johnston Corp. Model PFTE1500-G460W Capacity: 50.2 MMBtu/hr Installed in November 1996	40 CFR 52.21 Avoidance 40 CFR 60 Subpart A 40 CFR 60 Subpart Dc 391-3-1-.02(2)(d) 391-3-1-.02(2)(g) 391-3-1-.02(2)(yy)1	n/a	None
VH8	Vaporizer Heater No. 8 Stone-Johnston Corp. Model PFTE1500-G460W Capacity: 50.2 MMBtu/hr Installed in November 1996	40 CFR 52.21 Avoidance 40 CFR 60 Subpart A 40 CFR 60 Subpart Dc 391-3-1-.02(2)(d) 391-3-1-.02(2)(g) 391-3-1-.02(2)(yy)1	n/a	None

Title V Permit

Atlanta Gas Light Company – Cherokee LNG Plant

Permit No.: 4924-057-0036-V-05-0

Emission Units		Applicable Requirements/Standards	Air Pollution Control Devices	
ID No.	Description		ID No.	Description
VH9	Vaporizer Heater No. 9 Stone-Johnston Corp. Model PFTE1500-G460W Capacity: 50.2 MMBtu/hr Installed in November 1996	40 CFR 52.21 Avoidance 40 CFR 60 Subpart A 40 CFR 60 Subpart Dc 391-3-1-.02(2)(d) 391-3-1-.02(2)(g) 391-3-1-.02(2)(yy)1	n/a	None
VH10	Vaporizer Heater No. 10 Stone-Johnston Corp. Model PFTA1500-4G60WG Capacity: 57.9 MMBtu/hr Installed in 2011	40 CFR 52.21 Avoidance 40 CFR 60 Subpart A 40 CFR 60 Subpart Dc 391-3-1-.02(2)(d) 391-3-1-.02(2)(g) 391-3-1-.02(2)(lll)	n/a	None
VH11	Vaporizer Heater No. 11 Stone-Johnston Corp. Model PFTA1500-4G60WG Capacity: 57.9 MMBtu/hr Installed in 2011	40 CFR 52.21 Avoidance 40 CFR 60 Subpart A 40 CFR 60 Subpart Dc 391-3-1-.02(2)(d) 391-3-1-.02(2)(g) 391-3-1-.02(2)(lll)	n/a	None
VH12	Vaporizer Heater No. 12 Stone-Johnston Corp. Model PFTA1500-4G60WG Capacity: 57.9 MMBtu/hr Installed in 2011	40 CFR 52.21 Avoidance 40 CFR 60 Subpart A 40 CFR 60 Subpart Dc 391-3-1-.02(2)(d) 391-3-1-.02(2)(g) 391-3-1-.02(2)(lll)	n/a	None
VH13	Vaporizer Heater No. 13 (Glycol Boiler) 58 MMBtu/hr	40 CFR 60 Subpart A 40 CFR 60 Subpart Dc 391-3-1-.02(2)(d) 391-3-1-.02(2)(g) 391-3-1-.02(2)(lll)	n/a	None
VH14	Vaporizer Heater No. 14 (Glycol Boiler) 58 MMBtu/hr	40 CFR 60 Subpart A 40 CFR 60 Subpart Dc 391-3-1-.02(2)(d) 391-3-1-.02(2)(g) 391-3-1-.02(2)(lll)	n/a	None
VH15	Vaporizer Heater No. 15 (Glycol Boiler) 58 MMBtu/hr	40 CFR 60 Subpart A 40 CFR 60 Subpart Dc 391-3-1-.02(2)(d) 391-3-1-.02(2)(g) 391-3-1-.02(2)(lll)	n/a	None
VH16	Vaporizer Heater No. 16 (Glycol Boiler) 58 MMBtu/hr	40 CFR 60 Subpart A 40 CFR 60 Subpart Dc 391-3-1-.02(2)(d) 391-3-1-.02(2)(g) 391-3-1-.02(2)(lll)	n/a	None
VH17	Vaporizer Heater No. 17 (Glycol Boiler) 58 MMBtu/hr	40 CFR 60 Subpart A 40 CFR 60 Subpart Dc 391-3-1-.02(2)(d) 391-3-1-.02(2)(g) 391-3-1-.02(2)(lll)	n/a	None
VH18	Vaporizer Heater No. 18 (Glycol Boiler) 58 MMBtu/hr	40 CFR 60 Subpart A 40 CFR 60 Subpart Dc 391-3-1-.02(2)(d) 391-3-1-.02(2)(g) 391-3-1-.02(2)(lll)	n/a	None
RH1	Regeneration Heater No. 1 CHF Model D-93934 Capacity: 10.6 MMBtu/hr Installed in 1994	40 CFR 52.21 Avoidance 40 CFR 60 Subpart A 40 CFR 60 Subpart Dc 391-3-1-.02(2)(d) 391-3-1-.02(2)(yy)1	n/a	None

Title V Permit

Atlanta Gas Light Company – Cherokee LNG Plant

Permit No.: 4924-057-0036-V-05-0

Emission Units		Applicable Requirements/Standards	Air Pollution Control Devices	
ID No.	Description		ID No.	Description
C1	Engine for Boil-off Compressor No. 1 Waukesha Model F2895GSIU Capacity: 4.86 MMBtu/hr Output: 628 Hp Installed in June 1988	40 CFR 52.21 Avoidance 40 CFR 63 Subpart A 40 CFR 63 Subpart ZZZZ 391-3-1-.02(2)(b)1 391-3-1-.02(2)(yy)1 40 CFR 64	CC01	Three-way NSCR Catalytic Converter
C2	Engine for Boil-off Compressor No. 2 Waukesha Model F2895GSIU Capacity: 4.86 MMBtu/hr Output: 628 Hp Installed in June 1988	40 CFR 52.21 Avoidance 40 CFR 63 Subpart A 40 CFR 63 Subpart ZZZZ 391-3-1-.02(2)(b)1 391-3-1-.02(2)(yy)1 40 CFR 64	CC02	Three-way NSCR Catalytic Converter
T1	Compressor Turbine Ruston Model Tornado Capacity: 63.31 MMBtu/hr Output: 8,500 Hp Installed in June 1988	40 CFR 52.21 Avoidance 40 CFR 60 Subpart A 40 CFR 60 Subpart GG 391-3-1-.02(2)(b)1 391-3-1-.02(2)(g)2. 391-3-1-.02(2)(yy)1	n/a	None
G1	Generator Engine No. 1 Waukesha Model L7042GU Capacity: 10.0 MMBtu/hr Output: 1,200 Hp Installed in June 1988	40 CFR 52.21 Avoidance 40 CFR 63 Subpart A 40 CFR 63 Subpart ZZZZ 391-3-1-.02(2)(b)1 391-3-1-.02(2)(yy)1 40 CFR 64	CG01	Three-way NSCR Catalytic Converter
G2	Generator Engine No. 2 Waukesha Model L7042GU Capacity: 10.0 MMBtu/hr Output: 1,200 Hp Installed in June 1988	40 CFR 52.21 Avoidance 40 CFR 63 Subpart A 40 CFR 63 Subpart ZZZZ 391-3-1-.02(2)(b)1 391-3-1-.02(2)(yy)1 40 CFR 64	CG02	Three-way NSCR Catalytic Converter
G3	Generator Engine No. 3 Waukesha Model L7042GU Capacity: 10.0 MMBtu/hr Output: 1,200 Hp Installed in June 1988	40 CFR 52.21 Avoidance 40 CFR 63 Subpart A 40 CFR 63 Subpart ZZZZ 391-3-1-.02(2)(b)1 391-3-1-.02(2)(yy)1 40 CFR 64	CG03	Three-way NSCR Catalytic Converter
G4	Generator Engine No. 4 Waukesha Model L7042GU Capacity: 10.0 MMBtu/hr Output: 1,200 Hp Installed in June 1988	40 CFR 52.21 Avoidance 40 CFR 63 Subpart A 40 CFR 63 Subpart ZZZZ 391-3-1-.02(2)(b)1 391-3-1-.02(2)(yy)1 40 CFR 64	CG04	Three-way NSCR Catalytic Converter
G5	Generator Engine No. 5 Waukesha Model L7042G Capacity: 8.0 MMBtu/hr Output: 1,067 Hp Installed in 2007	40 CFR 52.21 Avoidance 40 CFR 63 Subpart A 40 CFR 63 Subpart ZZZZ 391-3-1-.02(2)(b)1 391-3-1-.02(2)(yy)1 40 CFR 64	G5C	Three-way NSCR Catalytic Converter

Title V Permit

Emission Units		Applicable Requirements/Standards	Air Pollution Control Devices	
ID No.	Description		ID No.	Description
G6	Generator Engine No. 6 Waukesha Model L7042G Capacity: 8.0 MMBtu/hr Output: 1,067 Hp Installed in 2011	40 CFR 52.21 Avoidance 40 CFR 63 Subpart A 40 CFR 63 Subpart ZZZZ 391-3-1-.02(2)(b)1 391-3-1-.02(2)(yy)1 40 CFR 64	G6C	Three-way NSCR Catalytic Converter
G7	Generator Engine No. 7 Waukesha Model L7042G Capacity: 8.0 MMBtu/hr Output: 1,067 Hp Installed in 2011	40 CFR 52.21 Avoidance 40 CFR 63 Subpart A 40 CFR 63 Subpart ZZZZ 391-3-1-.02(2)(b)1 391-3-1-.02(2)(yy)1 40 CFR 64	G7C	Three-way NSCR Catalytic Converter
GT1	Generator Turbine No. 1 Solar Turbine Mars 100 120.5 MMBtu/hr	40 CFR 60 Subpart A 40 CFR 60 Subpart KKKK 391-3-1-.02(2)(b) 391-3-1-.02(2)(g) 391-3-1-.02(2)(mmm)	n/a	None
GT2	Generator Turbine No. 2 Solar Turbine Mars 100 120.5 MMBtu/hr	40 CFR 60 Subpart A 40 CFR 60 Subpart KKKK 391-3-1-.02(2)(b) 391-3-1-.02(2)(g) 391-3-1-.02(2)(mmm)	n/a	None
EG	Emergency Generator Waukesha Model F2895GU Capacity: 3.0 MMBtu/hr Output: 400 Hp Installed in 1988	40 CFR 52.21 Avoidance 40 CFR 63 Subpart A 40 CFR 63 Subpart ZZZZ 391-3-1-.02(2)(b)1 391-3-1-.02(2)(g)	n/a	None
EG1	Emergency Generator No. 1 1,475 horsepower 10.33 MMBtu/hr	40 CFR 60 Subpart A 40 CFR 60 Subpart JJJJ 40 CFR 63 Subpart A 40 CFR 63 Subpart ZZZZ 391-3-1-.02(2)(b) 391-3-1-.02(2)(g)	n/a	None
FP1	Fire Pump Engine No. 1 Waukesha Model F3521GU Capacity: 2.86 MMBtu/hr Output: 350 Hp Installed in 1988	40 CFR 52.21 Avoidance 40 CFR 63 Subpart A 40 CFR 63 Subpart ZZZZ 391-3-1-.02(2)(b)1	n/a	None
SB1	Steam Boiler Cleaver Brooks Model CBH-700-25 Capacity: 1.0 MMBtu/hr	40 CFR 52.21 Avoidance 391-3-1-.02(2)(d)2 391-3-1-.02(2)(g)	n/a	None

* Generally applicable requirements contained in this permit may also apply to emission units listed above. The lists of applicable requirements/standards are intended as a compliance tool and may not be definitive.

Table 3-A

ID No.	Description	Make	NOx Emission Limit	Operating Limit
T1	Compressor Turbine	Ruston Tornado	90 ppmv @ 15% O ₂	N/A
C1	Engine for Boil-off Compressor No. 1	Waukesha	139 ppmv @ 15% O ₂	N/A
C2	Engine for Boil-off Compressor No. 2	Waukesha		

Title V Permit

G1	Generator Engine No. 1	Waukesha	139 ppmv @ 15% O ₂	140 million cubic feet of natural gas per year
G2	Generator Engine No. 2	Waukesha		
G3	Generator Engine No. 3	Waukesha		
G4	Generator Engine No. 4	Waukesha		
SB1	Steam Boiler	Cleaver-Brooks	0.10 lb/hr	N/A
EG	Emergency Generator	Waukesha	9.60 lbs/hr	200 hrs/yr
FP1	Fire Pump Engine No. 1	Waukesha	8.40 lbs/hr	125 hrs/yr
VH1	Vaporizer Heater No. 1	Stone-Johnston	174 lbs per million cubic feet of natural gas	80 million cubic feet of natural gas per year
VH2	Vaporizer Heater No. 2	Stone-Johnston		
VH3	Vaporizer Heater No. 3	Stone-Johnston		
VH4	Vaporizer Heater No. 4	Stone-Johnston		
VH5	Vaporizer Heater No. 5	Stone-Johnston		
VH6	Vaporizer Heater No. 6	Stone-Johnston		
VH7	Vaporizer Heater No. 7	Stone-Johnston		
VH8	Vaporizer Heater No. 8	Stone-Johnston		
VH9	Vaporizer Heater No. 9	Stone-Johnston		
RH1	Regeneration Heater No. 1	CHF	1.21 lbs/hr	N/A
G5	Generator Engine No. 5	Waukesha	80 ppmv@ 15% O ₂	N/A
G6	Generator Engine No. 6	Waukesha	80 ppmv @ 15% O ₂	47.1 million cubic feet of natural gas per year
G7	Generator Engine No. 7	Waukesha		
VH10	Vaporizer Heater No. 10	Stone-Johnston	30 ppmv@ 3% O ₂ during ozone season	85.2 million cubic feet of natural gas per year
VH11	Vaporizer Heater No. 11	Stone-Johnston		
VH12	Vaporizer Heater No. 12	Stone-Johnston		

3.2 Equipment Emission Caps and Operating Limits

3.2.1 The Permittee shall not fire any fuel other than natural gas in the emission units listed in Table 3.1.

[NAA NSR Avoidance – 40 CFR 52.21, Avoidance of 40 CFR 63 Subpart JJJJJ – 63.11195(e) for All Boilers, and 391-3-1-.02(2)(g)2.(subsumed)]

3.2.2 The Permittee shall not cause, let, suffer, permit, or allow any gases which:

- a. Contain nitrogen oxides (NO_x) in excess of 90 parts per million by volume (ppmv), corrected to 15% oxygen, from the compressor turbine with ID No. T1.
[NAA NSR Avoidance – 40 CFR 52.21, 40 CFR 60.332(a)(2) and (c) (subsumed), and 391-3-1-.02(2)(yy) – RACT]
- b. Contain NO_x in excess of 139 ppmv, corrected to 15% oxygen, from the engines for boil-off compressors with ID Nos. C1 and C2.
[NAA NSR Avoidance – 40 CFR 52.21 and 391-3-1-.02(2)(yy) – RACT]
- c. Contain NO_x in excess of 139 ppmv, corrected to 15% oxygen, from the generator engines with ID Nos. G1 through G4.
[NAA NSR Avoidance – 40 CFR 52.21 and 391-3-1-.02(2)(yy) – RACT]
- d. Contain NO_x in excess of 0.10 pounds per hour (lbs/hr) from the steam boiler with ID No. SB1.
[NAA NSR Avoidance – 40 CFR 52.21]
- e. Contain NO_x in excess of 9.60 lbs/hr from the emergency generator with ID No. EG.
[NAA NSR Avoidance – 40 CFR 52.21]

Title V Permit

- f. Contain NOx in excess of 8.40 lbs/hr from the fire pump engine with ID No. FP1.
[NAA NSR Avoidance – 40 CFR 52.21]
- g. Contain NOx in excess of 174 pounds per million cubic foot (lbs/MMcf) of natural gas from the Vaporizer Heaters with ID Nos. VH1 through VH9.
[NAA NSR Avoidance – 40 CFR 52.21]
- h. Contain NOx in excess of 1.21 lbs/hr from the regeneration heater with ID No. RH1.
[NAA NSR Avoidance – 40 CFR 52.21]
- i. Contain NOx in excess of 80 ppmv, corrected to 15% oxygen on a dry basis, from the generator engines with ID Nos. G5 through G7.
[NAA NSR Avoidance – 40 CFR 52.21 and 391-3-1-.02(2)(mmm)1.(ii)]
- j. Contain NOx in excess of 30 ppmv, corrected to 3% oxygen on a dry basis, from the Vaporizer Heaters (Source Codes: VH10 through VH18) during the period from May 1 through September 30 of each year.
[391-3-1-.02(2)(III)1.]

3.2.3 The Permittee shall comply with the following fuel consumption limitations:
[NAA NSR Avoidance – 40 CFR 52.21]

- a. No more than 140 million cubic feet per year (MMcf/yr) natural gas for the generator engines with ID Nos. G1 through G4, combined.
- b. No more than 80 MMcf/yr natural gas for the Vaporizer Heaters with ID Nos. VH1 through VH9, combined.
- c. No more than 47.1 MMcf/yr natural gas for the generator engines with ID Nos. G6 and G7, combined.
- d. No more than 85.2 MMcf/yr natural gas for the Vaporizer Heaters with ID Nos. VH10 through VH12, combined.

3.2.4 The Permittee shall limit the hours of operation (in hours per 12-consecutive months) of Vaporizer Heaters Nos. 13 through 18 (Source Codes: VH13 through VH18), Generator Turbines Nos. 1 and 2 (Source Codes: GT1 and GT2), Fire Pump Engine No. 1 (Source Code: FP1), and Emergency Generators (Source Codes: EG and EG1) as specified in the following table:

[Avoidance of PSD – 40 CFR 52.21]

Source Code	Emission Unit Description	Hours per 12-consecutive month limit
VH13	Vaporizer Heater No. 13	500
VH14	Vaporizer Heater No. 14	500
VH15	Vaporizer Heater No. 15	500
VH16	Vaporizer Heater No. 16	500
VH17	Vaporizer Heater No. 17	500

Title V Permit

VH18	Vaporizer Heater No. 18	500
GT1	Generator Turbine No. 1	6,000
GT2	Generator Turbine No. 2	6,000
EG	Emergency Generator	200
EG1	Emergency Generator No. 1	200
FP1	Fire Pump Engine No. 1	125

3.3 Equipment Federal Rule Standards

- 3.3.1 The Permittee shall comply with all applicable provisions of the New Source Performance Standards (NSPS) as found in 40 CFR 60 Subpart A – “General Provisions,” and 40 CFR 60 Subpart Dc – “Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units,” for the operation of the Vaporizer Heaters (Source Codes: VH7 through VH18) and the regeneration heater (Source Code: RH1).
[40 CFR 60 Subpart A and Subpart Dc]
- 3.3.2 The Permittee shall comply with all applicable provisions of the New Source Performance Standards (NSPS) as found in 40 CFR 60 Subpart A – “General Provisions,” and 40 CFR 60 Subpart GG – “Standards of Performance for Stationary Gas Turbines,” for the operation of the compressor turbine with ID No. T1.
[40 CFR 60 Subpart A and Subpart GG]
- 3.3.3 The Permittee shall not fire any fuel containing sulfur in excess of 0.8 percent by weight in Compressor Turbine (T1).
[40 CFR 60.333(b) and 391-3-1-.02(2)(g)2.(subsumed)]
- 3.3.4 The Permittee shall comply with all applicable provisions of the National Emission Standards for Hazardous Air Pollutants (NESHAP) as found in 40 CFR Part 63, Subpart A – “General Provisions,” and Subpart ZZZZ – “National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines,” for the operation of the engines Boil-off Compressors (C1 & C2), the Generator Engines (G1 through G7), Emergency Generators (Source Codes: EG and EG1), and Fire Pump Engine (FP1).
[40 CFR 63 Subpart A and Subpart ZZZZ]
- 3.3.5 The Permittee shall comply with the following operating limitations for the operation of Boil-off Compressors (C1 & C2) and Generator Engines (G1 through G7):
[40 CFR 63.6603(a) and Item 11 of Table 2d to 40 CFR 63 Subpart ZZZZ]
- a. Change oil and filter every 2,160 hours of operation or annually, whichever comes first;
 - b. Inspect spark plugs every 2,160 hours of operation or annually, whichever comes first, and replace as necessary; and
 - c. Inspect all hoses and belts every 2,160 hours of operation or annually, whichever comes first, and replace as necessary.
- 3.3.6 The Permittee shall comply with the following operating limitations for the operation of the Emergency Generator (EG) and Fire Pump Engine (FP1):

Title V Permit

[40 CFR 63.6603(a) and Item 5 of Table 2d to 40 CFR 63 Subpart ZZZZ]

- a. Change oil and filter every 500 hours of operation or annually, whichever comes first.
- b. Inspect spark plugs every 1,000 hours of operation or annually, whichever comes first.
- a. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.

3.3.7 The Permittee shall operate and maintain each of Boil-off Compressors (C1 & C2), Generator Engines (G1 through G7), Emergency Generator (EG) and Fire Pump Engine (FP1) according to the manufacturer's emission-related operation and maintenance instructions; or develop and follow own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.

[40 CFR 63.6625(e)(3), 40 CFR 63.6640(a) and Item 9 of Table 6 to 40 CFR 63 Subpart ZZZZ]

3.3.8 The Permittee shall operate the Emergency Generator (EG) and Fire Pump Engine (FP1) according to the following:

- a. There is no time limit on the use of Fire Pump Engine (FP1) in emergency situations.
[40 CFR 63.6640(f)(1)]
- b. The Permittee may operate the Emergency Generator (EG) and Fire Pump Engine (FP1) for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by Federal, State or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Maintenance checks and readiness testing of each engine is limited to 100 hours per year. However, the Permittee may petition the Division for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the Permittee maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency engines beyond 100 hours per year.
[40 CFR 63.6640(f)(2)]
- c. The Permittee may operate the Fire Pump Engine (FP1) for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing. Except as provided in Subparagraph c.i. below, the 50 hours per any 12-consecutive month period for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.
[40 CFR 63.6640(f)(4)]
 - i. The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met:

Title V Permit

- (A) The engine is dispatched by the local balancing authority or local transmission and distribution system operator;
 - (B) The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.
 - (C) The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.
 - (D) The power is provided only to the facility itself or to support the local transmission and distribution system.
 - (E) The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution system operator may keep these records on behalf of the engine owner or operator.
- 3.3.9 For the operation of the Boil-off Compressors (C1 & C2), the Generator Engines (G1 through G7), Emergency Generator (EG) and Fire Pump Engine (FP1), the Permittee shall:
- a. Minimize the engine’s time spent at idle during startup and minimize the engine’s startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes.
[40 CFR 63.6625(h)]
 - b. Operate and maintain the engines, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions.
[40 CFR 63.6605(b)]
- 3.3.10 If the Permittee opts to utilize an oil analysis program in order to extend a 40 CFR 63 Subpart ZZZZ oil change requirement, the Permittee shall develop this oil analysis program in accordance with the requirements specified in 40 CFR 63.6625(j) and include it in the maintenance plan.
[40 CFR 63.6625(j)]
- 3.3.11 The Permittee shall comply with all applicable provisions of the New Source Performance Standards (NSPS) as found in 40 CFR 60 Subpart A – “General Provisions” and 40 CFR 60 Subpart KKKK – “Standards of Performance for Stationary Combustion Turbines,” for operation of Generator Turbines Nos. 1 and 2 (Source Codes: GT1 and GT2).
[40 CFR 60 Subpart A and Subpart KKKK]

Title V Permit

- 3.3.12 The Permittee shall not cause to be discharged into the atmosphere from Generator Turbines Nos. 1 and 2 (Source Codes: GT1 and GT2) any gases which contain nitrogen oxides in excess of 25 parts per million by volume on a dry basis (ppmvd) corrected to 15 percent oxygen (O₂).
[Table 1 of 40 CFR 60 Subpart KKKK and 40 CFR 60.4320]
- 3.3.13 The Permittee shall not combust in Generator Turbines Nos. 1 and 2 (Source Codes: GT1 and GT2) any natural gas with a sulfur content that would allow emissions in excess of 0.060 lb SO₂ per MMBtu of heat input.
[40 CFR 60.4330(a)(2)]
- 3.3.14 The Permittee shall operate and maintain Generator Turbines Nos. 1 and 2 (Source Codes: GT1 and GT2) in a manner consistent with good air pollution control practices for minimizing emissions at all times including during startup, shutdown and malfunction.
[40 CFR 60.4333(a)]
- 3.3.15 The Permittee shall comply with all the applicable provisions of the New Source Performance Standards (NSPS), 40 CFR 60, Subpart A – “General Provisions,” and Subpart JJJJ – “Standards of Performance for Stationary Spark Ignition Internal Combustion Engines,” for the operation of Emergency Generator No. 1 (Source Code: EG1).
[40 CFR 60, Subparts A and JJJJ]
- 3.3.16 The Permittee shall not cause, let, suffer, permit or allow the rate of emissions from Emergency Generator No. 1 (Source Code: EG1) any gases which contain emissions in total quantities exceeding the allowable rate as indicated below:
[40 CFR 60.4233(e) and Table 1 of 40 CFR 60 Subpart JJJJ]
- a. NO_x emissions in excess of 2.0 g/HP-hr or 160 ppmvd at 15% oxygen
 - b. CO emissions in excess of 4.0 g/HP-hr or 540 ppmvd at 15% oxygen
 - c. VOC emissions in excess of 1.0 g/HP-hr or 86 ppmvd at 15% oxygen
- The Permittee may choose to comply with the emission standards in units of either g/HP-hr or ppmvd at 15 percent oxygen.
- 3.3.17 The Permittee shall operate the Emergency Generator (Source Code: EG1) for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by Federal, State or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Maintenance checks and readiness testing of each engine is limited to 100 hours per year. However, the Permittee may petition the Division for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the Permittee maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency engines beyond 100 hours per year.
[40 CFR 60.4243(d)(2)]
- 3.3.18 The Permittee shall operate and maintain Emergency Generator No. 1 (Source Code: EG1) according to the manufacturer’s emission-related written instructions.

[40 CFR 60.4243(a)]

3.4 Equipment SIP Rule Standards

- 3.4.1 The Permittee shall not cause, let, suffer, permit or allow emissions from the compressor turbine (Source Code: T1), the boil-off compressors engines (Source Codes: C1 and C2), the generator engines (Source Codes: G1 through G7), generator turbines (Source Codes: GT1 and GT2), emergency generators (Source Codes: EG and EG1); and the fire pump engine (Source Code: FP1), the opacity of which is equal to or greater than forty (40) percent.
[391-3-1-.02(2)(b)1.]
- 3.4.2 The Permittee shall not cause, let, suffer, permit, or allow any emissions from the Steam Boiler (Source Code: SB1) which:
- a. Contain fly ash and/or other particulate matter in amounts equal to or exceeding 0.5 pounds per million BTU heat input.
[391-3-1-.02(2)(d)2.(i)]
 - b. Exhibit visible emissions, the opacity of which is equal to or greater than 20 percent except for one six minute period per hour of not more than 27 percent opacity.
[391-3-1-.02(2)(d)3.]
- 3.4.3 The Permittee shall not cause, let, suffer, permit, or allow any emissions from the Vaporizer Heaters (Source Codes: VH1 through VH18) and the Regeneration Heater (Source Code: RH1) which:
- a. Contain fly ash and/or other particulate matter in amounts equal to or exceeding the rate derived from $P = 0.5(10/R)^{0.5}$ where R equals heat input rate in million BTU per hour and P equals the allowable emission rate in pounds per million BTU.
[391-3-1-.02(2)(d)2.(ii)]
 - b. Exhibit visible emissions, the opacity of which is equal to or greater than 20 percent except for one six minute period per hour of not more than 27 percent opacity.
[391-3-1-.02(2)(d)3.]
- 3.4.4 The Permittee shall, pursuant to the Division-approved NO_x reasonably available control technology (RACT) plan dated November 14, 2014, employ the following RACT for the operation of the Vaporizer Heaters (ID Nos. VH1 through VH9) and regeneration heater (ID No. RH1):
[391-3-1-.02(2)(yy)1.]
- a. The Permittee shall employ good combustion practices and apply low excess air technique in the operation of VH1 through VH9 and RH1.
 - b. The Permittee shall burn only natural gas in VH1 through VH9 and RH1.
 - c. The design of VH7 through VH9 and RH1 shall incorporate flue gas recirculation.

Title V Permit

- d. The Permittee shall perform a tune-up on each of VH1 through VH9 and RH1 once every 24 calendar months to ensure proper operation of the heaters for reduced NO_x emissions.
- 3.4.5 The Permittee shall not burn fuel containing more than 2.5 percent sulfur, by weight, in Vaporizer Heaters (Source Codes: VH13 through VH18), Generator Turbines (Source Codes: GT1 and GT2) and Emergency Generator No. 1 (Source Code: EG1), unless otherwise specified by the Director.
[391-3-1-.02(2)(g)2]
- 3.4.6 The Permittee shall not cause, let, suffer, permit, or allow the emissions of nitrogen oxides (NO_x), from Generator Turbines Nos. 1 and 2 (Source Codes: GT1 and GT2), to exceed 30 ppm @ 15 percent O₂, dry basis during the ozone season. For purposes of this condition, the ozone season is defined as the time period beginning May 1 and ending September 30 of each year.
[391-3-1-.02(2)(mmm)]
- 3.4.7 The Permittee shall limit the operation of the Emergency Generator No. 1 (Source Code: EG1) to operation in the event of power loss from the local grid (emergency standby mode), in case of a fire emergency, or for the purpose of maintenance checks and readiness testing such that the total hours of operation is less than 200 hours during any consecutive 12-month period.
[391-3-1-.02(2)(mmm)]
- 3.5 Equipment Standards Not Covered by a Federal or SIP Rule and Not Instituted as an Emission Cap or Operating Limit**
- 3.5.1 The Permittee must decommission compressor turbine (ID No.: T1), regeneration heater (ID No.: RH1), and emergency generator (ID No.: EG) once construction of the generator turbines (ID Nos.: GT1 and GT2) and the new emergency generator (ID No.: EG1) is complete.

PART 4.0 REQUIREMENTS FOR TESTING**4.1 General Testing Requirements**

- 4.1.1 The Permittee shall cause to be conducted a performance test at any specified emission unit when so directed by the Environmental Protection Division (“Division”). The test results shall be submitted to the Division within 60 days of the completion of the testing. Any tests shall be performed and conducted using methods and procedures that have been previously specified or approved by the Division.
[391-3-1-.02(6)(b)1(i)]
- 4.1.2 The Permittee shall provide the Division thirty (30) days (or sixty (60) days for tests required by 40 CFR Part 63) prior written notice of the date of any performance test(s) to afford the Division the opportunity to witness and/or audit the test, and shall provide with the notification a test plan in accordance with Division guidelines.
[391-3-1-.02(3)(a) and 40 CFR 63.7(b)(1)]
- 4.1.3 Performance and compliance tests shall be conducted and data reduced in accordance with applicable procedures and methods specified in the Division’s Procedures for Testing and Monitoring Sources of Air Pollutants. The methods for the determination of compliance with emission limits listed under Sections 3.2, 3.3, 3.4 and 3.5 are as follows:
- a. Method 1 shall be used for the determination of sample point locations.
 - b. Method 2 shall be used for the determination of stack gas flow rate.
 - c. Method 3 or 3A shall be used for the determination of stack gas molecular weight.
 - d. Method 3B shall be used for the determination of the correction factor or excess air. Method 3A may be used as an alternative.
 - e. Method 4 shall be used for the determination of stack moisture.
 - f. Method 5 shall be used for the determination of particulate matter emissions.
 - g. Method 7E shall be used for the determination of nitrogen oxides (NO_x) emissions.
 - h. Method 9 and the Procedures of Section 1.3 of the above referenced document shall be used for the determination of the opacity of visible emissions.
 - i. Method 19, when applicable, shall be used to convert particulate matter, carbon monoxide, sulfur dioxide, and nitrogen oxides concentrations (i.e. grains/dscf for PM, ppm for gaseous pollutants), as determined using other methods specified in this section, to emission rates (i.e. lb/MMBtu).
 - j. Method 20 shall be used for the determination of NO_x concentration when determining compliance with the NO_x emission limit in Condition 3.2.2.a.
[40 CFR 60.335(a)(1)]

- k. ASTM Method D 1072 (-80 and -90), D 3246 (-81, -92, and -96), D4468 (-85), or D6667 (-01) shall be used for the determination of sulfur content of gaseous fuels. Alternatively, if the total sulfur content of the gaseous fuel during the most recent performance test was less than 0.4 weight percent (4000 ppmw), ASTM Method D 4084 (-82 and -94), D5504 (-01), D6228 (-98), or Gas Processors Association Standard 2377 (-86) may also be used for the determination of sulfur content of gaseous fuels. [40 CFR 60.334(h)(1), 40 CFR 60.4415(a)(2)(ii), and 60.335(b)(10)(ii)]

Minor changes in methodology may be specified or approved by the Director or his designee when necessitated by process variables, changes in facility design, or improvement or corrections that, in his opinion, render those methods or procedures, or portions thereof, more reliable.

[391-3-1-.02(3)(a)]

- 4.1.4 The Permittee shall submit performance test results to the US EPA's Central Data Exchange (CDX) using the Compliance and Emissions Data Reporting Interface (CEDRI) in accordance with any applicable NSPS or NESHAP standards (40 CFR 60 or 40 CFR 63) that contain Electronic Data Reporting Requirements. This Condition is only applicable if required by an applicable standard and for the pollutant(s) subject to said standard.

[391-3-1-.02(8)(a) and 391-3-1-.02(9)(a)]

4.2 Specific Testing Requirements

- 4.2.1 The Permittee shall conduct an annual performance test on each of the generator engines with ID Nos. G1 through G7 and the engines for boil-off compressors with ID Nos. C1 and C2 to determine compliance with the nitrogen oxides (NOx) emission limit of Condition 3.2.2.b, c, and i. The performance tests shall be conducted each year during the period from May through September and within 90 days of the testing period from the previous year. Each performance test shall consist of three one-hour test runs. The results of the annual tests shall be submitted to the Division within 60 days of completion of testing. The annual tests shall be conducted and the data reduced in accordance with methods and procedures approved by the Division prior to such testing.

[391-3-1-.02(6)(b)1.(i)]

- 4.2.2 At intervals of 24 months or less, the Permittee shall conduct a performance test on the compressor turbine with ID No. T1 to determine compliance with the nitrogen oxides (NOx) emission limit contained in Condition 3.2.2.a and re-establish the average combustor outlet temperature at which compliance with the emissions limitation is demonstrated.

[391-3-1-.02(6)(b)1.(i)]

- 4.2.3 Within 60 days after achieving the maximum production rate at which Generator Turbines Nos. 1 and 2 (Source Codes: GT1 and GT2) will be operated, but no later than 180 days after the initial startup of each combustion turbine, the Permittee shall conduct the initial performance tests for NOx emissions from Generator Turbines Nos. 1 and 2 (Source Codes: GT1 and GT2). Subsequent NOx performance tests shall be conducted on an annual basis (no more than 14 calendar months following the previous performance test). Performance testing for NOx emissions shall be conducted using the methodologies as specified in 40 CFR

Title V Permit

60.4400(a). If the NO_x emission result from the performance test is less than or equal to 75 percent of the NO_x emission limit for the turbine, the Permittee may reduce the frequency of subsequent performance tests to once every 2 years (no more than 26 calendar months following the previous performance test). If the results of any subsequent performance test exceed 75 percent of the NO_x emission limit for the turbine, the Permittee must resume annual performance tests.

[40 CFR 60.4340(a) and 40 CFR 60.4400(a)]

PART 5.0 REQUIREMENTS FOR MONITORING (Related to Data Collection)**5.1 General Monitoring Requirements**

- 5.1.1 Any continuous monitoring system required by the Division and installed by the Permittee shall be in continuous operation and data recorded during all periods of operation of the affected facility except for continuous monitoring system breakdowns and repairs. Monitoring system response, relating only to calibration checks and zero and span adjustments, shall be measured and recorded during such periods. Maintenance or repair shall be conducted in the most expedient manner to minimize the period during which the system is out of service.
[391-3-1-.02(6)(b)1]

5.2 Specific Monitoring Requirements

- 5.2.1 The Permittee shall install, calibrate, maintain, and operate a system to continuously monitor and record the indicated parameters on the following equipment. Where such performance specification(s) exist, each system shall meet the applicable performance specification(s) of the Division's monitoring requirements.
[391-3-1-.02(6)(b)1 and 40 CFR 70.6(a)(3)(i)]
- a. A non-resettable hour meter for continuously measuring and recording the cumulative total hours of operation for Emergency Generators (Source Code: EG) and Fire Pump Engine (FP1). Data shall be recorded monthly.
[40 CFR 63.6625(f)]
 - b. A non-resettable hour meter on Vaporizer Heaters Nos. 13 through 18 (Source Codes: VH13 through VH18), Generator Turbines Nos. 1 and 2 (Source Codes: GT1 and GT2) and Emergency Generator No. 1 (Source Code: EG1). The meter readings shall be recorded at least once each month. For Emergency Generator No. 1 (Source Code: EG1), the Permittee shall also record the monthly hours of operation for maintenance and readiness checks and monthly hours of operation for all non-emergency operations.
[40 CFR 60.4237(a), Avoidance of PSD, and Avoidance of 391-3-1-.02(2)(mmm)]
- 5.2.2 The Permittee shall install, calibrate, maintain, and operate monitoring devices for the measurement of the indicated parameters on the following equipment. Data shall be recorded at the frequency specified below. Where such performance specification(s) exist, each system shall meet the applicable performance specification(s) of the Division's monitoring requirements.
[391-3-1-.02(6)(b)1 and 40 CFR 70.6(a)(3)(i)]
- a. A natural gas consumption meter to continuously measure and record the total quantity of natural gas, in cubic feet, burned in the Vaporizer Heaters with ID Nos. VH1 through VH6. Data shall be recorded monthly.
[NAA NSR Avoidance – 40 CFR 52.21]

Title V Permit

- b. A natural gas consumption meter to continuously measure and record the quantity of natural gas, in cubic feet, burned in each of the Vaporizer Heaters with ID Nos. VH7 through VH18. Data shall be recorded monthly.
[NAA NSR Avoidance – 40 CFR 52.21, 40 CFR 60 Subpart Dc, and 40 CFR 60.48c(g)(2)]
 - c. A natural gas consumption meter to continuously measure and record the total quantity of natural gas, in cubic feet, burned in the generator engines with ID Nos. G1 through G4. Data shall be recorded monthly.
[NAA NSR Avoidance – 40 CFR 52.21]
 - d. A natural gas consumption meter to continuously measure and record the total quantity of natural gas, in cubic feet, burned in the generator engines with ID Nos. G6 and G7. Data shall be recorded monthly.
[NAA NSR Avoidance – 40 CFR 52.21]
 - e. A natural gas consumption meter to continuously measure and record the quantity of natural gas, in cubic feet, burned in the Regeneration Heater (Source Code: RH1). Data shall be recorded monthly.
[40 CFR 60.48c(g)(2)]
 - f. A temperature indicator for the measurement of the combustor outlet temperature on the compressor turbine with ID No. T1. Data shall be recorded at least once every 15 minutes and reduced to hourly averages.
[391-3-1-.02(6)(b)1 and 40 CFR 70.6(a)(3)(i)]
 - g. A temperature indicator at the inlet of each catalytic converter (ID Nos. CC01; CC02; CG01 through CG04; and G5C through G7C) to continuously measure the temperature, in degrees Fahrenheit. Data shall be recorded at least once every 15 minutes and reduced to 4-hour rolling averages.
[391-3-1-.02(6)(b)1 and 40 CFR 70.6(a)(3)(i)]
- 5.2.3 The Permittee shall, each calendar year, monitor emissions of nitrogen oxides (NO_x) from the Vaporizer Heaters (Source Codes: VH10 through VH18) unless the heaters will not operate during the ozone season (May 1 through September 30 of each year) by performing a tune-up for each heater to demonstrate compliance with the NO_x concentration limit of Condition 3.2.2.j using the following procedures:
[391-3-1-.02(6)(b)1, PTM Section 2.119, and 40 CFR 70.6(a)(3)(i)]
- a. The tune-up shall be performed no earlier than March 1 and no later than May 1 of each calendar year. In the case of initial startups that occur after May 1 but before September 30, tune-ups shall be performed no later than 120 hours after startup. The tune-up shall be performed at the normal maximum operating load expected during the period from May 1 to September 30 of each year.
 - b. The tune-up shall be performed by using the manufacturer recommended settings for reduced NO_x emissions or by using a NO_x analyzer. Adjustments shall be made, as

Title V Permit

needed, so that NO_x emissions are reduced in a manner consistent with good combustion practices and safe fuel-burning equipment operation.

- c. Following the adjustments, or determination that adjustments are not required, the Permittee shall perform a measurement consisting of a minimum of three test runs to demonstrate that the average emissions are less than or equal to the NO_x concentration limit of Condition No. 3.2.2.j. Each test run shall be a minimum of 30 minutes of operational data in length. Following any test run which results in an average NO_x concentration that exceeds the NO_x limit of Condition No. 3.2.2.j, the Permittee shall make adjustments to the heater and conduct a new set of test runs within one day. Subsequent adjustments followed by test runs shall be continued until the average of 3 consecutive test runs do not exceed the NO_x concentration limit of Condition No. 3.2.2.j.
- d. All measurements of NO_x and oxygen concentrations in paragraphs b. and c. of this condition shall be conducted using procedures of the American Society for Testing and Materials (ASTM) Standard Test Method for Determination of NO_x, Carbon Monoxide (CO), and Oxygen Concentrations in Emissions from Natural Gas-Fired Reciprocating Engines, Combustion Turbines, Boilers, and Process Heaters Using Portable Analyzers, ASTM D 6522; procedures of Gas Research Institute Method GRI-96/0008, EPA/EMC Conditional Test Method (CTM-30) Determination of Nitrogen Oxides, Carbon Monoxide, and Oxygen Emissions from Natural Gas-Fired Engines, Boilers and Process Heaters Using Portable Analyzers; or procedures of EPA Reference Method 7E and 3A.
- e. The Permittee shall maintain records of all tune-ups performed in accordance with this condition. These records shall include the following:
 - i. date and time the tune-up was performed
 - ii. the heater settings for each test run
 - iii. the average NO_x concentration (in ppm at 3 percent O₂, dry basis) for each test run
 - iv. what operating parameters were adjusted to minimize NO_x emissions
 - v. an explanation of how the final (compliant) settings were determined
- f. Following the tune-up, from the period May 1 through September 30 of each year, the Permittee shall operate each affected heater using the settings determined during the annual tune-up. If no parameters can be monitored to indicate the performance of a specific heater, the Permittee shall certify that no adjustments have been made to the heater by the Permittee and/or any third party since the most recent successful tune-up was completed. This certification shall be made in writing no later than October 15 of each year and shall be maintained with the records required by paragraph e. of this condition.

Title V Permit

- g. If a heater is capable of operating for 3 consecutive test runs with average NO_x concentrations of less than or equal to 15 ppm corrected to 3 percent oxygen, the Permittee may conduct the next subsequent tune-up in the fourth calendar year following the demonstration of 15 ppm or less. Results of measurements of NO_x and oxygen concentrations and tune-ups, maintenance and records, and subsequent heater operation shall otherwise be conducted as described in paragraphs a. through f. of this condition. The Permittee shall continue to make annual certifications of no adjustments since the previous tune-up.
- h. As an alternative to complying with the requirements in this condition, the Permittee shall submit documentation no later than April 30 of each year confirming that an affected unit will not operate during the months of May through September. As a minimum, the documentation shall include the identification of the facility, the permit number, and the specific affected units that will not be operated.

5.2.4 The following pollutant specific emission units (PSEU) are subject to the Compliance Assurance Monitoring (CAM) Rule in 40 CFR 64. The following pollutant specific emission unit(s) (PSEU) is/are subject to the Compliance Assurance Monitoring (CAM) Rule in 40 CFR 64.

Emission Unit	Pollutant
C1	NO _x
C2	NO _x
G1	NO _x
G2	NO _x
G3	NO _x
G4	NO _x
G5	NO _x
G6	NO _x
G7	NO _x

Permit conditions in this permit for the PSEU(s) listed above with regulatory citation 40 CFR 70.6(a)(3)(i) are included for the purpose of complying with 40 CFR 64. In addition, the Permittee shall meet the requirements, as applicable, of 40 CFR 64.7, 40 CFR 64.8, and 40 CFR 64.9. [40 CFR 64]

5.2.5 The Permittee shall comply with the performance criteria listed in the table below for the NO_x emissions from the engines for boil-off compressors with ID Nos. C1 and C2 and the generator engines with ID Nos. G1 through G7. [40 CFR 64.6(c)(1)(iii)]

Performance Criteria [64.4(a)(3)]	Indicator No. 1 Catalytic Converter (Non-Selective Catalytic Reduction) Inlet Temperature
A. Data Representativeness [64.3(b)(1)]	Appropriate thermocouples were installed in the inlet of each catalytic converter, per the manufacturer's design.
B. Verification of Operational Status (new/modified monitoring equipment only) [64.3(b)(2)]	Calibrations are performed in accordance with the manufacturer's recommendations.

Title V Permit

Performance Criteria [64.4(a)(3)]	Indicator No. 1 Catalytic Converter (Non-Selective Catalytic Reduction) Inlet Temperature
C. QA/QC Practices and Criteria [64.3(b)(3)]	Operators check the data for completeness, legibility, reasonableness, and accuracy on a routine basis.
D. Monitoring Frequency [64.3(b)(4)]	Temperature is recorded at least every 15 minutes and data reduced to rolling 4-hour averages.
E. Data Collection Procedures [64.3(b)(4)]	Records of parametric monitoring, required maintenance, and corrective actions will be maintained at the facility, either in organized paper files or electronically. The data shall be retained for at least five (5) years following the date of entry.
F. Averaging Period [64.3(b)(4)]	Four-Hour Rolling Average. Excursions are defined in Condition 6.1.7.c.ii.

5.2.6 The Permittee shall monitor the emissions of NO_x from Generator Turbines Nos. 1 and 2 (Source Codes: GT1 and GT2), during the period from May 1 through September 30 each year by performing a test measurement to demonstrate that the NO_x concentrations corrected to 15 percent oxygen are below the applicable standard. The test measurements shall use the following procedures:

[391-3-1-.02(6)(b)1 and PTM Section 2.120]

- a. The measurements shall be performed no earlier than March 1 and no later than May 1 of each calendar year. Should an affected source become operational during the period from May 1 to September 20, a measurement shall be performed within the first 120 hours of operation.
- b. The measurement shall be performed using the manufacturer recommended settings for reduced NO_x emissions.
- c. The Permittee shall carry out a measurement consisting of a minimum of three test measurements to demonstrate that the average emissions are less than or equal to the applicable standards. Each test measurement shall be a minimum of 30 minutes in length. One test measurement shall be conducted at the minimum load during the past 12 months, one test measurement at the highest load operated during the past 12 months, and one test measurement at the average load operated during the past 12 months.
- d. All measurements of NO_x emissions and oxygen concentrations shall be conducted using the procedures of the American Society for Testing and Materials Standard (ASTM) Test Method for Determination of NO_x, Carbon Monoxide (CO), and Oxygen Concentrations in emissions from Natural Gas-Fired Reciprocating Engines, Combustion Turbines, Boilers, and Process Heaters Using Portable Analyzers, ASTM D 6522; or procedures of Gas Research Institute Method GRI-96-0008, EPA/EMC Conditional Test Method (CTM-30) Determination of NO_x, Carbon Monoxide (CO), and Oxygen Concentrations in emissions from Natural Gas-Fired Reciprocating Engines, Combustion Turbines, Boilers, and Process Heaters Using Portable Analyzers or the Procedures of EPA Reference Methods 7E and 3A.

Title V Permit

- e. The Permittee shall maintain records of all measurements performed in accordance with this section. These records shall indicate the date and time the measurements were performed and the NO_x and oxygen values determined during the measurements.

- f. Following the measurements, from the period May 1 through September 30 of each year, the Permittee shall operate the affected facility using the settings determined during the annual measurement. The Permittee shall certify that no adjustments have been made to the affected facility by the owner, operator and/or any third party since the measurements in paragraph c. of this condition were conducted. This certification shall be made in writing no later than October 15 of each year and shall be maintained with the records required to be maintained in paragraph e of this condition.

PART 6.0 RECORD KEEPING AND REPORTING REQUIREMENTS**6.1 General Record Keeping and Reporting Requirements**

6.1.1 Unless otherwise specified, all records required to be maintained by this Permit shall be recorded in a permanent form suitable for inspection and submission to the Division and to the EPA. The records shall be retained for at least five (5) years following the date of entry. [391-3-1-.02(6)(b)1(i) and 40 CFR 70.6(a)(3)]

6.1.2 In addition to any other reporting requirements of this Permit, the Permittee shall report to the Division in writing, within seven (7) days, any deviations from applicable requirements associated with any malfunction or breakdown of process, fuel burning, or emissions control equipment for a period of four hours or more which results in excessive emissions.

The Permittee shall submit a written report that shall contain the probable cause of the deviation(s), duration of the deviation(s), and any corrective actions or preventive measures taken.

[391-3-1-.02(6)(b)1(iv), 391-3-1-.03(10)(d)1(i) and 40 CFR 70.6(a)(3)(iii)(B)]

6.1.3 The Permittee shall submit written reports of any failure to meet an applicable emission limitation or standard contained in this permit and/or any failure to comply with or complete a work practice standard or requirement contained in this permit which are not otherwise reported in accordance with Conditions 6.1.4 or 6.1.2. Such failures shall be determined through observation, data from any monitoring protocol, or by any other monitoring which is required by this permit. The reports shall cover each semiannual period ending June 30 and December 31 of each year, shall be postmarked by August 29 and February 28, respectively following each reporting period, and shall contain the probable cause of the failure(s), duration of the failure(s), and any corrective actions or preventive measures taken. [391-3-1-.03(10)(d)1.(i) and 40 CFR 70.6(a)(3)(iii)(B)]

6.1.4 The Permittee shall submit a written report containing any excess emissions, exceedances, and/or excursions as described in this permit and any monitor malfunctions for each semiannual period ending June 30 and December 31 of each year. All reports shall be postmarked by August 29 and February 28, respectively following each reporting period. In the event that there have not been any excess emissions, exceedances, excursions or malfunctions during a reporting period, the report should so state. Otherwise, the contents of each report shall be as specified by the Division's Procedures for Testing and Monitoring Sources of Air Pollutants and shall contain the following:

[391-3-1-.02(6)(b)1 and 40 CFR 70.6(a)(3)(iii)(A)]

- a. A summary report of excess emissions, exceedances and excursions, and monitor downtime, in accordance with Section 1.5(c) and (d) of the above referenced document, including any failure to follow required work practice procedures.
- b. Total process operating time during each reporting period.
- c. The magnitude of all excess emissions, exceedances and excursions computed in accordance with the applicable definitions as determined by the Director, and any

Title V Permit

conversion factors used, and the date and time of the commencement and completion of each time period of occurrence.

- d. Specific identification of each period of such excess emissions, exceedances, and excursions that occur during startups, shutdowns, or malfunctions of the affected facility. Include the nature and cause of any malfunction (if known), the corrective action taken or preventive measures adopted.
- e. The date and time identifying each period during which any required monitoring system or device was inoperative (including periods of malfunction) except for zero and span checks, and the nature of the repairs, adjustments, or replacement. When the monitoring system or device has not been inoperative, repaired, or adjusted, such information shall be stated in the report.
- f. Certification by a Responsible Official that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.

6.1.5 Where applicable, the Permittee shall keep the following records:
[391-3-1-.03(10)(d)1(i) and 40 CFR 70.6(a)(3)(ii)(A)]

- a. The date, place, and time of sampling or measurement;
- b. The date(s) analyses were performed;
- c. The company or entity that performed the analyses;
- d. The analytical techniques or methods used;
- e. The results of such analyses; and
- f. The operating conditions as existing at the time of sampling or measurement.

6.1.6 The Permittee shall maintain files of all required measurements, including continuous monitoring systems, monitoring devices, and performance testing measurements; all continuous monitoring system or monitoring device calibration checks; and adjustments and maintenance performed on these systems or devices. These files shall be kept in a permanent form suitable for inspection and shall be maintained for a period of at least five (5) years following the date of such measurements, reports, maintenance and records.
[391-3-1-.03(10)(d)1(i) and 40 CFR 70.6 (a)(3)(ii)(B)]

6.1.7 For the purpose of reporting excess emissions, exceedances or excursions in the report required in Condition 6.1.4, the following excess emissions, exceedances, and excursions shall be reported:
[391-3-1-.02(6)(b)1 and 40 CFR 70.6(a)(3)(iii)]

Title V Permit

- a. Excess emissions: (means for the purpose of this Condition and Condition 6.1.4, any condition that is detected by monitoring or record keeping which is specifically defined, or stated to be, excess emissions by an applicable requirement)
 - i. Any analysis of the natural gas combusted by the compressor turbine with ID No. T1, determined in accordance with Condition 6.2.4.c, that indicates sulfur content greater than 0.8 percent by weight.
- b. Exceedances: (means for the purpose of this Condition and Condition 6.1.4, any condition that is detected by monitoring or record keeping that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) do not meet the applicable emission limitation or standard consistent with the averaging period specified for averaging the results of the monitoring)
 - i. Any twelve consecutive month period during which the total hours of operation for emergency generator with ID No. EG or fire pump engine with ID No. FP1, as determined in accordance with Condition 6.2.1a. and b., exceeds the limit on allowable hours of operation specified in Condition 3.2.4.
 - ii. Any twelve consecutive month period during which the total amount of natural gas fired in the generator engines with ID Nos. G1 through G4, as determined in accordance with Condition 6.2.2(a), exceeds 140 million cubic feet.
 - iii. Any twelve consecutive month period during which the total amount of natural gas fired in the Vaporizer Heaters with ID Nos. VH1 through VH9, as determined in accordance with Condition 6.2.2(b), exceeds 80 million cubic feet.
 - iv. Any twelve consecutive month period during which the total amount of natural gas fired in the generator engines with ID Nos. G6 and G7, as determined in accordance with Condition 6.2.2(c), exceeds 47.1 million cubic feet.
 - v. Any twelve consecutive month period during which the total amount of natural gas fired in the Vaporizer Heaters with ID Nos. VH10 through VH12, as determined in accordance with Condition 6.2.2(d), exceeds 85.2 million cubic feet.
 - vi. For Vaporizer Heaters Nos. 13 through 18 (Source Codes: VH13 through VH18), Generator Turbines Nos. 1 and 2 (Source Codes: GT1 and GT2) and Emergency Generator No. 1 (Source Code: EG1), any 12-consecutive month hours of operation, as determined in Condition 6.2.11, that exceeds the limits in Condition 3.2.5.
- c. Excursions: (means for the purpose of this Condition and Condition 6.1.4, any departure from an indicator range or value established for monitoring consistent with any averaging period specified for averaging the results of the monitoring)
 - i. Any one-hour average combustor outlet temperature for Compressor Turbine (Source Code: T1) as determined in accordance with Condition 5.2.2(f), that

- exceeds by more than 10 percent of 1,882°F or the average temperature determined during the most recent test required by Condition 4.2.2.
- ii. Any four-hour rolling average temperature at the inlet to any of the catalytic converters with ID Nos. CC01; CC02; and CG01 through CG04; and G5C through G7C, as determined in accordance with Condition 5.2.2(g), that is less than 750°F or greater than 1,250°F.
 - iii. Any instance that the Permittee does not meet the operating limitations specified in Conditions 3.3.5 and 3.3.6.
[40 CFR 63.6640(b)]
 - iv. Any instance that the Permittee does not meet the RACT requirements specified in Condition 3.4.4.
- d. In addition to the excess emissions, exceedances and excursions specified above, the following should also be included with the report required in Condition 6.1.4:
- i. For Vaporizer Heaters Nos. 13 through 18 (Source Codes: VH13 through VH18), Generator Turbines Nos. 1 and 2 (Source Codes: GT1 and GT2) and Emergency Generator No. 1 (Source Code: EG1), the 12-consecutive month hours of operation, as determined in Condition 6.2.11, for each month in the reporting period.

6.2 Specific Record Keeping and Reporting Requirements

- 6.2.1 The Permittee shall use the hour meters required by Condition 5.2.1 to determine and record the following:
[NAA NSR – 40 CFR 52.21, 40 CFR 70.6(a)(3)(i), and 391-3-1-.02(6)(b)1]
- a. The net operating hours for the emergency generator with ID No. EG during every calendar month. At the end of each calendar month, the Permittee shall use the monthly operating hour records to determine and record the twelve-month rolling total of the operating hours for EG.
 - b. The net operating hours for the fire pump engine with ID No. FP1 during every calendar month. At the end of each calendar month, the Permittee shall use the monthly operating hour records to determine and record the twelve-month rolling total of the operating hours for FP1.
- 6.2.2 The Permittee shall use the natural gas consumption meters required by Condition 5.2.2 to determine and record the following:
[391-3-1-.02(6)(b)1 and 40 CFR 70.6(a)(3)(i)]
- a. The total volume of natural gas burned in the generator engines with ID Nos. G1 through G4, combined, during each calendar month. At the end of each calendar month, the Permittee shall use the monthly natural gas consumption records to determine and record the twelve-month rolling total of the natural gas consumed in G1

Title V Permit

through G4, combined, by adding that month's natural gas usage to the previous eleven month totals.

[NAA NSR Avoidance – 40 CFR 52.21]

- b. The total volume of natural gas burned in the Vaporizer Heaters with ID Nos. VH1 through VH9, combined, during each calendar month. At the end of each calendar month, the Permittee shall determine and record the twelve-month rolling total of the natural gas consumed in VH1 through VH9, combined.

[NAA NSR Avoidance – 40 CFR 52.21]

- c. The total volume of natural gas burned in the generator engines with ID Nos. G6 and G7, combined, during each calendar month. At the end of each calendar month, the Permittee shall determine and record the twelve-month rolling total of the natural gas consumed in G6 and G7, combined.

[NAA NSR Avoidance – 40 CFR 52.21]

- d. The total volume of natural gas burned in Vaporizer Heaters VH10 through VH12, combined, during each calendar month. At the end of each calendar month, the Permittee shall determine and record the twelve-month rolling total of the natural gas consumed in Vaporizer Heaters VH10 through VH12, combined.

[NAA NSR Avoidance – 40 CFR 52.21]

- e. The total volume of natural gas burned in the Vaporizer Heaters (Source Codes: VH7 through VH18) and the Regeneration Heater (Source Code: RH1) each, during each calendar month.

[40 CFR 60.48c(g)(2)]

- 6.2.3 The Permittee shall submit, with the report required by Condition 6.1.4, a semiannual report that contains the following records. The records shall be available for inspection or submittal to the Division upon request and contain:

[NAA NSR – 40 CFR 52.21, 40 CFR 70.6(a)(3)(i), and 391-3-1-.02(6)(b)1]

- a. The total operating hours for the emergency generator with ID No. EG, calculated in accordance with Condition 6.2.1(a), for the 12 consecutive month period ending with each calendar month in the semiannual reporting period.

- b. The total operating hours for the fire pump engine with ID No. FP1, calculated in accordance with Condition 6.2.1(b), for the 12 consecutive month period ending with each calendar month in the semiannual reporting period.

- c. The total volume of natural gas burned in the generator engines with ID Nos. G1 through G4, combined, calculated in accordance with Condition 6.2.2a., for the 12 consecutive month period ending with each calendar month in the semiannual reporting period.

- d. The total volume of natural gas burned in the Vaporizer Heaters with ID Nos. VH1 through VH9, combined, calculated in accordance with Condition 6.2.2b., for the 12

Title V Permit

consecutive month period ending with each calendar month in the semiannual reporting period.

- e. The total volume of natural gas burned in the generator engines with ID Nos. G6 and G7, combined, calculated in accordance with Condition 6.2.2c., for the 12 consecutive month period ending with each calendar month in the semiannual reporting period.
- f. The total volume of natural gas burned in the Vaporizer Heaters with ID Nos. VH10 through VH12, combined, calculated in accordance with Condition 6.2.2d., for the 12 consecutive month period ending with each calendar month in the semiannual reporting period.

6.2.4 The Permittee shall comply with the following natural gas sulfur content monitoring, record keeping, and reporting requirements:

[40 CFR 60.334(h)(1) and (3), 40 CFR 70.6(a)(3)(i), and 391-3-1-.02(6)(b)1]

- a. As long as the natural gas tariff that is effective as of the date of permit issuance stays effective, which specifies that the gas contains 20.0 grains or less of total sulfur per 100 standard cubic feet and therefore is presumed to meet the definition of natural gas in 40 CFR 60.331(u), the Permittee may elect not to monitor the total sulfur content of the gaseous fuel combusted in T1.
- b. If the natural gas tariff is replaced by a new natural gas tariff by either the existing or a new natural gas supplier, and the tariff specifies that the gas contains 20.0 grains or less of total sulfur per 100 standard cubic feet and therefore is presumed to meet the definition of natural gas in 40 CFR 60.331(u), and the Permittee submits a notification attaching a copy of the new natural gas tariff to the Division within 30 days of such change, the Permittee may elect not to monitor the total sulfur content of the gaseous fuel combusted in T1.
- c. If the natural gas tariff is replaced by a new natural gas tariff by either the existing or a new natural gas supplier, and this tariff does not specify that the gas contains 20.0 grains or less of total sulfur per 100 standard cubic feet, so that it can not be presumed to meet the definition of natural gas in 40 CFR 60.331(u), the Permittee shall perform semiannual analyses of the natural gas fired in T1 for the sulfur content in percent by weight. However, in lieu of the Permittee performing the analysis of natural gas, semiannual analyses may be obtained from the suppliers of natural gas to the Permittee. The semiannual fuel analyses shall be submitted with the report required by Condition 6.1.4.

6.2.5 The Permittee shall maintain records of all tune-ups that are required to be performed by Condition 3.4.4.d. These records shall include the date and time the tune-up was performed, the burner settings which were determined to minimize NO_x emissions, and an explanation regarding how those settings were determined.

[40 CFR 70.6(a)(3)(i) and 391-3-1-.02(6)(b)1]

Title V Permit

- 6.2.6 For the operation of the Boil-off Compressors (C1 & C2), the Generator Engines (G1 through G7), Emergency Generator (EG) and Fire Pump Engine (FP1), the Permittee shall keep and maintain the following records:
[40 CFR 63.6655(a) and 391-3-1-.02(6)(b)1]
- a. A copy of each notification and report that was submitted to comply with 40 CFR 63 Subpart ZZZZ.
 - b. Records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment.
 - c. Records of all required maintenance performed on the air pollution control and monitoring equipment.
 - d. Records of actions taken during periods of malfunction to minimize emissions in accordance with Condition 3.3.9, including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation.
 - e. Records of performance tests and performance evaluations as required in § 63.10(b)(2)(viii).
- 6.2.7 The Permittee shall record and maintain the following records:
[391-3-1-.02(6)(b)1]
- a. Records that demonstrate continuous compliance with the requirements specified in Condition 3.3.7.
[40 CFR 63.6655(d) and Item 9 of Table 6 to 40 CFR 63 Subpart ZZZZ]
 - b. Records of the maintenance conducted on the Boil-off Compressors (C1 & C2), the Generator Engines (G1 through G7), Emergency Generator (EG) and Fire Pump Engine (FP1).
[40 CFR 63.6655(e)]
- 6.2.8 The Permittee shall record and maintain the records of the hours of operation of Emergency Generator (EG) and Fire Pump Engine (FP1), each, using the non-resettable hour meter required in Condition 5.2.1. The Permittee shall document how many hours are spent for emergency operation, including what classified the operation as emergency, and how many hours are spent for non-emergency operation. If the Fire Pump Engine (FP1) is used for the purpose specified in § 63.6640(f)(4)(ii), the owner or operator must keep records of the notification of the emergency situation, and the date, start time, and end time of engine operation.
[40 CFR 63.6655(f) and 391-3-1-.02(6)(b)1]
- 6.2.9 The Permittee shall evaluate the status of existing non-emergency 4SRB stationary RICE with a site rating of more than 500 HP located at area sources of HAP, (i. e. Boil-off Compressors (C1 & C2), the Generator Engines (G1 through G7)), every twelve months to determine if the engines still meet the definition of remote stationary RICE in 40 CFR

Title V Permit

- 63.6675. The Permittee shall keep and maintain records of the initial and annual evaluation of the status of each engine. If the evaluation indicates that the stationary RICE no longer meets the definition of remote stationary RICE in 40 CFR 63.6675, the Permittee shall comply with all of the requirements for existing non-emergency spark ignition 4-stroke rich burn (SI 4SRB) stationary RICE with a site rating of more than 500 HP located at area sources of HAP that are not remote stationary RICE within 1 year of the evaluation.
[391-3-1-.02(6)(b)1 and 40 CFR 63.6603(f)]
- 6.2.10 For each calendar month, the Permittee shall maintain records of the hours of operation during the month for Vaporizer Heaters Nos. 13 through 18 (Source Codes: VH13 through VH18), Generator Turbines Nos. 1 and 2 (Source Codes: GT1 and GT2) and Emergency Generator No. 1 (Source Code: EG1).
[391-3-1-.02(6)(b)1 and 40 CFR 70.6(a)(3)(i)]
- 6.2.11 The Permittee shall use the monthly records required in Condition 6.2.10 to calculate the twelve-month rolling total hours of operation for each calendar month for Vaporizer Heaters Nos. 13 through 18 (Source Codes: VH13 through VH18), Generator Turbines Nos. 1 and 2 (Source Codes: GT1 and GT2) and Emergency Generator No. 1 (Source Code: EG1). All the calculations shall be kept as part of the records required in Condition 6.2.10.
[391-3-1-.02(6)(b)1 and 40 CFR 70.6(a)(3)(i)]
- 6.2.12 The Permittee shall submit notification of the date of construction and actual startup of the Vaporizer Heaters (Source Codes: VH13 through VH18), Generator Turbines (Source Codes: GT1 and GT2) and Emergency Generator (Source Code: EG1). For Vaporizer Heaters Nos. 13 through 18, this notification shall include all items specified in 40 CFR 60.48c(a). The notifications shall be submitted within 30 days of the event.
[40 CFR 60.48c(a), 391-3-1-.02(6)(b)1, and 40 CFR 70.6(a)(3)(i)]
- 6.2.13 To demonstrate compliance with Permit Condition 3.3.13, the Permittee shall submit a report containing the following information for each semiannual period ending June 30 and December 31 of each year. All reports shall be postmarked by August 29 and February 28, respectively following each reporting period.
[391-3-1-.02(6)(b)1(i), 40 CFR 60.4365(a) and (b), and 40 CFR 60.4395]
- a. Submit the fuel quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the fuel, specifying that the maximum total sulfur content 20 grains of sulfur or less per 100 standard cubic feet and has potential sulfur emissions of equal to or less than 26 ng SO₂ /J (0.060 lb SO₂ /MMBtu) heat input; or
 - b. Submit representative fuel sampling data which shows that the sulfur content of the fuel does not exceed 26 ng SO₂ /J (0.060 lb SO₂ /MMBtu) heat input. At a minimum the amount of fuel sampling data specified in 2.3.1.4 or 2.3.2.4 of Appendix D of 40 CFR Part 75 is required.
- 6.2.14 The Permittee shall submit to the Division the calendar year hours of non-emergency operation for Emergency Generator No. 1 (Source Code: EG1). This report shall be postmarked by February 28 of each calendar year.
[40 CFR 60.4243(d)]

- 6.2.15 The Permittee shall maintain records of the following information for Emergency Generator No. 1 (Source Code: EG1):
[40 CFR 60.4245(a) and 40 CFR 60.4243(a)(2)]
- a. All notifications submitted to comply with 40 CFR 60 Subpart JJJJ and all documentation supporting any notification.
 - b. Maintenance conducted on the engines.
 - c. Documentation that the engine meets the emission standards in 40 CFR 60 Subpart JJJJ and Condition 3.3.16.

PART 7.0 OTHER SPECIFIC REQUIREMENTS**7.1 Operational Flexibility**

7.1.1 The Permittee may make Section 502(b)(10) changes as defined in 40 CFR 70.2 without requiring a Permit revision, if the changes are not modifications under any provisions of Title I of the Federal Act and the changes do not exceed the emissions allowable under the Permit (whether expressed therein as a rate of emissions or in terms of total emissions). For each such change, the Permittee shall provide the Division and the EPA with written notification as required below in advance of the proposed changes and shall obtain any Permits required under Rules 391-3-1-.03(1) and (2). The Permittee and the Division shall attach each such notice to their copy of this Permit.

[391-3-1-.03(10)(b)5 and 40 CFR 70.4(b)(12)(i)]

- a. For each such change, the Permittee's written notification and application for a construction Permit shall be submitted well in advance of any critical date (typically at least 3 months in advance of any commencement of construction, Permit issuance date, etc.) involved in the change, but no less than seven (7) days in advance of such change and shall include a brief description of the change within the Permitted facility, the date on which the change is proposed to occur, any change in emissions, and any Permit term or condition that is no longer applicable as a result of the change.
- b. The Permit shield described in Condition 8.16.1 shall not apply to any change made pursuant to this condition.

7.2 Off-Permit Changes

7.2.1 The Permittee may make changes that are not addressed or prohibited by this Permit, other than those described in Condition 7.2.2 below, without a Permit revision, provided the following requirements are met:

[391-3-1-.03(10)(b)6 and 40 CFR 70.4(b)(14)]

- a. Each such change shall meet all applicable requirements and shall not violate any existing Permit term or condition.
- b. The Permittee must provide contemporaneous written notice to the Division and to the EPA of each such change, except for changes that qualify as insignificant under Rule 391-3-1-.03(10)(g). Such written notice shall describe each such change, including the date, any change in emissions, pollutants emitted, and any applicable requirement that would apply as a result of the change.
- c. The change shall not qualify for the Permit shield in Condition 8.16.1.
- d. The Permittee shall keep a record describing changes made at the source that result in emissions of a regulated air pollutant subject to an applicable requirement, but not otherwise regulated under the Permit, and the emissions resulting from those changes.

7.2.2 The Permittee shall not make, without a Permit revision, any changes that are not addressed or prohibited by this Permit, if such changes are subject to any requirements under Title IV of the Federal Act or are modifications under any provision of Title I of the Federal Act. [Rule 391-3-1-.03(10)(b)7 and 40 CFR 70.4(b)(15)]

7.3 Alternative Requirements

[White Paper #2]
Not Applicable

7.4 Insignificant Activities

(see Attachment B for the list of Insignificant Activities in existence at the facility at the time of permit issuance)

7.5 Temporary Sources

[391-3-1-.03(10)(d)5 and 40 CFR 70.6(e)]
Not Applicable

7.6 Short-term Activities

Not Applicable

7.7 Compliance Schedule/Progress Reports

[391-3-1-.03(10)(d)3 and 40 CFR 70.6(c)(4)]
None Applicable

7.8 Emissions Trading

[391-3-1-.03(10)(d)1(ii) and 40 CFR 70.6(a)(10)]
Not Applicable

7.9 Acid Rain Requirements

Not Applicable

7.10 Prevention of Accidental Releases (Section 112(r) of the 1990 CAAA)

[391-3-1-.02(10)]

7.10.1 When and if the requirements of 40 CFR Part 68 become applicable, the Permittee shall comply with all applicable requirements of 40 CFR Part 68, including the following.

- a. The Permittee shall submit a Risk Management Plan (RMP) as provided in 40 CFR 68.150 through 68.185. The RMP shall include a registration that reflects all covered processes.
- b. For processes eligible for Program 1, as provided in 40 CFR 68.10, the Permittee shall comply with 7.10.1.a. and the following additional requirements:
 - i. Analyze the worst-case release scenario for the process(es), as provided in 40 CFR 68.25; document that the nearest public receptor is beyond the distance to a toxic or flammable endpoint defined in 40 CFR 68.22(a); and submit in the RMP the worst-case release scenario as provided in 40 CFR 68.165.

Title V Permit

- ii. Complete the five-year accident history for the process as provided in 40 CFR 68.42 and submit in the RMP as provided in 40 CFR 68.168
 - iii. Ensure that response actions have been coordinated with local emergency planning and response agencies
 - iv. Include a certification in the RMP as specified in 40 CFR 68.12(b)(4)
- c. For processes subject to Program 2, as provided in 40 CFR 68.10, the Permittee shall comply with 7.10.1.a., 7.10.1.b. and the following additional requirements:
- i. Develop and implement a management system as provided in 40 CFR 68.15
 - ii. Conduct a hazard assessment as provided in 40 CFR 68.20 through 68.42
 - iii. Implement the Program 2 prevention steps provided in 40 CFR 68.48 through 68.60 or implement the Program 3 prevention steps provided in 40 CFR 68.65 through 68.87
 - iv. Develop and implement an emergency response program as provided in 40 CFR 68.90 through 68.95
 - v. Submit as part of the RMP the data on prevention program elements for Program 2 processes as provided in 40 CFR 68.170
- d. For processes subject to Program 3, as provided in 40 CFR 68.10, the Permittee shall comply with 7.10.1.a., 7.10.1.b. and the following additional requirements:
- i. Develop and implement a management system as provided in 40 CFR 68.15
 - ii. Conduct a hazard assessment as provided in 40 CFR 68.20 through 68.42
 - iii. Implement the prevention requirements of 40 CFR 68.65 through 68.87
 - iv. Develop and implement an emergency response program as provided in 40 CFR 68.90 through 68.95
 - v. Submit as part of the RMP the data on prevention program elements for Program 3 as provided in 40 CFR 68.175
- e. All reports and notification required by 40 CFR Part 68 must be submitted electronically using RMP*[eSubmit](http://www.epa.gov/rmp/rmpsubmit) (information for establishing an account can be found at www.epa.gov/rmp/rmpsubmit). Electronic Signature Agreements should be mailed to:

MAIL

**Risk Management Program (RMP) Reporting Center
P.O. Box 10162
Fairfax, VA 22038**

COURIER & FEDEX

**Risk Management Program (RMP) Reporting Center
CGI Federal
12601 Fair Lakes Circle
Fairfax, VA 22033**

Compliance with all requirements of this condition, including the registration and submission of the RMP, shall be included as part of the compliance certification submitted in accordance with Condition 8.14.1.

7.11 Stratospheric Ozone Protection Requirements (Title VI of the CAAA of 1990)

- 7.11.1 If the Permittee performs any of the activities described below or as otherwise defined in 40 CFR Part 82, the Permittee shall comply with the standards for recycling and emissions reduction pursuant to 40 CFR Part 82, Subpart F, except as provided for motor vehicle air conditioners (MVACs) in Subpart B:
- a. Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices pursuant to 40 CFR 82.156.
 - b. Equipment used during the maintenance, service, repair, or disposal of appliance must comply with the standards for recycling and recovery equipment pursuant to 40 CFR 82.158.
 - c. Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to 40 CFR 82.161.
 - d. Persons disposing of small appliances, MVACs, and MVAC-like appliances must comply with record keeping requirements pursuant to 40 CFR 82.166.
[Note: “MVAC-like appliance” is defined in 40 CFR 82.152.]
 - e. Persons owning commercial or industrial process refrigeration equipment must comply with the leak repair requirements pursuant to 40 CFR 82.156.
 - f. Owners/operators of appliances normally containing 50 or more pounds of refrigerant must keep records of refrigerant purchased and added to such appliances pursuant to 40 CFR 82.166.
- 7.11.2 If the Permittee performs a service on motor (fleet) vehicles and if this service involves an ozone-depleting substance (refrigerant) in the MVAC, the Permittee is subject to all the applicable requirements as specified in 40 CFR Part 82, Subpart B, Servicing of Motor Vehicle Air Conditioners.

The term “motor vehicle” as used in Subpart B does not include a vehicle in which final assembly of the vehicle has not been completed. The term “MVAC” as used in Subpart B does not include air-tight sealed refrigeration systems used for refrigerated cargo, or air conditioning systems on passenger buses using HCFC-22 refrigerant.

Title V Permit

7.12 Revocation of Existing Permits and Amendments

The following Air Quality Permits, Amendments, and 502(b)10 are subsumed by this permit and are hereby revoked:

Air Quality Permit and Amendment Number(s)	Dates of Original Permit or Amendment Issuance
4924-057-0036-V-04-0	August 10, 2017
4924-057-0036-V-04-1	October 22, 2021

7.13 Pollution Prevention

Not Applicable

7.14 Specific Conditions

Not Applicable

PART 8.0 GENERAL PROVISIONS**8.1 Terms and References**

- 8.1.1 Terms not otherwise defined in the Permit shall have the meaning assigned to such terms in the referenced regulation.
- 8.1.2 Where more than one condition in this Permit applies to an emission unit and/or the entire facility, each condition shall apply and the most stringent condition shall take precedence.
[391-3-1-.02(2)(a)2]

8.2 EPA Authorities

- 8.2.1 Except as identified as “State-only enforceable” requirements in this Permit, all terms and conditions contained herein shall be enforceable by the EPA and citizens under the Clean Air Act, as amended, 42 U.S.C. 7401, et seq.
[40 CFR 70.6(b)(1)]
- 8.2.2 Nothing in this Permit shall alter or affect the authority of the EPA to obtain information pursuant to 42 U.S.C. 7414, “Inspections, Monitoring, and Entry.”
[40 CFR 70.6(f)(3)(iv)]
- 8.2.3 Nothing in this Permit shall alter or affect the authority of the EPA to impose emergency orders pursuant to 42 U.S.C. 7603, “Emergency Powers.”
[40 CFR 70.6(f)(3)(i)]

8.3 Duty to Comply

- 8.3.1 The Permittee shall comply with all conditions of this operating Permit. Any Permit noncompliance constitutes a violation of the Federal Clean Air Act and the Georgia Air Quality Act and/or State rules and is grounds for enforcement action; for Permit termination, revocation and reissuance, or modification; or for denial of a Permit renewal application. Any noncompliance with a Permit condition specifically designated as enforceable only by the State constitutes a violation of the Georgia Air Quality Act and/or State rules only and is grounds for enforcement action; for Permit termination, revocation and reissuance, or modification; or for denial of a Permit renewal application.
[391-3-1-.03(10)(d)1(i) and 40 CFR 70.6(a)(6)(i)]
- 8.3.2 The Permittee shall not use as a defense in an enforcement action the contention that it would have been necessary to halt or reduce the Permitted activity in order to maintain compliance with the conditions of this Permit.
[391-3-1-.03(10)(d)1(i) and 40 CFR 70.6(a)(6)(ii)]
- 8.3.3 Nothing in this Permit shall alter or affect the liability of the Permittee for any violation of applicable requirements prior to or at the time of Permit issuance.
[391-3-1-.03(10)(d)1(i) and 40 CFR 70.6(f)(3)(ii)]

- 8.3.4 Issuance of this Permit does not relieve the Permittee from the responsibility of obtaining any other permits, licenses, or approvals required by the Director or any other federal, state, or local agency.
[391-3-1-.03(10)(e)1(iv) and 40 CFR 70.7(a)(6)]

8.4 Fee Assessment and Payment

- 8.4.1 The Permittee shall calculate and pay an annual Permit fee to the Division. The amount of fee shall be determined each year in accordance with the “Procedures for Calculating Air Permit Fees.”
[391-3-1-.03(9)]

8.5 Permit Renewal and Expiration

- 8.5.1 This Permit shall remain in effect for five (5) years from the issuance date. The Permit shall become null and void after the expiration date unless a timely and complete renewal application has been submitted to the Division at least six (6) months, but no more than eighteen (18) months prior to the expiration date of the Permit.
[391-3-1-.03(10)(d)1(i), (e)2, and (e)3(ii) and 40 CFR 70.5(a)(1)(iii)]
- 8.5.2 Permits being renewed are subject to the same procedural requirements, including those for public participation and affected State and EPA review, that apply to initial Permit issuance.
[391-3-1-.03(10)(e)3(i)]
- 8.5.3 Notwithstanding the provisions in 8.5.1 above, if the Division has received a timely and complete application for renewal, deemed it administratively complete, and failed to reissue the Permit for reasons other than cause, authorization to operate shall continue beyond the expiration date to the point of Permit modification, reissuance, or revocation.
[391-3-1-.03(10)(e)3(iii)]

8.6 Transfer of Ownership or Operation

- 8.6.1 This Permit is not transferable by the Permittee. Future owners and operators shall obtain a new Permit from the Director. The new Permit may be processed as an administrative amendment if no other change in this Permit is necessary, and provided that a written agreement containing a specific date for transfer of Permit responsibility coverage and liability between the current and new Permittee has been submitted to the Division at least thirty (30) days in advance of the transfer.
[391-3-1-.03(4)]

8.7 Property Rights

- 8.7.1 This Permit shall not convey property rights of any sort, or any exclusive privileges.
[391-3-1-.03(10)(d)1(i) and 40 CFR 70.6(a)(6)(iv)]

8.8 Submissions

- 8.8.1 Reports, test data, monitoring data, notifications, annual certifications, and requests for revision and renewal shall be submitted to:

**Georgia Department of Natural Resources
Environmental Protection Division
Air Protection Branch
Atlanta Tradeport, Suite 120
4244 International Parkway
Atlanta, Georgia 30354-3908**

- 8.8.2 Any records, compliance certifications, and monitoring data required by the provisions in this Permit to be submitted to the EPA shall be sent to:

**Air and Radiation Division
Air Planning and Implementation Branch
U. S. EPA Region 4
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW
Atlanta, Georgia 30303-3104**

- 8.8.3 Any application form, report, or compliance certification submitted pursuant to this Permit shall contain a certification by a responsible official of its truth, accuracy, and completeness. This certification shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. [391-3-1-.03(10)(c)2, 40 CFR 70.5(d) and 40 CFR 70.6(c)(1)]

- 8.8.4 Unless otherwise specified, all submissions under this permit shall be submitted to the Division only.

8.9 Duty to Provide Information

- 8.9.1 The Permittee, upon becoming aware that any relevant facts were omitted or incorrect information was submitted in the Permit application, shall promptly submit such supplementary facts or corrected information to the Division. [391-3-1-.03(10)(c)5]

- 8.9.2 The Permittee shall furnish to the Division, in writing, information that the Division may request to determine whether cause exists for modifying, revoking and reissuing, or terminating the Permit, or to determine compliance with the Permit. Upon request, the Permittee shall also furnish to the Division copies of records that the Permittee is required to keep by this Permit or, for information claimed to be confidential, the Permittee may furnish such records directly to the EPA, if necessary, along with a claim of confidentiality. [391-3-1-.03(10)(d)1(i) and 40 CFR 70.6(a)(6)(v)]

8.10 Modifications

- 8.10.1 Prior to any source commencing a modification as defined in 391-3-1-.01(pp) that may result in air pollution and not exempted by 391-3-1-.03(6), the Permittee shall submit a Permit application to the Division. The application shall be submitted sufficiently in advance of any critical date involved to allow adequate time for review, discussion, or revision of plans, if necessary. Such application shall include, but not be limited to, information describing the precise nature of the change, modifications to any emission control system, production capacity of the plant before and after the change, and the anticipated completion date of the change. The application shall be in the form of a Georgia air quality Permit application to construct or modify (otherwise known as a SIP application) and shall be submitted on forms supplied by the Division, unless otherwise notified by the Division.
[391-3-1-.03(1) through (8)]

8.11 Permit Revision, Revocation, Reopening and Termination

- 8.11.1 This Permit may be revised, revoked, reopened and reissued, or terminated for cause by the Director. The Permit will be reopened for cause and revised accordingly under the following circumstances:
[391-3-1-.03(10)(d)1(i)]
- a. If additional applicable requirements become applicable to the source and the remaining Permit term is three (3) or more years. In this case, the reopening shall be completed no later than eighteen (18) months after promulgation of the applicable requirement. A reopening shall not be required if the effective date of the requirement is later than the date on which the Permit is due to expire, unless the original permit or any of its terms and conditions has been extended under Condition 8.5.3;
[391-3-1-.03(10)(e)6(i)(I)]
 - b. If any additional applicable requirements of the Acid Rain Program become applicable to the source;
[391-3-1-.03(10)(e)6(i)(II)] (Acid Rain sources only)
 - c. The Director determines that the Permit contains a material mistake or inaccurate statements were made in establishing the emissions standards or other terms or conditions of the Permit; or
[391-3-1-.03(10)(e)6(i)(III) and 40 CFR 70.7(f)(1)(iii)]
 - d. The Director determines that the Permit must be revised or revoked to assure compliance with the applicable requirements.
[391-3-1-.03(10)(e)6(i)(IV) and 40 CFR 70.7(f)(1)(iv)]
- 8.11.2 Proceedings to reopen and reissue a Permit shall follow the same procedures as applicable to initial Permit issuance and shall affect only those parts of the Permit for which cause to reopen exists. Reopenings shall be made as expeditiously as practicable.
[391-3-1-.03(10)(e)6(ii)]

- 8.11.3 Reopenings shall not be initiated before a notice of intent to reopen is provided to the source by the Director at least thirty (30) days in advance of the date the Permit is to be reopened, except that the Director may provide a shorter time period in the case of an emergency.
[391-3-1-.03(10)(e)6(iii)]
- 8.11.4 All Permit conditions remain in effect until such time as the Director takes final action. The filing of a request by the Permittee for any Permit revision, revocation, reissuance, or termination, or of a notification of planned changes or anticipated noncompliance, shall not stay any Permit condition.
[391-3-1-.03(10)(d)1(i) and 40 CFR 70.6(a)(6)(iii)]
- 8.11.5 A Permit revision shall not be required for changes that are explicitly authorized by the conditions of this Permit.
- 8.11.6 A Permit revision shall not be required for changes that are part of an approved economic incentive, marketable Permit, emission trading, or other similar program or process for change which is specifically provided for in this Permit.
[391-3-1-.03(10)(d)1(i) and 40 CFR 70.6(a)(8)]

8.12 Severability

- 8.12.1 Any condition or portion of this Permit which is challenged, becomes suspended or is ruled invalid as a result of any legal or other action shall not invalidate any other portion or condition of this Permit.
[391-3-1-.03(10)(d)1(i) and 40 CFR 70.6(a)(5)]

8.13 Excess Emissions Due to an Emergency

- 8.13.1 An “emergency” means any situation arising from sudden and reasonably unforeseeable events beyond the control of the source, including acts of God, which situation requires immediate corrective action to restore normal operation, and that causes the source to exceed a technology-based emission limitation under the Permit, due to unavoidable increases in emissions attributable to the emergency. An emergency shall not include noncompliance to the extent caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.
[391-3-1-.03(10)(d)7 and 40 CFR 70.6(g)(1)]
- 8.13.2 An emergency shall constitute an affirmative defense to an action brought for noncompliance with the technology-based emission limitations if the Permittee demonstrates, through properly signed contemporaneous operating logs or other relevant evidence, that:
[391-3-1-.03(10)(d)7 and 40 CFR 70.6(g)(2) and (3)]
 - a. An emergency occurred and the Permittee can identify the cause(s) of the emergency;
 - b. The Permitted facility was at the time of the emergency being properly operated;

- c. During the period of the emergency, the Permittee took all reasonable steps to minimize levels of emissions that exceeded the emissions standards, or other requirements in the Permit; and
 - d. The Permittee promptly notified the Division and submitted written notice of the emergency to the Division within two (2) working days of the time when emission limitations were exceeded due to the emergency. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.
- 8.13.3 In an enforcement proceeding, the Permittee seeking to establish the occurrence of an emergency shall have the burden of proof.
[391-3-1-.03(10)(d)7 and 40 CFR 70.6(g)(4)]
- 8.13.4 The emergency conditions listed above are in addition to any emergency or upset provisions contained in any applicable requirement.
[391-3-1-.03(10)(d)7 and 40 CFR 70.6(g)(5)]

8.14 Compliance Requirements

8.14.1 Compliance Certification

The Permittee shall provide written certification to the Division and to the EPA, at least annually, of compliance with the conditions of this Permit. The annual written certification shall be postmarked no later than February 28 of each year and shall be submitted to the Division and to the EPA. The certification shall include, but not be limited to, the following elements:

[391-3-1-.03(10)(d)3 and 40 CFR 70.6(c)(5)]

- a. The identification of each term or condition of the Permit that is the basis of the certification;
- b. The status of compliance with the terms and conditions of the permit for the period covered by the certification, including whether compliance during the period was continuous or intermittent, based on the method or means designated in paragraph c below. The certification shall identify each deviation and take it into account in the compliance certification. The certification shall also identify as possible exceptions to compliance any periods during which compliance is required and in which an excursion or exceedance as defined under 40 CFR Part 64 occurred;
- c. The identification of the method(s) or other means used by the owner or operator for determining the compliance status with each term and condition during the certification period;
- d. Any other information that must be included to comply with section 113(c)(2) of the Act, which prohibits knowingly making a false certification or omitting material information; and
- e. Any additional requirements specified by the Division.

8.14.2 Inspection and Entry

- a. Upon presentation of credentials and other documents as may be required by law, the Permittee shall allow authorized representatives of the Division to perform the following:
[391-3-1-.03(10)(d)3 and 40 CFR 70.6(c)(2)]
 - i. Enter upon the Permittee's premises where a Part 70 source is located or an emissions-related activity is conducted, or where records must be kept under the conditions of this Permit;
 - ii. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Permit;
 - iii. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this Permit; and
 - iv. Sample or monitor any substances or parameters at any location during operating hours for the purpose of assuring Permit compliance or compliance with applicable requirements as authorized by the Georgia Air Quality Act.
- b. No person shall obstruct, hamper, or interfere with any such authorized representative while in the process of carrying out his official duties. Refusal of entry or access may constitute grounds for Permit revocation and assessment of civil penalties.
[391-3-1-.07 and 40 CFR 70.11(a)(3)(i)]

8.14.3 Schedule of Compliance

- a. For applicable requirements with which the Permittee is in compliance, the Permittee shall continue to comply with those requirements.
[391-3-1-.03(10)(c)2 and 40 CFR 70.5(c)(8)(iii)(A)]
- b. For applicable requirements that become effective during the Permit term, the Permittee shall meet such requirements on a timely basis unless a more detailed schedule is expressly required by the applicable requirement.
[391-3-1-.03(10)(c)2 and 40 CFR 70.5(c)(8)(iii)(B)]
- c. Any schedule of compliance for applicable requirements with which the source is not in compliance at the time of Permit issuance shall be supplemental to, and shall not sanction noncompliance with, the applicable requirements on which it is based.
[391-3-1-.03(10)(c)2 and 40 CFR 70.5(c)(8)(iii)(C)]

8.14.4 Excess Emissions

- a. Excess emissions resulting from startup, shutdown, or malfunction of any source which occur though ordinary diligence is employed shall be allowed provided that:
[391-3-1-.02(2)(a)7(i)]
 - i. The best operational practices to minimize emissions are adhered to;

- ii. All associated air pollution control equipment is operated in a manner consistent with good air pollution control practice for minimizing emissions; and
- iii. The duration of excess emissions is minimized.

- b. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction are prohibited and are violations of Chapter 391-3-1 of the Georgia Rules for Air Quality Control.
[391-3-1-.02(2)(a)7(ii)]

- c. The provisions of this condition and Georgia Rule 391-3-1-.02(2)(a)7 shall apply only to those sources which are not subject to any requirement under Georgia Rule 391-3-1-.02(8) – New Source Performance Standards or any requirement of 40 CFR, Part 60, as amended concerning New Source Performance Standards.
[391-3-1-.02(2)(a)7(iii)]

8.15 Circumvention

State Only Enforceable Condition.

- 8.15.1 The Permittee shall not build, erect, install, or use any article, machine, equipment or process the use of which conceals an emission which would otherwise constitute a violation of an applicable emission standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of the pollutants in the gases discharged into the atmosphere.
[391-3-1-.03(2)(c)]

8.16 Permit Shield

- 8.16.1 Compliance with the terms of this Permit shall be deemed compliance with all applicable requirements as of the date of Permit issuance provided that all applicable requirements are included and specifically identified in the Permit.
[391-3-1-.03(10)(d)6]

- 8.16.2 Any Permit condition identified as “State only enforceable” does not have a Permit shield.

8.17 Operational Practices

- 8.17.1 At all times, including periods of startup, shutdown, and malfunction, the Permittee shall maintain and operate the source, including associated air pollution control equipment, in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on any information available to the Division that may include, but is not limited to, monitoring results, observations of the opacity or other characteristics of emissions, review of operating and maintenance procedures or records, and inspection or surveillance of the source.
[391-3-1-.02(2)(a)10]

State Only Enforceable Condition.

8.17.2 No person owning, leasing, or controlling, the operation of any air contaminant sources shall willfully, negligently or through failure to provide necessary equipment or facilities or to take necessary precautions, cause, permit, or allow the emission from said air contamination source or sources, of such quantities of air contaminants as will cause, or tend to cause, by themselves, or in conjunction with other air contaminants, a condition of air pollution in quantities or characteristics or of a duration which is injurious or which unreasonably interferes with the enjoyment of life or use of property in such area of the State as is affected thereby. Complying with Georgia’s Rules for Air Quality Control Chapter 391-3-1 and Conditions in this Permit, shall in no way exempt a person from this provision.
[391-3-1-.02(2)(a)1]

8.18 Visible Emissions

8.18.1 Except as may be provided in other provisions of this Permit, the Permittee shall not cause, let, suffer, permit or allow emissions from any air contaminant source the opacity of which is equal to or greater than forty (40) percent.
[391-3-1-.02(2)(b)1]

8.19 Fuel-burning Equipment

8.19.1 The Permittee shall not cause, let, suffer, permit, or allow the emission of fly ash and/or other particulate matter from any fuel-burning equipment with rated heat input capacity of less than 10 million Btu per hour, in operation or under construction on or before January 1, 1972 in amounts equal to or exceeding 0.7 pounds per million BTU heat input.
[391-3-1-.02(2)(d)]

8.19.2 The Permittee shall not cause, let, suffer, permit, or allow the emission of fly ash and/or other particulate matter from any fuel-burning equipment with rated heat input capacity of less than 10 million Btu per hour, constructed after January 1, 1972 in amounts equal to or exceeding 0.5 pounds per million BTU heat input.
[391-3-1-.02(2)(d)]

8.19.3 The Permittee shall not cause, let, suffer, permit, or allow the emission from any fuel-burning equipment constructed or extensively modified after January 1, 1972, visible emissions the opacity of which is equal to or greater than twenty (20) percent except for one six minute period per hour of not more than twenty-seven (27) percent opacity.
[391-3-1-.02(2)(d)]

8.20 Sulfur Dioxide

8.20.1 Except as may be specified in other provisions of this Permit, the Permittee shall not burn fuel containing more than 2.5 percent sulfur, by weight, in any fuel burning source that has a heat input capacity below 100 million Btu's per hour.
[391-3-1-.02(2)(g)]

8.21 Particulate Emissions

8.21.1 Except as may be specified in other provisions of this Permit, the Permittee shall not cause, let, permit, suffer, or allow the rate of emission from any source, particulate matter in total quantities equal to or exceeding the allowable rates shown below. Equipment in operation, or under construction contract, on or before July 2, 1968, shall be considered existing equipment. All other equipment put in operation or extensively altered after said date is to be considered new equipment.

[391-3-1-.02(2)(e)]

- a. The following equations shall be used to calculate the allowable rates of emission from new equipment:

$$E = 4.1P^{0.67}; \text{ for process input weight rate up to and including 30 tons per hour.}$$

$$E = 55P^{0.11} - 40; \text{ for process input weight rate above 30 tons per hour.}$$

- b. The following equation shall be used to calculate the allowable rates of emission from existing equipment:

$$E = 4.1P^{0.67}$$

In the above equations, E = emission rate in pounds per hour, and
P = process input weight rate in tons per hour.

8.22 Fugitive Dust

[391-3-1-.02(2)(n)]

8.22.1 Except as may be specified in other provisions of this Permit, the Permittee shall take all reasonable precautions to prevent dust from any operation, process, handling, transportation or storage facility from becoming airborne. Reasonable precautions that could be taken to prevent dust from becoming airborne include, but are not limited to, the following:

- a. Use, where possible, of water or chemicals for control of dust in the demolition of existing buildings or structures, construction operations, the grading of roads or the clearing of land;
- b. Application of asphalt, water, or suitable chemicals on dirt roads, materials, stockpiles, and other surfaces that can give rise to airborne dusts;
- c. Installation and use of hoods, fans, and fabric filters to enclose and vent the handling of dusty materials. Adequate containment methods can be employed during sandblasting or other similar operations;
- d. Covering, at all times when in motion, open bodied trucks transporting materials likely to give rise to airborne dusts; and
- e. The prompt removal of earth or other material from paved streets onto which earth or other material has been deposited.

8.22.2 The opacity from any fugitive dust source shall not equal or exceed 20 percent.

8.23 Solvent Metal Cleaning

8.23.1 Except as may be specified in other provisions of this Permit, the Permittee shall not cause, suffer, allow, or permit the operation of a cold cleaner degreaser subject to the requirements of Georgia Rule 391-3-1-.02(2)(ff) “Solvent Metal Cleaning” unless the following requirements for control of emissions of the volatile organic compounds are satisfied:
[391-3-1-.02(2)(ff)1]

- a. The degreaser shall be equipped with a cover to prevent escape of VOC during periods of non-use,
- b. The degreaser shall be equipped with a device to drain cleaned parts before removal from the unit,
- c. If the solvent volatility is 0.60 psi or greater measured at 100 °F, or if the solvent is heated above 120 °F, then one of the following control devices must be used:
 - i. The degreaser shall be equipped with a freeboard that gives a freeboard ratio of 0.7 or greater, or
 - ii. The degreaser shall be equipped with a water cover (solvent must be insoluble in and heavier than water), or
 - iii. The degreaser shall be equipped with a system of equivalent control, including but not limited to, a refrigerated chiller or carbon adsorption system.
- d. Any solvent spray utilized by the degreaser must be in the form of a solid, fluid stream (not a fine, atomized or shower type spray) and at a pressure which will not cause excessive splashing, and
- e. All waste solvent from the degreaser shall be stored in covered containers and shall not be disposed of by such a method as to allow excessive evaporation into the atmosphere.

8.24 Incinerators

8.24.1 Except as specified in the section dealing with conical burners, no person shall cause, let, suffer, permit, or allow the emissions of fly ash and/or other particulate matter from any incinerator subject to the requirements of Georgia Rule 391-3-1-.02(2)(c) “Incinerators”, in amounts equal to or exceeding the following:
[391-3-1-.02(2)(c)1-4]

- a. Units with charging rates of 500 pounds per hour or less of combustible waste, including water, shall not emit fly ash and/or particulate matter in quantities exceeding 1.0 pound per hour.

- b. Units with charging rates in excess of 500 pounds per hour of combustible waste, including water, shall not emit fly ash and/or particulate matter in excess of 0.20 pounds per 100 pounds of charge.

- 8.24.2 No person shall cause, let, suffer, permit, or allow from any incinerator subject to the requirements of Georgia Rule 391-3-1-.02(2)(c) “Incinerators”, visible emissions the opacity of which is equal to or greater than twenty (20) percent except for one six minute period per hour of not more than twenty-seven (27) percent opacity.

- 8.24.3 No person shall cause or allow particles to be emitted from an incinerator subject to the requirements of Georgia Rule 391-3-1-.02(2)(c) “Incinerators” which are individually large enough to be visible to the unaided eye.

- 8.24.4 No person shall operate an existing incinerator subject to the requirements of Georgia Rule 391-3-1-.02(2)(c) “Incinerators” unless:
 - a. It is a multiple chamber incinerator;
 - b. It is equipped with an auxiliary burner in the primary chamber for the purpose of creating a pre-ignition temperature of 800°F; and
 - c. It has a secondary burner to control smoke and/or odors and maintain a temperature of at least 1500°F in the secondary chamber.

8.25 Volatile Organic Liquid Handling and Storage

- 8.25.1 The Permittee shall ensure that each storage tank subject to the requirements of Georgia Rule 391-3-1-.02(2)(vv) “Volatile Organic Liquid Handling and Storage” is equipped with submerged fill pipes. For the purposes of this condition and the permit, a submerged fill pipe is defined as any fill pipe with a discharge opening which is within six inches of the tank bottom.
[391-3-1-.02(2)(vv)(1)]

8.26 Use of Any Credible Evidence or Information

- 8.26.1 Notwithstanding any other provisions of any applicable rule or regulation or requirement of this permit, for the purpose of submission of compliance certifications or establishing whether or not a person has violated or is in violation of any emissions limitation or standard, nothing in this permit or any Emission Limitation or Standard to which it pertains, shall preclude the use, including the exclusive use, of any credible evidence or information, relevant to whether a source would have been in compliance with applicable requirements if the appropriate performance or compliance test or procedure had been performed.
[391-3-1-.02(3)(a)]

8.27 Internal Combustion Engines

- 8.27.1 For diesel-fired internal combustion engine(s) manufactured after April 1, 2006 or modified/reconstructed after July 11, 2005, the Permittee shall comply with all applicable

Title V Permit

provisions of New Source Performance Standards (NSPS) as found in 40 CFR 60 Subpart A - “General Provisions” and 40 CFR 60 Subpart IIII – “Standards of Performance for Stationary Compression Ignition Internal Combustion Engines.” Such requirements include but are not limited to:

[40 CFR 60.4200]

- a. Equip all emergency generator engines with non-resettable hour meters in accordance with Subpart IIII.
- b. Purchase only diesel fuel with a maximum sulfur content of 15 ppm unless otherwise specified by the Division in accordance with Subpart IIII.
- c. Conduct engine maintenance prescribed by the engine manufacturer in accordance with Subpart IIII.
- d. Limit non-emergency operation of each emergency generator to 100 hours per year in accordance with Subpart IIII. Non-emergency operation other than maintenance and readiness testing is prohibited for engines qualifying as “emergency generators” for the purposes of Ga Rule 391-3-1-.02(2)(mmm).
- e. Maintain any records in accordance with Subpart IIII
- f. Maintain a list of engines subject to 40 CFR 60 Subpart IIII, including the date of manufacture.[391-3-1-.02(6)(b)]

8.27.2 The Permittee shall comply with all applicable provisions of New Source Performance Standards (NSPS) as found in 40 CFR 60 Subpart A - “General Provisions” and 40 CFR 60 Subpart JJJJ - “Standards of Performance for Stationary Spark Ignition Internal Combustion Engines,” for spark ignition internal combustion engine(s) (gasoline, natural gas, liquefied petroleum gas or propane-fired) manufactured after July 1, 2007 or modified/reconstructed after June 12, 2006.
[40 CFR 60.4230]

8.27.3 The Permittee shall comply with all applicable provisions of National Emission Standards for Hazardous Air Pollutants (NESHAP) as found in 40 CFR 63 Subpart A - “General Provisions” and 40 CFR 63 Subpart ZZZZ - “National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.”

For diesel-fired emergency generator engines defined as “existing” in 40 CFR 63 Subpart ZZZZ (constructed prior to June 12, 2006 for area sources of HAP, constructed prior to June 12, 2006 for ≤500hp engines at major sources, and constructed prior to December 19, 2002 for >500hp engines at major sources of HAP), such requirements (if applicable) include but are not limited to:

[40 CFR 63.6580]

- a. Equip all emergency generator engines with non-resettable hour meters in accordance with Subpart ZZZZ.

Title V Permit

- b. Purchase only diesel fuel with a maximum sulfur content of 15 ppm unless otherwise specified by the Division in accordance with Subpart ZZZZ.
- c. Conduct the following in accordance with Subpart ZZZZ.
 - i. Change oil and filter every 500 hours of operation or annually, whichever comes first
 - ii. Inspect air cleaner every 1000 hours of operation or annually, whichever comes first and replace as necessary
 - iii. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first and replace as necessary.
- d. Limit non-emergency operation of each emergency generator to 100 hours per year in accordance with Subpart ZZZZ. Non-emergency operation other than maintenance and readiness testing is prohibited for engines qualifying as “emergency generators” for the purposes of Ga Rule 391-3-1-.02(2)(mmm).
- e. Maintain any records in accordance with Subpart ZZZZ
- f. Maintain a list of engines subject to 40 CFR 63 Subpart ZZZZ, including the date of manufacture.[391-3-1-.02(6)(b)]

8.28 Boilers and Process Heaters

- 8.28.1 If the facility/site is an area source of Hazardous Air Pollutants, the Permittee shall comply with all applicable provisions of National Emission Standards for Hazardous Air Pollutants (NESHAP) 40 CFR Part 63 Subpart A - “General Provisions” and 40 CFR 63 Subpart JJJJJ - “National Emission Standards for Hazardous Air Pollutants for Area Sources: Industrial, Commercial, and Institutional Boilers.”
[40 CFR 63.11193]
- 8.28.2 If the facility/site is a major source of Hazardous Air Pollutants, the Permittee shall comply with all applicable provisions of National Emission Standards for Hazardous Air Pollutants (NESHAP) 40 CFR Part 63 Subpart A - “General Provisions” and 40 CFR 63 Subpart DDDDD - “National Emission Standards for Hazardous Air Pollutants for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters.”
[40 CFR 63.7480]

Attachments

- A. List of Standard Abbreviations and List of Permit Specific Abbreviations
- B. Insignificant Activities Checklist, Insignificant Activities Based on Emission Levels and Generic Emission Groups
- C. List of References

Title V Permit

Atlanta Gas Light Company – Cherokee LNG Plant

Permit No.: 4924-057-0036-V-05-0

ATTACHMENT A

List Of Standard Abbreviations

AIRS	Aerometric Information Retrieval System
APCD	Air Pollution Control Device
ASTM	American Society for Testing and Materials
BACT	Best Available Control Technology
BTU	British Thermal Unit
CAAA	Clean Air Act Amendments
CEMS	Continuous Emission Monitoring System
CERMS	Continuous Emission Rate Monitoring System
CFR	Code of Federal Regulations
CMS	Continuous Monitoring System(s)
CO	Carbon Monoxide
COMS	Continuous Opacity Monitoring System
dscf/dscm	Dry Standard Cubic Foot / Dry Standard Cubic Meter
EPA	United States Environmental Protection Agency
EPCRA	Emergency Planning and Community Right to Know Act
gr	Grain(s)
GPM (gpm)	Gallons per minute
H ₂ O (H2O)	Water
HAP	Hazardous Air Pollutant
HCFC	Hydro-chloro-fluorocarbon
MACT	Maximum Achievable Control Technology
MMBtu	Million British Thermal Units
MMBtu/hr	Million British Thermal Units per hour
MVAC	Motor Vehicle Air Conditioner
MW	Megawatt
NESHAP	National Emission Standards for Hazardous Air Pollutants
NO _x (NOx)	Nitrogen Oxides
NSPS	New Source Performance Standards
OCGA	Official Code of Georgia Annotated

PM	Particulate Matter
PM ₁₀ (PM10)	Particulate Matter less than 10 micrometers in diameter
PPM (ppm)	Parts per Million
PSD	Prevention of Significant Deterioration
RACT	Reasonably Available Control Technology
RMP	Risk Management Plan
SIC	Standard Industrial Classification
SIP	State Implementation Plan
SO ₂ (SO2)	Sulfur Dioxide
USC	United States Code
VE	Visible Emissions
VOC	Volatile Organic Compound

List of Permit Specific Abbreviations

Title V Permit

ATTACHMENT B

NOTE: Attachment B contains information regarding insignificant emission units/activities and groups of generic emission units/activities in existence at the facility at the time of Permit issuance. Future modifications or additions of insignificant emission units/activities and equipment that are part of generic emissions groups may not necessarily cause this attachment to be updated.

INSIGNIFICANT ACTIVITIES CHECKLIST

Category	Description of Insignificant Activity/Unit	Quantity
Mobile Sources	1. Cleaning and sweeping of streets and paved surfaces	
Combustion Equipment	1. Fire fighting and similar safety equipment used to train fire fighters or other emergency personnel.	1
	2. Small incinerators that are not subject to any standard, limitation or other requirement under Section 111 or 112 (excluding 112(r)) of the Federal Act and are not considered a “designated facility” as specified in 40 CFR 60.32e of the Federal emissions guidelines for Hospital/Medical/Infectious Waste Incinerators, that are operating as follows: i) Less than 8 million BTU/hr heat input, firing types 0, 1, 2, and/or 3 waste. ii) Less than 8 million BTU/hr heat input with no more than 10% pathological (type 4) waste by weight combined with types 0, 1, 2, and/or 3 waste. iii) Less than 4 million BTU/hr heat input firing type 4 waste. (Refer to 391-3-1-.03(10)(g)2.(ii) for descriptions of waste types)	
	3. Open burning in compliance with Georgia Rule 391-3-1-.02 (5).	
	4. Stationary engines burning: i) Natural gas, LPG, gasoline, dual fuel, or diesel fuel which are used exclusively as emergency generators shall not exceed 500 hours per year or 200 hours per year if subject to Georgia Rule 391-3-1-.02(2)(mmm).7 ii) Natural gas, LPG, and/or diesel fueled generators used for emergency, peaking, and/or standby power generation, where the combined peaking and standby power generation do not exceed 200 hours per year. iii) Natural gas, LPG, and/or diesel fuel used for other purposes, provided that the output of each engine does not exceed 400 horsepower and that no individual engine operates for more than 2,000 hours per year. iv) Gasoline used for other purposes, provided that the output of each engine does not exceed 100 horsepower and that no individual engine operates for more than 500 hours per year.	
Trade Operations	1. Brazing, soldering, and welding equipment, and cutting torches related to manufacturing and construction activities whose emissions of hazardous air pollutants (HAPs) fall below 1,000 pounds per year.	
Maintenance, Cleaning, and Housekeeping	1. Blast-cleaning equipment using a suspension of abrasive in water and any exhaust system (or collector) serving them exclusively.	
	2. Portable blast-cleaning equipment.	1
	3. Non-Perchloroethylene Dry-cleaning equipment with a capacity of 100 pounds per hour or less of clothes.	
	4. Cold cleaners having an air/vapor interface of not more than 10 square feet and that do not use a halogenated solvent.	1
	5. Non-routine clean out of tanks and equipment for the purposes of worker entry or in preparation for maintenance or decommissioning.	
	6. Devices used exclusively for cleaning metal parts or surfaces by burning off residual amounts of paint, varnish, or other foreign material, provided that such devices are equipped with afterburners.	
	7. Cleaning operations: Alkaline phosphate cleaners and associated cleaners and burners.	

Title V Permit

INSIGNIFICANT ACTIVITIES CHECKLIST

Category	Description of Insignificant Activity/Unit	Quantity
Laboratories and Testing	1. Laboratory fume hoods and vents associated with bench-scale laboratory equipment used for physical or chemical analysis.	
	2. Research and development facilities, quality control testing facilities and/or small pilot projects, where combined daily emissions from all operations are not individually major or are support facilities not making significant contributions to the product of a collocated major manufacturing facility.	
Pollution Control	1. Sanitary waste water collection and treatment systems, except incineration equipment or equipment subject to any standard, limitation or other requirement under Section 111 or 112 (excluding 112(r)) of the Federal Act.	
	2. On site soil or groundwater decontamination units that are not subject to any standard, limitation or other requirement under Section 111 or 112 (excluding 112(r)) of the Federal Act.	
	3. Bioremediation operations units that are not subject to any standard, limitation or other requirement under Section 111 or 112 (excluding 112(r)) of the Federal Act.	
	4. Landfills that are not subject to any standard, limitation or other requirement under Section 111 or 112 (excluding 112(r)) of the Federal Act.	
Industrial Operations	1. Concrete block and brick plants, concrete products plants, and ready mix concrete plants producing less than 125,000 tons per year.	
	2. Any of the following processes or process equipment which are electrically heated or which fire natural gas, LPG or distillate fuel oil at a maximum total heat input rate of not more than 5 million BTU's per hour: <ul style="list-style-type: none"> i) Furnaces for heat treating glass or metals, the use of which do not involve molten materials or oil-coated parts. ii) Porcelain enameling furnaces or porcelain enameling drying ovens. iii) Kilns for firing ceramic ware. iv) Crucible furnaces, pot furnaces, or induction melting and holding furnaces with a capacity of 1,000 pounds or less each, in which sweating or distilling is not conducted and in which fluxing is not conducted utilizing free chlorine, chloride or fluoride derivatives, or ammonium compounds. v) Bakery ovens and confection cookers. vi) Feed mill ovens. vii) Surface coating drying ovens 	
	3. Carving, cutting, routing, turning, drilling, machining, sawing, surface grinding, sanding, planing, buffing, shot blasting, shot peening, or polishing; ceramics, glass, leather, metals, plastics, rubber, concrete, paper stock or wood, also including roll grinding and ground wood pulping stone sharpening, provided that: <ul style="list-style-type: none"> i) Activity is performed indoors; & ii) No significant fugitive particulate emissions enter the environment; & iii) No visible emissions enter the outdoor atmosphere. 	4
	4. Photographic process equipment by which an image is reproduced upon material sensitized to radiant energy (e.g., blueprint activity, photographic developing and microfiche).	
	5. Grain, food, or mineral extrusion processes	
	6. Equipment used exclusively for sintering of glass or metals, but not including equipment used for sintering metal-bearing ores, metal scale, clay, fly ash, or metal compounds.	
	7. Equipment for the mining and screening of uncrushed native sand and gravel.	
	8. Ozonization process or process equipment.	
	9. Electrostatic powder coating booths with an appropriately designed and operated particulate control system.	
	10. Activities involving the application of hot melt adhesives where VOC emissions are less than 5 tons per year and HAP emissions are less than 1,000 pounds per year.	
	11. Equipment used exclusively for the mixing and blending water-based adhesives and coatings at ambient temperatures.	
	12. Equipment used for compression, molding and injection of plastics where VOC emissions are less than 5 tons per year and HAP emissions are less than 1,000 pounds per year.	
	13. Ultraviolet curing processes where VOC emissions are less than 5 tons per year and HAP emissions are less than 1,000 pounds per year.	

Title V Permit

INSIGNIFICANT ACTIVITIES CHECKLIST

Category	Description of Insignificant Activity/Unit	Quantity
Storage Tanks and Equipment	1. All petroleum liquid storage tanks storing a liquid with a true vapor pressure of equal to or less than 0.50 psia as stored.	
	2. All petroleum liquid storage tanks with a capacity of less than 40,000 gallons storing a liquid with a true vapor pressure of equal to or less than 2.0 psia as stored that are not subject to any standard, limitation or other requirement under Section 111 or 112 (excluding 112(r)) of the Federal Act.	
	3. All petroleum liquid storage tanks with a capacity of less than 10,000 gallons storing a petroleum liquid.	2
	4. All pressurized vessels designed to operate in excess of 30 psig storing petroleum fuels that are not subject to any standard, limitation or other requirement under Section 111 or 112 (excluding 112(r)) of the Federal Act.	6
	5. Gasoline storage and handling equipment at loading facilities handling less than 20,000 gallons per day or at vehicle dispensing facilities that are not subject to any standard, limitation or other requirement under Section 111 or 112 (excluding 112(r)) of the Federal Act.	
	6. Portable drums, barrels, and totes provided that the volume of each container does not exceed 550 gallons.	50
	7. All chemical storage tanks used to store a chemical with a true vapor pressure of less than or equal to 10 millimeters of mercury (0.19 psia).	

INSIGNIFICANT ACTIVITIES BASED ON EMISSION LEVELS

Description of Emission Units / Activities	Quantity

Title V Permit

ATTACHMENT B (continued)

GENERIC EMISSION GROUPS

Emission units/activities appearing in the following table are subject only to one or more of Georgia Rules 391-3-1-.02 (2) (b), (e) &/or (n). Potential emissions of particulate matter, from these sources based on TSP, are less than 25 tons per year per process line or unit in each group. Any emissions unit subject to a NESHAP, NSPS, or any specific Air Quality Permit Condition(s) are not included in this table.

Description of Emissions Units / Activities	Number of Units (if appropriate)	Applicable Rules		
		Opacity Rule (b)	PM from Mfg Process Rule (e)	Fugitive Dust Rule (n)

The following table includes groups of fuel burning equipment subject only to Georgia Rules 391-3-1-.02 (2) (b) & (d). Any emissions unit subject to a NESHAP, NSPS, or any specific Air Quality Permit Condition(s) are not included in this table.

Description of Fuel Burning Equipment	Number of Units
Fuel burning equipment with a rated heat input capacity of less than 10 million BTU/hr burning only natural gas and/or LPG.	0
Fuel burning equipment with a rated heat input capacity of less than 5 million BTU/hr, burning only distillate fuel oil, natural gas and/or LPG.	1
Any fuel burning equipment with a rated heat input capacity of 1 million BTU/hr or less.	0

ATTACHMENT C**LIST OF REFERENCES**

1. The Georgia Rules for Air Quality Control Chapter 391-3-1. All Rules cited herein which begin with 391-3-1 are State Air Quality Rules.
2. Title 40 of the Code of Federal Regulations; specifically 40 CFR Parts 50, 51, 52, 60, 61, 63, 64, 68, 70, 72, 73, 75, 76 and 82. All rules cited with these parts are Federal Air Quality Rules.
3. *Georgia Department of Natural Resources, Environmental Protection Division, Air Protection Branch, Procedures for Testing and Monitoring Sources of Air Pollutants.*
4. *Georgia Department of Natural Resources, Environmental Protection Division, Air Protection Branch, Procedures for Calculating Air Permit Fees.*
5. Compilation of Air Pollutant Emission Factors, AP-42, Fifth Edition, Volume I: Stationary Point and Area Sources. This information may be obtained from EPA's TTN web site at www.epa.gov/ttn/chief/ap42/index.html.
6. The latest properly functioning version of EPA's **TANKS** emission estimation software. The software may be obtained from EPA's TTN web site at www.epa.gov/ttn/chief/software/tanks/index.html.
7. The Clean Air Act (42 U.S.C. 7401 et seq).
8. White Paper for Streamlined Development of Part 70 Permit Applications, July 10, 1995 (White Paper #1).
9. White Paper Number 2 for Improved Implementation of the Part 70 Operating Permits Program, March 5, 1996 (White Paper #2).