

Georgia Environmental Protection Division - Underground Storage Tank (UST) Management Program

Public Record Report for FFY 2020

General Information

Public Record Posted Date: October 28, 2020

Total Number of UST Facilities: 9,743
 Total Number of USTs: 29,231

Summary Information For Inspections

Number of UST Facilities Inspected: 1,770
 Inspection Period Dates Were From: To: 10/01/2019 - 09/30/2020
 Percent Compliance (Combined Measure): 54%

Note: Tank, facility, and on-site inspection information is based on underground storage tanks regulated under Subtitle I that satisfy the definition of UST in 40 CFR 280.12, except for those tanks identified in 40 CFR 280.10(b) as excluded USTs and those deferred in 40 CFR 280.10(c). Inspections measure compliance with EPA SOC for the combined measures of Release Prevention and Realease Detection.

Summary Information for Releases

Number of Confirmed UST Releases: 204
 Release Period Dates Were From: To: 10/01/2019 - 09/30/2020

Summary Information for Release Sources And Causes

Source			Cause													
			Spill		Overfill		Phys/Mech		Corrosion		Install		Other		Unknown	
#	%		#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	18	9%	0	0%	1	6%	0	0%	0	0%	0	0%	0	0%	17	94%
Piping	23	11%	0	0%	0	0%	21	91%	0	0%	0	0%	0	0%	2	9%
Dispenser	3	1%	0	0%	0	0%	1	33%	0	0%	0	0%	0	0%	2	67%
Submerged Turbine Pump	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Delivery Problem	1	0%	1	100%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Other	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Unknown	159	78%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	159	100%
Totals	204		1		1		22		0		0		0		180	

= number, % = percent of total number

If you have site specific or general UST questions or you cannot download this report, please contact the UST Program by calling 404-362-2687.

Note: Release, source and cause information is based on underground storage tanks regulated under Subtitle I that satisfy the definition of UST in 40 CFR 280.12, except for those USTs identified in 40 CFR 280.10(b) UST's deferred in 40 CFR 280.10(c) and those used for emergency power generation (deferred from release detection by 40 CFR 280.10(d)) are included as part of the public record.

This report reflects data from releases reported to EPD during the time period of the report. Source and cause data were collected using on-site inspections and reports from facilities. The locations of these releases were notidentifiable. "OTHER" is an identifiable source that does not fit specific locations identified in the chart.