

# UST Common Violations

Your success is important to us. The following lists the most common violations identified during a routine inspection. Knowing the areas of concern will allow you to be proactive in your efforts to stay in compliance.

---

- Failure to monitor tanks every 30 days (ATG, SIR, Interstitial Monitoring [IM])
- Failure to conduct annual Operability Test of IM device
- Failure to conduct annual Line Tightness Test
- Failure to conduct Line Leak Detector Test
- Failure to test Cathodic Protection System every three (3) years
- Failure to register tanks annually (visit our website for step-by-step guides at <https://epd.georgia.gov/underground-storage-tank-annual-tank-registration-instructions>)
- Failure to keep proof of overfill type and proper operation
- Failure to keep spill buckets and sumps clean and empty
- Failure to make necessary repairs to broken or damaged equipment in the required timeframe
- Failure to report a Suspected Release (indication of release would be a failing test result)
- Failure to comply with Temporary Out of Use (TOU) requirements (visit our website for information regarding TOUs at <https://epd.georgia.gov/underground-storage-tank-regulatory-compliance-forms>)
- Failure to test spill bucket, sumps, and overfill every 3 years
- Failure to conduct monthly walkthrough and annual ATG walkthrough inspections

**Be Prepared. Be Ready**



**GEORGIA**  
DEPARTMENT OF NATURAL RESOURCES

ENVIRONMENTAL PROTECTION DIVISION