

Georgia Environmental Protection Division - Underground Storage Tank (UST) Management Program

Public Record Report for FFY 2023

General Information

Public Record Posted Date: October 16, 2023

Total Number of UST Facilities: 9,874
 Total Number of USTs: 29,622

Summary Information For Inspections

Number of UST Facilities Inspected: 3,573
 Inspection Period Dates Were From: To: 10/01/2022 - 09/30/2023
 Percent Compliance (Combined Measure): 42%

Note: Tank, facility, and on-site inspection information is based on underground storage tanks regulated under Subtitle I that satisfy the definition of UST in 40 CFR 280.12, except for those tanks identified in 40 CFR 280.10(b) as excluded USTs and those deferred in 40 CFR 280.10(c). Inspections measure compliance with EPA TCR for the combined measures of Spill Prevention, Overfill Prevention, Corrosion Protection and Release Detection.

Summary Information for Releases

Number of Confirmed UST Releases: 202
 Release Period Dates Were From: To: 10/01/2022 - 09/30/2023

Summary Information for Release Sources And Causes

Source			Cause													
			Spill		Overfill		Phys/Mech		Corrosion		Install		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	52	26%	1	2%	1	2%	1	2%	0	0%	0	0%	1	2%	48	92%
Piping	17	8%	0	0%	0	0%	0	0%	1	6%	0	0%	0	0%	16	94%
Dispenser	7	3%	2	29%	0	0%	1	14%	0	0%	0	0%	0	0%	4	57%
Submerged Turbine Pump	1	0%	0	0%	0	0%	1	100%	0	0%	0	0%	0	0%	0	0%
Delivery Problem	1	0%	0	0%	1	100%	0	0%	0	0%	0	0%	0	0%	0	0%
Other	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Unknown	124	61%	0	0%	0	0%	0	0%	0	0%	0	0%	1	1%	123	99%
Totals	202		3		2		3		1		0		2		191	

= number, % = percent of total number

If you have site specific or general UST questions or you cannot download this report, please contact the UST Program by calling 404-362-2687.

Note: Release, source and cause information is based on underground storage tanks regulated under Subtitle I that satisfy the definition of UST in 40 CFR 280.12, except for those USTs identified in 40 CFR 280.10(b) UST's deferred in 40 CFR 280.10(c) and those used for emergency power generation (deferred from release detection by 40 CFR 280.10(d)) are included as part of the public record.

This report reflects data from releases reported to EPD during the time period of the report. Source and cause data were collected using on-site inspections and reports from facilities. The locations of these releases were not identifiable. "OTHER" is an identifiable source that does not fit specific locations identified in the chart.

