

PSD PERMIT APPLICATION
Volume I – Construction Permit Application

Fuel Oil Conversion Project

Washington County Power, LLC

Prepared By:

TRINITY CONSULTANTS

3495 Piedmont Road
Building 10, Suite 905
Atlanta, GA 30305
(678) 441-9977

Date

Project 201101.0039



TABLE OF CONTENTS

1. EXECUTIVE SUMMARY	1-1
1.1 Proposed Project Description	1-1
1.2 Permitting and Regulatory Requirements	1-1
1.3 BACT Determination	1-2
1.4 Application Contents.....	1-4
2. PROPOSED PROJECT DESCRIPTION	2-1
3. EMISSIONS CALCULATION METHODOLOGY	3-1
3.1 NSR Permitting Evaluation Methodology.....	3-1
3.2 Defining Existing versus New Emission Units.....	3-1
3.3 Annual Emission Increase Calculation Methodology	3-2
3.3.1 Potential Emissions	3-3
3.3.2 Baseline Actual Emissions.....	3-3
3.3.3 Projected Actual Emissions	3-4
3.3.4 Could Have Accommodated Emissions.....	3-4
3.3.5 Additional Associated Emission Unit Increases.....	3-5
3.4 Net Emission Increase Evaluation	3-5
3.4.1 Baseline Actual Emissions.....	3-5
3.4.2 Project Potential-to-Emit.....	3-5
3.4.3 New Unit Potential Emissions.....	3-6
3.4.4 Additional Associated Emission Unit Increases.....	3-7
3.4.5 NSR Emissions Increase Summary	3-7
3.5 Potential Emissions Estimate.....	3-7
3.5.1 Natural Gas-Fired Fuel Preheaters.....	3-7
3.5.2 Emergency Generators and Fire Pump.....	3-8
3.5.3 HAP/TAP Emissions.....	3-8
3.5.4 Insignificant Emissions Sources.....	3-8
4. REGULATORY APPLICABILITY ANALYSIS	4-1
4.1 New Source Review Applicability.....	4-1
4.2 Title V Operating Permits.....	4-2
4.3 New Source Performance Standards	4-2
4.3.1 40 CFR 60 Subpart A – General Provisions.....	4-3
4.3.2 40 CFR 60 Subpart D – Fossil Fuel-Fired Steam Generators > 250 MMBtu/hr.....	4-3
4.3.3 40 CFR 60 Subpart Da – Electric Utility Steam Generating Units	4-3
4.3.4 40 CFR 60 Subpart Db – Steam Generating Units > 100 MMBtu/hr.....	4-4
4.3.5 40 CFR 60 Subpart Dc – Small Steam Generating Units.....	4-4
4.3.6 40 CFR 60 Subpart K –Storage Vessels for Petroleum Liquids for Which Construction, Reconstruction, or Modification Commenced After June 11, 1973, and Prior to May 19, 1978....	4-4
4.3.7 40 CFR 60 Subpart Ka – Storage Vessels for Petroleum Liquids for Which Construction, Reconstruction, or Modification Commenced After May 18, 1978, and Prior to July 23, 1984	4-5
4.3.8 40 CFR 60 Subpart Kb – Volatile Organic Liquid Storage Vessels (Including Petroleum Liquids Storage Vessels) for Which Construction, Reconstruction, or Modification Commenced After July 23, 1984	4-5
4.3.9 40 CFR 60 Subpart GG – Stationary Gas Turbines.....	4-5
4.3.10 40 CFR 60 Subpart KKKK – Stationary Combustion Turbines	4-5

4.3.10.1	Emission Limits.....	4-6
4.3.10.2	Monitoring and Testing Requirements.....	4-6
4.3.10.3	Initial Notification	4-8
4.3.11	<i>40 CFR 60 Subpart TTTT – Greenhouse Gas Emissions for Electric Generating Units</i>	4-8
4.3.12	<i>Non-Applicability of All Other NSPS</i>	4-9
4.4	National Emission Standards for Hazardous Air Pollutants	4-9
4.4.1	<i>40 CFR 63 Subpart A – General Provisions</i>	4-9
4.4.2	<i>40 CFR 63 Subpart YYYY – Combustion Turbines</i>	4-9
4.4.3	<i>40 CFR 63 Subpart DDDDD – Industrial, Commercial, and Institutional Boilers and Process Heaters</i>	4-10
4.4.4	<i>40 CFR 63 Subpart UUUUU – Electric Utility Steam Generating Units</i>	4-10
4.4.5	<i>40 CFR 63 Subpart JJJJJ – Industrial, Commercial, and Institutional Boilers at Area Sources</i>	4-10
4.4.6	<i>Non-Applicability of All Other NESHAP</i>	4-10
4.5	Compliance Assurance Monitoring	4-10
4.6	Risk Management Plan	4-11
4.7	Stratospheric Ozone Protection Regulations	4-11
4.8	Clean Air Markets Regulations	4-11
4.8.1	<i>Acid Rain Program</i>	4-12
4.8.2	<i>Clean Air Interstate Rule / Cross-State Air Pollution Rule</i>	4-12
4.9	State Regulatory Requirements	4-13
4.9.1	<i>GRAQC 391-3-1-.02(2)(b) – Visible Emissions</i>	4-13
4.9.2	<i>GRAQC 391-3-1-.02(2)(d) – Fuel-Burning Equipment</i>	4-13
4.9.3	<i>GRAQC 391-3-1-.02(2)(e) – Particulate Emissions from Manufacturing Processes</i>	4-14
4.9.4	<i>GRAQC 391-3-1-.02(2)(g) – Sulfur Dioxide</i>	4-14
4.9.5	<i>GRAQC 391-3-1-.02(2)(n) – Fugitive Dust</i>	4-14
4.9.6	<i>GRAQC 391-3-1-.02(2)(bb) – Petroleum Liquid Storage</i>	4-14
4.9.7	<i>GRAQC 391-3-1-.02(2)(nn) – VOC Emissions from External Floating Roof Tanks</i>	4-14
4.9.8	<i>GRAQC 391-3-1-.02(2)(tt) – VOC Emissions from Major Sources</i>	4-15
4.9.9	<i>GRAQC 391-3-1-.02(2)(uu) – Visibility Protection</i>	4-15
4.9.10	<i>GRAQC 391-3-1-.02(2)(vv) Volatile Organic Liquid Handling and Storage</i>	4-15
4.9.11	<i>GRAQC 391-3-1-.02(2)(yy) – Nitrogen Oxides from Major Sources</i>	4-15
4.9.12	<i>GRAQC 391-3-1-.02(2)(jjj) – NO_x from Electric Utility Steam Generating Units</i>	4-15
4.9.13	<i>GRAQC 391-3-1-.02(2)(lll) – NO_x from Fuel-Burning Equipment</i>	4-15
4.9.14	<i>GRAQC 391-3-1-.02(2)(mmm) – NO_x Emissions from Stationary Gas Turbines and Stationary Engines used to Generate Electricity</i>	4-16
4.9.15	<i>GRAQC 391-3-1-.02(2)(nnn) – NO_x Emissions from Large Stationary Gas Turbines</i>	4-16
4.9.16	<i>GRAQC 391-3-1-.02(2)(rrr) – NO_x from Small Fuel-Burning Equipment</i>	4-16
4.9.17	<i>GRAQC 391-3-1-.02(2)(sss) – Multipollutant Control for Electric Utility Steam Generating Units</i>	4-16
4.9.18	<i>GRAQC 391-3-1-.02(2)(uuu) – SO₂ Emissions from Electric Utility Steam Generating Units</i>	4-16
4.9.19	<i>GRAQC 391-3-1-.02(12), (13), and (14) – Cross State Air Pollution Rules (Annual NO_x, Annual SO₂, and Ozone Season NO_x)</i>	4-16
4.9.20	<i>GRAQC 391-3-1-.03(1) – Construction (SIP) Permitting</i>	4-16
4.9.21	<i>GRAQC 391-3-1-.03(10) – Title V Operating Permits</i>	4-17
4.9.22	<i>Incorporation of Federal Regulations by Reference</i>	4-17
4.9.23	<i>Non-Applicability of Other GRAQC</i>	4-17

5. BACT ANALYSIS	5-1
5.1 BACT Requirement	5-1
5.2 BACT Definition	5-2
5.2.1 Emission Limitation	5-2
5.2.2 Each Pollutant	5-3
5.2.3 Case-by-Case Basis	5-3
5.2.4 Achievable	5-4
5.2.5 Floor	5-6
5.3 BACT Assessment Methodology	5-6
5.4 BACT "Top-Down" Approach	5-7
5.4.1 Identification of Potential Control Technologies (Step 1)	5-7
5.4.2 Elimination of Technically Infeasible Control Options (Step 2)	5-8
5.4.2.1 Demonstrated Technology	5-9
5.4.2.2 Emerging and Undemonstrated Technology	5-9
5.4.3 Rank of Remaining Control Technologies (Step 3)	5-9
5.4.4 Evaluation of Most Stringent Control Technologies (Step 4)	5-9
5.4.5 Selection of BACT (Step 5)	5-10
5.5 Defining the Source	5-11
5.6 Combustion Turbines NO _x Assessment	5-12
5.6.1 NO _x Formation – Combustion Turbines	5-12
5.6.2 Identification of NO _x Control Technologies – Combustion Turbines (Step 1)	5-14
5.6.2.1 Water or Steam Injection	5-14
5.6.2.2 Dry Low-NO _x (DLN) Combustors	5-15
5.6.2.3 Good Combustion Practices	5-15
5.6.2.4 EM _x TM /SCONO _x	5-15
5.6.2.5 Selective Catalytic Reduction (SCR)	5-16
5.6.2.6 SCR with Ammonia Oxidation Catalyst (Zero-Slip TM)	5-16
5.6.2.7 Selective Non-Catalytic Reduction (SNCR)	5-17
5.6.2.8 Multi-Function Catalyst (METEOR TM)	5-17
5.6.3 Elimination of Technically Infeasible NO _x Control Options – Combustion Turbines (Step 2)	5-17
5.6.3.1 Water or Steam Injection Feasibility	5-18
5.6.3.2 Dry Low NO _x Combustion Technology Feasibility	5-18
5.6.3.3 Good Combustion Practices Feasibility	5-18
5.6.3.4 EM _x TM /SCONO _x TM Technology Feasibility	5-18
5.6.3.5 SCR Feasibility	5-19
5.6.3.6 SCR with Ammonia Oxidation Catalyst (Zero-Slip TM) Feasibility	5-19
5.6.3.7 SNCR Feasibility	5-19
5.6.3.8 Multi-Function Catalyst (METEOR TM) Feasibility	5-19
5.6.4 Summary and Ranking of Remaining NO _x Controls – Combustion Turbines (Step 3)	5-20
5.6.5 Evaluation of Most Stringent NO _x Controls – Combustion Turbines (Step 4)	5-20
5.6.6 Selection of Emission Limits and Controls for NO _x BACT – Combustion Turbines (Step 5)	5-21
5.6.6.1 Selection of Emission Limits for NO _x BACT - Natural Gas Firing	5-22
5.6.6.2 Selection of Emission Limits for NO _x BACT – Fuel Oil Firing	5-30
5.6.6.3 Secondary BACT Limit – NO _x	5-34
5.7 Combustion Turbines Filterable PM and Total PM ₁₀ /PM _{2.5} Assessment	5-34
5.7.1 PM Formation – Combustion Turbines	5-34
5.7.2 Identification of PM Control Technologies – Combustion Turbine (Step 1)	5-34

5.7.2.1	Multicyclone	5-35
5.7.2.2	Wet Scrubber	5-35
5.7.2.3	ESP	5-35
5.7.2.4	Baghouse (Fabric Filter)	5-36
5.7.2.5	Low Sulfur Fuels	5-36
5.7.2.6	Good Combustion and Operating Practices.....	5-36
5.7.3	<i>Elimination of Technically Infeasible PM Control Options – Combustion Turbines (Step 2)</i> 5-37	
5.7.4	<i>Summary and Ranking of Remaining PM Controls – Combustion Turbines (Step 3)</i>	5-37
5.7.5	<i>Evaluation of Most Stringent PM Controls – Combustion Turbines (Step 4)</i>	5-37
5.7.6	<i>Selection of Emission Limits and Controls for PM BACT – Combustion Turbines (Step 5)</i> ... 5-38	
5.7.6.1	Selection of Emission Limits for PM BACT - Natural Gas Firing	5-38
5.7.6.2	Selection of Emission Limits for PM BACT – Fuel Oil Firing	5-43
5.7.6.3	Secondary BACT Limit – PM.....	5-45
5.8	Combustion Turbines CO Assessment.....	5-45
5.8.1	<i>CO Formation – Combustion Turbines</i>	5-46
5.8.2	<i>Identification of CO Control Technologies – Combustion Turbines (Step 1)</i>	5-46
5.8.2.1	Oxidation Catalysts	5-46
5.8.2.2	EM _x TM /SCONO _x TM	5-46
5.8.2.3	Combustion Process Design and Good Combustion Practices	5-46
5.8.3	<i>Elimination of Technically Infeasible CO Control Options – Combustion Turbines (Step 2)</i> 5-46	
5.8.3.1	Oxidation Catalyst	5-46
5.8.3.2	EM _x TM /SCONO _x TM	5-47
5.8.3.3	Combustion Process Design and Good Combustion Practices	5-47
5.8.4	<i>Summary and Ranking of Remaining CO Controls – Combustion Turbines (Step 3)</i>	5-47
5.8.5	<i>Evaluation of Most Stringent CO Controls – Combustion Turbines (Step 4)</i>	5-47
5.8.6	<i>Selection of Emission Limits and Controls for CO BACT – Combustion Turbines (Step 5)</i> ... 5-48	
5.8.6.1	Selection of Emission Limits for CO BACT - Natural Gas Firing.....	5-48
5.8.6.2	Selection of Emission Limits for CO BACT – Fuel Oil Firing	5-52
5.8.6.3	Secondary BACT Limit – CO.....	5-54
5.9	Combustion Turbines VOC Assessment.....	5-54
5.9.1	<i>VOC Formation – Combustion Turbines</i>	5-55
5.9.2	<i>Identification of VOC Control Technologies – Combustion Turbines (Step 1)</i>	5-55
5.9.2.1	Oxidation Catalysts	5-55
5.9.2.2	EM _x TM /SCONO _x TM	5-55
5.9.2.3	Combustion Process Design and Good Combustion Practices	5-55
5.9.3	<i>Elimination of Technically Infeasible VOC Control Options – Combustion Turbines (Step 2)</i> 5-55	
5.9.3.1	Oxidation Catalyst	5-55
5.9.3.2	EM _x TM /SCONO _x TM	5-56
5.9.3.3	Combustion Process Design and Good Combustion Practices	5-56
5.9.4	<i>Summary and Ranking of Remaining VOC Controls – Combustion Turbines (Step 3)</i>	5-56
5.9.5	<i>Evaluation of Most Stringent VOC Controls – Combustion Turbines (Step 4)</i>	5-56
5.9.6	<i>Selection of Emission Limits and Controls for VOC BACT – Combustion Turbines (Step 5)</i> . 5-57	
5.9.6.1	Selection of Emission Limits for VOC BACT - Natural Gas Firing.....	5-57

5.9.6.2	Selection of Emission Limits for VOC BACT – Fuel Oil Firing	5-61
5.10	Fuel Oil Storage Tank VOC Assessment	5-63
5.11	Combustion Turbines GHG Assessment	5-64
<i>5.11.1</i>	<i>Turbine Systems CO₂ BACT</i>	<i>5-64</i>
5.11.1.1	Identification of Potential CO ₂ Control Technologies (Step 1)	5-64
5.11.1.2	Elimination of Technically Infeasible CO ₂ Control Options – Turbine Systems (Step 2) ..	5-67
5.11.1.3	Summary and Ranking of Remaining CO ₂ Controls (Step 3)	5-71
5.11.1.4	Evaluation of Most Stringent CO ₂ Control Technologies (Step 4)	5-71
5.11.1.5	Selection of CO ₂ BACT (Step 5)	5-73
<i>5.11.2</i>	<i>Turbine Systems CH₄ BACT</i>	<i>5-74</i>
5.11.2.1	Identification of Potential CH ₄ Control Technologies (Step 1)	5-74
5.11.2.2	Technically Infeasible CH ₄ Control Options (Step 2)	5-74
5.11.2.3	Summary and Ranking of Remaining CH ₄ Control Technologies (Step 3)	5-74
5.11.2.4	Evaluation of Most Stringent CH ₄ Control Technologies (Step 4)	5-74
5.11.2.5	Selection of CH ₄ BACT (Step 5)	5-74
<i>5.11.3</i>	<i>Turbine Systems N₂O BACT</i>	<i>5-75</i>
5.11.3.1	Identification of Potential N ₂ O Control Technologies (Step 1)	5-75
5.11.3.2	Technically Infeasible N ₂ O Control Options (Step 2)	5-75
5.11.3.3	Summary and Ranking of Remaining N ₂ O Control Technologies (Step 3)	5-76
5.11.3.4	Evaluation of Most Stringent N ₂ O Control Technologies (Step 4)	5-76
5.11.3.5	Selection of N ₂ O BACT (Step 5)	5-76

APPENDIX A. AREA MAP AND PROCESS FLOW DIAGRAM	A
APPENDIX B. EMISSION CALCULATIONS	B
APPENDIX C. RBLC SEARCH RESULTS	C
APPENDIX D. CONTROL COST ANALYSES	D
APPENDIX E. SIP PERMIT APPLICATION FORMS	E

LIST OF FIGURES

Figure 5-1. Map of Potential Carbon Sequestration Sites

5-70

LIST OF TABLES

Table 1-1. Proposed Project Emissions Increases	1-2
Table 1-2. Summary of Proposed BACT Limits	1-3
Table 3-1. Criteria Pollutant Potential Emission Factors for Simple-Cycle Combustion Turbine Firing of Natural Gas	3-6
Table 3-2. Criteria Pollutant Potential Emission Factors for Simple-Cycle Combustion Turbine Firing of Fuel Oil	3-6
Table 3-3. Project Emissions Increase	3-7
Table 4-1. Project Emission Increases Compared to PSD SER	4-2
Table 5-1. Summary of Proposed BACT Limits	5-1
Table 5-2. Remaining NO _x Control Technologies	5-20
Table 5-3. Natural Gas Simple-Cycle Combustion Turbine NO _x RBLC Data for Potentially Modified Units	5-23
Table 5-4. Unit Comparability for NO _x Assessment – Natural Gas Firing	5-29
Table 5-5. Fuel Oil Simple-Cycle Combustion Turbine NO _x RBLC Data for Potentially Modified Units	5-32
Table 5-6. Unit Comparability for NO _x Assessment – Fuel Oil Firing	5-33
Table 5-7. Remaining Particulate Matter Control Technologies	5-37
Table 5-8. Natural Gas Simple-Cycle Combustion Turbine PM RBLC Data for Potentially Modified Units	5-39
Table 5-9. Unit Comparability for PM Assessment – Natural Gas Firing	5-41
Table 5-10. Fuel Oil Simple-Cycle Combustion Turbine PM RBLC Data for Potentially Modified Units	5-44
Table 5-11. Unit Comparability for PM Assessment – Fuel Oil Firing	5-45
Table 5-12. Natural Gas Fired Simple-Cycle Combustion Turbine CO RBLC Data for Potentially Modified Units	5-49
Table 5-13. Unit Comparability for CO Assessment – Natural Gas Firing	5-51
Table 5-14. Fuel Oil Simple-Cycle Combustion Turbine CO RBLC Data for Potentially Modified Units	5-53
Table 5-15. Unit Comparability for CO Assessment – Fuel Oil Firing	5-54
Table 5-16. Natural Gas Fired Simple-Cycle Combustion Turbine VOC RBLC Data for Potentially Modified Units	5-58

Table 5-17. Unit Comparability for VOC Assessment – Natural Gas Firing

5-60

Table 5-18. Fuel Oil Fired Simple-Cycle Combustion Turbine VOC RBL Data for Potentially Modified Units 5-62

1. EXECUTIVE SUMMARY

Washington County Power, LLC (“WCP”) owns and operates a natural gas-fired simple-cycle power generation facility northwest of Sandersville, Georgia (the “Facility”). The Facility consists of four General Electric (GE) Frame 7A combustion turbines, with the capacity to generate approximately 680 MW, along with other ancillary facility equipment including two fuel gas heaters, an emergency fire pump engine, and an auxiliary generator engine. This facility currently operates under Permit No. 4911-303-0039-V-08-0, issued January 11, 2021.

The facility is proposing to modify the four existing simple-cycle turbines to allow combustion of either natural gas or fuel oil. There is the desire to burn up to 3,000 hr/yr per turbine on natural gas, and 500 hr/yr on fuel oil.

The proposed project will require a Prevention of Significant Deterioration (PSD) permit as a major modification to an existing major source.¹ Projected-related emissions increases are anticipated to exceed the PSD significant emission rate (SER) thresholds for particulate matter (PM), particulate matter with an aerodynamic diameter of 10 microns (PM₁₀), particulate matter with an aerodynamic diameter of 2.5 microns (PM_{2.5}), nitrogen oxides (NO_x), volatile organic compounds (VOC), carbon monoxide (CO), and greenhouse gases (GHG) in terms of carbon dioxide equivalents (CO_{2e}).²

The application package contains the necessary state air construction and operating permit application for the proposed projects, included in two (2) separate application volumes. This Volume I of the application details the required emissions analyses, regulatory review, and control technology analyses. Volume II of the application package includes all the required air quality assessments necessary as part of this PSD permit application.

1.1 Proposed Project Description

WCP is proposing the addition of fuel oil combustion capability for all existing facility turbines to enhance fuel resiliency given increased reliance within the utilities and industrial sectors on natural gas for energy generation. This project requires physical modifications to each of the four turbines and installation of fuel oil storage capacity. WCP is requesting permit conditions limiting natural gas firing from the group of four turbines to 12,000 hours per year (hr/yr) and fuel oil combustion to 2,000 hr/yr.³ More detail regarding the proposed projects is provided in Section 2 of this report.

1.2 Permitting and Regulatory Requirements

WCP is submitting this construction and operating permit application, in accordance with the PSD permitting requirements, to request authorization to modify and operate the site’s simple-cycle combustion turbines. Since WCP is a major source under the PSD permitting program, emission increases from the proposed projects must be evaluated and compared to the SER thresholds for regulated pollutants under the PSD

¹ The Facility is currently a PSD minor source, with PSD avoidance limitations (e.g. Permit Condition No. 2.1.1) limiting facility wide emissions of NO_x to less than 250 tpy. The facility is not classified as one of the 28 named source categories, and is subject to a 250 tpy PSD major source threshold.

² CO_{2e} is carbon dioxide equivalents calculated as the sum of the six well-mixed GHGs (CO₂, CH₄, N₂O, HFCs, PFCs, and SF₆) with applicable global warming potentials per 40 CFR 98 applied.

³ Proposed limits based on 3,000 hr/yr natural gas firing per turbine and 500 hr/yr fuel oil combustion per turbine.

program. WCP has evaluated emissions increases of CO, NO_x, PM, PM₁₀, PM_{2.5}, CO_{2e}, sulfur dioxide (SO₂), sulfuric acid mist (H₂SO₄), and VOC resulting from the proposed project for comparison to their respective PSD SER to determine whether PSD permitting is required, as shown in Table 1-1.⁴

Table 1-1. Proposed Project Emissions Increases

Pollutant	Project Emissions Increases (tpy)	PSD Significant Emission Rate	PSD Triggered? (Yes/No)
Filterable PM	97.11	25	Yes
Total PM ₁₀	154.76	15	Yes
Total PM _{2.5}	154.76	10	Yes
SO ₂	8.86	40	No
NO _x	565.97	40	Yes
VOC	95.21	40	Yes
CO	264.21	100	Yes
CO _{2e}	1,402,932	75,000	Yes
Lead	0.03	0.60	No
Sulfuric Acid Mist	3.77	7.00	No

Since the combined project emissions increases of filterable PM, total PM₁₀, total PM_{2.5}, NO_x, VOC, CO, and CO_{2e} exceed their respective SERs, the proposed project is required to undergo PSD review for each of those pollutants. Emission calculations are described in Section 3 of this application, and PSD permitting requirements are detailed in Section 4.1.

WCP is submitting this construction and operating permit application package in accordance with all federal and state requirements. The proposed project will be subject to federal New Source Performance Standards (NSPS) and the Georgia Rules for Air Quality Control (GRAQC). Applicability of these programs is discussed in Section 4 of this application.

1.3 BACT Determination

WCP performed an analysis of Best Available Control Technology (BACT) for each of the PSD-regulated pollutants that exceeded their SERs (filterable PM, total PM₁₀, total PM_{2.5}, NO_x, VOC, CO, and CO_{2e}), following the “top-down” approach suggested by U.S. EPA. The top-down process begins by identifying all potential control technologies for the pollutant in question and making a determination if those control options are technically feasible for the specific process. The approach then involves ranking all potentially relevant control technologies in descending order of control effectiveness. The most stringent or “top” control option is BACT unless the applicant demonstrates, and the permitting authority in its informed opinion agrees, that energy, environmental, and/or economic impacts justify the conclusion that the most stringent control option does not meet the definition of BACT. Where the top option is not determined to be BACT, the next most stringent alternative is evaluated in the same manner. This process continues until

⁴ AP-42, Chapter 3, Section 1, *Stationary Gas Turbines*, lists the lead (Pb) emission factor for natural gas turbines as ND (no detect); therefore, Pb emissions increases for the proposed projects were not evaluated.

BACT is selected. Based on the BACT review, WCP proposes the technology and limits presented in Table 1-2 as BACT for the modified and new emission units. The detailed BACT analysis is presented in Section 5 of this application.

Table 1-2. Summary of Proposed BACT Limits

Unit	Pollutant	Fuel	Selected BACT	Emission / Operating Limit	Compliance Method
Each Simple Cycle Combustion Turbine	NO _x	Natural Gas	DLN Combustors and Good Combustion and Operating Practices	9.0 ppmvd at 15% O ₂ on a 4-hour rolling average basis	CEM
		Fuel Oil	Water Injection and Good Combustion and Operating Practices	42.0 ppmvd at 15% O ₂ on a 4-hour rolling average basis	
		Both	Secondary BACT	152.7 tpy per rolling 12-months per turbine	
	Filterable PM/Total PM ₁₀ /Total PM _{2.5}	Natural Gas	Good Combustion and Operating Practices and Low Sulfur Fuels	24.2 lb/hr	Performance Test
		ULSD		26.8 lb/hr	
	CO	Natural Gas	Good Combustion and Operating Practices	9.0 ppmvd at 15% O ₂ on a 3-hour rolling average basis	Performance Test
		Fuel Oil		20.0 ppmvd at 15% O ₂ on a 3-hour rolling average basis	
		Both	Secondary BACT	70.9 tpy per rolling 12-months per turbine	
	VOC	Natural Gas	Good Combustion and Operating Practices	2.0 ppmvd at 15% O ₂	Performance Test
		Fuel Oil		5.0 ppmvd at 15% O ₂	
GHGs		Efficient Turbine Operation and Good Combustion, Operating, and Maintenance Practices	387,497 tpy CO ₂ e per rolling 12-months (each CCCT)	Records of Fuel Usage	
Fuel Oil Storage Tank	VOC	N/A	Submerged Fill Pipe, Light Colored Paint for Tank Shell, Good Maintenance Practices	N/A	

1.4 Application Contents

Volume I of this permit application is organized as follows:

- ▶ Section 2 contains a description of the proposed project;
- ▶ Section 3 summarizes emissions calculation methodologies and assesses PSD applicability;
- ▶ Section 4 details the regulatory applicability analysis for the proposed project;
- ▶ Section 5 contains the required BACT assessment;
- ▶ Appendix A includes an area map, site plot plan and simplified process flow diagram;
- ▶ Appendix B includes detailed emission calculations;
- ▶ Appendix C includes the applicable Reasonably Available Control Technology (RACT)/BACT/Lowest Achievable Emission Reduction (LAER) Clearinghouse (RBLC) database tables;
- ▶ Appendix D includes the control costs analyses completed in support of the BACT review;
- ▶ Appendix E contains the Georgia Environmental Protection Division (EPD) SIP construction permit application forms; and

2. PROPOSED PROJECT DESCRIPTION

WCP is proposing the addition of fuel oil combustion capability for all existing facility turbines to enhance fuel resiliency given increased reliance within the utilities and industrial sectors on natural gas for energy generation. This project requires physical modifications to each of the four turbines and installation of fuel oil storage capacity. WCP is requesting permit conditions limiting natural gas firing from the group of four turbines to 12,000 hours per year (hr/yr) and fuel oil combustion to 2,000 hr/yr. The proposed fuel oil storage capacity on-site could be as much as a 2.5 million gallon vertical fixed-roof storage tank, with a conservatively estimated fuel oil throughput of 30 million gallons per year. WCP proposes to continue operating the existing Dry Low NO_x burners on the turbines during gas combustion and proposes to install and operate a water-injection system during fuel oil combustion.

As the units are large-frame simple-cycle units, startup and shutdown operations will generally be limited to less than 30 minutes for both gas and oil operations. Therefore, worst-case hourly conditions for these turbines is generally considered to be a full hour at 100% operating load (steady-state). During gas combustion at 100% operating load, the estimated heat input capacity is estimated to be 1,766 Million British Thermal Units per hour (MMBtu/hr) for each turbine, whereas during fuel oil combustion at 100% operating load, the heat input capacity is estimated to be 1,890 MMBtu/hr for each turbine. Collectively, the four turbines will continue to maintain a 680-MW capacity for the site. WCP does not plan to expand overall short-term generating capacity. However, the annual generation (MW-hr) may increase due to both the addition of fuel oil operating capacity and additional run-time capacity on natural gas. This project would also require WCP to add pump skids, tanks, and a raw water storage tank for the purposes of water injection control but should not require the addition or modification of any other emission units on-site.

WCP proposes to begin making investments (i.e., purchasing equipment) as early as September 2021, and proposes to be operational by the end of 2022. Therefore, WCP is submitting this application into EPD's Expedited Permitting Program to ensure that a final permit is obtained by September 2021.

3. EMISSIONS CALCULATION METHODOLOGY

This section addresses the methodology used to quantify the emissions from the proposed projects and assesses federal New Source Review (NSR) permitting applicability. Emissions from the proposed projects will include CO, NO_x, SO₂, VOC, PM, PM₁₀, PM_{2.5}, lead (Pb), H₂SO₄, GHG in the form of CO_{2e}, and hazardous air pollutants (HAP). These emissions occur as a result of natural gas and fuel oil combustion in the combustion turbines. A new storage tank for fuel oil will also emit small quantities of VOC. Detailed emission calculations are presented in Appendix B.

3.1 NSR Permitting Evaluation Methodology

The NSR permitting program generally requires that a source obtain a permit prior to construction of any project at an industrial facility if the proposed project results in the potential to emit air pollution in excess of certain threshold levels. The NSR program is comprised of two elements: nonattainment NSR (NNSR) and PSD. The NNSR program potentially applies to new construction or modifications that result in emission increases of a particular pollutant for which the area the facility is located in is classified as “nonattainment” with the National Ambient Air Quality Standards (NAAQS) for that pollutant. The PSD program applies to project increases of those pollutants for which the area the facility is located in is classified as “attainment” or “unclassifiable” for the NAAQS. The WCP Sandersville facility is located in Washington County, which is presently designated as “attainment” or “unclassifiable” for all criteria pollutants.⁵ As such, PSD permitting is potentially applicable to the proposed projects.

As presently permitted, the existing facility is a synthetic minor PSD source. To facilitate fuel oil combustion, removal of conditions that limit fuel combustion to natural gas will be required. Estimated facility-wide potential-to-emit (PTE) following the proposed change indicates the facility will be considered a PSD major source. Accordingly, if the proposed project meets the definition of *major modification*, the full PSD permitting requirements apply.

The following sections discuss the methodology used in the project emissions increase evaluation conducted to assess PSD applicability under the NSR program. For all PSD-regulated pollutants other than CO_{2e}, PSD permitting is required if the emissions increase of a specific pollutant exceeds that pollutant’s PSD SER. For CO_{2e}, PSD permitting is only required if the emissions increase exceeds the SER for CO_{2e} and the project is already undergoing PSD permitting for at least one other PSD-regulated pollutant.⁶

3.2 Defining Existing versus New Emission Units

For purposes of calculating project emissions increases, different calculation methodologies are used for existing and new units; therefore, it is important to clarify whether a source affected by the proposed projects are considered new or existing emission units.

40 CFR 52.21(b)(7)(i) and (ii) define new unit and existing units, and are incorporated by reference in the GRAQC:

⁵ 40 CFR 81.311

⁶ 40 CFR 52.21(b)(49)(iii) as incorporated by reference in the GRAQC

- (i) *A new emissions unit is any emissions unit that is (or will be) newly constructed and that has existed for less than 2 years from the date such emissions unit first operated.*
- (ii) *An existing emissions unit is any unit that does not meet the requirements in paragraph (b)(7)(i) of this section. A replacement unit, as defined in paragraph (b)(33) of this section, is an existing emissions unit.*

As the combustion turbines at WCP have operated for more than two years, the proposed projects involve physical or operational changes to existing emission units. The proposed fuel oil storage tank will be considered a new emission unit.

3.3 Annual Emission Increase Calculation Methodology

As WCP is classified as a major source for PSD, if the proposed projects meet the definition of a *major modification*, then the full PSD permitting requirements apply. *Major modification* is defined by 40 CFR 52.21(b)(2)(i):

“Major Modification” means any physical change in or change in the method of operation of a major stationary source that would result in a significant emission increase ... of a regulated NSR pollutant ... and a significant net emissions increase of that pollutant ...

Certain exemptions to the major modification definition exist that, if applicable, means a project does not require an emission increase assessment. The proposed projects do not qualify for any of the established exemptions.

The project emissions have been analyzed using the current NSR Reform methodology to determine if a significant emissions increase will occur. *Net emissions increase* (NEI) is defined by 40 CFR 52.21(b)(3)(i):

“Net Emissions Increase” means, with respect to any regulated NSR pollutant ... the amount by which the sum of the following exceeds zero:

- (a) *The increase in emissions ... as calculated pursuant to paragraph (a)(2)(iv) [for existing units, calculated by actual-to-projected actual⁷ or actual-to-potential; for new units, calculated by actual-to-potential]⁸*
- (b) *Any other increases or decreases in actual emissions...that are contemporaneous with the particular change and are otherwise creditable. Baseline emissions for calculating increases and decreases...shall be determined as provided...*

The first step (1) is commonly referred to as the “project emission increases” as it has historically accounted only for emissions related to the proposed project itself. If the emission increases estimated per step (1) exceed the major modification thresholds, then the applicant may move to step (2), commonly referred to

⁷ 40 CFR 52.21(a)(2)(iv)(c), Actual-to-projected-actual applicability test for projects that only involve existing emissions units, states: *A significant emissions increase of a regulated NSR pollutant is projected to occur if the sum of the difference between the projected actual emissions ... and the baseline actual emissions ... equals or exceeds the significant amount for that pollutant ...*

⁸ 40 CFR 52.21(a)(2)(iv)(d), Actual-to-potential test for projects that only involve construction of new emissions units, states: *A significant emissions increase of a regulated NSR pollutant is projected to occur if the sum of the difference between the potential to emit ... and the baseline actual emissions ... equals or exceeds the significant amount for that pollutant ...*

as the 5-year netting analysis. The netting analysis includes all projects for which emission increases or decreases (e.g., equipment shutdown) occurred. If the resulting net emission increases exceed the major modification threshold, then NSR permitting is required. WCP has evaluated the project emissions increase for the proposed projects (i.e., Step 1) using the methodologies outlined in the following sections. An evaluation of the net emissions increase (i.e., Step 2) was not conducted as the facility has no other emissions increases or decreases during the contemporaneous period for the proposed projects.

While the prior quotations only reference three components of the NEI calculation (actual, projected actual, and potential emissions), there are actually five calculated components, with the additional components being (1) a subset of the definition for *projected actual* and (2) additional associated emission unit increases:

- ▶ Potential emissions
- ▶ Baseline actual emissions
- ▶ Projected actual emissions
- ▶ “Could have accommodated” emissions exclusion (commonly called the demand growth exclusion)
- ▶ Additional associated emission unit increases

3.3.1 Potential Emissions

Potential emissions are defined by 40 CFR 52.21(b)(4) where the potential to emit:

...means the maximum capacity of a stationary source to emit a pollutant under its physical and operational design. Any physical or operational limitation on the capacity of the source to emit a pollutant, including air pollution control equipment and restrictions on hours of operation or on the type or amount of material combusted, stored, or processed, shall be treated as part of its design if the limitation or the effect it would have on emissions is federally enforceable...

3.3.2 Baseline Actual Emissions

Baseline actual emissions are defined in GRAQC 391-3-1-.02(7)(a)2(i)(II):

For an existing emission unit (other than an electric utility steam generating unit), baseline actual emissions means the average rate, in tons per year, at which the emissions unit actually emitted the pollutant during any consecutive 24-month period selected by the owner or operator within the 10-year period immediately preceding either the date the owner or operator begins actual construction of the project, or the date a complete permit application is received by the Division...

Critical to the use of a 10-year baseline period is the determination that simple-cycle combustion turbines do not qualify as “electric utility steam generating units.” As defined per 52.21(b)(31) and incorporated by reference per GRAQC 391-3-1-.02(7)(a)2, an electric utility steam generating unit:

...means any steam electric generating unit that is constructed for the purpose of supplying more than one-third of its potential electric output capacity and more than 25 MW electrical output to any utility power distribution system for sale.

Simple-cycle combustion turbines do not generate steam, only thermal energy for generation of electric power. Accordingly, simple-cycle combustion turbines are not “electric utility steam generating units”, allowing the use of a 10-year baseline period for actual emissions.

Pursuant to GRAQC 391-3-1-.02(7)(a)2(ii)(II)IV, when a project involves multiple emission units, only one consecutive 24-month period may be used to determine the baseline actual emissions for all of the emission units to be modified. However, a different consecutive 24-month period can be used for each pollutant.

3.3.3 Projected Actual Emissions

Projected actual emissions are defined by GRAQC 391-3-1-.02(7)(a)2(ii)(I):

“Projected actual emissions” means the maximum annual rate, in tons per year, at which an existing emissions unit is projected to emit a regulated NSR pollutant in any one of the 5 years (12-month period) following the date the unit resumes regular operation after the project, or in any one of the 10 years following that date, if the project involves increasing the emissions unit’s design capacity or its potential to emit that regulated NSR pollutant and full utilization of the unit would result in a significant emissions increase or a significant net emissions increase at the major stationary source.

For units in which the proposed projects would not change the potential to emit or the design capacity, projected actual emissions would be for the following five years after authorization of the proposed projects.

In determining projected actual emissions, following GRAQC 391-3-1-.02(7)(a)2(ii)(II)I, the source:

Shall consider all relevant information, including but not limited to, historical operational data, the company’s own representations, the company’s expected business activity and the company’s highest projections of business activity, the company’s filings with the State or Federal regulatory authorities, and compliance plans under the approved State Implementation Plan.

In addition, when calculating projected actual emissions WCP can exclude emissions that could have been accommodated prior to the projects and that are unrelated to the projects, pursuant to GRAQC 391-3-1-.02(7)(a)2(ii)(II)III.

3.3.4 Could Have Accommodated Emissions

An exclusion, per GRAQC 391-3-1-.02(7)(a)2(ii)(II)III, is included in the definition of projected actual emissions and is a value that is subtracted from the projected actual emissions for existing emission units:

May exclude, in calculating any increase in emissions that results from the particular project, [1] that portion of the unit’s emissions following the project that an existing unit could have accommodated during the consecutive 24-month period used to establish the baseline actual emissions under subparagraph (7)(a)2.(i) of this rule and that is also [2] unrelated to the particular project, including any [3] increased utilization due to product demand growth (the increase in emissions that may be excluded under this subparagraph shall hereinafter be referred to as “demand growth emissions”)... [emphasis added, numbers 1, 2, 3 added]

Thus, projected emissions increases are exempted when (1) a unit could have accommodated the emissions during the baseline 24-month period, (2) the increases do not result from the particular project, and (3) the increases are related to increased product demand. As the proposed project entails the use of a new fuel, potential emission increases from the combustion of fuel oil would result from the proposed project, therefore the emissions cannot be exempted as could have accommodated emissions.

3.3.5 Additional Associated Emission Unit Increases

In addition to the emission increases from new or modified units, emission increases from associated emission units that may realize an increase in emissions due to a project must be included in the assessment of the project emissions increases. WCP has accounted for the possibility of associated emission increases from the natural gas preheaters at the facility.

3.4 Net Emission Increase Evaluation

The following sections summarize the methods used to estimate the emissions increases from the proposed project. Detailed emission calculations are presented in Appendix B.

3.4.1 Baseline Actual Emissions

As discussed in Section 3.3.2, the allowable lookback period for baseline actual emissions is 10 years. For the purposes of selecting appropriate baseline actual emissions, WCP has obtained historically monitored monthly emission totals of NO_x as well as historically monitored monthly heat inputs for each simple-cycle combustion turbine during the period of January 2010 through June 2020. For each pollutant which has not been historically monitored, emissions are calculated using the historically monitored monthly heat inputs for each simple-cycle combustion turbine and the emission factors for turbine combustion of natural gas.

The period of June 2010 to May 2012 was selected as the 2-year (consecutive 24-month) baseline period for Filterable PM, Total PM₁₀, Total PM_{2.5}, NO_x, VOC, CO, CO_{2e}, and H₂SO₄. Additionally, a period of August 2011 to July 2013 was selected as the 2-year (consecutive 24-month) baseline period for SO₂. Baseline actual emissions data utilized for the NSR analysis for each simple-cycle combustion turbine can be found in Appendix B.

3.4.2 Project Potential-to-Emit

Project potential emissions for the modified simple-cycle combustion turbines were determined for use in the NSR analysis and are based on a maximum annual operation of 3,000 hours of natural gas-firing and 500 hours of fuel oil-firing for each simple-cycle combustion turbine. The potential emissions for each simple-cycle combustion turbine are determined on a pollutant-by-pollutant basis for the combustion of natural gas and fuel oil. This potential to emit also includes annual tpy emission estimates for NO_x, CO, and VOC considering and inclusive of startup/shutdown activities at the facility. A number of hours were allotted for startup/shutdown activities for each turbine under both natural gas and fuel oil usage. These hourly estimates of startup/shutdown hours were used along with estimates of emissions for the pollutants in question during a startup/shutdown hour to estimate annual emissions. Table 3-1 summarizes the emission factors utilized for estimation of potential emissions from natural gas combustion for the four simple-cycle combustion turbine units. Emission factor references are provided in Appendix B.

Table 3-1. Criteria Pollutant Potential Emission Factors for Simple-Cycle Combustion Turbine Firing of Natural Gas

Pollutant	Turbine System		
	Emission Factor	Unit	Basis
NO _x	9	ppmv at 15% O ₂	Proposed BACT Limit
CO	9	ppmv at 15% O ₂	Proposed BACT Limit
VOC	2	ppmv at 15% O ₂	Proposed BACT Limit
Total PM/PM ₁₀ /PM _{2.5}	0.0137	lb/MMBtu	Equivalent to BACT Limit
SO ₂	0.0006	lb/MMBtu	Emission Factor
H ₂ SO ₄	0.0004	lb/MMBtu	Emission Factor

Table 3-2 summarizes the emission factors utilized for estimation of potential emissions from fuel oil combustion for the four simple-cycle combustion turbine units. Emission factor references are provided in Appendix B.

Table 3-2. Criteria Pollutant Potential Emission Factors for Simple-Cycle Combustion Turbine Firing of Fuel Oil

Pollutant	Turbine System		
	Emission Factor	Unit	Basis
NO _x	42	ppmv at 15% O ₂	Proposed BACT Limit
CO	20	ppmv at 15% O ₂	Proposed BACT Limit
VOC	5	ppmv at 15% O ₂	Proposed BACT Limit
Total PM/PM ₁₀ /PM _{2.5}	0.0142	lb/MMBtu	Equivalent to BACT Limit
SO ₂	0.0015	lb/MMBtu	Emission Factor
Lead	0.000014	lb/MMBtu	Emission Factor
H ₂ SO ₄	0.0039	lb/MMBtu	Emission Factor

Additionally, GHG emissions from the combustion of natural gas and fuel oil are calculated based on the emission factors for CO₂, CH₄, and N₂O listed in 40 CFR 98 Subpart C, Tables C-1 and C-2. Total GHG in terms of CO₂e is calculated by multiplying each individual GHG emitted by its respective global warming potential from Table 1 to 40 CFR 98 Subpart A.

3.4.3 New Unit Potential Emissions

A new fuel oil storage tank is being proposed for installation. The fuel oil storage tank will have a capacity of 2.5 million gallons and is assumed to operate continuously at 8,760 hours per year. Emissions from the storage tank are estimated using the latest version of Trinity's TankESP Software (TankESP). TankESP is a tank emissions calculation software product suite that uses the emission estimation procedures from Chapter 7 of AP-42 for VOC emissions from storage tanks. Physical data for the fuel oil storage tank and area-specific meteorological data was utilized in the TankESP software to generate an accurate estimate of VOC emissions. For the purposes of estimating potential emissions, it is conservatively assumed that the

tank will experience one turnover of fuel oil per month for a total fuel oil throughput of 30 million gallons per year.⁹

3.4.4 Additional Associated Emission Unit Increases

WCP anticipates that each of the two natural gas preheaters at the facility will experience associated emission increases due to additional hours of potential annual operation resulting from the proposed project. To estimate the preheater operational increases associated with this project, WCP analyzed historical annual turbine usage (from 2015 to 2019) relative to the proposed 3,000 hours of annual natural gas combustion per turbine. A ratio of potential to historical turbine natural gas combustion was established and utilized in conjunction with historical annual preheater usage (from 2015 to 2019) to ascertain an estimated increase in annual operation for the preheaters. This analysis resulted in an estimated operational increase of 5,088 hours per year for each natural gas preheater. Please refer to Appendix B for detailed calculations regarding anticipated operational increases for the two natural gas preheaters.

3.4.5 NSR Emissions Increase Summary

Table 3-3 shows the total emissions increase of the proposed project compared to the NSR major modification thresholds. Detailed emission calculations can be found in Appendix B of this application report.

Table 3-3. Project Emissions Increase

Pollutant	Modified Unit Baseline Emissions (tpy)	Modified Unit Projected Actual Emissions	New Unit Potential Emissions (tpy)	Emissions Increase from New & Modified Units (tpy)	Associated Units Emissions Increases (tpy)	Project Emissions Increases (tpy)	PSD Significant Emission Rate	PSD Triggered? (Yes/No)
Filterable PM	11.58	108.59	--	97.02	0.10	97.11	25	Yes
Total PM ₁₀	17.63	172.00	--	154.38	0.38	154.76	15	Yes
Total PM _{2.5}	17.63	172.00	--	154.38	0.38	154.76	10	Yes
SO ₂	0.40	9.19	--	8.79	0.07	8.86	40	No
NO _x	50.00	610.94	--	560.94	5.04	565.97	40	Yes
VOC	8.19	102.45	0.66	94.93	0.28	95.21	40	Yes
CO	23.46	283.44	--	259.98	4.23	264.21	100	Yes
CO ₂ e	153,070	1,549,985	--	1,396,914	6,017	1,402,932	75,000	Yes
Lead	--	0.03	--	0.03	2.52E-05	0.03	0.60	No
Sulfuric Acid Mist	0.51	4.26	--	3.75	0.02	3.77	7.00	No

3.5 Potential Emissions Estimate

The following sections discuss the methodology used to calculate the potential emissions for each emission unit at the facility. While only the potential annual emissions from each combustion turbine and the new storage tank are necessary for purposes of the NSR project emission increase assessment, the potential emissions of other facility emission units are detailed herein to support the air dispersion modeling analyses detailed in Volume II of this application package.

3.5.1 Natural Gas-Fired Fuel Preheaters

Potential criteria emissions for the natural gas preheaters are conservatively based on 8,760 operational hours per year for each preheater. Emissions of Total PM/PM₁₀/PM_{2.5}, NO_x, CO, VOC, and lead are calculated using emission factors from AP-42 Section 1.4, *Natural Gas Combustion*, Tables 1.4-1 and 2 (July

⁹ Potential Turbine Fuel Oil Usage (MM gal/yr) = 1,890 (MMBtu/hr/turbine) / 0.139 (MMBtu/gal distillate oil) * 500 (hr/yr) / 10⁶ (gal/MM gal) * 4 (turbines) = 27.2 (MM gal/yr)

1998). Emissions of SO₂ and H₂SO₄ are estimated based on the assumption that the sulfur content in natural gas is 0.50 grains per 100 standard cubic feet, 7,000 grains of sulfur per molar pound of sulfur, 100% conversion of fuel sulfur to SO₂, and a 15% oxidation rate of H₂SO₄. GHG emissions from preheater combustion of natural gas are calculated based on the emission factors for CO₂, CH₄, and N₂O listed in 40 CFR 98 Subpart C, Tables C-1 and C-2. Total GHG in terms of CO₂e is calculated by multiplying each individual GHG emitted by its respective global warming potential from Table 1 to 40 CFR 98 Subpart A. See Appendix B for detailed calculations.

3.5.2 Emergency Generators and Fire Pump

Emissions of criteria pollutants from the fire pump engine and auxiliary generator engine are calculated using factors from AP-42 Section 3.3, *Gasoline and Diesel Industrial Engines*, Table 3.3-1 (October 1996). GHG emissions from heater combustion of natural gas are calculated based on the emission factors for CO₂, CH₄, and N₂O listed in 40 CFR 98 Subpart C, Tables C-1 and C-2. Total GHG in terms of CO₂e is calculated by multiplying each individual GHG emitted by its respective global warming potential from Table 1 to 40 CFR 98 Subpart A. Emissions from these engines are calculated assuming 500 hours per year of operation per unit. See Appendix B for detailed calculations.

3.5.3 HAP/TAP Emissions

HAP and toxic air pollutant (TAP) emissions are evaluated from facility sources based on a variety of resources including AP-42 based emission factors. Details regarding the estimation of HAP/TAP emissions, can be found in Appendix B.

3.5.4 Insignificant Emissions Sources

The facility has other small insignificant sources of emissions (e.g. fugitive piping leaks, roads, etc.) at the facility which are not quantified within the potential to emit estimates within this application.

4. REGULATORY APPLICABILITY ANALYSIS

These projects will be subject to certain federal and state air regulations. This section of the application summarizes the air permitting requirements and key air quality regulations that will potentially apply to WCP as a result of these projects. Applicability to NSR, Title V, NSPS, National Emission Standards for Hazardous Air Pollutants (NESHAP), GRAQC, and other potentially applicable regulations to the proposed projects are addressed herein.

4.1 New Source Review Applicability

The NSR permitting program generally requires a source to obtain a permit and undertake other obligations prior to construction of any project at an industrial facility if the proposed project results in an emissions increase in excess of certain pollutant threshold levels. EPD administers its major NSR permitting program through GRAQC Rule 391-3-1-.02(7), *Prevention of Significant Deterioration of Air Quality*, which establishes preconstruction, construction and operation requirements for new and modified sources.

The NSR program is comprised of two elements: NNSR and PSD. The NNSR program potentially applies to new construction or modifications that result in emission increases of a particular pollutant for which the area where the facility is located is classified as “nonattainment” for that pollutant. The PSD program applies to project increases of those pollutants for which the area the facility is located in is classified as “attainment” or “unclassifiable.” The WCP Sandersville facility is located in Washington County, which has been designated by the U.S. EPA as “attainment” or “unclassifiable” for all criteria pollutants.¹⁰ Therefore, the facility is not subject to NNSR permitting requirements. However, new construction or modifications that result in emissions increases are potentially subject to PSD permitting requirements.

The PSD program only regulates emissions from “major” stationary sources of regulated air pollutants. A stationary source is considered PSD major if potential emissions of any regulated pollutant exceed the major source thresholds. The PSD major source threshold for the Facility is 250 tpy for all regulated pollutants, except GHG.^{11, 12} As presently permitted, the existing facility is a synthetic minor PSD source. To facilitate fuel oil combustion, removal of conditions that limit fuel combustion to natural gas will be required. Estimated facility-wide PTE following the proposed change indicates the facility will be considered a PSD major source as potential emissions of at least one regulated pollutant will exceed 250 tpy. For sources which are PSD major for at least one regulated pollutant, the emissions increases for all regulated pollutants resulting from the proposed project must be compared against the PSD SER to determine if the project is subject to PSD review. For CO₂e, PSD permitting is only required if the emissions increase from the proposed project exceeds the SER for CO₂e and the project is already undergoing PSD permitting for at least one other PSD-regulated pollutant. The emissions increases from the proposed project for each PSD-regulated pollutant compared to the respective SER are shown in Table 4-1.

¹⁰ 40 CFR 81.311

¹¹ While fossil fuel-fired steam electric plants of more than 250 MMBtu/hr input are on the “List of 28” named source categories which are subject to a lower major source threshold for criteria pollutants of 100 tpy, the simple-cycle combustion turbines operated at the Facility do not meet the definition of steam electric plants.

¹² 40 CFR 52.21(b)(49)(iii) and (iv)

Table 4-1. Project Emission Increases Compared to PSD SER

Pollutant	Project Emissions Increases (tpy)	PSD Significant Emission Rate	PSD Triggered? (Yes/No)
Filterable PM	97.11	25	Yes
Total PM ₁₀	154.76	15	Yes
Total PM _{2.5}	154.76	10	Yes
SO ₂	8.86	40	No
NO _x	565.97	40	Yes
VOC	95.21	40	Yes
CO	264.21	100	Yes
CO _{2e}	1,402,932	75,000	Yes
Lead	0.03	0.60	No
Sulfuric Acid Mist	3.77	7.00	No

As illustrated in Table 4-1, the proposed projects emissions increases exceeds the SER for filterable PM, total PM₁₀, total PM_{2.5}, NO_x, VOC, CO, and CO_{2e}. Accordingly, PSD review is required for these pollutants.

4.2 Title V Operating Permits

40 CFR 70 establishes the federal Title V operating permit program. Georgia has incorporated the provisions of this federal program in its state regulation, Rule 391-3-1-.03(10), *Title V Operating Permits*. This regulation requires that all new and existing Title V major sources of air emissions obtain federally approved state-administered operating permits. A major source as defined under the Title V program is a facility that has the potential to emit either more than 100 tpy for any criteria pollutant, more than 10 tpy for any single HAP, or more than 25 tpy for combined HAP. Potential emissions from WCP exceed the major source threshold for several pollutants. Therefore, the Facility is subject to the Title V program and currently operates under the State issued Part 70 Operating Permit No. 4911-303-0039-V-08-0 issued January 11, 2021.

The proposed projects represent a significant modification of the operating permit. As such, the required Title V modification application elements are included in the Georgia EPD Online System (GEOS) submittal with Application No. 547905.

4.3 New Source Performance Standards

NSPS, located in 40 CFR 60, require new, modified, or reconstructed sources to control emissions to the level achievable by the best demonstrated technology as specified in the applicable provisions. The following is a summary of applicability and non-applicability determinations for NSPS regulations of relevance to the proposed project. Rules that are specific to certain source categories unrelated to the proposed project are not discussed in this regulatory review.

4.3.1 40 CFR 60 Subpart A – General Provisions

All affected sources subject to source-specific NSPS are subject to the general provisions of NSPS Subpart A unless specifically excluded by the source-specific NSPS. Subpart A requires initial notification, performance testing, recordkeeping and monitoring, provides reference methods, and mandates general control device requirements for all other subparts as applicable.

4.3.2 40 CFR 60 Subpart D – Fossil Fuel-Fired Steam Generators > 250 MMBtu/hr

NSPS Subpart D, *Standards of Performance for Fossil-Fuel-Fired Steam Generators*, applies to fossil fuel-fired steam generating units with heat input capacities greater than 250 MMBtu/hr that have been constructed or modified since August 17, 1971. The rule defines a fossil fuel-fired steam generating unit as:¹³

A furnace or boiler used in the process of burning fossil fuel for the purpose of producing steam by heat transfer.

The combustion turbines will not be subject to NSPS Subpart D, because:

- > The turbines do not burn fossil fuel for the purpose of producing steam; and
- > Units that are subject to NSPS Subpart KKKK are not subject to NSPS Subpart D. Following the proposed modifications, the simple-cycle combustion turbines will be NSPS Subpart KKKK affected facilities.¹⁴

4.3.3 40 CFR 60 Subpart Da – Electric Utility Steam Generating Units

NSPS Subpart Da, *Standards of Performance for Electric Utility Steam Generating Units*, provides standards of performance for electric utility steam generating units with heat input capacities greater than 250 MMBtu/hr of fossil fuel (alone or in combination with any other fuel) for which construction, modification or reconstruction commenced after September 18, 1978.¹⁵ The rule defines an electric utility steam generating unit as:¹⁶

...any steam electric generating unit that is constructed for the purpose of supplying more than one-third of its potential electric output capacity and more than 25 MW net-electrical output to any utility power distribution system for sale. Also, any steam supplied to a steam distribution system for the purpose of providing steam to a steam-electric generator that would produce electrical energy for sale is considered in determining the electrical energy output capacity of the affected facility.

The next critical definition relates to steam generating unit:¹⁷

Steam generating unit for facilities constructed, reconstructed, or modified before May 4, 2011, means any furnace, boiler, or other device used for combusting fuel for the purpose of producing steam (including fossil-fuel-fired steam generators associated with combined cycle gas turbines;

¹³ 40 CFR 60.41

¹⁴ 40 CFR 60.40(e)

¹⁵ 40 CFR 60.40Da(a)

¹⁶ 40 CFR 60.41Da

¹⁷ 40 CFR 60.41Da

nuclear steam generators are not included). For units constructed, reconstructed, or modified after May 3, 2011, steam generating unit means any furnace, boiler, or other device used for combusting fuel for the purpose of producing steam (including fossil-fuel-fired steam generators associated with combined cycle gas turbines; nuclear steam generators are not included) plus any integrated combustion turbines and fuel cells.

The essential component of the definition is that the unit must be “steam generating”. As simple-cycle combustion turbines do not create steam, they do not meet the applicability definition of NSPS Subpart Da and are therefore not subject to NSPS Subpart Da requirements.

4.3.4 40 CFR 60 Subpart Db – Steam Generating Units > 100 MMBtu/hr

NSPS Subpart Db, *Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units*, provides standards of performance for steam generating units with capacities greater than 100 MMBtu/hr for which construction, modification, or reconstruction commenced after June 19, 1984.¹⁸ The term “steam generating unit” is defined under this regulation as:¹⁹

Steam generating unit means a device that combusts any fuel or byproduct/waste and produces steam or heats water or heats any heat transfer medium. This term includes any municipal-type solid waste incinerator with a heat recovery steam generating unit or any steam generating unit that combusts fuel and is part of a cogeneration system or a combined cycle system. This term does not include process heaters as they are defined in this subpart.

As the simple-cycle combustion turbines do not generate steam, they are not subject to requirements per NSPS Subpart Db.

4.3.5 40 CFR 60 Subpart Dc – Small Steam Generating Units

NSPS Subpart Dc, *Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units*, provides standards of performance for each steam generating unit for which construction, modification, or reconstruction commenced after June 9, 1989.²⁰ This subpart applies to steam generating units having a maximum rated heat input capacity of less than or equal to 100 MMBtu/hr and greater than or equal to 10 MMBtu/hr. NSPS Subpart Dc does not apply for similar reasons as detailed for NSPS Subpart Db: combustion turbines are not steam generating units.²¹

4.3.6 40 CFR 60 Subpart K –Storage Vessels for Petroleum Liquids for Which Construction, Reconstruction, or Modification Commenced After June 11, 1973, and Prior to May 19, 1978

The requirements of NSPS Subpart K apply to storage vessels for petroleum liquids which have a storage capacity greater than 65,000 gallons and that commenced construction, modification, or reconstruction after

¹⁸ 40 CFR 60.40b(a)

¹⁹ 40 CFR 60.41b

²⁰ 40 CFR 60.40c(a)

²¹ 40 CFR 60.41c

June 11, 1973 and prior to May 19, 1978.²² The proposed fuel oil storage tank at the Facility has not yet been constructed; therefore, the requirements of NSPS Subpart K do not apply.

4.3.7 40 CFR 60 Subpart Ka – Storage Vessels for Petroleum Liquids for Which Construction, Reconstruction, or Modification Commenced After May 18, 1978, and Prior to July 23, 1984

The requirements of NSPS Subpart Ka apply to storage vessels for petroleum liquids which have a storage capacity greater than 40,000 gallons and that commenced construction, modification, or reconstruction after May 18, 1978 and prior to July 23, 1984.²³ The proposed fuel oil storage tank at the Facility has not yet been constructed; therefore, the requirements of NSPS Subpart Ka do not apply.

4.3.8 40 CFR 60 Subpart Kb – Volatile Organic Liquid Storage Vessels (Including Petroleum Liquids Storage Vessels) for Which Construction, Reconstruction, or Modification Commenced After July 23, 1984

The requirements of NSPS Subpart Kb apply to storage vessels which have a storage capacity greater than 19,813 gallons that store Volatile Organic Liquids (VOL) for which construction, modification, or reconstruction commenced after July 23, 1984.²⁴ However, per 40 CFR 60.110b(b), NSPS Kb does not apply to storage vessels with a storage capacity greater than 39,890 gallons storing a liquid with a maximum true vapor pressure less than 3.5 kilopascals (kPa). The proposed fuel oil storage tank at the Facility will have a storage capacity of 2.5 million gallons and will store ultra low-sulfur diesel (ULSD). The maximum true vapor pressure of the ULSD stored in the fuel oil storage tank is far less than the 3.5 kPa threshold; therefore, the requirements of NSPS Kb do not apply.

4.3.9 40 CFR 60 Subpart GG – Stationary Gas Turbines

NSPS Subpart GG, *Standards of Performance for Stationary Gas Turbines*, applies to all stationary gas turbines with a heat input at peak load equal to or greater than 10 MMBtu/hr, based on the lower heating value of the fuel fired, that are constructed, modified, or reconstructed after October 3, 1977.²⁵

Presently, the combustion turbines are subject to NSPS Subpart GG. However, upon completion of the proposed modifications, the combustion turbines will be subject to the more recently promulgated standards for Stationary Combustion Turbines under NSPS Subpart KKKK. Pursuant to 40 CFR 60.4305(b) (NSPS Subpart KKKK), stationary combustion turbines regulated under NSPS Subpart KKKK are exempt from the requirements of NSPS Subpart GG. Therefore, NSPS Subpart GG will no longer apply to the WCP combustion turbines following the proposed project.

4.3.10 40 CFR 60 Subpart KKKK – Stationary Combustion Turbines

NSPS Subpart KKKK, *Standards of Performance for Stationary Combustion Turbines*, applies to all stationary combustion turbines with a heat input at peak load equal to or greater than 10 MMBtu/hr, based on the lower heating value of the fuel fired, and were constructed, reconstructed, or modified after February 18,

²² 40 CFR 60.110(c)

²³ 40 CFR 60.110a

²⁴ 40 CFR 60.110b(a)

²⁵ 40 CFR 60.330(a), (b)

2005.²⁶ The Facility presently operates four natural gas-fired simple-cycle combustion turbines, each with a heat input capacity exceeding 10 MMBtu/hr. Following the proposed project, the turbines will also be able to combust fuel oil. To determine if the turbines will be subject to NSPS Subpart KKKK following the proposed project, it is necessary to ascertain if a “modification” per the NSPS has occurred. For purposes of NSPS, a modification is defined as:²⁷

...any physical change in, or change in the method of operation of, an existing facility which increases the amount of any air pollutant (to which a standard applies) emitted into the atmosphere by that facility or which results in the emission of any air pollutant (to which a standard applies) into the atmosphere not previously emitted.

NSPS Subpart KKKK establishes standards for NO_x and SO₂.²⁸ As the combustion of fuel oil will result in the increase of both pollutants when compared to natural gas combustion, the proposed project qualifies as an NSPS modification, resulting in the Facility's combustion turbines being subject to the requirements of NSPS Subpart KKKK. Per 40 CFR 60.4305(b), stationary combustion turbines regulated under NSPS Subpart KKKK are exempt from the requirements of NSPS Subpart GG. Therefore, the existing NSPS Subpart GG requirements will no longer apply.

The following sections detail the applicable requirements as a result of NSPS Subpart KKKK applicability.

4.3.10.1 Emission Limits

Per Table 1 to Subpart KKKK, a modified combustion turbine is limited to NO_x emission limits depending on the type of fuel combusted and the heat input at peak load. For modified combustion turbines firing natural gas with a rating greater than 850 MMBtu/hr, the NO_x emission standard is 15 ppm at 15% O₂ or 0.43 lb/MWh useful output. Additionally, for modified combustion turbines firing fuels other than natural gas with a rating greater than 850 MMBtu/hr, the NO_x emission standard is 42 ppm at 15% O₂ or 1.3 lb/MWh useful output. Subpart KKKK also includes, for units greater than 30 MW output, a NO_x limit of 96 ppm at 15% O₂ or 4.7 lb/MWh useful output for turbine operation at ambient temperatures less than 0°F and turbine operation at loads less than 75% of peak load.²⁹ Compliance with the NO_x emission limit is determined on a 4-hour rolling average basis.³⁰ These NSPS Subpart KKKK requirements will replace the NSPS Subpart GG requirements established per Condition 3.3.3 of the existing Title V operating permit.

SO₂ emissions from combustion turbines located in the continental U.S. are limited to 0.9 lb/MWh gross output (or 110 ng/J), or the units must not burn any fuel with total potential sulfur emissions in excess of 0.060 lb SO₂/MMBtu heat input (or 26 ng SO₂/J).³¹

4.3.10.2 Monitoring and Testing Requirements

Pursuant to 40 CFR 60.4333(a), the combustion turbines, air pollution control equipment, and monitoring equipment will be maintained in a manner that is consistent with good air pollution control practices for

²⁶ 40 CFR 60.4305(a), (b)

²⁷ 40 CFR 60.2

²⁸ 40 CFR 60.4315

²⁹ Table 1 to Subpart KKKK of Part 60

³⁰ 40 CFR 60.4350(g), 40 CFR 60.4380(b)(1)

³¹ 40 CFR 60.4330(a)(1) or (a)(2), respectively

minimizing emissions. This requirement applies at all times including during startup, shutdown, and malfunction.

4.3.10.2.1 NO_x Compliance Demonstration Requirements

The combustion turbine systems currently employ a continuous emission monitoring system (CEMS) for NO_x per the requirements of the Acid Rain Program (ARP), promulgated in 40 CFR Part 75. Per 40 CFR 4340(b)(2)(iv), units operating without water injection that are regulated by 40 CFR Part 75 may rely on the 40 CFR Part 75 Appendix E procedures for documenting ongoing compliance with the NSPS Subpart KKKK NO_x standards with approval from the state. The WCP units operate without water injection during natural gas combustion.

Water injection will be required for fuel oil combustion. 40 CFR 60.4335 establishes NO_x monitoring options for water injection, including use of a CEM, but does not explicitly state that the Part 75 procedures may be relied upon. However, NSPS Subpart KKKK specific requirements for a CEM are detailed in 40 CFR 60.4345, including an option to rely on a CEM installed and certified per 40 CFR Part 75.³² Therefore, the use of the existing NO_x CEMs meeting the requirements of 40 CFR Part 75 Appendix E should be sufficient for NSPS Subpart KKKK NO_x ongoing compliance monitoring purposes.

Sources demonstrating compliance with the NO_x emission limits via CEMS are not subject to the requirement to perform initial and annual NO_x stack tests.³³ Initial compliance with the applicable NO_x emission limits will be demonstrated by comparing the arithmetic average of the NO_x emissions measurements taken during the initial RATA to the NO_x emission limit under this subpart.³⁴

4.3.10.2.2 SO₂ Compliance Demonstration Requirements

For compliance with the SO₂ emission limit, facilities are required to perform regular determinations of the total sulfur content of the combustion fuel and to conduct initial and annual compliance demonstrations. The total sulfur content of gaseous fuel combusted in the combustion turbine must be determined and recorded once per operating day or using a custom schedule as approved by EPD.³⁵ The total sulfur content of fuel oil combusted in the combustion turbine must be determined by flow proportional sampling, daily sampling, sampling from the unit's storage tank after each addition of fuel to the tank, or sampling each delivery prior to combining it with fuel oil already in the intended storage tank.³⁶

However, as allowed per 40 CFR 60.4365, WCP elects to opt out of these provisions of the rule by using natural gas and fuel oil which are demonstrated not to exceed potential sulfur emissions of 0.060 lb/MMBtu SO₂. This demonstration can be made using one of the following methods:

1. By using valid purchase contracts, tariff sheets, or transportation contracts for the fuel, specifying that the fuel sulfur content for the natural gas is less than or equal to 20 grains of sulfur per 100 standard cubic feet and/or that the maximum total sulfur content for fuel oil is 0.05 weight percent (500 ppmw)

³² 40 CFR 60.4345(a), requiring that the relative accuracy test audit of the CEM be performed on a lb/MMBtu basis.

³³ 40 CFR 60.4340(b), 40 CFR 60.4405

³⁴ 40 CFR 60.4405(c) and (d)

³⁵ 40 CFR 60.4370(b) and (c)

³⁶ 40 CFR 60.4370(a), procedures and frequencies per 40 CFR 75, Appendix D, Sections 2.2.3, 2.2.4.1, 2.2.4.2, or 2.2.4.3

or less. These limitations will serve as demonstration that potential emissions will not exceed 0.060 lb/MMBtu.

2. By using representative fuel sampling data meeting the requirements of 40 CFR 75, Appendix D, Sections 2.3.1.4 or 2.3.2.4 which show that the sulfur content of the fuel does not exceed 0.060 lb SO₂/MMBtu heat input.

WCP is currently required to monitor the sulfur content of the natural gas burned in the combustion turbines through submittal of a semiannual analysis of the gas by the supplier or a current, valid purchase contract, tariff sheet, or transportation contract for the gaseous fuel, specifying that the maximum sulfur content does not exceed its excursion threshold of 20.0 grains per 100 standard cubic feet.³⁷ This sulfur content analysis by the supplier satisfies the sulfur content demonstration methodologies for natural gas in 40 CFR 60.4365(a) and (b), respectively. Therefore, continued compliance with this existing permit condition will guarantee compliance with these NSPS KKKK requirements for natural gas combustion.

As a result of this proposed project, all four combustion turbines at the facility will be retrofitted to allow for the combustion of fuel oil. Therefore, in accordance with 40 CFR 60.6365(a) and (b), WCP will now be required to monitor the sulfur content of the fuel oil burned in the combustion turbines through the submittal of a semiannual analysis of the fuel oil by the supplier or a current, valid purchase contract, tariff sheet, or transportation contract for the fuel oil, specifying that the maximum total sulfur content is 0.05 weight percent (500 ppmw) or less.

4.3.10.3 Initial Notification

Per 40 CFR 60.7(a)(4), this permit application serves as the required notification for any physical or operational change to an existing facility which qualifies as an NSPS modification.

4.3.11 40 CFR 60 Subpart TTTT – Greenhouse Gas Emissions for Electric Generating Units

NSPS Subpart TTTT, *Standards of Performance for Greenhouse Gas Emissions for Electric Generating Units* applies to any fossil fuel fired steam generating unit, Integrated Gasification Combined Cycle (IGCC) unit, or stationary combustion turbine constructed after January 8, 2014 or reconstructed after June 8, 2014 and to any steam generating unit or IGCC modified after June 8, 2014, provided that unit has a base load rating greater than 250 MMBtu/hr and serves a generator capable of selling greater than 25 MW of electricity to the grid.³⁸ The existing simple-cycle combustion turbines at the Facility each have peak heat inputs greater than 250 MMBtu/hr and serve a generator greater than 25 MW. Therefore, these stationary combustion turbines could potentially be subject to the provisions of NSPS TTTT.

With respect to stationary combustion turbines, NSPS Subpart TTTT applies only to units that commenced construction or reconstruction after June 18, 2014, not modification. “Reconstruction” is defined as the replacement of components of an existing affected facility such that the fixed capital cost of the new components exceeds 50% of the fixed capital cost that would be required to construct a comparable, entirely new affected facility that is technologically and economically capable of complying with the applicable standards. The retrofit cost of the proposed project per turbine is \$18.5 million. In comparison, the cost of a comparable, entirely new “stationary combustion turbine” capable of combusting both natural gas and fuel oil under NSPS Subpart KKKK is approximately \$83 million. Thus, the costs per turbine is far

³⁷ Permit No. 4911-303-0039-V-08-0, Condition 6.2.8

³⁸ 40 CFR 60.5509(a)

less than 50% of comparable, entirely new “stationary combustion turbines” under Subpart KKKK. As the combustion turbines at WCP are existing units and the proposed projects do not meet the reconstruction definition, the modifications to the turbine systems will not trigger applicability of NSPS Subpart TTTT requirements.³⁹

4.3.12 Non-Applicability of All Other NSPS

NSPS are developed for particular industrial source categories. The applicability of a particular NSPS to the proposed project can be readily ascertained based on the industrial source category covered. All other NSPS, besides Subpart A, are categorically not applicable to the proposed project.

4.4 National Emission Standards for Hazardous Air Pollutants

NESHAP, located in 40 CFR 61 and 40 CFR 63, have been promulgated for source categories that emit HAP to the atmosphere. A facility that is a major source of HAP is defined as having potential emissions of greater than 25 tpy of total HAP and/or 10 tpy of individual HAP. Facilities with a potential to emit HAP at an amount less than that which is defined as a major source are otherwise considered an area source. The NESHAP allowable emissions limits are most often established on the basis of a maximum achievable control technology (MACT) determination for the particular major source. The NESHAP apply to sources in specifically regulated industrial source categories (Clean Air Act Section 112(d)) or on a case-by-case basis (Section 112(g)) for facilities not regulated as a specific industrial source type.

The WCP Sandersville facility is presently classified as an area source of HAP emissions and will remain so following the proposed projects. The determination of applicability to NESHAP requirements for the proposed projects is detailed in the following sections. Rules that are specific to certain source categories unrelated to the proposed projects are not discussed in this regulatory review.

4.4.1 40 CFR 63 Subpart A – General Provisions

NESHAP Subpart A, *General Provisions*, contains national emission standards for HAP defined in Section 112(b) of the Clean Air Act. All affected sources, which are subject to another NESHAP in 40 CFR 63, are subject to the general provisions of NESHAP Subpart A, unless specifically excluded by the source-specific NESHAP.

4.4.2 40 CFR 63 Subpart YYYY – Combustion Turbines

NESHAP Subpart YYYY, *NESHAP for Stationary Combustion Turbines*, establishes emission and operating limits for stationary combustion turbines located at major sources of HAP.⁴⁰ As an area source of HAP, NESHAP Subpart YYYY does not apply to operations at the Facility.

³⁹ 40 CFR 60.5509(a)

⁴⁰ 40 CFR 63.6080

4.4.3 40 CFR 63 Subpart DDDDD – Industrial, Commercial, and Institutional Boilers and Process Heaters

NESHAP Subpart DDDDD, *NESHAP for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters* (Major Source Boiler MACT) regulates boilers and process heaters at major sources of HAP.⁴¹ As an area source of HAP, the Facility is not subject to the Major Source Boiler MACT.

4.4.4 40 CFR 63 Subpart UUUUU – Electric Utility Steam Generating Units

NESHAP Subpart UUUUU, *NESHAP for Electric Utility Steam Generating Units*, applies to electric utility steam generating units (EGUs) that combust coal or oil.⁴² Pursuant to 40 CFR 63.9983(a), area source stationary combustion turbines, other than IGCC units, are not subject to Subpart UUUUU. As the WCP Facility is an area source, NESHAP Subpart UUUUU will not apply.

4.4.5 40 CFR 63 Subpart JJJJJ – Industrial, Commercial, and Institutional Boilers at Area Sources

NESHAP Subpart JJJJJ, *NESHAP for Industrial, Commercial, and Institutional Boilers Area Sources* (Area Source Boiler MACT) regulates boilers at area sources of HAP.⁴³ The simple-cycle combustion turbines do not meet the boiler definition pursuant to 40 CFR 63.11237, which also excludes waste heat boilers:

Boiler means an enclosed device using controlled flame combustion in which water is heated to recover thermal energy in the form of steam and/or hot water. Controlled flame combustion refers to a steady-state, or near steady-state, process wherein fuel and/or oxidizer feed rates are controlled. A device combusting solid waste, as defined in § 241.3 of this chapter, is not a boiler unless the device is exempt from the definition of a solid waste incineration unit as provided in section 129(g)(1) of the Clean Air Act. Waste heat boilers, process heaters, and autoclaves are excluded from the definition of Boiler.

Therefore, the requirements of NESHAP Subpart JJJJJ do not apply to any equipment being modified as part of the proposed project.

4.4.6 Non-Applicability of All Other NESHAP

NESHAP are developed for particular industrial source categories. The applicability of a particular NESHAP to the proposed project can be readily ascertained based on the industrial source category covered. All other NESHAP are categorically not applicable to the proposed projects.

4.5 Compliance Assurance Monitoring

Under 40 CFR 64, Compliance Assurance Monitoring (CAM) facilities are required to prepare and submit monitoring plans for certain emissions units with Title V operating permit applications. The CAM plans are intended to provide an on-going and reasonable assurance of compliance with emission limits. Under the general applicability criteria, this regulation only applies to emission units that use a control device to achieve compliance with an emission limit and whose pre-control emissions exceed the major source

⁴¹ 40 CFR 63.7480

⁴² 40 CFR 63.9980

⁴³ 40 CFR 63.11193

thresholds under the Title V operating program. For a subject unit whose post-control emissions also exceed the major source threshold, a CAM plan is required to be submitted with the initial or modification Title V operating permit application. For a subject unit whose post-control emissions are less than the major source threshold, a CAM plan does not have to be submitted until the next Title V renewal application.

The simple-cycle combustion turbines at the Facility are presently not subject to CAM requirements as they do not operate control devices. Following the proposed project, each combustion turbine will operate with water injection during periods of fuel oil combustion to reduce NO_x emissions. These units have NO_x CEMS to verify proper operation. Per 40 CFR 64.2(b)(1)(vi), use of a continuous compliance demonstration exempts a unit from the CAM requirements. Therefore, the turbines are not subject to CAM for NO_x purposes.

4.6 Risk Management Plan

Subpart B of 40 CFR 68 outlines requirements for risk management prevention plans pursuant to Section 112(r) of the Clean Air Act. Applicability of the subpart is determined based on the type and quantity of chemicals stored at a facility. The Facility does not exceed the threshold quantity for any of the chemicals and is, therefore, not subject to 40 CFR 68 Subpart B. The Facility is and will continue to be subject to the General Duty Clause under the Clean Air Act Section 112(r)(1), which states:

The owners and operators of stationary sources producing, processing, handling or storing such substances [i.e., a chemical in 40 CFR part 68 or any other extremely hazardous substance] have a general duty [in the same manner and to the same extent as the general duty clause in the Occupational Safety and Health Act (OSHA)] to identify hazards which may result from (such) releases using appropriate hazard assessment techniques, to design and maintain a safe facility taking such steps as are necessary to prevent releases, and to minimize the consequences of accidental releases which do occur.

4.7 Stratospheric Ozone Protection Regulations

The requirements originating from Title VI of the Clean Air Act, entitled *Protection of Stratospheric Ozone*, are contained in 40 CFR 82. Subparts A through E and Subparts G and H of 40 CFR 82 are not applicable to the Facility. 40 CFR 82 Subpart F, *Recycling and Emissions Reduction*, potentially applies if the facility operates, maintains, repairs, services, or disposes of appliances that utilize Class I, Class II, or non-exempt substitute refrigerants.⁴⁴ Subpart F generally requires persons completing the repairs, service, or disposal to be properly certified. It is expected that all repairs, service, and disposal of ozone depleting substances from such equipment (air conditioners, refrigerators, etc.) at the facility will be completed by a certified technician. WCP will continue to comply with 40 CFR 82 Subpart F.

4.8 Clean Air Markets Regulations

Starting with the Acid Rain Program (ARP) mandated by the 1990 Clean Air Act Amendments, U.S. EPA has developed several market-based “cap and trade” regulatory programs. All market-based regulatory programs are overseen by U.S. EPA’s Clean Air Markets Divisions (CAMD) and are referred to as CAMD regulations. The programs that are potentially applicable to WCP are:

⁴⁴ 40 CFR 82.150

- ▶ Acid Rain Program (ARP) – 1990 - ongoing
- ▶ Clean Air Interstate Rule (CAIR) – 2009 - 2014
- ▶ Cross-State Air Pollution Rule (CSAPR) – 2015 (ongoing)

4.8.1 Acid Rain Program

In order to reduce acid rain in the United States and Canada, Title IV (40 CFR 72 *et seq.*) of the Clean Air Act Amendments of 1990 established the ARP to substantially reduce SO₂ and NO_x emissions from electric utility plants. Affected units are specifically listed in Tables 1 and 2 of 40 CFR 73.10 under Phase I and Phase II of the program. Upon Phase III implementation, the ARP in general applies to fossil fuel-fired combustion sources that drive generators for the purposes of generating electricity for sale. The turbines at the Facility are utility units subject to the ARP. The facility is subject to the requirements of 40 CFR 72 (permits), 40 CFR 73 (SO₂), and 40 CFR 75 (monitoring) but is not subject to the NO_x provisions (40 CFR 76) of the ARP regulations because the turbines do not have the capability to burn coal.

Under 40 CFR 75 of the ARP, WCP is required to operate a NO_x CEMS for each unit to monitor the NO_x emission rate (lb/MMBtu) and to determine SO₂ and CO₂ mass emissions (tons) following the procedures in Appendices D and G, respectively. Further, the ARP requires the facility to possess SO₂ allowances for each ton of SO₂ emitted. The ARP also requires initial certification of the monitors within 90 days of commencement of commercial operation, quarterly reports, and an annual compliance certification. The ARP requirements are outlined in Section 7.9 and Attachment D of the Title V permit No. 4911-303-0039-V-08-0. The proposed projects should not alter any applicable requirements of ARP to the WCP operations, with the exception of possible modifications to monitoring methods with use of fuel oil under 40 CFR Part 75. The facility will continue to maintain sufficient allowances under ARP for its operations.

4.8.2 Clean Air Interstate Rule / Cross-State Air Pollution Rule

The CAIR, 40 CFR 96, called for reductions in SO₂ and NO_x by utilizing an emissions trading program. More broadly, 40 CFR 96 also includes a forerunner to CAIR, the NO_x SIP Call / NO_x Budget program, and the name of 40 CFR 96 (NO_x Budget Trading Program for State Implementation Plans) still reflects the origins in regulating only NO_x.

The CSAPR was developed to require affected states to reduce emissions from power plants that contribute to ozone and/or particulate matter emissions.⁴⁵ Initially finalized on July 6, 2011, the CSAPR was scheduled to replace the CAIR on January 1, 2012. However, on December 30, 2011, the U.S. Court of Appeals for the District of Columbia Circuit (the "D.C. Circuit") stayed CSAPR, pending a subsequent decision. On August 21, 2012, the D.C. Circuit then vacated CSAPR, remanding it back to EPA for further rulemaking, leaving CAIR in effect until a replacement rule was promulgated.⁴⁶ Upon appeal, the U.S. Supreme Court – on April 29, 2014 – upheld the CSAPR, reversing the D.C. Circuit's decision and remanding the case back to that Court for further proceedings consistent with its April 2014 decision. Upon remand, the U.S. government filed a motion with the D.C. Circuit for a lift of the stay of CSAPR on June 26, 2014, and this motion was granted on October 23, 2014. Therefore, the CSAPR has replaced the CAIR. CSAPR Phase 1 implementation began January 1, 2015 for annual programs and May 1, 2015 for the ozone season program. Phase 2 implementation began on January 1, 2017 for annual programs and May 1, 2017 for ozone season programs.

⁴⁵ <http://www.epa.gov/airtransport/>

⁴⁶ EME Homer City Generation, L.P. v. U.S. EPA. U.S. Court of Appeals for the District of Columbia Circuit, No. 11-1302, decided August 21, 2012.

Therefore, since CSAPR is currently effective, potential applicability is evaluated against the CSAPR Program and not CAIR. CSAPR applicability is found in 40 CFR 97.404 and definitions in 40 CFR 97.402 and implemented via Georgia EPD through GRAQC 391-3-1-.02(12) – (13). The CSAPR rule aims to improve air quality by reducing emissions from power plants that contribute to ozone and/or fine particulate pollution in other states. Georgia is subject to CSAPR programs for both fine particles (SO₂ and annual NO_x) and ozone (ozone season NO_x).⁴⁷

CSAPR applicability is similar but distinct from ARP, with applicability criteria and definitions per 40 CFR 97.402.⁴⁸ In general, CSAPR regulates fossil-fuel-fired boilers and combustion turbines serving, on any day starting November 15, 1990 or later, an electrical generator with a nameplate capacity exceeding 25 MWe and producing power for sale. WCP's combustion turbines are affected sources under this regulation, and the proposed project will not alter the applicability of CSAPR to the facility's operations. WCP will continue to maintain sufficient allowances under CSAPR for its operations.

4.9 State Regulatory Requirements

In addition to federal air regulations, GRAQC Chapter 393-3-1 establishes regulations applicable at the emission unit level (source specific) and at the facility level.⁴⁹ This section reviews the source specific requirements for the proposed projects and does not detail generally applicable requirements such as payment of permit fees.

4.9.1 GRAQC 391-3-1-.02(2)(b) – Visible Emissions

Rule (b) limits the visible emissions from any emissions source not subject to some other visible emissions limitation under GRAQC 391-3-1-.02 to 40% opacity. Visible emissions testing may be required at the discretion of the Director. The turbines at WCP are subject to this regulation.

The turbines presently fire pipeline-quality natural gas with emissions exhibiting minimal opacity. As the turbines will be modified to combust ULSD fuel oil, it is anticipated that the firing of these relatively clean fuels in conjunction with proper operation ensures compliance with this rule. No applicable requirements per Rule (b) will be altered as a result of the proposed projects.

4.9.2 GRAQC 391-3-1-.02(2)(d) – Fuel-Burning Equipment

Rule (d) limits the PM emissions, visible emissions, and NO_x emissions from fuel-burning equipment. The standards are applied based on installation date, the heat input capacity of the unit, and the fuel(s) combusted. The GRAQC define "fuel-burning equipment" as follows:⁵⁰

"Fuel-burning equipment" means equipment the primary purpose of which is the production of thermal energy from the combustion of any fuel. Such equipment is generally that used for, but not limited to, heating water, generating or super heating steam, heating air as in warm air furnaces,

⁴⁷ <https://www.epa.gov/airmarkets/map-states-covered-csapr>

⁴⁸ CSAPR applicability and definitions are repeated in four separate subparts of 40 CFR 97, but each has identical definitions and applicability requirements. Subpart AAAAA (5A), which is for the NO_x Annual program, is used in this discussion.

⁴⁹ Current through rules and regulations filed through December 8, 2020. <http://rules.sos.ga.gov/gac/391-3-1>

⁵⁰ GRAQC 391-3-1-.01(cc)

furnishing process heat indirectly, through transfer by fluids or transmissions through process vessel walls.

The combustion turbines are used for the generation of electric power, not the production of thermal energy. Therefore, they do not meet the definition of fuel burning equipment and are not subject to the requirements of Rule (d).

4.9.3 GRAQC 391-3-1-.02(2)(e) – Particulate Emissions from Manufacturing Processes

Rule (e), commonly known as the process weight rule, establishes PM limits where not elsewhere specified. Combustion turbines are not technically subject to a separate particulate limit rule, and historically have not been regulated by Rule (e). Therefore, the combustion turbines at WCP are not subject to this regulation.

4.9.4 GRAQC 391-3-1-.02(2)(g) – Sulfur Dioxide

Rule (g) limits the maximum sulfur content of any fuel combusted in a fuel-burning source, based on the heat input capacity. As this rule applies to fuel-burning sources, not “fuel-burning equipment,” this regulation presently applies to the combustion turbines. For the turbines with heat input capacities greater than 100 MMBtu/hr, the fuel sulfur content is limited to not more than 3% by weight.⁵¹ The proposed projects do not alter the applicable requirements of Rule (g), and WCP will continue to comply with Rule (g) via the combustion of pipeline quality natural gas and ULSD. This limit is subsumed by the more stringent fuel sulfur limit under NSPS Subpart KKKK.

4.9.5 GRAQC 391-3-1-.02(2)(n) – Fugitive Dust

Rule (n) requires facilities to take reasonable precautions to prevent fugitive dust from becoming airborne. WCP will continue to take the appropriate precautions to prevent fugitive dust from becoming airborne for any applicable equipment.

4.9.6 GRAQC 391-3-1-.02(2)(bb) – Petroleum Liquid Storage

Rule (bb) establishes requirements for storage tanks with a capacity greater than 40,000 gallons storing a petroleum liquid with a true vapor pressure greater than 1.52 pounds per square inch absolute (psia). As the ULSD has a true vapor pressure less than 1.52 psia, the new fuel oil storage tank is not subject to the requirements of Rule (bb).

4.9.7 GRAQC 391-3-1-.02(2)(nn) – VOC Emissions from External Floating Roof Tanks

Rule (nn) establishes requirements for external floating roof tanks storing petroleum liquids with a capacity greater than 40,000 gallons. As the proposed fuel oil storage tank is a fixed roof tank and not an external floating roof tank, Rule (nn) will not apply.

⁵¹ GRAQC 391-3-1-.02(2)(g)2

4.9.8 GRAQC 391-3-1-.02(2)(tt) – VOC Emissions from Major Sources

Rule (tt) limits VOC emissions from facilities that are located in or near the original Atlanta 1-hour ozone nonattainment area. WCP is not located within the geographic area covered by this rule and is, therefore, not subject to this regulation.⁵²

4.9.9 GRAQC 391-3-1-.02(2)(uu) – Visibility Protection

Rule (uu) requires EPD to provide an analysis of a proposed major source or a major modification to an existing source's anticipated impact on visibility in any federal Class I area to the appropriate Federal Land Manager (FLM). The visibility-impacting pollutants include NO_x, PM₁₀, SO₂, and H₂SO₄. A screening analysis of federal Class I areas resulted in a Q/d value less than 10. Therefore, a full review of the anticipated impact on visibility was not performed. Further documentation regarding an evaluation of impacts related to these projects on Class I areas, and further documentation referenced such as correspondence with the appropriate FLM, is provided in Volume II of this application.

4.9.10 GRAQC 391-3-1-.02(2)(vv) Volatile Organic Liquid Handling and Storage

Georgia Rule (vv) establishes a requirement for use of submerged fill pipes for transfer of volatile organic liquids into storage tanks for specific counties in the state. Washington county is not a listed county, therefore Rule (vv) does not apply to the proposed fuel oil storage tank.⁵³

4.9.11 GRAQC 391-3-1-.02(2)(yy) – Nitrogen Oxides from Major Sources

Rule (yy) limits NO_x emissions from facilities that are located in or near the original Atlanta 1-hour ozone nonattainment area. WCP is not located within the geographic area covered by this rule and is, therefore, not subject to this regulation.⁵⁴

4.9.12 GRAQC 391-3-1-.02(2)(jjj) – NO_x from Electric Utility Steam Generating Units

Rule (jjj) limits NO_x emissions from electric utility steam generating units located in or near the original Atlanta 1-hour ozone nonattainment area. WCP is not located within the geographic area covered by this rule.⁵⁵ Therefore, Rule (jjj) is not applicable.

4.9.13 GRAQC 391-3-1-.02(2)(III) – NO_x from Fuel-Burning Equipment

Rule (III) limits NO_x emissions from fuel-burning equipment with capacities between 10 and 250 MMBtu/hr that are located in or near the original Atlanta 1-hour ozone nonattainment area. WCP is not located within the geographic area covered by this rule and is, therefore, not subject to this regulation.⁵⁶

⁵² GRAQC 391-3-1-.02(2)(tt)3

⁵³ GRAQC 391-3-.02(2)(vv)1, 3

⁵⁴ GRAQC 391-3-1-.02(2)(yy)2

⁵⁵ GRAQC 391-3-1-.02(2)(jjj)8

⁵⁶ GRAQC 391-3-1-.02(2)(III)4

4.9.14 GRAQC 391-3-1-.02(2)(mmm) – NO_x Emissions from Stationary Gas Turbines and Stationary Engines used to Generate Electricity

Rule (mmm) restricts NO_x emissions from small combustion turbines located in or near the Atlanta nonattainment area that are used to generate electricity. WCP is located in Washington County, which is not one of the listed counties regulated under this rule.⁵⁷ Therefore, Rule (mmm) does not apply.

4.9.15 GRAQC 391-3-1-.02(2)(nnn) – NO_x Emissions from Large Stationary Gas Turbines

Additional restrictions apply to NO_x emissions from sources located in or near the original Atlanta 1-hour ozone nonattainment area. Specifically, these regulations limit NO_x emissions from stationary gas turbines used to generate electricity. WCP is located in Washington County, which is not one of the listed counties regulated under this rule.⁵⁸ Therefore, Rule (nnn) does not apply.

4.9.16 GRAQC 391-3-1-.02(2)(rrr) – NO_x from Small Fuel-Burning Equipment

Rule (rrr) specifies requirements for fuel-burning equipment with capacities of less than 10 MMBtu/hr located in or near the original Atlanta 1-hour ozone nonattainment area. WCP is not located within the geographic area covered by this rule, and is, therefore, not subject to this regulation.⁵⁹

4.9.17 GRAQC 391-3-1-.02(2)(sss) – Multipollutant Control for Electric Utility Steam Generating Units

Rule (sss) applies to certain large electric utility steam generating units listed within the rule. WCP is not subject to this regulation, because none of its units are listed in the regulation.

4.9.18 GRAQC 391-3-1-.02(2)(uuu) – SO₂ Emissions from Electric Utility Steam Generating Units

Rule (uuu) applies to certain large electric utility steam generating units listed within the rule. WCP is not subject to this regulation, because none of its units are listed in the regulation.

4.9.19 GRAQC 391-3-1-.02(12), (13), and (14) – Cross State Air Pollution Rules (Annual NO_x, Annual SO₂, and Ozone Season NO_x)

These regulations incorporate the Cross State Air Pollution Rule (CSAPR) requirements into the Georgia Rules for Air Quality Control. The regulations provide allocations for Georgia for 2017 and thereafter.

4.9.20 GRAQC 391-3-1-.03(1) – Construction (SIP) Permitting

The proposed projects will require physical construction activities to complete the proposed modifications. Potential emissions associated with the proposed projects are above the *de minimis* construction permitting thresholds specified in GRAQC 391-3-1-.03(6)(i).⁶⁰ Further, as discussed in Section 4.1, PSD permitting is

⁵⁷ GRAQC 391-3-1-.02(2)(mmm)6

⁵⁸ GRAQC 391-3-1-.02(2)(nnn)6

⁵⁹ GRAQC 391-3-1-.02(2)(rrr)2

⁶⁰ Based on Georgia EPD guidance, usage of the *de minimis* permitting exemption thresholds must consider actual-to-potential emissions increases, not actual-to-projected actual emissions increases.

required for multiple pollutants. Therefore, a construction permit application is necessary, and the appropriate forms are included in Appendix D.

4.9.21 GRAQC 391-3-1-.03(10) – Title V Operating Permits

The potential emissions of certain pollutants exceed the major source thresholds established by Georgia's Title V operating permit program. Therefore, WCP is a Title V major source. The facility currently operates under Permit No. 4911-303-0039-V-08-0. This application represents a significant modification to the existing Title V operating permit; accordingly, a GEOS application has been submitted to address Title V related permitting requirements.

4.9.22 Incorporation of Federal Regulations by Reference

The following federal regulations are incorporated in the GRAQC by reference and were addressed previously in the application:

- ▶ GRAQC 391-3-1-.02(7) – PSD
- ▶ GRAQC 391-3-1-.02(8) – NSPS
- ▶ GRAQC 391-3-1-.02(9) – NESHAP
- ▶ GRAQC 391-3-1-.02(10) – Chemical Accident Prevention
- ▶ GRAQC 391-3-1-.02(11) – CAM
- ▶ GRAQC 391-3-1-.02(12) – CSAPR for Annual NO_x
- ▶ GRAQC 391-3-1-.02(13) – CSAPR for Annual SO₂
- ▶ GRAQC 391-3-1-.02(14) – CSAPR for Ozone Season NO_x
- ▶ GRAQC 391-3-1-.13 – ARP

4.9.23 Non-Applicability of Other GRAQC

A thorough examination of the GRAQC applicability to the proposed projects reveals many GRAQC that do not currently apply, will not apply once the proposed modifications are complete, and do not impose additional requirements on operations. Such GRAQC rules include those specific to a particular type of industrial operation which is not and will not be performed at the Facility or is not impacted by the proposed projects.

5. BACT ANALYSIS

This section discusses the regulatory basis for BACT, the approach used in completing the BACT analyses, and the BACT analyses for the modified turbines and the new storage tank. Based on the BACT review, WCP proposes the technology and limits presented in Table 5-1 as BACT for the modified units.

Table 5-1. Summary of Proposed BACT Limits

Unit	Pollutant	Fuel	Selected BACT	Emission / Operating Limit	Compliance Method
Each Simple Cycle Combustion Turbine	NO _x	Natural Gas	DLN Combustors and Good Combustion and Operating Practices	9.0 ppmvd at 15% O ₂ on a 4-hour rolling average basis	CEM
		Fuel Oil	Water Injection and Good Combustion and Operating Practices	42.0 ppmvd at 15% O ₂ on a 4-hour rolling average basis	
		Both	Secondary BACT	152.7 tpy per rolling 12-months per turbine	
	Filterable PM/Total PM ₁₀ /Total PM _{2.5}	Natural Gas	Good Combustion and Operating Practices and Low Sulfur Fuels	24.2 lb/hr	Performance Test
		ULSD		26.8 lb/hr	
	CO	Natural Gas	Good Combustion and Operating Practices	9.0 ppmvd at 15% O ₂ on a 3-hour rolling average basis	Performance Test
		Fuel Oil		20.0 ppmvd at 15% O ₂ on a 3-hour rolling average basis	
		Both		Secondary BACT	
	VOC	Natural Gas	Good Combustion and Operating Practices	2.0 ppmvd at 15% O ₂	Performance Test
		Fuel Oil		5.0 ppmvd at 15% O ₂	
GHGs		Efficient Turbine Operation and Good Combustion, Operating, and Maintenance Practices	387,497 tpy CO ₂ e per rolling 12-months (each CCCT)	Records of Fuel Usage	
Fuel Oil Storage Tank	VOC	N/A	Submerged Fill Pipe, Light Colored Paint for Tank Shell, Good Maintenance Practices	N/A	

5.1 BACT Requirement

The BACT requirement applies to each new or modified emission unit from which there is an emissions increase of pollutants subject to PSD review. WCP has determined that the proposed project is subject to PSD permitting for filterable PM, total PM₁₀, total PM_{2.5}, NO_x, VOC, CO, and GHGs, and thus, is subject to BACT for these pollutants. A BACT review is required for each physically modified or newly constructed emission unit. Accordingly, a BACT analysis and detailed discussion of each pollutant subject to PSD

permitting is assessed herein for the simple-cycle combustion turbines and the new storage tank. No other units are being physically modified or constructed as part of the proposed project.

5.2 BACT Definition

The requirement to conduct a BACT analysis is set forth in the PSD regulations [40 CFR 52.21(j)(3)]:

(j) Control Technology Review.

(3) A major modification shall apply best available control technology for each regulated NSR pollutant for which it would result in a significant net emissions increase at the source. This requirement applies to each proposed emissions unit at which a net emissions increase in the pollutant would occur as a result of a physical change or change in the method of operation in the unit.

BACT is defined in the PSD regulations [40 CFR 52.21(b)(12)] as:

*... an **emissions limitation** (including a visible emission standard) based on the maximum degree of reduction for **each pollutant** subject to regulation under Act which would be emitted from any proposed major stationary source or major modification which the Administrator, on a **case-by-case basis**, taking into account energy, environmental, and economic impacts and other costs, determines is **achievable** for such source or modification through application of production processes or available methods, systems and techniques, including fuel cleaning or treatment or innovative fuel combustion techniques for control of such pollutant. **In no event shall application of best available control technology result in emissions of any pollutant which would exceed the emissions allowed by any applicable standard under 40 CFR 60 and 61.***

[primary BACT definition]

*If the Administrator determines that technological or economic limitations on the application of measurement methodology to a particular emissions unit would make the imposition of an emissions standard infeasible, a **design, equipment, work practice, operational standard, or combination thereof may be prescribed instead to satisfy the requirement for the application of best achievable control technology.** Such standard shall, to the degree possible, set forth the emissions reduction achievable by implementation of such design, equipment, work practice, or operation, and shall provide for compliance by means which achieve equivalent results.*

[allowance for secondary BACT standard under certain conditions]

The primary BACT definition can be best understood by breaking it apart into its separate components.

5.2.1 Emission Limitation

...an emissions limitation...

First and foremost, BACT is an emission limit. While BACT is predicated upon the application of technologies to achieve that limit, the final result of BACT is a limit. In general, when quantifiable and measurable, this limit would be expressed as an emission rate limit of a pollutant (e.g., lb/ton, ppm, lb/hr or lb/MMBtu).⁶¹

⁶¹ Emission limits can be broadly differentiated as “rate-based” or “mass-based.” For a boiler, a rate-based limit would typically be in units of lb/MMBtu (mass emissions per heat input). In contrast, a typical mass-based limit would be in units of lb/hr (mass emissions per time).

Furthermore, U.S. EPA's guidance on GHG BACT has indicated that GHG BACT limitations should be averaged over long-term timeframes such as 30- or 365-day rolling averages.⁶² It should be noted that the secondary BACT definition per 40 CFR 52.21(b)(12) identifies that in cases where the implementation of an emission limitation is deemed infeasible, a design, equipment, work practice, operational standard or combination of the same may be prescribed as a BACT standard.

5.2.2 Each Pollutant

...each pollutant subject to regulation under the Act which would be emitted from any proposed major stationary source or major modification...

BACT is analyzed for each pollutant, not a combination of pollutants, even where the technology reduces emissions of more than one pollutant. This is particularly important in performing costs analyses. While BACT emission limits for PM₁₀ and PM_{2.5} must include the condensable portion of particulate, most demonstrated control techniques are limited to those that reduce filterable particulate matter. As such, control techniques for filterable PM or PM₁₀ also reduce filterable PM_{2.5}. The PM BACT analyses for filterable PM and filterable PM₁₀ will also satisfy BACT for the filterable portion of PM_{2.5}. In the prepared BACT analyses, references to PM₁₀ are also relevant for PM_{2.5}. A potential source of secondary particulate matter from the proposed projects is due to NO_x emissions from the turbines. Any secondary PM BACT is effectively addressed by controlling the direct emissions of NO_x, which is addressed through the NO_x BACT analysis conducted for the turbines.

For PSD applicability assessments involving GHGs, the regulated NSR pollutant subject to regulation under the Clean Air Act is the sum of **six** greenhouse gases and not a single pollutant.⁶³ Though the primary GHG emissions from natural gas and fuel oil combustion at the combustion turbines are of carbon dioxide (CO₂), GHG BACT is discussed separately for the following additional GHG components: methane (CH₄) and nitrous oxide (N₂O).

5.2.3 Case-by-Case Basis

...a case-by-case basis, taking into account energy, environmental and economic impacts and other costs...

Unlike many of the Clean Air Act programs, the PSD program's BACT evaluation is case-by-case. As noted by U.S. EPA,

The case-by-case analysis is far more complex than merely pointing to a lower emissions limit or higher control efficiency elsewhere in a permit or a permit application. The BACT determination must take into account all of the factors affecting the facility, such as the choice of [fuel]... The BACT analysis, therefore, involves judgment and balancing.⁶⁴

⁶² PSD and Title V Permitting Guidance for Greenhouse Gases. March 2011, page 46.

⁶³ The six GHGs are: CO₂, N₂O, CH₄, hydrofluorocarbons (HFCs), perfluorocarbons (PFCs), and sulfur hexafluoride (SF₆).

⁶⁴ U.S. EPA Responses to Public Comments on the Proposed PSD Permit for the Desert Rock Energy Facility, July 31, 2008, pages 41-42.

The case-by-case analysis has also been affirmed by the U.S. EPA Environmental Appeals Board in an order denying review of the PSD permit for the La Paloma Energy Center.⁶⁵

As the Board explained in In re Northern Michigan University (“NMU”), the BACT definition requires permit issuers to “proceed[] on a case-by-case basis, taking a careful and detailed look, attentive to the technology or methods appropriate for the particular facility, [] to seek the result tailor-made for that facility and that pollutant. 14 E.A.D. 283, 291 (EAB 2009)

To assist applicants and regulators with the case-by-case process, in 1987 U.S. EPA issued a memorandum that implemented certain program initiatives to improve the effectiveness of the PSD program within the confines of existing regulations and state implementation plans.⁶⁶ Among the initiatives was a “top-down” approach for determining BACT. In brief, the top-down process suggests that all available control technologies be ranked in descending order of control effectiveness. The most stringent or “top” control option is the default BACT emission limit unless the applicant demonstrates, and the permitting authority in its informed opinion agrees, that energy, environmental, and/or economic impacts justify the conclusion that the most stringent control option is not achievable in that case. Upon elimination of the most stringent control option based upon energy, environmental, and/or economic considerations, the next most stringent alternative is evaluated in the same manner. This process continues until BACT is selected.

The five steps in a top-down BACT evaluation can be summarized as follows:

- Step 1. Identify all possible control technologies;
- Step 2. Eliminate technically infeasible options;
- Step 3. Rank the technically feasible control technologies based upon emission reduction potential;
- Step 4. Evaluate ranked controls based on energy, environmental, and/or economic considerations; and
- Step 5. Select BACT.

Each of these steps is discussed in detail in Section 5.4. While the top-down BACT analysis is a procedural approach suggested by U.S. EPA policy, this approach is not specifically mandated as a statutory requirement of the BACT determination. As discussed in Section 5.2.1, the BACT determination is an emissions limitation and does not require the installation of any specific control device.

5.2.4 Achievable

...based on the maximum degree of reduction ...[that Georgia EPD] ... determines is achievable ... through application of production processes or available methods, systems and techniques, including fuel cleaning or treatment or innovative fuel combustion techniques...

BACT is to be set at the lowest value that is achievable. However, there is an important distinction between emission rates achieved at a specific time on a specific unit, and an emission limitation that a unit must be able to meet continuously over its operating life.

⁶⁵ U.S. EPA Environmental Appeals Board decision, In re: La Paloma Energy Center L.L.C. PSD Appeal No. 13-10, decided March 14, 2014. Environmental Administrative Decisions, Volume 16, page 273.

⁶⁶ Memo dated December 1, 1987, from J. Craig Potter (EPA Headquarters) to EPA Regional Administrators, titled “Improving New Source Review Implementation.”

As discussed by the DC Circuit Court of Appeals,

In National Lime Ass'n v. EPA, 627 F.2d 416, 431 n.46 (D.C. Cir. 1980), we said that where a statute requires that a standard be "achievable," it must be achievable "under most adverse circumstances which can reasonably be expected to recur."⁶⁷

U.S. EPA has reached similar conclusions in prior determinations for PSD permits.

Agency guidance and our prior decisions recognize a distinction between, on the one hand, measured 'emissions rates,' which are necessarily data obtained from a particular facility at a specific time, and on the other hand, the 'emissions limitation' determined to be BACT and set forth in the permit, which the facility is required to continuously meet throughout the facility's life. Stated simply, if there is uncontrollable fluctuation or variability in the measured emission rate, then the lowest measured emission rate will necessarily be more stringent than the "emissions limitation" that is "achievable" for that pollution control method over the life of the facility. Accordingly, because the "emissions limitation" is applicable for the facility's life, it is wholly appropriate for the permit issuer to consider, as part of the BACT analysis, the extent to which the available data demonstrate whether the emissions rate at issue has been achieved by other facilities over a long term.⁶⁸

More recently, this issue was addressed for GHG BACT:⁶⁹

Efficiency standards may vary on a case-by-case basis to account for site variability (e.g., altitude) and other factors that could impact process efficiency. In addition, any system will "age" over time and achievable efficiencies may deteriorate. Section 169 contains multiple statutory factors that must be evaluated in determining the "maximum degree of reduction" on which BACT is based. Efficiency improvements in combination with some other control option could be listed as the maximum control, in which case the standard process limits would likely incorporate the effects of the more efficient design and a separate "efficiency" standard would not be necessary. Page B.16 of the 1990 Draft NSR Workshop Manual notes that "combinations of techniques should be considered to the extent they result in more effective means of achieving stringent emissions levels represented by the "top" alternative, particularly if the "top" alternative is eliminated."⁷⁰

This stance continues to be affirmed by the U.S. EPA Environmental Appeals Board in an order denying review of the PSD permit for the La Paloma Energy Center:⁷¹

"...the Board has recognized that permitting authorities are not always required to impose the highest possible level of control efficiency, but may take case-specific circumstances into consideration in determining what level of control is achievable for a given source. See In re Russell City Energy Ctr., 15 E.A.D. 1, 58-61 (EAB 2010) (rejecting a "bright line" test of requiring the

⁶⁷ As quoted in *Sierra Club v. U.S. EPA* (97-1686).

⁶⁸ U.S. EPA Environmental Appeals Board decision, *In re: Newmont Nevada Energy Investment L.L.C. PSD Appeal No. 05-04*, decided December 21, 2005. Environmental Administrative Decisions, Volume 12, page 442.

⁶⁹ Clean Air Act Advisory Committee (CAAAC) Climate Change Workgroup, *Report of Issue Group 2: Technical Feasibility* <https://www.epa.gov/caaac/climate-change-workgroup-reports-and-presentations>

⁷⁰ <https://www.epa.gov/sites/production/files/2015-07/documents/1990wman.pdf>

⁷¹ U.S. EPA Environmental Appeals Board decision, *In re: La Paloma Energy Center L.L.C. PSD Appeal No. 13-10*, decided March 14, 2014. Environmental Administrative Decisions, Volume 16, pages 280-281.

highest or average level of control that another source has achieved), petition denied sub nom. Chabot-Las Positas Cmty, Coll. Dist. V. EPA, 428 F. App'x 219 (9th Cir. 2012); In re Newmont Nev. Energy Inv., LLC, 12 E.A.D. 429, 441 (EAB 2005). ("We recently explained that '[t]he underlying principle of all of these cases is that PSD permit limits are not necessarily a direct translation of the lowest emissions rate that has been achieved by a particular technology at another facility, but that those limits must also reflect consideration of any practical difficulties associated with using the control technology." (citing In re Cardinal FG Co., 12 E.A.D. 153, 170 (EAB 2005)))

Thus, BACT must be set at the lowest feasible emission rate recognizing that the emission unit must be in compliance with that limit for the lifetime of the unit on a continuous basis. While viewing individual unit performance can be instructive in evaluating what BACT might be, any actual performance data must be viewed carefully, as rarely will the data be adequate to truly assess the performance that a unit will achieve during its entire operating life. While statistical variability of actual performance can be used to infer what is "achievable," such testing requires a detailed test plan akin to what teams in U.S. EPA use to develop MACT standards over a several year period, and is far beyond what is reasonable to expect of an individual source. In contrast to limited snapshots of actual performance data, emission limits from similar sources can reasonably be used to infer what is "achievable."⁷²

To assist in meeting the BACT limit, the source must consider production processes or available methods, systems or techniques, as long as those considerations do not redefine the source (see Section 5.5).

5.2.5 Floor

Emissions [shall not] exceed the emissions allowed by any applicable standard under 40 CFR 60 and 61.

The least stringent emission rate allowable for BACT is any applicable limit under either New Source Performance Standards (NSPS – Part 60) or National Emission Standards for Hazardous Air Pollutants (NESHAP – Parts 61 and 63).⁷³ State SIP limitations must also be considered when determining the floor. The modified combustion turbine systems are subject to NO_x and SO₂ emission limits under NSPS Subpart KKKK. The modified turbine systems are not subject to any NSPS or NESHAP standard for PM/PM₁₀/PM_{2.5} or GHGs and thus there is no floor of allowable filterable PM or total PM₁₀/PM_{2.5} or GHGs BACT limits.⁷⁴

5.3 BACT Assessment Methodology

The primary document referenced for the traditional "top-down" BACT methodology is U.S. EPA's 1990 *NSR Workshop Manual (Draft), Prevention of Significant Deterioration and Nonattainment New Source Review Permitting*.⁷⁵ U.S. EPA has issued the following guidance documents related to the completion of GHG BACT analyses, which also have relevance to other NSR pollutants. These documents were utilized as resources in completing the BACT evaluation for the proposed projects:

⁷² Emission limits must be used with care in assessing what is "achievable." Limits established for facilities which were never built must be viewed with care, as they have never been demonstrated and that company never took a significant liability in having to meet that limit. Likewise, permitted units which have not yet commenced construction must also be viewed with special care for similar reasons.

⁷³ While not specified as the BACT floor, NESHAP under 40 CFR 63 sometimes regulate NSR pollutants as a surrogate for non-NSR pollutants.

⁷⁴ As discussed in Section 4.3.11, NSPS Subpart TTTT does not regulate modified combustion turbine systems.

⁷⁵ U.S. EPA, October 1990. <https://www.epa.gov/sites/production/files/2015-07/documents/1990wman.pdf>.

- ▶ PSD and Title V Permitting Guidance For Greenhouse Gases⁷⁶
- ▶ Air Permitting Streamlining Techniques and Approaches for Greenhouse Gases: A Report to the U.S. Environmental Protection Agency from the Clean Air Act Advisory Committee; Permits, New Source Reviews and Toxics Subcommittee GHG Permit Streamlining Workgroup; Final Report⁷⁷
- ▶ 2010 Group Reports from the Clean Air Act Advisory Committee, Climate Change Work Group⁷⁸

5.4 BACT “Top-Down” Approach

The following sections present the top-down BACT analysis for each pollutant for which these projects trigger PSD and is specific to each emission unit, unless otherwise specified. The five steps in such an evaluation can be summarized as follows:⁷⁹

- ▶ **Step 1.** Identify all possible control technologies;
- ▶ **Step 2.** Eliminate technically infeasible control options;
- ▶ **Step 3.** Rank the technically feasible control technologies based upon emission reduction potential;
- ▶ **Step 4.** Evaluate ranked control technologies based on energy, environmental, and/or economic considerations; and
- ▶ **Step 5.** Select BACT.

This process is typically conducted on a unit-by-unit, pollutant-by-pollutant basis. While the top-down BACT analysis is a procedural approach suggested by U.S. EPA policy, this approach is not specifically mandated as a statutory requirement of the BACT determination. BACT for the proposed projects has been evaluated via this “top-down” approach.

5.4.1 Identification of Potential Control Technologies (Step 1)

Available control technologies with the practical potential for application to the emission unit are identified. The application of demonstrated control technologies in other similar source categories to the emission unit in question can also be considered. While identified technologies may be eliminated in subsequent steps in the analysis based on technical and economic infeasibility or environmental, energy, economic or other impacts, control technologies with potential application to the emission unit under review are identified in this step. Under Step 1 of a criteria pollutant BACT analysis, the following resources are typically consulted when identifying potential technologies:

1. U.S. EPA’s RBLC database.
2. Determinations of BACT by regulatory agencies for other similar sources or air permits and permit files from federal or state agencies.
3. Engineering experience with similar control applications.

⁷⁶ U.S. EPA, Office of Air and Radiation, Office of Air Quality Planning and Standards, (Research Triangle Park, NC: March 2011). <https://www.epa.gov/sites/production/files/2015-07/documents/ghgguid.pdf>.

⁷⁷ U.S. EPA, September 2012. <https://www.epa.gov/sites/production/files/2014-08/documents/ghg-permit-streamlining-final-report.pdf>.

⁷⁸ <https://www.epa.gov/caaac/climate-change-workgroup-reports-and-presentations>.

⁷⁹ This five step process can be directly applied to GHGs without any significant modifications, per *PSD and Title V Permitting Guidance for Greenhouse Gases*.

4. Information provided by air pollution control equipment vendors with significant market share in the industry.
5. Review of literature from industrial technical or trade organizations.

Trinity Consultants reviewed recently issued air permits and permit files and performed searches of the RBLC database in November 2020 to identify the emission control technologies and emission levels that were determined by permitting authorities as BACT within the past ten years for emission sources comparable to the proposed project. To ensure that the units being reviewed were comparable in size to the turbine units proposed for modification at the WCP facility, only turbine units with potential generating capacities larger than 100 MW were considered.⁸⁰ For combustion turbines, the following categories were searched:⁸¹

- ▶ Permit Data between 1/1/2010 and 11/12/2020
- ▶ Process Types⁸²
 - 15.110 Large Natural Gas Simple Cycle Combustion Turbines
 - 15.190 Large Liquid Fuel Simple Cycle Combustion Turbines
 - 15.210 Large Natural Gas Combined Cycle Combustion Turbines
 - 15.290 Large Liquid Fuel Combined Cycle Combustion Turbines
 - 15.900 Large Unknown Fuel and/or Cycle Combustion Turbines
 - 16.110 Small Natural Gas Simple Cycle Combustion Turbines
 - 16.190 Small Liquid Fuel Simple Cycle Combustion Turbines
 - 16.210 Small Natural Gas Combined Cycle Combustion Turbines
 - 16.290 Small Liquid Fuel Combined Cycle Combustion Turbines
 - 16.900 Small Unknown Fuel and/or Cycle Combustion Turbines
 - 19.700 Miscellaneous Combustion Turbines
- ▶ Process Pollutants: NO_x, PM/PM₁₀/PM_{2.5}, CO, VOC, and GHG, including CO₂, CH₄ and N₂O
- ▶ Results are for USA only.

Appendix C presents summary tables of relevant BACT determinations for the proposed emission units.

5.4.2 Elimination of Technically Infeasible Control Options (Step 2)

After the available control technologies have been identified, each technology is evaluated with respect to its technical feasibility in controlling emissions from the source in question. The first question in determining whether or not a technology is feasible is whether or not it is demonstrated. If so, it is feasible. Whether or not a control technology is demonstrated is considered to be a relatively straightforward determination.

⁸⁰ Conservatively ignoring combustion efficiency losses, a 100 MW unit would be the equivalent of 341 MMBtu/hr. This size unit was chosen as a benchmark as it is a size range for which transition from aeroderivative to large frame units generally occur, although there can be aeroderivative units greater than 100 MW.

⁸¹ The proposed combustion turbine system modifications are for simple-cycle combustion turbines. RBLC searches were performed for simple-cycle combustion turbines as well as combined cycle for completeness.

⁸² Upon review of records from the RBLC database, certain determinations were made regarding the entries as appropriate. For instance, many entries designated as 15.110 Simple Cycle Combustion Turbines were actually Combined Cycle Combustion Turbines or vice versa. In cases where a clear determination could be made based on the project description or other details provided, the correct details were noted and utilized to include or exclude potentially applicable turbines in the final RBLC review tables. Note also that units combusting fuels in addition to natural gas and fuel oil (such as biomass or ethanol blends) have been removed from the summary list.

5.4.2.1 *Demonstrated Technology*

Demonstrated means that it has been installed and operated successfully elsewhere on a similar facility. If the control technology has been installed and operated successfully on the type of source under review, it is demonstrated and it is technically feasible.⁸³

5.4.2.2 *Emerging and Undemonstrated Technology*

An undemonstrated technology is only technically feasible if it is "available" and "applicable." A control technology or process is only considered available if it has reached the licensing and commercial sales phase of development and is "commercially available."⁸⁴ Control technologies in the R&D and pilot scale phases are not considered available. Based on U.S. EPA guidance, an available control technology is presumed to be applicable if it has been permitted or actually implemented by a similar source. Decisions about technical feasibility of a control option consider the physical or chemical properties of the emissions stream in comparison to emissions streams from similar sources successfully implementing the control alternative. The NSR Manual explains the concept of applicability as follows: "An available technology is "applicable" if it can reasonably be installed and operated on the source type under consideration."⁸⁵ Applicability of a technology is determined by technical judgment and consideration of the use of the technology on similar sources as described in the NSR Manual.

5.4.3 **Rank of Remaining Control Technologies (Step 3)**

All remaining technically feasible control options are ranked based on their overall control effectiveness for the pollutant of interest. For GHGs, this ranking may be based on energy efficiency and/or emission rate.

5.4.4 **Evaluation of Most Stringent Control Technologies (Step 4)**

After identifying and ranking available and technically feasible control technologies, the economic, environmental, and energy impacts are evaluated to select the best control option. If adverse collateral impacts do not disqualify the top-ranked option from consideration it is selected as the basis for the BACT limit. Alternatively, in the judgment of the permitting agency, if unreasonable adverse economic, environmental, or energy impacts are associated with the top control option, the next most stringent option is evaluated. This process continues until a control technology is identified.

If necessary, economic analyses compare total costs (capital and annual) for potential control technologies. Capital costs include the initial cost of the components intrinsic to the complete control system. Annual operating costs include the financial requirements to operate the control system on an annual basis and include overhead, maintenance, outages, raw materials, and utilities.

The capital cost estimating technique used is based on a factored method of determining direct and indirect installation costs. That is, installation costs are expressed as a function of known equipment costs. This

⁸³ NSR Workshop Manual (Draft), Prevention of Significant Deterioration and Nonattainment New Source Review Permitting, page B.17.

⁸⁴ NSR Workshop Manual (Draft), Prevention of Significant Deterioration and Nonattainment New Source Review Permitting, page B.18.

⁸⁵ NSR Workshop Manual (Draft), Prevention of Significant Deterioration and Nonattainment New Source Review Permitting, page B.18.

method is consistent with the latest U.S. EPA OAQPS guidance manual on estimating control technology costs.⁸⁶

Total Purchased Equipment Cost represents the delivered cost of the control equipment, auxiliary equipment, and instrumentation. Auxiliary equipment consists of all the structural, mechanical, and electrical components required for the efficient operation of the device. Auxiliary equipment costs are estimated as a straight percentage of the equipment cost. Direct installation costs consist of the direct expenditures for materials and labor for site preparation, foundations, structural steel, erection, piping, electrical, painting and facilities. Indirect installation costs include engineering and supervision of contractors, construction and field expenses, construction fees, and contingencies. Other indirect costs include equipment startup, performance testing, working capital, and interest during construction.

Annual costs are comprised of direct and indirect operating costs. Direct annual costs include labor, maintenance, replacement parts, raw materials, utilities, and waste disposal. Indirect operating costs include plant overhead, taxes, insurance, general administration, and capital charges. Replacement part costs, such as the cost of a replacement catalyst, were included where applicable, while raw material costs were estimated based upon the unit cost and annual consumption. With the exception of overhead, indirect operating costs were calculated as a percentage of the total capital costs. The indirect capital costs were based on the capital recovery factor (CRF) defined as:

$$CRF = \frac{i(1+i)^n}{(1+i)^n - 1}$$

where *i* is the annual interest rate and *n* is the equipment life in years.

The equipment life is based on the normal life of the control equipment and varies on an equipment type basis. The same interest applies to all control equipment cost calculations. For required analyses, an interest rate of 7% was used based on information provided in the most recent OAQPS Control Cost Manual.⁸⁷

5.4.5 Selection of BACT (Step 5)

In the final step, the BACT emission limit is determined for each emission unit under review based on evaluations from the previous step.

Although the first four steps of the top-down BACT process involve technical and economic evaluations of potential control options (i.e., defining the appropriate technology), the selection of BACT in the fifth step involves an evaluation of emission rates achievable with the selected control technology. BACT is an emission limit unless technological or economic limitations of the measurement methodology would make the imposition of an emissions standard infeasible, in which case a work practice or operating standard can be imposed.

⁸⁶ U.S. EPA, *OAQPS Control Cost Manual*, 6th edition, EPA 452/B-02-001, July 2002. http://www.epa.gov/ttn/catc/dir1/c_allchs.pdf Note that updated sections of the manual relate to NO_x control costs and are not utilized herein. For more details on the updating of the control cost manual see <https://www.epa.gov/economic-and-cost-analysis-air-pollution-regulations/cost-reports-and-guidance-air-pollution>

⁸⁷ U.S. EPA, *OAQPS Control Cost Manual*, 6th edition, Section 2, Chapter 1, page 1-52. <https://www.epa.gov/economic-and-cost-analysis-air-pollution-regulations/cost-reports-and-guidance-air-pollution>

5.5 Defining the Source

To assist in meeting the BACT limit, the source must consider production processes or available methods, systems or techniques, as long as those considerations do not redefine the source. Historical practice, as well as recent court rulings, have been clear that a key foundation of the BACT process is that BACT applies to the type of source proposed by the applicant, and that options that would fundamentally redefine the nature of the source is not appropriate in a BACT determination.

Though BACT is based on the type of source as proposed by the applicant, the scope of the applicant's ability to define the source is not absolute. As U.S. EPA notes, a key task for the reviewing agency is to determine which parts of the proposed process are inherent to the applicant's purpose and which parts may be changed without changing that purpose. As discussed by U.S. EPA in an opinion on the Prairie State project,

We find it significant that all parties here, including Petitioners, agree that Congress intended the permit applicant to have the prerogative to define certain aspects of the proposed facility that may not be redesigned through application of BACT and that other aspects must remain open to redesign through application of BACT.⁸⁸

...

When the Administrator first developed [U.S. EPA's policy against redefining the source] in Pennsauken, the Administrator concluded that permit conditions defining the emissions control systems "are imposed on the source as the applicant has defined it" and that "the source itself is not a condition of the permit."⁸⁹

Given that some parts of the project are not open for review under BACT, U.S. EPA then discusses that it is the permit reviewer's burden to define the boundary. Based on precedent set in multiple prior U.S. EPA rulings (e.g., Pennsauken County Resource Recovery [1988], Old Dominion Electric Coop [1992], Spokane Regional Waste to Energy [1989], U.S. EPA states the following in Prairie State:

For these reasons, we conclude that the permit issuer appropriately looks to how the applicant, in proposing the facility, defines the goals, objectives, purpose, or basic design for the proposed facility. Thus, the permit issuer must be mindful that BACT, in most cases, should not be applied to regulate the applicant's objective or purpose for the proposed facility, and therefore, the permit issuer must discern which design elements are inherent to that purpose, articulated for reasons independent of air quality permitting, and which design elements may be changed to achieve pollutant emissions reductions without disrupting the applicant's basic business purpose for the proposed facility.⁹⁰

⁸⁸ EPA Environmental Appeals Board decision, *In re: Prairie State Generating Company*. PSD Appeal No. 05-05, decided August 24, 2006, page 26.

⁸⁹ EPA Environmental Appeals Board decision, *In re: Prairie State Generating Company*. PSD Appeal No. 05-05, decided August 24, 2006, page 29.

⁹⁰ EPA Environmental Appeals Board decision, *In re: Prairie State Generating Company*. PSD Appeal No. 05-05, decided August 24, 2006, Page 30. See also EPA Environmental Appeals Board decision, *In re: Desert Rock Energy Company LLC*. PSD Appeal Nos. 08-03, 08-04, 08-05 & 08-06, decided Sept. 24, 2009, page 64 ("The Board articulated the proper test to be used to [assess whether a technology redefines the source] in *Prairie State*.").

U.S. EPA's opinion in *Prairie State* was upheld on appeal to the Seventh Circuit Court of Appeals, where the court affirmed the substantial deference due the permitting authority on defining the demarcation point.⁹¹

Taken as a whole, the permitting agency is tasked with determining which controls are appropriate, but the discretion of the agency does not extend to a point requiring the applicant to redefine the source.

WCP presently operates four simple-cycle natural gas combustion turbines. WCP is proposing the addition of fuel oil combustion capability for these existing turbines to enhance fuel resiliency given increased reliance within the utilities and industrial sectors on natural gas for energy generation. This project requires physical modifications to each of the four turbines and installation of fuel oil storage capacity. WCP is requesting permit conditions limiting natural gas firing from the group of four turbines to 12,000 hr/yr and fuel oil combustion to 2,000 hr/yr. The proposed fuel oil storage capacity on-site could be as much as a 2.5 million gallon vertical fixed-roof storage tank. WCP proposes to continue operating the existing Dry Low NO_x burners on the turbines during gas combustion and proposes to install and operate a water-injection system during fuel oil combustion.

During gas combustion at 100% operating load, the estimated heat input capacity is estimated to be 1,766 Million British Thermal Units per hour (MMBtu/hr) for each turbine, whereas during fuel oil combustion at 100% operating load, the heat input capacity is estimated to be 1,890 MMBtu/hr for each turbine. Collectively, the four turbines will continue to maintain a 680-MW capacity for the site. WCP does not plan to expand overall short-term generating capacity. However, the annual generation (MW-hr) may increase due to both the addition of fuel oil operating capacity and additional run-time capacity on natural gas. WCP will continue to operate as a peaking facility, although operational hours are expected to increase from current levels following these changes.

The BACT selections are based on these design constraints, and any potential control methods that would require OPC to redefine these sources has been explained as such, and were not considered further.

5.6 Combustion Turbines NO_x Assessment

This section contains a review of pollutant formation, possible control technologies, and the ranking and selection of such controls with associated emission limits, for proposed BACT on NO_x emissions from each combustion turbine. The following sections contain details on the "top down" BACT review, as well as the control technology and emission limits that are selected as BACT for NO_x.

5.6.1 NO_x Formation – Combustion Turbines

There are five (5) primary pathways of NO_x production from turbine combustion processes: thermal NO_x, prompt NO_x, NO_x from N₂O intermediate reactions, fuel NO_x, and NO_x formed through reburning. The three most important mechanisms are thermal NO_x, prompt NO_x, and fuel NO_x.⁹² For natural gas-fired units, most NO_x is derived from thermal NO_x. Distillate oils also have low levels of fuel-bound nitrogen (N₂) that contribute to NO_x formation.

⁹¹ *Sierra Club v. EPA and Prairie State Generating Company LLC*, Seventh Circuit Court of Appeals, No. 06-3907, August 24, 2007. Rehearing denied October 11, 2007.

⁹² AP-42, Chapter 1, Section 4, *Natural Gas Combustion*, July 1998, and AP-42, Chapter 3, Section 1, *Stationary Gas Turbines*, April 2000.

Thermal NO_x is formed mainly via the Zeldovich mechanism where the N₂ and oxygen (O₂) molecules in the combustion air react to form nitrogen monoxide (NO).⁹³ Most thermal NO_x is formed in high temperature flame pockets downstream from the fuel injectors.⁹⁴ Temperature is the most important factor, and at combustion temperatures above 2,370°F, thermal NO_x is formed readily.⁹⁵ Therefore, reducing combustion temperature is a common approach to reducing NO_x emissions.

Prompt NO_x, a form of thermal NO_x, is formed in the proximity of the flame front as intermediate combustion products such as hydrogen cyanide (HCN), N, and NH are oxidized to form NO_x.⁹⁶ The contribution of prompt NO_x to overall NO_x is relatively small but increases in low-NO_x combustor designs. Prompt NO_x formation is also largely insensitive to changes in temperature and pressure.⁹⁷

Fuel NO_x forms when fuels containing nitrogen are burned. When these fuels are burned, the nitrogen bonds break and some of the resulting free nitrogen oxidizes to form NO_x. With excess air, the degree of fuel NO_x formation is primarily a function of the nitrogen content of the fuel. Therefore, since natural gas contains little fuel bound nitrogen, fuel NO_x is not a major contributor to NO_x emissions from natural gas-fired combustion turbines.⁹⁸ Most distillate oils have nitrogen content less than 0.015 percent by weight, resulting in more fuel NO_x generation than natural gas.⁹⁹

In general, technology and emissions performance data could be limited to those turbines within the size range of typical simple-cycle units, and specifically those size of turbines in operation at WCP. U.S. EPA has, in support of federal regulations such as the NSPS for combustion turbines (NSPS Subpart KKKK), reviewed the NO_x emissions performance data for combustion turbines of all sizes and found differing performance data for turbines based on the size of the unit. As quoted by U.S. EPA, per 70 FR 8318 (2/18/05):

We identified a distinct difference in the technologies and capabilities between small and large turbines.... the smaller combustion chamber of small turbines provides inadequate space for the adequate mixing needed for very low NO_x emission levels.

U.S. EPA finalized NSPS Subpart KKKK with a breakpoint in consideration of turbine sizes greater than 850 MMBtu/hr, between 50 MMBtu/hr and 850 MMBtu/hr, and less than 50 MMBtu/hr. Since the WCP units are above the 850 MMBtu/hr size range, only units greater than 850 MMBtu/hr are truly comparable, since as identified by U.S. EPA, there are inherent design differences in units at that size and above that can lead

⁹³ U.S. EPA, Emission Standards Division, *Alternative Control Techniques Document - NO_x Emissions from Stationary Gas Turbines*, EPA-453/R-93-007. January 1993.

⁹⁴ AP-42, Chapter 1, Section 4, *Natural Gas Combustion*, July 1998, and AP-42, Chapter 3, Section 1, *Stationary Gas Turbines*, April 2000.

⁹⁵ U.S. EPA, Clean Air Technology Center, *Technical Bulletin: Nitrogen Oxides (NO_x), Why and How They are Controlled*, EPA 456/F-99-006R. November 1999.

⁹⁶ U.S. EPA, Emission Standards Division, *Alternative Control Techniques Document - NO_x Emissions from Stationary Gas Turbines*, EPA-453/R-93-007. January 1993.

⁹⁷ U.S. EPA, Emission Standards Division, *Alternative Control Techniques Document - NO_x Emissions from Stationary Gas Turbines*, EPA-453/R-93-007. January 1993.

⁹⁸ U.S. EPA, Emission Standards Division, *Alternative Control Techniques Document - NO_x Emissions from Stationary Gas Turbines*, EPA-453/R-93-007. January 1993.

⁹⁹ U.S. EPA, Emission Standards Division, *Alternative Control Techniques Document - NO_x Emissions from Stationary Gas Turbines*, EPA-453/R-93-007. January 1993.

to inherently lower NO_x emission levels. Therefore, the RBLC review was limited to units of comparable size. For conservatism, WCP focused on units of approximately 100 Megawatts (MW) in size or greater.¹⁰⁰

NO_x emissions are a potential contributor to secondary particulate formation. Since OPC is conducting a top-down BACT analysis for NO_x for the proposed projects, secondary PM BACT is effectively addressed by reducing the direct emissions of NO_x. As such, secondary PM BACT is not separately addressed.

5.6.2 Identification of NO_x Control Technologies – Combustion Turbines (Step 1)

NO_x reduction can be accomplished by two general methodologies: combustion control techniques and post-combustion control methods. Combustion control techniques incorporate fuel or air staging that affect the kinetics of NO_x formation (reducing peak flame temperature) or introduce inerts (combustion products, for example) that limit initial NO_x formation, or both. Several post-combustion NO_x control technologies could potentially be employed for the WCP turbines. These technologies use various strategies to chemically reduce NO_x to N₂ with or without the use of a catalyst.

Detailed tables of BACT determinations from the RBLC database are provided in Appendix C. Using the RBLC search, as well as a review of technical literature, potentially applicable NO_x control technologies for turbines were identified based on the principles of control technology and engineering experience for general combustion units.

Combustion control options include:¹⁰¹

- ▶ Water or Steam Injection
- ▶ Dry Low-NO_x (DLN) Combustion Technology (such as SoLoNO_xTM)
- ▶ Good Combustion Practices (Base Case)

Post-combustion control options include:

- ▶ EM_xTM/SCONO_xTM Technology
- ▶ Selective Catalytic Reduction (SCR)
- ▶ SCR with Ammonia Oxidation Catalyst (Zero-SlipTM)
- ▶ Selective Non-Catalytic Reduction (SNCR)
- ▶ Multi-Function Catalyst (METEORTM)

Each control technology is described in detail in the following sections.

5.6.2.1 Water or Steam Injection

Water or steam injection operates by introducing water or steam into the flame area of the gas turbine combustor. The injected fluid provides a heat sink that absorbs some of the heat of combustion, thereby reducing the peak flame temperature and reducing the formation of thermal NO_x. The water injected into the turbine must be of high purity such that no dissolved solids are injected into the turbine. Dissolved

¹⁰⁰ Conservatively ignoring combustion efficiency losses, a 100 MW unit would be the equivalent of 341 MMBtu/hr.

¹⁰¹ An additional combustion control technology potentially identified was XONON which was offered by Catalytica Energy Systems. Catalytica merged with NZ Legacy in 2007 to form Renergy Holdings Inc. In November 2007, Renergy sold its SCR catalyst and management services business (SCR-Tech, LLC). SCR-Tech, LLC was acquired by Steag Energy Services, LLC in 2016. Based on research, there is no company which currently makes XONON. As such, it is not considered available for this BACT analysis.

solids in the water may damage the turbine due to erosion and/or the formation of deposits in the hot section of the turbine. Although water/steam injection can reduce NO_x emissions by over 60%, the lower average temperature within the combustor may produce higher levels of CO and VOC as a result of incomplete combustion.¹⁰² Additionally, water/steam injection results in a decrease in combustion efficiency, an increase in power (due to increased mass flow), and an increase in maintenance requirements due to wear.¹⁰³

5.6.2.2 Dry Low-NO_x (DLN) Combustors

The lean premix technology, also referred to as dry low-NO_x combustion technology, is a pollution prevention technology that minimizes NO_x emissions by reducing the conversion of atmospheric nitrogen to NO_x in the turbine combustor. This is accomplished by reducing the combustor temperature using lean mixtures of air and/or fuel staging or by decreasing the residence time of the combustor.¹⁰⁴ In lean combustion systems, excess air is introduced into the combustion zone to produce a significantly leaner fuel/air mixture than is required for complete combustion. This excess air decreases the overall flame temperature because a portion of the energy released from the fuel must be used to heat the excess air to the reaction temperature. Pre-mixing the fuel and air prior to introduction into the combustion zone provides a uniform fuel/air mixture and prevents localized high temperature regions within the combustor area.¹⁰⁵ Since NO_x formation rates are an exponential function of temperature, a considerable reduction in NO_x can be achieved by the lean pre-mix system.¹⁰⁶ Depending on the manufacturer and product, different levels of control efficiencies can be achieved.

5.6.2.3 Good Combustion Practices

Good combustion practices are those, in the absence of control technology, which allow the equipment to operate as efficiently as possible. The operating parameters most likely to affect NO_x emissions include ambient temperature, fuel characteristics, and air-to-fuel ratios.

5.6.2.4 EM_xTM/SCONO_x

EM_xTM (the second-generation of the SCONO_x NO_x Absorber Technology) is a multi-pollutant control technology that utilizes a coated oxidation catalyst to remove both NO_x and CO without a reagent, such as ammonia (NH₃). The SCONO_x system consists of a platinum-based catalyst coated with potassium carbonate [K₂(CO₃)] to oxidize NO_x (to potassium nitrate [K(NO₃)]) and CO (to CO₂).¹⁰⁷ Hydrogen (H₂) is then used as the basis for the catalyst regeneration process where K(NO₃) is reacted to reform the K₂(CO₃)

¹⁰² AP-42, Chapter 1, Section 4, *Natural Gas Combustion*, July 1998, and AP-42, Chapter 3, Section 1, *Stationary Gas Turbines*, April 2000.

¹⁰³ AP-42, Chapter 1, Section 4, *Natural Gas Combustion*, July 1998, and AP-42, Chapter 3, Section 1, *Stationary Gas Turbines*, April 2000.

¹⁰⁴ AP-42, Chapter 1, Section 4, *Natural Gas Combustion*, July 1998, and AP-42, Chapter 3, Section 1, *Stationary Gas Turbines*, April 2000.

¹⁰⁵ AP-42, Chapter 1, Section 4, *Natural Gas Combustion*, July 1998, and AP-42, Chapter 3, Section 1, *Stationary Gas Turbines*, April 2000.

¹⁰⁶ AP-42, Chapter 1, Section 4, *Natural Gas Combustion*, July 1998, and AP-42, Chapter 3, Section 1, *Stationary Gas Turbines*, April 2000.

¹⁰⁷ Georgia EPD, *Prevention of Significant Air Quality Deterioration Review Preliminary Determination – Dahlberg Combustion Turbine Electric Generating Facility*, October 2009.


https://epd.georgia.gov/air/sites/epd.georgia.gov.air/files/related_files/document/1570034pd.pdf

catalyst and release nitrogen gas and water.¹⁰⁸ The catalyst is installed in the flue gas with a temperature range between 300°F to 700°F. The SCONO_x catalyst is susceptible to fouling by sulfur if the sulfur content of the flue gas is high.¹⁰⁹

Estimates of control efficiency for a SCONO_x system vary depending on the pollutant controlled. California Energy Commission reports a control efficiency of 78% for NO_x reductions down to 2.0 ppm, and even higher NO_x reductions down to 1 ppm for some designs.¹¹⁰

5.6.2.5 Selective Catalytic Reduction (SCR)

SCR is a post-combustion gas treatment process in which NH₃ is injected into the exhaust gas upstream of a catalyst bed. On the catalyst surface, NH₃ and NO react to form diatomic N₂ and H₂O vapor. The overall chemical reaction can be expressed as:



When operated within the optimum temperature range, the reaction can result in removal efficiencies between 70 and 90 percent.¹¹¹ Optimal temperatures for SCR units ranges from 480°F to 800°F and typical SCR systems have the ability to function effectively under temperature fluctuations of up to 200°F.¹¹² SCR can be used to reduce NO_x emissions from combustion of natural gas and light oils (e.g., distillate). Combustion of heavier oils can produce high levels of particulate, which may foul the catalyst surface, reducing the NO_x removal efficiency.¹¹³ Other considerations include the possibility for ammonia slip, which refers to emissions of unreacted ammonia escaping with the flue gas and its contribution to secondary particulate formation.¹¹⁴

5.6.2.6 SCR with Ammonia Oxidation Catalyst (Zero-Slip™)

SCR with Ammonia Oxidation Catalyst (Zero-Slip™) is a refinement on standard post-combustion SCR technology developed by Cormetech and Mitsubishi Power Systems to reduce ammonia slip associated with traditional SCR systems. The Zero-Slip™ technology consists of a second bed of catalyst that is installed

¹⁰⁸ Georgia EPD, *Prevention of Significant Air Quality Deterioration Review Preliminary Determination – Dahlberg Combustion Turbine Electric Generating Facility*, October 2009.

https://epd.georgia.gov/air/sites/epd.georgia.gov.air/files/related_files/document/1570034pd.pdf

¹⁰⁹ California Energy Commission, *Evaluation of Best Available Control Technology*, Appendix 8.1E, pages 8.1E-9 and 8.1E-10.

¹¹⁰ California Energy Commission, *Evaluation of Best Available Control Technology*, Appendix 8.1E, page 8.1E-6.

¹¹¹ U.S. EPA, Clean Air Technology Center, *Air Pollution Control Technology Fact Sheet: Selective Catalytic Reduction (SCR)*, EPA-452/F-03-032.

¹¹² U.S. EPA, Clean Air Technology Center, *Air Pollution Control Technology Fact Sheet: Selective Catalytic Reduction (SCR)*, EPA-452/F-03-032.


¹¹³ U.S. EPA, Clean Air Technology Center, *Air Pollution Control Technology Fact Sheet: Selective Catalytic Reduction (SCR)*, EPA-452/F-03-032.

¹¹⁴ U.S. EPA, Clean Air Technology Center, *Air Pollution Control Technology Fact Sheet: Selective Catalytic Reduction (SCR)*, EPA-452/F-03-032.)

after the main SCR catalyst to further react NO_x with the ammonia. This results in NO_x emissions on par with standard SCR systems and less ammonia slip (less than 2.0 ppmvd at 15% O₂).¹¹⁵

5.6.2.7 Selective Non-Catalytic Reduction (SNCR)

SNCR is a post-combustion NO_x control technology based on the reaction of urea or ammonia with NO_x. In the SNCR chemical reaction, urea [CO(NH₂)₂] or ammonia is injected into the combustion gas path to reduce the NO_x to nitrogen and water. The overall reaction schemes for both urea and ammonia systems can be expressed as follows:



Typical removal efficiencies for SNCR range from 30 to 50 percent and higher when coupled with combustion controls.¹¹⁶ An important consideration for implementing SNCR is the operating temperature range. The optimum temperature range is approximately 1,600 to 2,000°F.¹¹⁷ Operation at temperatures below this range results in ammonia slip. Operation above this range results in oxidation of ammonia, forming additional NO_x.

5.6.2.8 Multi-Function Catalyst (METEOR™)

METEOR™ is a multi-pollutant post-combustion control technology originally developed and patented by Siemens Energy Inc., and optimized by Cormetech. The METEOR™ catalyst uses ammonia, similar to standard SCR systems, to reduce NO_x emissions but is also able to reduce CO, VOC, and ammonia emissions using a single catalyst bed (i.e., eliminate the need for a separate oxidation catalyst system if CO and VOC reductions are required), resulting in reduced pressure drop and parasitic load requirements.¹¹⁸ The ability of the METEOR™ catalyst to reduce NO_x emissions is on par with more traditional SCR designs.¹¹⁹

5.6.3 Elimination of Technically Infeasible NO_x Control Options – Combustion Turbines (Step 2)

After the identification of potential control options, the second step in the BACT assessment is to eliminate technically infeasible options. A control option is eliminated from consideration if there are process-specific conditions that would prohibit the implementation of the control, if a control technology has not been commercially demonstrated to be achievable, or if the highest control efficiency of the option would result in an emission level that is higher than any applicable regulatory limits.

¹¹⁵ Application No. 17040013, *Project Summary for a Construction Permit Application from Jackson Generation, LLC, for an Electrical Generating Facility in Elwood, Illinois*, issued by the Illinois EPA for the public comment period beginning on September 21, 2018. Discussion related to selection of BACT for emissions of NO_x, Attachment B pages 13-14.

¹¹⁶ U.S. EPA, Clean Air Technology Center, Air Pollution Control Technology Fact Sheet: Selective Non-Catalytic Reduction (SNCR), EPA-452/F-03-031.

¹¹⁷ U.S. EPA, Clean Air Technology Center, Air Pollution Control Technology Fact Sheet: Selective Non-Catalytic Reduction (SNCR), EPA-452/F-03-031.

¹¹⁸ Siemens Energy and Cormetech, *Capital and O&M Benefits of Advanced Multi-Function Catalyst Technology for Combustion Turbine Power Plants*, Power Gen 2015, page 2.

¹¹⁹ Application No. 17040013, *Project Summary for a Construction Permit Application from Jackson Generation, LLC, for an Electrical Generating Facility in Elwood, Illinois*, issued by the Illinois EPA for the public comment period beginning on September 21, 2018. Discussion related to selection of BACT for emissions of NO_x, Attachment B pages 15-16.

5.6.3.1 Water or Steam Injection Feasibility

Water or steam injection is a NO_x reduction technology that is commonly used to control NO_x emissions when fuel oil is burned, but is not as effective as DLN combustors when firing natural gas.¹²⁰ Water or steam injection also cannot be used in conjunction with DLN because it leads to unstable combustion and increases CO emissions.¹²¹ As the WCP turbines utilize DLN combustors for natural gas combustion that reduce NO_x emissions further than water or steam injection would, water or steam injection is deemed to be infeasible when combusting natural gas, but feasible for purposes of fuel oil combustion.

5.6.3.2 Dry Low NO_x Combustion Technology Feasibility

Dry low NO_x combustion technology is a NO_x control technology that is integral to the combustion turbine. It is determined to be technically feasible for the combustion turbine itself for natural gas combustion and is currently installed on the WCP units. Therefore, DLN combustion technology is included in the following BACT steps for natural gas but represents part of the base case for NO_x performance as it is inherent in the operation of the combustion systems.

5.6.3.3 Good Combustion Practices Feasibility

Good combustion practices are those that allow equipment to operate as efficiently as possible and maintain minimal emission releases with or without the operation of other control technologies. This is considered technically feasible for the minimization of NO_x emissions from the turbines.

5.6.3.4 EM_xTM/SCONO_xTM Technology Feasibility

The EM_xTM/SCONO_xTM catalyst system is a post-combustion technology that utilizes a proprietary oxidation catalyst and absorption technology using a single catalyst (potassium carbonate) for removal of NO_x, CO, and VOC without the use of ammonia. As summarized by Illinois EPA in their project summary for the Jackson Energy Center PSD permit, the EM_xTM/SCONO_xTM catalyst system has operated successfully on several smaller, natural gas-fired combined-cycle units, but there are engineering challenges with applying this technology to larger plants with full scale operation.¹²² Additionally, the operating range of the catalyst is 300 to 700°F, well below the exhaust temperature for simple-cycle combustion turbines.¹²³

Consequently, it is concluded that EM_xTM/SCONO_xTM is not technically feasible for control of NO_x emissions from the WCP turbines.

¹²⁰ Application No. 17040013, *Project Summary for a Construction Permit Application from Jackson Generation, LLC, for an Electrical Generating Facility in Elwood, Illinois*, issued by the Illinois EPA for the public comment period beginning on September 21, 2018. Discussion related to selection of BACT for emissions of NO_x, Attachment B page 12.

¹²¹ Application No. 17040013, *Project Summary for a Construction Permit Application from Jackson Generation, LLC, for an Electrical Generating Facility in Elwood, Illinois*, issued by the Illinois EPA for the public comment period beginning on September 21, 2018. Discussion related to selection of BACT for emissions of NO_x, Attachment B page 12.

¹²² Application No. 17040013, *Project Summary for a Construction Permit Application from Jackson Generation, LLC, for an Electrical Generating Facility in Elwood, Illinois*, issued by the Illinois EPA for the public comment period beginning on September 21, 2018. Discussion related to selection of BACT for emissions of NO_x, Attachment B page 14.

¹²³ U.S. EPA Office of Air and Radiation, *Final Technical Support Document (TSD) for the Cross-State Air Pollution Rule for the 2008 Ozone NAAQS: Assessment of Non-EGU NO_x Emission Controls, Cost of Controls, and Time for Compliance Final TSD*, August 2016, Appendix A, Page 3-5. Docket ID No. EPA-HQ-OAR-2015-0500.

5.6.3.5 SCR Feasibility

Optimal temperatures for the operation of SCR ranges from 480°F to 800°F and typical SCR systems have the ability to function effectively under temperature fluctuations of up to 200°F.¹²⁴ Given the exhaust temperature of utility-scale simple-cycle turbines is typically in excess of 1,000°F, use of SCR could be considered technically infeasible for such units.¹²⁵ However tempering air could potentially be added to such systems, at significant cost, to allow for use of SCR for such units, as has been done for smaller simple-cycle combustion turbine units. The problem with tempering air is the mass/volume of air required, as it is not just the higher temperature but also the larger volume of air flow involved with larger frame units. Therefore, a cost analysis has been conservatively included in Step 4 to ascertain feasibility.

5.6.3.6 SCR with Ammonia Oxidation Catalyst (Zero-Slip™) Feasibility

Based on WCP's review of available control technologies, to date, the Zero-Slip™ catalyst technology has not been demonstrated on large, utility-size units, with full scale operation demonstrated on a 7.5 MW Solar Taurus combustion turbine.¹²⁶ In addition, this technology is essentially SCR with a focus on reducing ammonia slip; accordingly, as SCR has been deemed infeasible, as this technology has not been demonstrated on large, utility size units, and it would not achieve NO_x emission rates lower than that achieved by conventional SCR designs, the Zero-Slip™ technology option is not considered a technically feasible control option.

5.6.3.7 SNCR Feasibility

The temperature range required for effective operation of this technology, 1,600 to 2,000°F, is above the peak exhaust temperature for the WCP turbine units.¹²⁷ In addition, a review of the RBLC database and AP-42's supplemental database for Chapter 3.1, *Stationary Gas Turbines*, April 2000, shows that SNCR has not been demonstrated on a turbine of this size. Given the changes to adapt units for use of SNCR, such as adding a flue gas heater, are not practical and reduces the energy efficiency of the generating units, SNCR is eliminated as a technically feasible option for control of NO_x emissions from the WCP turbine systems.

5.6.3.8 Multi-Function Catalyst (METEOR™) Feasibility

The METEOR™ catalyst technology, developed and patented by Siemens Energy Inc., is currently only in use on one 320 MW Siemens/Westinghouse 501G combustion turbine installed in November 2015.^{128,129} A review of the RBLC database for turbines similar to the WCP units did not return any units that use the

¹²⁴ U.S. EPA, Clean Air Technology Center, *Air Pollution Control Technology Fact Sheet: Selective Catalytic Reduction (SCR)*, EPA-452/F-03-032.

¹²⁵ WCP turbine exhaust temperatures are represented as 1,113°F in the facility's Title V Renewal Application, dated December 11, 2019 (Submittal ID: 288236).

¹²⁶ Application No. 17040013, *Project Summary for a Construction Permit Application from Jackson Generation, LLC, for an Electrical Generating Facility in Elwood, Illinois*, issued by the Illinois EPA for the public comment period beginning on September 21, 2018. Discussion related to selection of BACT for emissions of NO_x, Attachment B page 14.

¹²⁷ U.S. EPA, Clean Air Technology Center, *Air Pollution Control Technology Fact Sheet: Selective Non-Catalytic Reduction (SNCR)*, EPA-452/F-03-031.

¹²⁸ Application No. 17040013, *Project Summary for a Construction Permit Application from Jackson Generation, LLC, for an Electrical Generating Facility in Elwood, Illinois*, issued by the Illinois EPA for the public comment period beginning on September 21, 2018. Discussion related to selection of BACT for emissions of NO_x, Attachment B page 16.

¹²⁹ Siemens Energy and Cormetech, *Capital and O&M Benefits of Advanced Multi-Function Catalyst Technology for Combustion Turbine Power Plants*, Power Gen 2015, page 2.

METEOR™ catalyst technology. As there is limited commercial operating experience with the METEOR™ catalyst, and the system would have similar technical considerations as a traditional SCR system, the METEOR™ technology option is not considered a technically feasible control option for purposes of BACT.

5.6.4 Summary and Ranking of Remaining NO_x Controls – Combustion Turbines (Step 3)

Of the control technologies available for NO_x emissions, the options technically feasible for each unit are shown in Table 5-2.

Table 5-2. Remaining NO_x Control Technologies

Control Technology	Feasible For Natural Gas	Feasible for Fuel Oil	Estimated Efficiency
Water or Steam Injection	No	Yes	>60%
DLN Combustion Technology	Yes	No	Base Case
Good Combustion Practice	Yes	Yes	Base Case
EM _x ™/SCONO _x ™ Technology	No	No	Infeasible
SCR	Yes	Yes	70-90%
SCR with Zero-Slip™	No	No	Infeasible
SNCR	No	No	Infeasible
METEOR™	No	No	Infeasible

As shown in Table 5-2, the remaining potentially feasible control technologies could include SCR, DLN combustors (natural gas only), water or steam injection (fuel oil only), and good combustion practices. The WCP units already utilize DLN combustors for natural gas combustion.

5.6.5 Evaluation of Most Stringent NO_x Controls – Combustion Turbines (Step 4)

Per Table 5-2, SCR is the highest ranking potentially feasible control technology for both natural gas and fuel oil combustion in the turbines. The estimated cost of controlling NO_x using SCR for the WCP simple-cycle turbines is approximately \$20,000 per ton of NO_x removed based on the detailed cost analysis provided in Appendix D, developed using the methods outlined by the U.S. EPA in the OAQPS guidance manual.¹³⁰ As previously discussed, estimated costs are high given the high volume of tempering air that would be required to reduce the turbine exhaust temperatures to an acceptable range for operation of the SCR. Therefore, WCP concludes that SCR is not cost effective and is not considered BACT for the Facility's turbines

For fuel oil combustion, the next highest ranked control system is a water or steam injection system. WCP is proposing to install a water injection system on the modified turbines as BACT; hence a cost-effectiveness calculation is not presented. Since the highest remaining control technology for fuel oil combustion has been selected as BACT, no further evaluation of remaining control technologies is required.

¹³⁰ U.S. EPA, *OAQPS Control Cost Manual*, 6th edition, EPA 452/B-02-001, July 2002.

http://www.epa.gov/ttn/catc/dir1/c_allchs.pdf Note that data from updated sections of the manual related to NO_x control costs is utilized as applicable. For more details on the updating of the control cost manual see <https://www.epa.gov/economic-and-cost-analysis-air-pollution-regulations/cost-reports-and-guidance-air-pollution>

For natural gas combustion, DLN combustors are the next highest ranked control and represent the present technology in use for the Facility turbines. Therefore, DLN is selected as BACT for purposes of natural gas combustion.

5.6.6 Selection of Emission Limits and Controls for NO_x BACT – Combustion Turbines (Step 5)

Once the proposed modifications are complete, the combustion turbine systems will be subject to an NSPS Subpart KKKK NO_x emission standard of 15 ppm at 15% O₂ or 0.43 lb/MWh useful output during natural gas combustion; for fuel oil combustion the NO_x emissions standard will be 42 ppm at 15% O₂ or 1.3 lb/MWh useful output. These NSPS Subpart KKKK limits serve as the floor for allowable NO_x BACT limits. Each individual combustion turbine is presently subject to a NO_x limit from NSPS Subpart GG per Condition 3.3.3 of Permit No. 4911-303-0039-V-08-0, however the NSPS Subpart GG limit will no longer apply as a result of applicability of the NSPS Subpart KKKK NO_x limits.¹³¹

As the selected BACT technology for NO_x emissions relies on DLN combustors and good combustion practices for natural gas, and water injection and good combustion practices for fuel oil combustion, WCP searched U.S. EPA's RBLC database for modifications of similar units at other facilities to determine what has been established as a BACT emission requirement for comparable operations. Numerous entries for natural gas or fuel oil simple-cycle combustion turbines are provided in the RBLC summary table in Appendix C. Review of the RBLC entries confirms that controls for NO_x emissions are typically DLN combustors (natural gas), water or steam injection (fuel oil), and good combustion practices for similarly sized simple-cycle combustion turbines. "Good combustion practices" typically refers to practices inherent in the routine operation and maintenance of the generating unit, such as automated operating systems and periodic tuning of the turbines.

Once the technology is established, an emission limitation must be proposed, and review of the RBLC entries listed in Appendix C provides an indication of what has been established as BACT emission limitations for potentially similar units as those being modified by WCP. The majority of the RBLC database entries relate to the installation of new state-of-the-art simple-cycle units, not modifications of existing simple-cycle units. Given the advancements in turbine design and control systems, it is not anticipated that modification of an older generation turbine system would improve combustion efficiency, controls and performance in a manner that would be comparable to installation of a new, state-of-the-art turbine and controls system. Therefore, for comparison purposes, the RBLC entries of interest for WCP are those which include turbine units deemed to be potentially modified. A review of the RBLC database entries listed in Appendix C reveals that many of the entries do not provide sufficient detail to determine whether the turbines listed were to be newly constructed units or modified units.

For these RBLC entries, further research was conducted as needed using available permits, permit applications, and public documentation. The following qualifying criteria for potentially comparable units to the WCP turbines include:

¹³¹ 40 CFR 60.4305(b)

- ▶ Turbine is existing and proposed a modification; exclude units proposed for initial construction;
- ▶ Control method includes DLN combustors (natural gas firing) or water injection (fuel oil firing) and does not include control technologies which have been deemed to be infeasible (i.e., SCR, SNCR);
- ▶ Units are similar GE Frame 7 units; and
- ▶ Units are utilized for the purposes of power generation and not utilized for other purposes such as compression.

This review has been conducted on a fuel-specific basis, detailed in the following sections.

5.6.6.1 Selection of Emission Limits for NO_x BACT - Natural Gas Firing

Table 5-3 includes NO_x RBLC database entries for turbine units combusting natural gas which are potentially comparable to the existing units at the WCP facility. Further research was performed for each of these entries using available permits, permit applications, and public documentation to analyze whether the turbine units are comparable to the existing units at the WCP facility. Findings and notes from this research are further detailed in Sections 5.6.6.1.1 through 5.6.6.1.10.

Table 5-3. Natural Gas Simple-Cycle Combustion Turbine NO_x RBLC Data for Potentially Modified Units

Facility Name	State	Permit Issuance	System Size	Turbine Model	NO _x Emission Limit ^[1]	Units ^[1]	Averaging Period ^[1]	Notes
Cunningham Power Plant	NM	5/2/2011	Unknown	Unknown	21 and 30	ppmvd @ 15% O ₂	1-hr Avg.	Two simple-cycle combustion turbines utilizing DLN burners. The turbines are capable of operating with or without power augmentation and have specific NO _x limitations for each operating mode (emissions of NO _x are limited to 21 ppmvd without power augmentation and 30 ppmvd with power augmentation). NO _x emission limit excludes periods of startup and shutdown. Permit revises the NO _x BACT ppmvd limit for turbines established in previous PSD Permit No. PSD-NM-622-M2 because turbines have not been able to meet NO _x BACT limits. No modification or change to mass emissions. Former NO _x BACT was at 15 ppmvd w/out power augmentation (normal mode) and 25 ppmvd w/ power augmentation (see RBLC ID NM-0028).
Calcasieu Plant	LA	12/21/2011	1,900 MMBtu/hr Heat Input for Each Turbine	Unknown	17.5	ppmvd @ 15% O ₂	Annual Avg.	Two simple-cycle combustion turbines of unknown make and model utilizing DLN combustors. NO _x emission limit excludes periods of startup and shutdown. PSD was triggered due to relaxation of a federally enforceable condition limiting potential emissions below major stationary source thresholds; subsequently revoked. PSD permit issued in 2015 lists NO _x limit as 34.5 ppmvd @ 15% O ₂ .
Westar Energy – Emporia Energy Center	KS	3/18/2013	405 MMBtu/hr Heat Input for Each Turbine	GE LM6000 PC Sprint	25.0	ppmvd @ 15% O ₂	24-hr Rolling Avg.	Four GE LM6000 PC Sprint natural gas fired simple-cycle turbines which are considered aeroderivative turbines. NO _x emission limit excludes periods of startup, shutdown, or malfunction. There are two RBLC database entries for these turbines associated with the 3/18/2013 permit issuance; one entry lists water injection as control for NO _x and the other lists DLN burners as control for NO _x . Permit renewal dated 7/27/2017 lists water injection as control for NO _x .
Westar Energy – Emporia Energy Center	KS	3/18/2013	1,780 MMBtu/hr Heat Input for Each Turbine	GE 7FA	9.0	ppmvd @ 15% O ₂	24-hr Rolling Avg.	Three GE 7FA natural gas fired simple-cycle turbines which utilize DLN burners for control. NO _x emission limit excludes periods of startup, shutdown, or malfunction.
Doswell Energy Center	VA	10/4/2016	1,961 MMBtu/hr for Each Turbine	GE Frame 7FA	9.0	ppmvd @ 15% O ₂	3-hr Avg.	Authorization to add two 170 MW GE 7FA.03 natural gas fired, simple-cycle combustion turbines (CT-2 and CT-3) at the Doswell Energy Center (DEC) equipped with low NO _x burners. Both CT-2 and CT-3 were proposed to be brought to DEC from an existing permitted site in Desoto, Florida. They are both similar in age and capability to the existing 190.5 MW GE 7FA.03 simple-cycle combustion turbine (CT-1) at the facility. CT-1 was added in a PSD permit dated April 7, 2000 and last amended on September 30, 2013. Emissions of NO _x are limited to 9 ppmvd excluding periods of startup, shutdown, and tuning.
Puente Power	CA	10/13/2016	262 MW	Unknown	2.5	ppmvd @ 15% O ₂	1-hr Avg.	One 262 MW gas turbine.

Facility Name	State	Permit Issuance	System Size	Turbine Model	NO _x Emission Limit ^[1]	Units ^[1]	Averaging Period ^[1]	Notes
Waverly Facility	WV	1/23/2017	1,571 MMBtu/hr for Each Turbine	GE 7FA	9.0	ppm @ loads of 60% or higher	30-day Rolling Avg.	Two GE Model 7FA turbines which are capable of combusting natural gas and firing fuel oil as back-up. The combustion turbines employ the use of DLN burners when firing natural gas. In this permitting action PSD only applies to the modified combustion turbines based on the relaxation of an original synthetic minor permit issued in 1999. Project also involves previous installation of turbo-charging. All BACT emission limits are given without turbocharging and startup/shutdown emissions are not included.
Waverly Power Plant	WV	3/13/2018	167.8 MW with 2,013 MMBtu/hr Heat Input for Each Turbine	GE 7FA.004	9.0	ppm @ loads of 60% or higher	30-day Rolling Avg.	Two GE Model 7FA turbines which are capable of combusting natural gas and firing fuel oil as back-up. The combustion turbines employ the use of DLN burners when firing natural gas. Modification to existing PSD Permit (R14-0034, RBLC Number WV-0027) to add advanced gas path technology to the turbines that was defined as a change in the method of operation that resulted a major modification to the turbines.
Cameron LNG Facility	LA	2/17/2017	1,069 MMBtu/hr Heat Input for Each Turbine	Unknown	15.0	ppmvd @ 15% O ₂	1-hr Avg.	Gas turbines which utilize DLN burners as control.
Mustang Station	TX	8/16/2017	163 MW	GE 7FA	9.0	ppmvd @ 15% O ₂	3-hr Rolling Avg.	One 163 MW GE 7FA turbine (Unit No. 6) which was constructed in 2013 and utilizes DLN burners for control. Permit involved increasing the turbine hours of operation to 3,000 hours per year. NO _x emission limit excludes periods of maintenance, startup, and shutdown.
Jackson County Generators	TX	1/26/2018	230 MW for Each Turbine	Unknown	9.0	ppmvd @ 15% O ₂	3-hr Rolling Avg.	Four natural gas fired simple-cycle combustion turbines which utilizes DLN burners for control. NO _x emission limit excludes periods of startup and shutdown.
Ector County Energy Station	TX	8/17/2020	Unknown	Unknown	9.0	ppmvd @ 15% O ₂	3-hr Rolling Avg.	Two simple-cycle gas turbines equipped with DLN burners for control. Emission limit for NO _x applies to normal operations.

^[1] Please note that the Emission Limit and Averaging Periods for each RBLC entry was cross referenced with the associated air permit for each entry, as available. Corrections were made as necessary, to ensure that emission limits and averaging periods were consistent with the air permits associated with each RBLC entry.

The following sections include detailed discussions of permitting actions and highlight the commonalities or differences between the turbines included in the Table 5-3 RBLC entries and the WCP turbine units. Additional details are included in these sections which were not available in the RBLC database entries.

5.6.6.1.1 Cunningham Power Plant

Southwestern Public Service Company is permitted to operate the Cunningham Station Power Plant, which incorporates the use of two 115 MW combustion turbines which were constructed in 1997. The turbines utilize DLN burners for control of NO_x and are capable of operating with or without power augmentation, in which power output is increased by lowering air temperature through water injections into the compressor. On May 2, 2011, the Cunningham Station Power Plant was issued an NSR permit in which BACT limits for NO_x were increased.¹³² However, upon further investigation of the facility's historical permits, it was determined that the turbine units are Westinghouse 501D5A model turbines. Given the unique emission profiles associated with the manufacturer design of different natural gas simple-cycle turbine units, WCP maintains that the Westinghouse model turbines are not necessarily an appropriate comparison for a GE 7FA turbine. However, it is worth noting that the permit issued on May 2, 2011 established a BACT emission limitation for NO_x of 21 ppmvd (without power augmentation) at 15 percent O₂ which excludes periods of startup and shutdown. This NO_x emission limitation is considered achievable for the existing WCP turbine units. A revised NSR permit was issued on May 23, 2012 which maintained the previously described BACT emission limits for NO_x.¹³³

5.6.6.1.2 Calcasieu Plant

Calcasieu Power, LLC, received a state preconstruction and Part 70 operating permit from the Louisiana Department of Environmental Quality (LDEQ) on October 21, 1999 for the operation of a peaking power plant consisting of two natural gas fired, simple-cycle combustion turbines with heat inputs of 1,900 MMBtu/hr.¹³⁴ Each of the combustion turbines utilize DLN combustors for emissions control. Effective March 2008, Entergy Gulf States Louisiana (Entergy), LLC purchased Calcasieu Power, LLC and the facility was thereafter referred to as the Calcasieu Plant.¹³⁵

Entergy received an initial PSD permit and a revised Title V permit on December 21, 2011 which allowed for the two combustion turbines to increase annual operating hours.¹³⁶ The initial PSD permit provided a BACT emission limit for NO_x during normal operation of 17.5 ppmvd corrected to 15% O₂ for each of the two turbines and required emissions of NO_x to be monitored by CEM. However, the changes associated with the December 11, 2011 Title V and PSD permits were never incorporated, and Entergy requested the revocation of the PSD permit.¹³⁷ On January 25, 2013, the LDEQ issued Permit No. 0520-00219-V4 which removed the changes authorized per the December 21, 2011 Title V permit as well as increased the maximum hourly firing rate of the turbines to 2,200 MMBtu/hr. A new PSD permit and revised Title V permit were issued on June 1, 2015 which allowed for an increase in the combined operating time for the turbines and allowed for additional periods of startup/shutdown time. The June 1, 2015 PSD permit also established BACT emission

¹³² NSR Permit No. PSD-NM-622-M3 issued by the NMED to the Southwester Public Service Company on May 2, 2011.

¹³³ NSR Permit No. PSD-NM-622-M4 issued by the NMED to the Southwester Public Service Company on May 23, 2012.

¹³⁴ Permit No. 0520-00219-V0 issued by the LDEQ to Dynegy Operating Company, Inc. – Calcasieu Power, LLC, October 21, 1999.

¹³⁵ Per Notification of Ownership, Facility Name, and Operator Change submitted to the LDEQ on May 12, 2008.

¹³⁶ Permit Nos. 0520-00219-V3 and PSD-LA-746 issued by the LDEQ to Entergy Gulf States LA LLC, December 21, 2011.

¹³⁷ Per Title V Permit Renewal Application submitted to the LDEQ on April 11, 2012.

limits for NO_x of 34.3 ppmvd corrected to 15% O₂ during normal operation for each of the two turbines and required emissions of NO_x to be monitored by CEM.

Although the make and model of the Calcasieu Plant turbines is not known, WCP anticipates that the NO_x emission limit of 34.3 ppmvd is conservative and higher than other comparable BACT limitations.

5.6.6.1.3 Emporia Energy Center

Westar Energy received an Air Emissions Source PSD Construction Permit for the Emporia Energy Center on April 17, 2007 (modified May 5, 2011).¹³⁸ The Emporia Energy Center is fossil fuel power plant which consists of four GE LM6000 PC natural gas fired, simple-cycle combustion turbines equipped with water injection and three GE 7FA natural gas fired, simple-cycle combustion turbines which utilize DLN burners.

The GE LM6000 PC model turbines are classified as aeroderivative gas turbines.¹³⁹ Aeroderivative turbines have a much smaller power output than what would be expected from a large frame unit such as a GE 7FA turbine; therefore, the GE LM6000 PC turbines cannot be considered relatively comparable units to reference for selection of BACT emission limits based on size.

The Emporia Energy Center does operate three GE 7FA simple-cycle turbines with heat inputs of 1,780 MMBtu/hr which were authorized for construction in 2007. The GE 7FA turbines would be considered comparable in size and age to the existing units operated by WCP, and because both units are GE 7FA model turbines, it can be assumed that the turbines would have similar emission profiles. On March 18, 2013, the Kansas Department of Health and Environment (KDHE) issued an amendment to the prior PSD permit to add tuning language to allow for the periodic tuning of the GE 7FA combustion turbines.¹⁴⁰ The GE 7FA turbines at the Emporia Energy Center are subject to a NO_x emission limitation of 9 ppmvd corrected to 15% O₂ on a 24-hr rolling average which excludes startup, shutdown, and malfunction periods. This BACT emission limit for NO_x should be considered an achievable limit for the proposed modifications to the existing turbines at the WCP facility.

5.6.6.1.4 Doswell Energy Center

On October 4, 2016, the Virginia Department of Environmental Quality (VDEQ) issued a permit which authorized the addition of two natural gas fired GE 7FA simple-cycle combustion turbines. Each turbine has a heat input of 1,961 MMBtu/hr and utilizes low NO_x burners for control. The two turbines were originally constructed in 2001 and were to be relocated from an existing permitted site in Desoto, Florida to the Doswell Energy Center. Based on turbine age, model, and size these units should be considered comparable to the existing WCP turbines. Therefore, it is reasonable to assume that this modification is comparable to the proposed modification to the existing WCP turbine units. Each of the simple-cycle turbines added to the Doswell Energy Center are subject to BACT emission limitations for NO_x of 9 ppmvd at 15% O₂ on a 3-hour average basis (averaging time based on the PSD permit), except during periods of startup, shutdown, and tuning. This is an achievable emission limitation for the existing WCP turbines at the WCP facility. Revised PSD permits for the two simple-cycle combustion turbines were issued on May 31, 2018 and July 30, 2018. The issuance of the July 30, 2018 PSD permit revised the averaging period for the BACT emission limit for NO_x from 3-hour averaging basis to a 1-hour averaging basis.

¹³⁸ Permit Nos. C-7072 and C-9132 issued by the KDHE on April 17, 2007 and May 5, 2011, respectively.

¹³⁹ <https://www.ge.com/power/gas/gas-turbines/lm6000>

¹⁴⁰ Permit No. C-10656 issued by the KDHE for the Emporia Energy Center on March 18, 2013.

5.6.6.1.5 Puente Power

The RBLC database entry for the Puente Power facility contained insufficient information needed to determine comparability relative to the proposed modified units at the WCP facility. Upon further research into publicly available information, it was discovered that the Puente Power facility was proposed for construction in 2015 in Ventura County California. The proposed facility would consist of one natural gas fired, simple-cycle GE 7HA.01 turbine with a net-nominal 262 MW generating capacity.¹⁴¹ However, in 2018, the California Energy Commission terminated the 2015 application to construct the facility and the project was voided.¹⁴² Therefore, as this project involved new units that were never constructed, the Puente Power RBLC database entry is not considered further in these BACT analyses.

5.6.6.1.6 Waverly Facility (Waverly Power Plant)

In 1999, Pleasants Energy LLC submitted a permit application to the West Virginia Department of Environmental Protection (WVDEP) to construct a peaking power facility in Waverly, West Virginia which would utilize two GE 7FA natural gas fired, simple-cycle combustion turbines capable of generating 300 MW. Natural gas was to be the primary fuel and fuel oil would be used as back-up.¹⁴³ The two combustion turbines were installed in 2001 and utilize DLN burners when firing natural gas and water injection for control of NO_x when firing fuel oil.¹⁴⁴ The facility was issued a Permit to Modify on November 24, 2015 which allowed for the addition of two TurboPhase systems (8 engines) to allow for increased generator output.¹⁴⁵ The facility received an additional Permit to Modify on January 23, 2017, which allowed for the relaxation of limits which were originally imposed to maintain the synthetic minor status of the source for PSD permitting purposes.¹⁴⁶

The authorization to operate the TurboPhase engines was removed by way of the Permit to Modify issued on March 13, 2018.¹⁴⁷ The Permit to Modify also allowed for the installation of "Advanced Gas Path" technology to the existing GE 7FA turbines which increased the maximum heat input of each turbine. The RBLC database entry for the issuance of the March 13, 2018 Permit to Modify states that the addition of the "Advanced Gas Path" technology to the combustion turbines was defined as a change in the method of operation that resulted in a major modification to the turbines. According to information available on General Electric's website, the incorporation of GE's "Advanced Gas Path" technology to GE 7FA turbines results in "increased output, efficiency, and availability, while reducing fuel consumption and extending gas turbine assets."¹⁴⁸

¹⁴¹ California Energy Commission, *Puente Power Project Final Staff Assessment Part 1*, Docket No. 15-AFC-01, Publication No. CEC-700-2016-006-FSA, December 8, 2016.

¹⁴² Wendy Leung, "NRG proposal to build Puente Power Project on Oxnard coast is dead," *Ventura County Star*, December 17, 2018, <https://www.vcstar.com/story/news/2018/12/17/power-plant-nrg-energy-inc-california-energy-commission-oxnard/2266774002/>. (accessed January 21, 2021).

¹⁴³ West Virginia Department of Environmental Protection, Division of Air Quality, *Preliminary Determination/Fact Sheet for the Construction of Pleasants Energy, LLC's Waverly Power Plant located in Waverly, Pleasants County, WV*, Permit No. R14-0034, September 29, 2016.

¹⁴⁴ Per Section 1.1 of Permit No. R30-07300022-2020 issued by the WVDEP for the Waverly Facility on June 10, 2020.

¹⁴⁵ Permit No. R13-2373B issued by the WVDEP for the Waverly Facility on March 18, 2013.

¹⁴⁶ Permit No. R14-0034 issued by the WVDEP for the Waverly Facility on January 23, 2017.

¹⁴⁷ Permit No. R14-0034A issued by the WVDEP for the Waverly Facility on January 13, 2018.

¹⁴⁸ https://www.ge.com/power/services/gas-turbines/upgrades/advanced-gas-path?gecid=press_release.

The Waverly facility GE 7FA turbines have been modified since installation, albeit in ways that are not like the proposed WCP modifications. The BACT emission limits established per the 2013 and 2017 permitting actions is 9 ppm NO_x at loads of 60% or higher based on a 30-day rolling average, excluding periods of startup and shutdown. This emission limit should be considered achievable for the existing turbines at the WCP facility.

5.6.6.1.7 Cameron LNG Facility

On October 1, 2013, the Cameron LNG Facility was issued an initial PSD permit and revised Title V permit which authorized the construction of additional equipment which included six refrigeration compressor turbines with heat inputs of 1,069 MMBtu/hr each.¹⁴⁹ The facility was again issued revised PSD and Title V permits on March 3, 2016 which authorized the construction of additional equipment, including four refrigeration compressor turbines with heat inputs of 1,069 MMBtu/hr each.¹⁵⁰ The RBLC database entry for the Cameron LNG Facility is associated with the February 17, 2017 issuance of revised PSD and Title V permits which incorporated two diesel tanks into the PSD permit and also incorporated administrative updates to both the PSD and Title V permits.¹⁵¹ The RBLC entry for the Cameron LNG Facility did not provide sufficient detail to make a determination of comparability for these turbines. However, upon further review of PSD and Title V permits, it is clear that the turbines at the Cameron LNG Facility were constructed for the purposes of refrigeration compression rather than for power generation, and therefore they cannot be considered comparable to the existing turbine units at the WCP facility. Therefore, the Cameron LNG Facility RBLC database entry is not considered further in these BACT analyses.

5.6.6.1.8 Mustang Station

Mustang Station commenced operation of a 168 MW GE 7FA simple-cycle combustion turbine (Unit 6) in 2013. The turbine unit utilizes DLN burners for control of NO_x emissions. The facility was issued an amended PSD permit on August 8, 2016 by the Texas Commission on Environmental Quality (TCEQ) which allowed for the combustion turbine to increase annual operation to 3,000 hours per year.¹⁵² Because the turbine was built in 2013, the equipment at the Mustang Station represents new turbines, albeit GE 7FA turbines of a more modern design than those installed and operating at the WCP facility. The turbine at the Mustang Station may not be considered comparable to existing units at the WCP facility which began operation in 2001, yet the established BACT emission limitation, 9 ppm NO_x corrected to 15 percent O₂ on a rolling 3-hour average (excluding periods of maintenance, startup, and shutdown) is considered achievable for the existing WCP turbine units.

5.6.6.1.9 Jackson County Generators

The Southern Power Company submitted an Air Preconstruction Permit General Application to the TCEQ in July 2014 for the construction of the Jackson County Generating Facility which would include four 230 MW natural gas fired simple-cycle combustion turbines with DLN burners.¹⁵³ An initial permit was issued by the

¹⁴⁹ Permit Nos. PSD-LA-766 and 0560-00184-V5 issued by the LDEQ to Cameron LNG, LLC on October 1, 2013.

¹⁵⁰ Permit Nos. PSD-LA-766(M2) and 0560-00184-V7 issued by the LDEQ to Cameron LNG, LLC on March 3, 2016.

¹⁵¹ Permit Nos. PSD-LA-766(M3) and 0560-00184-V8 issued by the LDEQ to Cameron LNG, LLC on February 17, 2017.

¹⁵² Permits 72579, PSDTX1080M1, and GHGPSDTX138 issued by the TCEQ to Cameron LNG, LLC on October 1, 2013.

¹⁵³ Per the Air Preconstruction Permit General Application submitted by the Southern Power Company to TCEQ on July 11, 2014.

TCEQ on February 2, 2018.¹⁵⁴ Upon further investigation of the February 2018 permit, it was determined that the proposed units are Siemens F5 model turbines. Given the unique emission profiles associated with the manufacturer design of different natural gas simple-cycle turbine units, WCP maintains that the Siemens F5 model turbines are not necessarily an appropriate comparison for a GE 7FA turbine. However, it is worth noting that the permit issued on February 2, 2018 established a BACT emission limitation for NO_x of 9 ppmvd at 15 percent O₂ on a rolling 3-hour average which excludes periods of startup and shutdown. This NO_x emission limitation is considered achievable for the existing WCP turbine units.

5.6.6.1.10 Ector County Energy Station

The Ector County Energy Station was issued initial permits for the construction of two simple-cycle turbine generating units on August 1, 2014.¹⁵⁵ Subsequent revisions to the initial permit were issued in 2014, 2017, 2018, 2019, and 2020. The permit allowed for the construction of two GE 7FA.03 or 7FA.05 combustion turbines capable of generating 165-193 MW of output; per more recent documentation it appears the GE 7FA.03 engines were installed. Each of the turbines were to be controlled using DLN burners. An RBLC database entry associated with a permit issuance dated 8/17/2020 states that hours of operation for the existing combustion turbines were increased per this permitting action. As the initial air permit was received in 2014, it is reasonable to assume that the turbines at the Ector County Energy Station are newer state-of-the-art simple-cycle combustion turbine units which would not necessarily be comparable to the existing WCP units. However, the units are subject to a 9 ppmvd NO_x limit at 15% O₂ on a rolling 3-hour average which excludes periods of startup and shutdown. This NO_x emission limitation is considered achievable for the existing WCP turbine units.

5.6.6.1.11 Summary – Natural Gas NO_x BACT

The anticipated NO_x BACT for natural gas firing would be good combustion practices and the use of DLN combustion technology. As was previously discussed, there are various factors as to why, even with the use of the same control technologies, the emissions limits presented for the facilities in Table 5-3 are not necessarily directly comparable to the WCP units. Table 5-4 summarizes whether the RBLC listing was actually for a modification of an existing unit, if the turbine involved was a GE Frame 7 turbine, and whether the facilities in Table 5-3 are comparable to the WCP units based on these factors.

Table 5-4. Unit Comparability for NO_x Assessment – Natural Gas Firing

Site	Modification?	GE Frame 7 Turbine?	Comparable?	NO _x Emission Limit	Averaging Period
Cunningham Station Power Plant	Increase NO _x BACT Emission Limits	No, Westinghouse 501D5A	No	Not Comparable	
Calcasieu Plant ^[1]	Increase hours, heat input	Unknown	Yes	34.5 ppmvd @ 15% O ₂	Annual Avg.
Emporia Energy Center – GE LM6000PC Units (Water Injection) ^[2]	N/A	No	No	Not Comparable	

¹⁵⁴ Permits Nos. 121917 and PSDTX1422 issued by the TCEQ to the Southern Power Company on February 2, 2018.

¹⁵⁵ Permits Nos. 110423 and PSDTX1366 issued by the TCEQ to Invenergy Thermal Development LLC on August 1, 2014.

Site	Modification?	GE Frame 7 Turbine?	Comparable?	NO _x Emission Limit	Averaging Period
Emporia Energy Center – GE LM6000PC Units (DLN) ^[2]	N/A	No	No	Not Comparable	
Emporia Energy Center – GE 7FA	No (New in 2007) Added Tuning Requirements in 2013	Yes	No (New Unit) Yes (Engine Type)	9.0 ppmvd @ 15% O ₂	24-hr Rolling Avg.
Doswell Energy Center	Turbine Relocation	Yes	Yes	9.0 ppmvd @ 15% O ₂	3-hr Avg. (2016) 1-hr Avg (2018)
Puente Power	No - New	Yes	No	Application Revoked	
Waverly Facility - 2017	Relaxed synthetic minor limits	Yes	Potentially	9.0 ppmvd @ 15% O ₂	30-day Rolling Avg.
Waverly Facility - 2018	Increase heat input	Yes	Potentially	9.0 ppmvd @ 15% O ₂	30-day Rolling Avg.
Cameron LNG Facility	No – New	Compressor Turbines	No	Not Comparable	
Mustang Station	Increase hours	Yes, 2013 install	Potentially	9.0 ppmvd @ 15% O ₂	3-hr Rolling Avg.
Jackson County Generators	No	No, Siemens F5	No	Not Comparable	
Ector County Energy Center	No (New in 2014), increased hours in 2020	Yes	Potentially	9.0 ppmvd @ 15% O ₂	3-hr Rolling Avg.

^[1] PSD Permit No. PSD-LA-746 issued on December 21, 2011 listed a BACT limit for NO_x of 17.5 ppmvd @ 15% O₂. However, this permit was requested for revocation in a 2012 Title V Renewal Application. PSD Permit No. PSD-LA-798 was issued on June 1, 2015 and established the BACT limit for NO_x as 34.5 ppmvd @ 15% O₂.

^[2] Please note that the RBL database entries in Appendix C include two separate entries for the GE LM6000 PC Sprint turbines at the Emporia Energy Center. One entry lists water injection as a control method and the other lists dry low NO_x burners as the control method.

As was discussed in Section 5.2.4, BACT is to be set at the lowest value that is achievable. Per Table 5-4, the remaining potentially comparable turbine units each have NO_x emission limits for BACT of 9 ppmvd at 15% O₂ or greater. A NO_x limit of 9 ppmvd at 15% O₂ is an achievable emission limitation for the turbine units at the WCP facility. **Therefore, WCP proposes a BACT limit for NO_x of 9 ppmvd at 15% O₂ on a 4-hr averaging basis when firing natural gas, excluding periods of startup and shutdown.** A 4-hr averaging period as documented per CEMS is proposed for consistency with the NSPS Subpart KKKK monitoring requirements and to ensure WCP's ability to demonstrate continuous compliance and reasonably aligns with the other BACT limitations reviewed per Table 5-4.

5.6.6.2 Selection of Emission Limits for NO_x BACT – Fuel Oil Firing

Table 5-5 includes NO_x RBL database entries for turbine units combusting fuel oil which are potentially comparable to the existing units at the WCP facility. Further research was performed as necessary for entries using available permits, permit applications, and public documentation to analyze whether the

turbine units are comparable to the existing units at the WCP facility. Findings and notes from this research are further detailed in Section 5.6.6.1.6 and 5.6.6.2.1.

Table 5-5. Fuel Oil Simple-Cycle Combustion Turbine NO_x RBLC Data for Potentially Modified Units

Facility Name	State	Permit Issuance	System Size	Turbine Model	NO _x Emission Limit ^[1]	Units ^[1]	Averaging Period ^[1]	Notes
Wolverine Power	MI	6/29/2011	540 MMBtu/hr Heat Input	Unknown	0.16	lb/MMBtu	Test protocol will specify avg. time	One ULSD fired turbine generator which will be used to start the plant when there is no power available from the electric grid and the plant must be brought back into service. Turbine utilizes good combustion control technology.
Waverly Facility ^[2]	WV	1/23/2017	1,571 MMBtu/hr for Each Turbine	GE 7FA	49.0	ppm @ loads of 60% or higher	30-day Rolling Avg.	Two GE Model 7FA turbines which are capable of combusting natural gas and firing fuel oil as back-up. The combustion turbines employ the use of water injection for control of NO _x when firing fuel oil. In this permitting action PSD only applies to the modified combustion turbines based on the relaxation of an original synthetic minor permit issued in 1999. Project also involves previous installation of turbo-charging. All BACT emission limits are given without turbocharging and startup/shutdown emissions are not included.
Waverly Power Plant ^[2]	WV	3/13/2018	167.8 MW with 2,013 MMBtu/hr Heat Input for Each Turbine	GE 7FA.004	42.0	ppm @ loads of 60% or higher	30-day Rolling Avg.	Two GE Model 7FA turbines which are capable of combusting natural gas and firing fuel oil as back-up. The combustion turbines employ the use of water injection for control of NO _x when firing fuel oil. Modification to existing PSD Permit (R14-0034, RBLC Number WV-0027) to add advanced gas path technology to the turbines that was defined as a change in the method of operation that resulted a major modification to the turbines.

^[1] Please note that the Emission Limit and Averaging Periods for each RBLC entry was cross referenced with the associated air permit for each entry, as available. Corrections were made as necessary, to ensure that emission limits and averaging periods were consistent with the air permits associated with each RBLC entry.

^[2] Facility did not have a RBLC database entry for NO_x associated with the turbine unit for fuel oil firing. However, upon further review of associated permits, permit applications, and other available documentation, it was determined that established BACT limits for NO_x existed for the associated turbine units when firing fuel oil. The established BACT limits for NO_x were added to this table.

5.6.6.2.1 Wolverine Power

Wolverine Power Supply Cooperative, Inc was issued a permit to install a coal fired power plant in Presque Isle County, Michigan by the Michigan Department of Environmental Quality (MDEQ) on June 29, 2011.¹⁵⁶ The permit was subsequently revised on July 12, 2011. The permitted sources include a 540 MMBtu/hr ULSD fired turbine generator of unknown make and model which would be used to start the plant when there is no power available from the electric grid. The turbine was permitted for 500 hours of operation annually and would utilize good combustion control technology only (i.e., did not require water injection). However, plans to build the coal-fired power plant were discontinued in 2013 and the project was voided.¹⁵⁷ Because the turbine at the Wolverine Power facility was never built, the BACT limit has not been demonstrated in practice and the associated RBLC database entry is not considered further in these BACT analyses.

5.6.6.2.2 Summary – Fuel Oil NO_x BACT

The anticipated NO_x BACT for fuel oil firing would be good combustion practices and the use of water or steam injection. Table 5-6 summarizes whether the RBLC listing was actually for a modification of an existing unit, if the turbine involved was a GE Frame 7 turbine, and whether the facilities in Table 5-5 are comparable to the WCP units based on these factors.

Table 5-6. Unit Comparability for NO_x Assessment – Fuel Oil Firing

Site	Modification?	GE Frame 7 Turbine?	Comparable?	NO _x Emission Limit	Averaging Period
Wolverine Power	No – New	Unknown	No	Project Voided – Facility Was Not Built	
Waverly Facility - 2017	Relaxed synthetic minor limits	Yes	Potentially	49 ppmvd	30-day Rolling Avg.
Waverly Facility - 2018	Increase heat input	Yes	Potentially	42 ppmvd	30-day Rolling Avg.

For the potentially comparable turbine units listed in Table 5-6, the 42 ppmvd requirement is similar to the BACT floor limitation established per NSPS Subpart KKKK of 42 ppm at 15% O₂ or 1.3 lb/MWh useful output when firing fuel oil. Therefore, this NSPS Subpart KKKK limit represents the proposed NO_x BACT limit for the WCP turbines when combusting fuel oil. Compliance with the NSPS KKKK NO_x emission limit is determined on a 4-hour rolling average basis.¹⁵⁸ **As such, WCP proposes a BACT limit for NO_x of 42 ppmvd at 15% O₂ on a 4-hour rolling average basis when firing fuel oil, excluding periods of startup and shutdown.** Compliance will be demonstrated via CEMS.

¹⁵⁶ Permit No. 317-07 issued by the MDEQ on June 29, 2011 and revised on July 12, 2011.

¹⁵⁷ "Wolverine Power scraps plan to build coal-fired plant," *UpNorthLive News on ABC*, Sinclair Broadcast Group, Inc., December 18, 2013, <https://upnorthlive.com/news/neighborhood/wolverine-power-scraps-plan-to-build-coal-fired-plant>. (accessed January 21, 2021).

¹⁵⁸ 40 CFR 60.4350(g), 40 CFR 60.4380(b)(1)

5.6.6.3 Secondary BACT Limit – NO_x

The proposed primary BACT limits of 9.0 ppmvd and 42 ppmvd for natural gas and fuel oil firing, respectively, do not apply during periods of startup/shutdown. Secondary BACT limits are required given that the non-steady state operations during periods of startup and shutdown result in a substantially different NO_x emissions profile as the combustion units are not operating in an ideal mode for managing combustion characteristics. WCP therefore proposes a secondary BACT limit per turbine of 152.7 tpy on a rolling 12-month basis to ensure the minimization of emissions during startup/shutdown periods.

5.7 Combustion Turbines Filterable PM and Total PM₁₀/PM_{2.5} Assessment

This section contains a review of pollutant formation, possible control technologies, and the ranking and selection of such controls with associated emission limits, for proposed BACT on particulate related emissions from each simple-cycle turbine. The following sections contain details on the “top down” BACT review, as well as the control technology and emission limits selected as BACT for filterable PM and total PM₁₀/PM_{2.5}.

While BACT emission limits for PM₁₀ and PM_{2.5} must include the condensable portion of particulate, most demonstrated control techniques are limited to those that reduce filterable particulate matter. As such, control techniques for filterable PM or PM₁₀ also reduce filterable PM_{2.5}. The PM BACT analyses for filterable PM and filterable PM₁₀ will also satisfy BACT for the filterable portion of PM_{2.5}. In the prepared BACT analyses, references to PM₁₀ are also relevant for PM_{2.5}. A potential source of secondary particulate matter from the proposed projects is due to NO_x emissions from each combustion turbine. As WCP is completing a BACT review for NO_x as part of this application, secondary PM BACT formation from NO_x emissions will be indirectly addressed. The proposed project does not trigger PSD review for the PM_{2.5} precursor SO₂, as project emissions increases are less than the applicable SO₂ SER. As such, secondary PM BACT is not required to be addressed separately.

5.7.1 PM Formation – Combustion Turbines

Filterable PM, PM₁₀ and PM_{2.5} emissions from gas or distillate oil combustion result primarily from incomplete combustion and by ash and sulfur in the fuel.¹⁵⁹ Combustion of natural gas or distillate oil generates low PM emissions in comparison to other fuels due to the low ash and sulfur contents of these fuels.

In contrast to filterable particulate, condensable particulate is the portion of PM emissions that exhausts from the stack in gaseous form but condenses to form particulate matter once mixed with the cooler ambient air. Condensable particulate results from sulfur in the fuel and the resultant H₂SO₄, NO_x being oxidized to nitric acid (HNO₃), and high molecular weight organics. A combustion turbine operating without an SCR will have lower condensable PM emissions than a similar unit operating with an SCR.

5.7.2 Identification of PM Control Technologies – Combustion Turbine (Step 1)

The following PM₁₀/PM_{2.5} control technologies were identified based on RBLC search (per the search criteria specified in Section 5.4.1), a limited review of information published in technical journals, and experience in conducting control technology reviews for similar types of equipment. Taking into account the physical and operational characteristics of the units, the candidate control options for particulate matter reduction include:

¹⁵⁹ AP-42, Chapter 3, Section 1, *Stationary Gas Turbines*. April 2000.

- ▶ Multicyclone
- ▶ Wet Scrubber
- ▶ Electrostatic Precipitator (ESP)
- ▶ Baghouse
- ▶ Low sulfur fuel
- ▶ Good combustion and operating practices

5.7.2.1 *Multicyclone*

Multicyclones consist of several small cyclones operating in parallel. The cyclone creates a double vortex inside its shell, conveying centrifugal force on the inlet exhaust stream. The exhaust stream is then forced to move circularly through the cyclone, and the particulate matter in the stream is pushed to the cyclone walls. While this is effective for larger particles, smaller particles tend to be overtaken by the fluid drag force of the air stream and will depart the cyclones with the exiting air stream. The particulate removal in cyclones can be improved by having more complex gas flow patterns.¹⁶⁰ The control efficiency range for high efficiency single cyclones is 30 - 90% for PM₁₀ and 20 - 70% for PM_{2.5}. The use of multicyclones leads to greater PM control efficiency than from a single cyclone, resulting in control efficiencies in the range of 80-95% for particles greater than 5 microns in diameter (PM₅).¹⁶¹ Multicyclones in parallel can typically handle a higher flowrate when compared to a single cyclone unit, up to approximately 106,000 standard cubic feet per minute (scfm). The allowable inlet gas temperature for a cyclone is limited by the type of construction material, but can be as high as 540°C (1,000°F).¹⁶² Cyclones are generally used as precleaners for final control devices such as fabric filters/baghouses or ESPs due to the lower control efficiency of smaller particles from a cyclone.¹⁶³

5.7.2.2 *Wet Scrubber*

Wet (in particular, venturi) scrubbers intercept dust particles using droplets of liquid (usually water). The larger, particle-enclosing water droplets are separated from the remaining droplets by gravity. The solid particulates are then separated from the water. The PM collection efficiencies of Venturi scrubbers range from 70% to greater than 99%, depending on the application. Collection efficiencies are generally higher for PM with aerodynamic diameters of approximately 0.5 μm (PM_{0.5}) to 5 μm (PM₅). Inlet gas temperatures for wet scrubbers usually range from 4 to 400°C (40 to 750°F), with typical gas flowrates for single-throat scrubbers ranging from 500 to 100,000 scfm.¹⁶⁴

5.7.2.3 *ESP*

An ESP removes particles from an air stream by electrically charging the particles then passing them through a force field that causes them to migrate to an oppositely charged collector plate. After the particles are collected, the plates are knocked ("rapped"), and the accumulated particles fall into a collection hopper at the bottom of the ESP. The collection efficiency of an ESP depends on particle diameter, electrical field strength, gas flow rate, gas temperature, and plate dimensions. An ESP can be designed for either dry or

¹⁶⁰ U.S. EPA, Clean Air Technology Center, Air Pollution Control Technology Fact Sheet: Cyclones, EPA-452/F-03-005.

¹⁶¹ U.S. EPA, Clean Air Technology Center, Air Pollution Control Technology Fact Sheet: Cyclones, EPA-452/F-03-005

¹⁶² U.S. EPA, Clean Air Technology Center, Air Pollution Control Technology Fact Sheet: Cyclones, EPA-452/F-03-005

¹⁶³ U.S. EPA, Clean Air Technology Center, Air Pollution Control Technology Fact Sheet: Cyclones, EPA-452/F-03-005

¹⁶⁴ U.S. EPA, Clean Air Technology Center, Air Pollution Control Technology Fact Sheet: Venturi Scrubbers, EPA-452/F-03-017.

wet applications.¹⁶⁵ An ESP can generally achieve approximately 99-99.9% reduction efficiency for PM emissions. Typical ESPs can handle approximately 1,000 to 100,000 scfm, at high temperatures up to 700°C (1,300°F).¹⁶⁶

5.7.2.4 *Baghouse (Fabric Filter)*

A baghouse consists of several fabric filters, typically configured in long, vertically suspended sock-like configurations. Particulate laden gas enters from one side, often from the outside of the bag, passing through the filter media and forming a particulate cake. The cake is removed by shaking or pulsing the fabric, which loosens the cake from the filter, allowing it to fall into a bin at the bottom of the baghouse. The air cleaning process stops once the pressure drop across the filter reaches an economically unacceptable level. Typically, the trade-off to frequent cleaning and maintaining lower pressure drops is the wear and tear on the bags suffered in the cleaning process.¹⁶⁷ Typically, gas temperatures up to 260°C (500°F) can be accommodated routinely in a baghouse. The fabric filters have relatively high maintenance requirements (for example, periodic bag replacement), and elevated temperatures above the designed temperature can shorten the fabric life. Additionally, a baghouse/fabric filter cannot be operated in moist environments where the condensation of moisture could cause the filter to be plugged, reducing efficiency. Under the proper operating conditions, a baghouse can generally achieve approximately 99-99.9% reduction efficiency for PM emissions.¹⁶⁸

Depending on the need, baghouses are available as standard units from the factory, or custom baghouses designed for specific applications. Standard baghouses can typically handle 100 to 100,000 scfm; while custom baghouses are generally larger, ranging from 100,000 to over 1,000,000 scfm.¹⁶⁹

5.7.2.5 *Low Sulfur Fuels*

Combusting pipeline-quality natural gas with an inherently low sulfur content reduces particulate emissions compared to other available fuels as there is less potential to form H₂SO₄. Similarly, use of ultra-low sulfur diesel fuel oil also minimizes H₂SO₄ formation leading to lower particulate emissions compared to other fuel oils.

5.7.2.6 *Good Combustion and Operating Practices*

Good combustion and operating practices imply that the unit is operated within parameters that, without significant control technology, allow the equipment to operate as efficiently as possible.

A properly operated combustion unit will minimize the formation of particulate emissions due to incomplete combustion. Good operating practices typically consist of controlling parameters such as fuel feed rates and air/fuel ratios and periodic tuning.

¹⁶⁵ Kitto, J.B. *Air Pollution Control for Industrial Boiler Systems*. Barberton, OH: Babcock & Wilcox. November 1996.

¹⁶⁶ U.S. EPA, Clean Air Technology Center, Air Pollution Control Technology Fact Sheet: Dry Electrostatic Precipitator (ESP) – Wire-Pipe Type, EPA-452/F-03-027.

¹⁶⁷ Kitto, J.B. *Air Pollution Control for Industrial Boiler Systems*. Barberton, OH: Babcock & Wilcox. November 1996.

¹⁶⁸ U.S. EPA, Clean Air Technology Center, Air Pollution Control Technology Fact Sheet: Fabric Filter – Pulse-Jet Cleaned Type, EPA-452/F-03-025.

¹⁶⁹ U.S. EPA, Clean Air Technology Center, Air Pollution Control Technology Fact Sheet: Fabric Filter – Pulse-Jet Cleaned Type, EPA-452/F-03-025.

5.7.3 Elimination of Technically Infeasible PM Control Options – Combustion Turbines (Step 2)

All four of the add-on control technologies (multicyclones, wet scrubbers, ESPs, and baghouses) are technically infeasible for filterable particulate from natural gas combustion. Although the add-on control technologies identified are utilized in a number of processes to control particulate emissions, none of these add-on control technologies are applicable to natural gas-fired or fuel oil fired combustion turbines. Combustion of natural gas and ultra-low sulfur diesel generates relatively low levels of particulate emissions in comparison to other fuels due to the low ash and sulfur contents. In addition, turbines operate with a significant amount of excess air, which generates large exhaust flow rates. The low level of particulate emissions combined with the large exhaust gas volume results in very low concentrations of particulate.

Due to the low particulate concentration in the exhaust gas, add-on filterable particulate controls would not provide any significant degree of emission reduction for the combustion turbines and are therefore not considered further in this analysis.¹⁷⁰

5.7.4 Summary and Ranking of Remaining PM Controls – Combustion Turbines (Step 3)

Of the control technologies available for PM₁₀/PM_{2.5} emissions, the options technically feasible for each unit are shown in Table 5-7.

Table 5-7. Remaining Particulate Matter Control Technologies

Control Technology	Technically Feasible for Combustion Turbine
Multicyclones	No
Wet Scrubber	No
ESP	No
Baghouse	No
Low Sulfur Fuel	Yes
Good Combustion and Operating Practices	Yes

As shown in Table 5-7, the remaining feasible control technologies include low sulfur fuels and good combustion and operating practices. Good combustion and operating practices in conjunction with low sulfur natural gas or ultra-low sulfur diesel combustion represents the base case for the combustion turbines. Therefore, as this is the highest-ranking feasible control remaining, it is selected as BACT.

5.7.5 Evaluation of Most Stringent PM Controls – Combustion Turbines (Step 4)

As stated previously, good combustion and operating practices with low sulfur natural gas or ultra-low sulfur diesel for the combustion turbines was determined as the most stringent filterable PM and total PM₁₀/PM_{2.5} control that is a technically feasible option.

¹⁷⁰ Application No. 17040013, *Project Summary for a Construction Permit Application from Jackson Generation, LLC, for an Electrical Generating Facility in Elwood, Illinois*, issued by the Illinois EPA for the public comment period beginning on September 21, 2018. Discussion related to selection of BACT for emissions of particulates, page 43.

5.7.6 Selection of Emission Limits and Controls for PM BACT – Combustion Turbines (Step 5)

The simple-cycle combustion turbines will not be subject to any NSPS or NESHAP standard for PM/PM₁₀/PM_{2.5} and thus there is no floor of allowable PM/PM₁₀/PM_{2.5} BACT limits. The units are also not subject to any PM emission limit per the GRAQC.

As the selected BACT for particulate matter emissions relies on good combustion and operating practices in conjunction with the use of low sulfur natural gas or ultra-low sulfur diesel, WCP searched U.S. EPA's RBLC database for modifications of similar units at other facilities to determine what has been established as a BACT emission requirement for comparable operations. Numerous entries for natural gas and fuel oil fired simple-cycle systems are provided in Appendix C. Review of the RBLC entries confirms that add-on control for particulate emissions is not required for natural gas-fired or fuel oil fired simple-cycle combustion turbines. Typical listings denote "good combustion practices" or similar variants. "Good combustion practices" typically refers to practices inherent in the routine operation and maintenance of the generating unit, such as automated operating systems and periodic tuning of the turbines.

Once the technology is established, an emission limitation must be proposed, and review of the RBLC entries provides an indication of what has been considered appropriate BACT emission limitations for potentially similar units as those being modified by WCP. As discussed previously, the following qualifying criteria were relied upon in review of the RBLC entries per Appendix C to identify potentially comparable units to the WCP turbines:

- ▶ Turbine is existing and proposed for a modification; exclude units proposed for initial construction;
- ▶ Units are similar GE Frame 7 units, and
- ▶ Units are utilized for the purposes of power generation and not utilized for other purposes such as compression.

This review has been conducted on a fuel-specific basis, detailed in the following sections.

5.7.6.1 Selection of Emission Limits for PM BACT - Natural Gas Firing

Table 5-8 includes PM RBLC database entries for turbine units combusting natural gas which are potentially comparable to the existing units at the WCP facility.

Table 5-8. Natural Gas Simple-Cycle Combustion Turbine PM RBLC Data for Potentially Modified Units

Facility Name	State	Permit Issuance	System Size	Turbine Model	PM Emission Limit ^[1]	Units ^[1]	Notes
Cunningham Power Plant	NM	5/2/2011	Unknown	Unknown	5.4 (FPM ₁₀)	lb/hr	Two simple-cycle combustion turbines utilizing good combustion practices as a control method. The turbines are capable of operating with or without power augmentation. Permit revises the NO _x BACT ppmvd limit for turbines established in previous PSD Permit No. PSD-NM-622-M2 because turbines have not been able to meet NO _x BACT limits.
Calcasieu Plant	LA	12/21/2011	1,900 MMBtu/hr Heat Input for Each Turbine	Unknown	17.0 (TPM ₁₀ and TPM _{2.5})	lb/hr	Two simple-cycle combustion turbines of unknown make and model which utilizes pipeline natural gas as a control method. PSD was triggered due to relaxation of a federally enforceable condition limiting potential emissions below major stationary source thresholds; subsequently revoked. PSD permit issued in 2015 lists the emission limitation for PM as 20 lb/hr.
Westar Energy – Emporia Energy Center	KS	3/18/2013	405 MMBtu/hr Heat Input for Each Turbine	GE LM6000 PC Sprint	6.0 (TPM and TPM ₁₀)	lb/hr	Four GE LM6000 PC Sprint natural gas fired simple-cycle turbines which are considered aeroderivative turbines and utilize pipeline quality natural gas as a control method.
Westar Energy – Emporia Energy Center	KS	3/18/2013	1,780 MMBtu/hr Heat Input for Each Turbine	GE 7FA	18.0 (TPM and TPM ₁₀)	lb/hr	Three GE 7FA natural gas fired simple-cycle turbines which utilize pipeline quality natural gas as a control method.
Pueblo Airport Generating Station	CO	5/30/2014	375 MMBtu/hr Heat Input	GE LM6000	4.8 (TPM ₁₀ and TPM _{2.5})	lb/hr	One GE LM6000 simple-cycle gas turbine (Unit 6 – CT08) which is considered an aeroderivative unit and utilizes pipeline quality natural gas and good combustor design as control methods.
Doswell Energy Center	VA	10/4/2016	1,961 MMBtu/hr for Each Turbine	GE Frame 7FA	0.0051 (10.0 lb/hr) (FPM) 0.00612 (12.0 lb/hr) (TPM ₁₀ and TPM _{2.5})	lb/MMBtu	Authorization to add two 170 MW GE 7FA.03 natural gas fired, simple-cycle combustion turbines (CT-2 and CT-3) at the Doswell Energy Center (DEC). Both CT-2 and CT-3 were proposed to be brought to DEC from an existing permitted site in Desoto, Florida. They are both similar in age and capability to the existing 190.5 MW GE 7FA.03 simple-cycle combustion turbine (CT-1) at the facility. The turbines utilize good combustion, operation, and maintenance practices and use of pipeline quality natural gas as control methods. CT-1 was added in a PSD permit dated April 7, 2000 and last amended on September 30, 2013. A modified PSD permit was issued on July 30, 2018. As a part of the modified PSD permit, emission limits for FPM and TPM ₁₀ /TPM _{2.5} were increased to 0.00513 lb/MMBtu and 0.00686 lb/MMBtu, respectively.
Waverly Facility	WV	1/23/2017	1,571 MMBtu/hr for Each Turbine	GE 7FA	15.0 (TPM, TPM ₁₀ , and TPM _{2.5})	lb/hr	Two GE Model 7FA turbines which are capable of combusting natural gas and firing fuel oil as back-up. The turbines utilize inlet air filtration as a control method. In this permitting action PSD only applies to the modified combustion turbines based on the relaxation of an original synthetic minor permit issued in 1999. Project also involves previous installation of turbo-charging. All BACT emission limits are given without turbocharging.

Facility Name	State	Permit Issuance	System Size	Turbine Model	PM Emission Limit ^[1]	Units ^[1]	Notes
Waverly Power Plant	WV	3/13/2018	167.8 MW with 2,013 MMBtu/hr Heat Input for Each Turbine	GE 7FA.004	15.09 (TPM, TPM ₁₀ , and TPM _{2.5})	lb/hr	Two GE Model 7FA turbines which are capable of combusting natural gas and firing fuel oil as back-up. The turbines utilize inlet air filtration as a control method. Emission limitation does not include periods of startup or shutdown. Modification to existing PSD Permit (R14-0034, RBLC Number WV-0027) to add advanced gas path technology to the turbines that was defined as a change in the method of operation that resulted a major modification to the turbines.
Cameron LNG Facility	LA	2/17/2017	1,069 MMBtu/hr Heat Input for Each Turbine	Unknown	0.0076 (TPM ₁₀ and TPM _{2.5})	lb/MMBtu	Gas turbines which utilize good combustion practices and natural gas fuel as control methods.
Mustang Station	TX	8/16/2017	163 MW	GE 7FA	27.0 (18.0 lb/hr) (TPM, TPM ₁₀ and TPM _{2.5})	ton/yr	One 163 MW GE 7FA turbine (Unit No. 6) which was constructed in 2013 and utilizes good combustion practices and natural gas fuel as control methods. Permit involved increasing the turbine hours of operation to 3,000 hours per year.
Jackson County Generators	TX	1/26/2018	230 MW for Each Turbine	Unknown	11.81 (10.19 lb/hr) (TPM, TPM ₁₀ and TPM _{2.5})	ton/yr	Four natural gas fired simple-cycle combustion turbines which utilize good combustion practices and natural gas fuel as control methods.
Ector County Energy Station ^[2]	TX	8/17/2020	Unknown	Unknown	-	-	Two simple-cycle gas turbines equipped with DLN burners for control. Firing of pipeline quality natural gas and good combustion practices is considered BACT for the turbines; a numeric emission limit was not established.

^[1] Please note that the Emission Limit and Averaging Periods for each RBLC entry was cross referenced with the associated air permit for each entry, as available. Corrections were made as necessary, to ensure that emission limits and averaging periods were consistent with the air permits associated with each RBLC entry.

^[2] Facility did not have a RBLC database entry for PM associated with the turbine unit for natural gas firing. However, upon further review of associated permits, permit applications, and other available documentation, it was determined that established BACT limits for PM existed for the associated turbine units when firing natural gas. The established BACT limits for PM were added to this table.

The RBLC entries detailed in Table 5-8 includes potential modifications at facilities which were discussed in Section 5.6.6.1, with the addition of the Pueblo Airport Generating Station in Pueblo, Colorado. Many of the RBLC database entries have been conservatively included in Table 5-8 as they could not be ruled out as units proposed for construction based on information presented in the RBLC database entry alone. As was previously stated, further review of available air permits, permit applications, and other facility documentation proved that many of the turbine units associated with these RBLC database entries are not necessarily comparable to the WCP turbine units. This was also the case for the RBLC entry associated with the Pueblo Airport Generating Station, as the associated turbine unit for that RBLC entry is a GE LM6000 model turbine which is considered an aeroderivative turbine. Aeroderivative turbines have a much smaller power output than what would be expected from a large frame unit such as a GE Frame 7 turbine; therefore, the GE LM6000 PC turbines cannot be considered comparable units to reference for selection of BACT emission limits based on size.

A review of the proposed control technologies for these facilities shows that use of good combustion practices and pipeline quality natural gas are common requirements for BACT. WCP already incorporates the use of good combustion practices and utilizes pipeline quality natural gas as fuel for the existing turbine systems.

As was discussed in detail in Section 5.6.6.1, there are various factors as to why, even with the use of the same control technologies, the emission limits presented for the facilities in Table 5-8 are not necessarily directly comparable to the WCP units. Table 5-9 summarizes whether the RBLC listing was actually for a modification of an existing unit, if the turbine involved was a GE Frame 7 turbine, and whether the facilities in Table 5-8 are comparable to the WCP units based on these factors.

Table 5-9. Unit Comparability for PM Assessment – Natural Gas Firing

Site	Modification?	GE Frame 7 Turbine?	Comparable?	PM Emission Limit	Estimated lb/MMBtu
Cunningham Station Power Plant	Increase NO _x BACT Emission Limits	No, Westinghouse 501D5A	No		Not Comparable
Calcasieu Plant ^[1]	Increase hours, heat input	Unknown	Yes	20.0 lb/hr (TPM ₁₀ /TPM _{2.5})	0.0105 (TPM ₁₀ and TPM _{2.5})
Emporia Energy Center – GE LM6000PC Units	N/A	No	No		Not Comparable
Emporia Energy Center – GE 7FA	No (New in 2007) Added Tuning Requirements in 2013	Yes	No (New Unit) Yes (Engine Type)	18.0 lb/hr (TPM/TPM ₁₀)	0.0101 (TPM and TPM ₁₀)
Pueblo Airport Generating Station	N/A	No	No		Not Comparable
Doswell Energy Center ^[2]	Turbine Relocation	Yes	Yes	0.00513 lb/MMBtu (9.0 lb/hr) (FPM) 0.00686 lb/MMBtu (12.0 lb/hr)	0.00513 (FPM) 0.00686 (TPM/TPM ₁₀ /TPM _{2.5})

Site	Modification?	GE Frame 7		PM Emission Limit	Estimated lb/MMBtu
		Turbine?	Comparable?		
(TPM/TPM ₁₀ /TPM _{2.5})					
Waverly Facility - 2017	Relaxed synthetic minor limits	Yes	Potentially	15.0 lb/hr (TPM, TPM ₁₀ , TPM _{2.5})	0.0095 (TPM, TPM ₁₀ , TPM _{2.5})
Waverly Facility - 2018	Increase heat input	Yes	Potentially	15.09 lb/hr (TPM, TPM ₁₀ , TPM _{2.5})	0.0075 (TPM, TPM ₁₀ , TPM _{2.5})
Cameron LNG Facility	No – New	Compressor Turbines	No	Not Comparable	
Mustang Station	Increase hours	Yes, 2013 install	Potentially	27.0 ton/yr (18.0 lb/hr) (TPM/TPM ₁₀ /TPM _{2.5})	Heat Input Capacity not determined
Jackson County Generators	No	No, Siemens F5	No	Not Comparable	
Ector County Energy Station	No (New in 2014), increased hours in 2020	Yes	Potentially	No Emission Limit Specified as BACT	

^[1] PSD Permit No. PSD-LA-746 issued on December 21, 2011 listed an emission limit for PM₁₀ of 17.0 lb/hr. However, this permit was requested for revocation in a 2012 Title V Renewal Application. PSD Permit No. PSD-LA-798 was issued on June 1, 2015 and established the emission limit for PM₁₀ as 20 lb/hr.

^[2] PSD Permit issued on October 4, 2016 listed the emission limit for FPM and TPM₁₀/PM_{2.5} as 0.00510 lb/MMBtu (10.0 lb/hr) and 0.00612 lb/MMBtu (12.0 lb/hr), respectively. A modified PSD permit was issued on July 30, 2018. As a part of the modified PSD permit, emission limits for FPM and TPM₁₀/PM_{2.5} were increased to 0.00513 lb/MMBtu (9.0 lb/hr) and 0.00686 lb/MMBtu (12.0 lb/hr), respectively.

For the units detailed in Table 5-9 that are potentially comparable to the modified WCP units, most limits for total PM₁₀/total PM_{2.5} are specified in terms of lb/hr. As this mass emission rate is dependent on the size of the combustion turbine, a direct comparison in terms of lb/hr is not appropriate. To facilitate a limit comparison, where information was readily available, an equivalent lb/MMBtu has been estimated. Based on the available data, the range of BACT limits for TPM/TPM₁₀/TPM_{2.5} when combusting natural gas is between 0.00686 – 0.0105 lb/MMBtu for units that are potentially comparable to the WCP turbines.

A historical review of information available for the WCP turbines when installed indicates a 19 lb/hr Total Suspended Particulate (TSP) and PM₁₀ guarantee. Given installation of the units in the early 2000s, these guarantees were likely intended to be filterable values based on Method 5 test methods. WCP, not the original site owners, does not have testing data related to the original turbine commissioning, nor has any recent PM related testing been conducted. When looking at the range of potential BACT limits (0.00686 – 0.0105 lb/MMBtu) and the heat input capacity of 1,766 MMBtu/hr for natural gas, the equivalent lb/hr rates would range from 12.1 – 18.5 lb/hr for total PM/PM₁₀/PM_{2.5}. As the highest lb/hr from the range for total PM is slightly less than the original manufacturer guarantee for filterable PM, WCP is proposing a BACT value that is higher than those summarized in Table 5-9.

If WCP relied on AP-42 for determining condensable emissions from the turbines 8.3 lb/hr of condensable PM would be estimated, leading to an estimated total PM/PM₁₀/PM_{2.5} of 27.3 lb/hr (0.0155 lb/MMBtu) when

combined with the filterable PM guarantee.¹⁷¹ However, WCP recognizes there is likely some conservatism in both the original guarantee and the AP-42 factor. Given the challenges associated with accurate measurement of condensables, and the lack of available test data for the WCP turbines, **WCP is proposing a BACT emission limit for each turbine of 24.2 lb/hr for total PM/PM₁₀/PM_{2.5}, equivalent to an emission rate of 0.0137 lb/MMBtu.** Compliance with this BACT limit will be demonstrated by stack testing via U.S. EPA Method 5 and/or 201A in conjunction with Method 202 or alternative methods as appropriate.

5.7.6.2 Selection of Emission Limits for PM BACT – Fuel Oil Firing

Table 5-10 includes PM RBLC database entries for turbine units combusting fuel oil which may be potentially comparable to the existing units at the WCP facility.

¹⁷¹ 1,766 MMBtu/hr (natural gas capacity) * 4.7E-3 lb condensables/MMBtu. Emission factor for Condensable PM is obtained from AP-42 Section 3.1, *Stationary Gas Turbines*, Table 3.1-2a (April 2000).

Table 5-10. Fuel Oil Simple-Cycle Combustion Turbine PM RBLC Data for Potentially Modified Units

Facility Name	State	Permit Issuance	System Size	Turbine Model	PM Emission Limit ^[1]	Units ^[1]	Notes
Wolverine Power	MI	6/29/2011	540 MMBtu/hr Heat Input	Unknown	0.03 (16.2 lb/hr) (TPM ₁₀ and TPM _{2.5})	lb/MMBtu	One ULSD fired turbine generator which will be used to start the plant when there is no power available from the electric grid and the plant must be brought back into service. Turbine utilizes good combustion control technology.
Waverly Facility ^[2]	WV	1/23/2017	1,571 MMBtu/hr for Each Turbine	GE 7FA	39.0	lb/hr	Two GE Model 7FA turbines which are capable of combusting natural gas and firing fuel oil as back-up. Turbines utilize inlet air filtration for control of PM. In this permitting action PSD only applies to the modified combustion turbines based on the relaxation of an original synthetic minor permit issued in 1999. Project also involves previous installation of turbo-charging. All BACT emission limits are given without turbocharging and startup/shutdown emissions are not included.
Waverly Power Plant ^[2]	WV	3/13/2018	167.8 MW with 2,013 MMBtu/hr Heat Input for Each Turbine	GE 7FA.004	39.0	lb/hr	Two GE Model 7FA turbines which are capable of combusting natural gas and firing fuel oil as back-up. Turbines utilize inlet air filtration for control of PM. Modification to existing PSD Permit (R14-0034, RBLC Number WV-0027) to add advanced gas path technology to the turbines that was defined as a change in the method of operation that resulted a major modification to the turbines.

^[1] Please note that the Emission Limit and Averaging Periods for each RBLC entry was cross referenced with the associated air permit for each entry, as available. Corrections were made as necessary, to ensure that emission limits and averaging periods were consistent with the air permits associated with each RBLC entry.

^[2] Facility did not have a RBLC database entry for PM associated with the turbine unit for fuel oil firing. However, upon further review of associated permits, permit applications, and other available documentation, it was determined that established BACT limits for PM existed for the associated turbine units when firing fuel oil. The established BACT limits for PM were added to this table.

5.7.6.2.1 Summary – Fuel Oil PM BACT

The anticipated PM BACT for fuel oil firing will be good combustion practices and the use of ultra-low sulfur diesel. As was previously discussed, there are various factors as to why, even with the use of the same control technologies, the emissions limits presented for the facilities in Table 5-10 are not necessarily directly comparable to the WCP units. Table 5-11 summarizes whether the RBLC listing was actually for a modification of an existing unit, if the turbine involved was a GE Frame 7 turbine, and whether the facilities in Table 5-10 are comparable to the WCP units based on these factors.

Table 5-11. Unit Comparability for PM Assessment – Fuel Oil Firing

Site	Modification?	GE Frame 7 Turbine?	Comparable?	PM Emission Limit	Estimated lb/MMBtu
Wolverine Power	No – New	Unknown	No	Project Voided – Facility Was Not Built	
Waverly Facility - 2017	Relaxed synthetic minor limits	Yes	Potentially	39.0 lb/hr (TPM, TPM ₁₀ , TPM _{2.5})	0.0248 (TPM, TPM ₁₀ , TPM _{2.5})
Waverly Facility - 2018	Increase heat input	Yes	Potentially	39.0 lb/hr (TPM, TPM ₁₀ , TPM _{2.5})	0.0194 (TPM, TPM ₁₀ , TPM _{2.5})

For the units detailed in Table 5-11 that are potentially comparable to the modified WCP units, the limits for total PM/PM₁₀/total PM_{2.5} are specified in terms of lb/hr. As this mass emission rate is dependent on the size of the combustion turbine, a direct comparison in terms of lb/hr is not appropriate. To facilitate a limit comparison, where information was readily available, an equivalent lb/MMBtu has been estimated. Based on the available data, the range of BACT limits for TPM/TPM₁₀/TPM_{2.5} when combusting fuel oil is between 0.0194 – 0.0248 lb/MMBtu for units that are potentially comparable to the WCP turbines.

Based on emissions information specific to turbines operated elsewhere by the owners of the WCP facility, **WCP proposes a BACT emission limit for each simple-cycle system of 26.8 lb/hr for filterable PM/total PM₁₀/PM_{2.5}, equivalent to an emission rate of 0.0142 lb/MMBtu.** Compliance with this BACT limit will be demonstrated by stack testing via U.S. EPA Method 5 and/or 201A in conjunction with Method 202 or alternative methods as appropriate.

5.7.6.3 Secondary BACT Limit – PM

Secondary BACT limits are not proposed as the particulate emissions of the combustion turbines are not considered to be dependent on control measures with varying effectiveness nor will they vary substantially in startup or shutdown modes.

5.8 Combustion Turbines CO Assessment

This section contains a review of pollutant formation, possible control technologies, and the ranking and selection of such controls with associated emission limits, for proposed BACT for CO emissions from each combustion turbine. The following sections details the “top down” BACT review, as well as the control technology and emission limits that are selected as BACT for CO.

5.8.1 CO Formation – Combustion Turbines

CO from combustion turbines is a by-product of incomplete combustion. Conditions leading in incomplete combustion can include insufficient oxygen availability, poor fuel/air mixing, reduced combustion-temperature, reduced combustion gas residence time, and load reduction. In addition, combustion modifications taken to ensure NO_x emissions remain low may result in increased CO emissions.

5.8.2 Identification of CO Control Technologies – Combustion Turbines (Step 1)

Candidate control options identified from the RBLC search and the literature review include those classified as pollution reduction techniques such as oxidation catalyst and combustion process design and good combustion practices.

5.8.2.1 Oxidation Catalysts

An oxidation catalyst is a post-combustion control technology that utilizes a catalyst to oxidize CO at lower temperatures. The addition of a catalyst to the basic thermal oxidation process accelerates the rate of oxidation by adsorbing oxygen from the air stream and CO in the waste stream onto the catalyst surface to react to form CO₂ and H₂O.

5.8.2.2 EM_xTM/SCONO_xTM

EM_xTM (the second-generation of the SCONO_x NO_x Absorber Technology) is a multi-pollutant control technology that utilizes a coated oxidation catalyst to remove both NO_x and CO without a reagent, discussed in Section 5.6.2.4.

5.8.2.3 Combustion Process Design and Good Combustion Practices

To minimize incomplete combustion and the resulting formation of CO, this control technology includes proper equipment design, proper operation, and good combustion practices. Proper equipment design is important in minimizing incomplete combustion by allowing for sufficient residence time at high temperature as well as turbulence to mitigate incomplete mixing. Generally, the effect of combustion zone temperature and residence time on CO emissions is the opposite of their effect on NO_x emissions. Accordingly, it is critical to optimize oxygen availability with input air, while controlling temperature to minimize NO_x formation.

5.8.3 Elimination of Technically Infeasible CO Control Options – Combustion Turbines (Step 2)

The second step in the BACT process is the elimination of technically infeasible control options based on process-specific conditions that prohibit implementation of the control, or the lack of commercial demonstration of achievability.

5.8.3.1 Oxidation Catalyst

Catalytic oxidizers typically operate within a temperature range between 600 to 800°F.¹⁷² Given the exhaust temperature of utility-scale simple-cycle combustion turbines is typically in excess of 1,000°F, use of oxidation catalyst could be considered technically infeasible, although the possibility of utilizing tempering air to reduce the inlet exhaust temperature, at substantial costs, exists. Therefore, oxidation catalyst is

¹⁷² U.S. EPA, CATC Fact Sheet for Catalytic Incineration, EPA-452/F-03-018. Available at: www.epa.gov/ttn/catc/dir1/fcataly.pdf

considered technically feasible for installation on the Facility's combustion turbines and will be considered further in Step 4 to evaluate cost effectiveness.

5.8.3.2 *EM_xTM/SCONO_xTM*

The EM_xTM/SCONO_xTM catalyst system is a post-combustion technology that utilizes a proprietary oxidation catalyst and absorption technology using a single catalyst (potassium carbonate) for removal of NO_x, CO, and VOC without the use of ammonia. As summarized by Illinois EPA in their project summary for the Jackson Energy Center PSD permit, the EM_xTM/SCONO_xTM catalyst system has operated successfully on several smaller, natural gas-fired combined-cycle units, but there are engineering challenges with applying this technology to larger plants with full scale operation.¹⁷³ Additionally, the operating range of the catalyst is 300 to 700°F, well below the exhaust temperature for simple-cycle combustion turbines.¹⁷⁴

Consequently, it is concluded that EM_xTM/SCONO_xTM is not technically feasible for control of CO emissions from the WCP turbines.

5.8.3.3 *Combustion Process Design and Good Combustion Practices*

This represents the base case for design and operation of the simple-cycle combustion turbines.

5.8.4 **Summary and Ranking of Remaining CO Controls – Combustion Turbines (Step 3)**

As detailed in the Step 2 analysis for CO per Section 5.8.3, the only add-on control technically feasible to reduce emissions below the base case (Combustion Process Design and Good Combustion Practices) is oxidation catalyst. As a technically feasible control option, it must be evaluated further in the BACT process.

5.8.5 **Evaluation of Most Stringent CO Controls – Combustion Turbines (Step 4)**

Oxidation catalyst is the highest ranking potentially feasible control technology for both natural gas and fuel oil combustion in the turbines. The estimated cost of controlling CO using oxidation catalyst for the WCP turbines is more than \$28K per ton of CO removed based on the detailed cost analysis provided in Appendix D, developed using the methods outline by the U.S. EPA in the OAQPS guidance manual.¹⁷⁵ Similar to the technical challenges discussed for SCR for NO_x emissions reductions, estimated costs are high given the high volume of tempering air that would be required to reduce the turbine exhaust temperatures to an acceptable range for operation of an oxidation catalyst. Therefore, WCP concludes that an oxidation catalyst is not cost effective and is not considered BACT for the Facility's turbines

Therefore, combustion process design and good combustion practices represent BACT for the Facility's combustion turbines for CO.

¹⁷³ Application No. 17040013, *Project Summary for a Construction Permit Application from Jackson Generation, LLC, for an Electrical Generating Facility in Elwood, Illinois*, issued by the Illinois EPA for the public comment period beginning on September 21, 2018. Discussion related to selection of BACT for emissions of NO_x, Attachment B pages 14.

¹⁷⁴ U.S. EPA Office of Air and Radition, *Final Technical Support Document (TSD) for the Cross-State Air Pollution Rule for the 2008 Ozone NAAQS: Assessment of Non-EGU NO_x Emission Controls, Cost of Controls, and Time for Compliance Final TSD*, August 2016, Appendix A, Page 3-5. Docket ID No. EPA-HQ-OAR-2015-0500.

¹⁷⁵ U.S. EPA, *OAQPS Control Cost Manual*, 6th edition, EPA 452/B-02-001, July 2002.

http://www.epa.gov/ttn/catc/dir1/c_allchs.pdf

For more details on the updating of the control cost manual see <https://www.epa.gov/economic-and-cost-analysis-air-pollution-regulations/cost-reports-and-guidance-air-pollution>

5.8.6 Selection of Emission Limits and Controls for CO BACT – Combustion Turbines (Step 5)

The simple-cycle combustion turbines are not presently subject to a CO emission limit and NSPS Subpart KKKK does not establish emission standards for CO. Accordingly, a BACT floor for CO does not exist.

As the selected BACT for CO emissions relies on the combustion process design and good combustion practices, WCP searched U.S. EPA's RBLC database for modifications of similar units at other facilities to determine what has been established as a BACT emission requirement for comparable operations. Numerous entries for natural gas or fuel oil simple-cycle combustion turbines are provided in the RBLC summary table in Appendix C. Review of the RBLC entries confirms that BACT for CO emissions are typically combustion process design and good combustion practices for similarly sized simple-cycle combustion turbines. "Good combustion practices" typically refers to practices inherent in the routine operation and maintenance of the generating unit, such as automated operating systems and periodic tuning of the turbines.

Once the technology is established, an emission limitation must be proposed, and review of the RBLC entries provides an indication of what has been considered appropriate BACT emission limitations for potentially similar units as those being modified by WCP. As discussed previously, the following qualifying criteria were relied upon in review of the RBLC entries per Appendix C to identify potentially comparable units to the WCP turbines include:

For these RBLC entries, further research was conducted as needed using available permits, permit applications, and public documentation. The following qualifying criteria for potentially comparable units to the WCP turbines include:

- ▶ Turbine is existing and proposed a modification; exclude units proposed for initial construction;
- ▶ Control method does not include control technologies which have been deemed to be infeasible (i.e., Oxidation Catalyst, EM_xTM/SCONO_xTM);
- ▶ Units are similar GE Frame 7 units; and
- ▶ Units are utilized for the purposes of power generation and not utilized for other purposes such as compression.

This review has been conducted on a fuel-specific basis, detailed in the following sections.

5.8.6.1 Selection of Emission Limits for CO BACT - Natural Gas Firing

Table 5-12 includes CO RBLC database entries for turbine units combusting natural gas which are potentially comparable to the existing units at the WCP facility.

Table 5-12. Natural Gas Fired Simple-Cycle Combustion Turbine CO RBLC Data for Potentially Modified Units

Facility Name	State	Permit Issuance	System Size	Turbine Model	CO Emission Limit ^[1]	Units ^[1]	Averaging Period ^[1]	Notes
Cunningham Power Plant ^[2]	NM	5/2/2011	Unknown	Unknown	77.2 and 138.9	lb/hr	-	Two simple-cycle combustion turbines equipped with DLN, capable of operating with or without power augmentation, and using good combustion practices as a control method. The turbines have specific CO limitations for each operating mode (emissions of CO are limited to 77.2 lb/hr without power augmentation and 138.9 lb/hr with power augmentation). CO emission limit excludes periods of startup and shutdown. Permit revises the NO _x BACT ppmvd limit for turbines established in previous PSD Permit No. PSD-NM-622-M2 because turbines have not been able to meet NO _x BACT limits.
Calcasieu Plant	LA	12/21/2011	1,900 MMBtu/hr Heat Input for Each Turbine	Unknown	15.0 (781.0 lb/hr)	ppmvd @ 15% O ₂	Annual Avg.	Two simple-cycle combustion turbines of unknown make and model utilizing DLN combustors. CO emission limit excludes periods of startup and shutdown. PSD was triggered due to relaxation of a federally enforceable condition limiting potential emissions below major stationary source thresholds; subsequently revoked. PSD permit issued in 2015 lists the emission limitation for CO as 15.83 ppmvd @ 15% O ₂ .
Westar Energy – Emporia Energy Center	KS	3/18/2013	405 MMBtu/hr Heat Input for Each Turbine	GE LM6000 PC Sprint	63.8 @ temps. ≤ 54 °F 36.0 @ temps. > 54 °F	lb/hr	At full load	Four GE LM6000 PC Sprint natural gas fired simple-cycle turbines which are considered aeroderivative turbines. CO emission limit excludes periods of startup, shutdown, or malfunction. Turbines utilize efficient combustion/design technology for control of CO.
Westar Energy – Emporia Energy Center	KS	3/18/2013	1,780 MMBtu/hr Heat Input for Each Turbine	GE 7FA	39.0	lb/hr	At full load	Three GE 7FA natural gas fired simple-cycle turbines which utilize DLN burners for control. CO emission limit excludes periods of startup, shutdown, or malfunction. Turbines utilize efficient combustion/design technology for control of CO.
Doswell Energy Center	VA	10/4/2016	1,961 MMBtu/hr for Each Turbine	GE Frame 7FA	4.0 (0.00713 lb/MMBtu) (14.0 lb/hr)	ppmvd @ 15% O ₂	3-hr Avg.	Authorization to add two 170 MW GE 7FA.03 natural gas fired, simple-cycle combustion turbines (CT-2 and CT-3) at the Doswell Energy Center (DEC) equipped with DLN burners. Both CT-2 and CT-3 were proposed to be brought to DEC from an existing permitted site in Desoto, Florida and utilize pipeline quality natural gas as a control method. They are both similar in age and capability to the existing 190.5 MW GE 7FA.03 simple-cycle combustion turbine (CT-1) at the facility. CT-1 was added in a PSD permit dated April 7, 2000 and last amended on September 30, 2013. Emissions of CO exclude periods of startup, shutdown, and tuning.

Facility Name	State	Permit Issuance	System Size	Turbine Model	CO Emission Limit ^[1]	Units ^[1]	Averaging Period ^[1]	Notes
Waverly Facility	WV	1/23/2017	1,571 MMBtu/hr for Each Turbine	GE 7FA	9.0	ppm @ loads of 60% or higher	30-day Rolling Avg.	Two GE Model 7FA turbines which are capable of combusting natural gas and firing fuel oil as back-up. The combustion turbines employ the use of DLN burners when firing natural gas. Turbines utilize good combustion practices as a control method. In this permitting action PSD only applies to the modified combustion turbines based on the relaxation of an original synthetic minor permit issued in 1999. Project also involves previous installation of turbo-charging. All BACT emission limits are given without turbocharging and startup/shutdown emissions are not included.
Waverly Power Plant	WV	3/13/2018	167.8 MW with 2,013 MMBtu/hr Heat Input for Each Turbine	GE 7FA.004	9.0	ppm @ loads of 60% or higher	30-day Rolling Avg.	Two GE Model 7FA turbines which are capable of combusting natural gas and firing fuel oil as back-up. The combustion turbines employ the use of DLN burners when firing natural gas. Modification to existing PSD Permit (R14-0034, RBLC Number WV-0028) to add advanced gas path technology to the turbines that was defined as a change in the method of operation that resulted a major modification to the turbines.
Cameron LNG Facility	LA	2/17/2017	1,069 MMBtu/hr Heat Input for Each Turbine	Unknown	15.0	ppmvd @ 15% O ₂	1-hr Avg.	Gas turbines which utilize DLN burners and good combustion practices as control.
Mustang Station ^[2]	TX	8/16/2017	163 MW	GE 7FA	9.0	ppmvd @ 15% O ₂	3-hr Rolling Avg.	One 163 MW GE 7FA turbine (Unit No. 6) which was constructed in 2013 and utilizes DLN burners. Turbine uses good combustion practices as a control method. Permit involved increasing the turbine hours of operation to 3,000 hours per year. CO emission limit excludes periods of maintenance, startup, and shutdown.
Jackson County Generators	TX	1/26/2018	230 MW for Each Turbine	Unknown	9.0	ppmvd @ 15% O ₂	3-hr Rolling Avg.	Four natural gas fired simple-cycle combustion turbines which utilizes DLN burners for control. CO emission limit excludes periods of startup and shutdown.
Ector County Energy Station ^[2]	TX	8/17/2020	Unknown	Unknown	9.0	ppmvd @ 15% O ₂	3-hr Rolling Avg.	Two simple-cycle gas turbines equipped with DLN burners which utilize good combustion practices as a control method. Emission limit for CO applies to normal operations.

^[1] Please note that the Emission Limit and Averaging Periods for each RBLC entry was cross referenced with the associated air permit for each entry, as available. Corrections were made as necessary, to ensure that emission limits and averaging periods were consistent with the air permits associated with each RBLC entry.

^[2] Facility did not have a RBLC database entry for CO associated with the turbine unit for natural gas firing. However, upon further review of associated permits, permit applications, and other available documentation, it was determined that established BACT limits for CO existed for the associated turbine units when firing natural gas. The established BACT limits for CO were added to this table.

The RBLC entries detailed in Table 5-12 includes potential modifications at facilities which were discussed in Section 5.6.6.1. Many of the RBLC database entries have been conservatively included in Table 5-12 as they could not be ruled out as units proposed for construction based on information presented in the RBLC database entry alone. As was previously stated, further review of available air permits, permit applications, and other facility documentation proved that many of the turbine units associated with these RBLC database entries are not comparable to the WCP turbine units.

A review of the proposed control technologies for these facilities shows that use of good combustion practices and pipeline quality natural gas are common requirements for BACT. WCP already incorporates the use of good combustion practices and utilizes pipeline quality natural gas as fuel for the existing turbine systems. WCP will continue to utilize those controls as BACT when firing natural gas in the turbines.

As was discussed in detail in Section 5.6.6.1, there are various factors as to why, even with the use of the same control technologies, the emissions limits presented for the facilities in Table 5-12 are not necessarily directly comparable to the WCP units. Table 5-13 summarizes whether the RBLC listing was actually for a modification of an existing unit, if the turbine involved was a GE Frame 7 turbine, and whether the facilities in Table 5-12 are comparable to the WPC units based on these factors.

Table 5-13. Unit Comparability for CO Assessment – Natural Gas Firing

Site	Modification?	GE Frame 7 Turbine?	Comparable?	CO Emission Limit	Averaging Period
Cunningham Station Power Plant	Increase NO _x BACT Emission Limits	No, Westinghouse 501D5A	No	Not Comparable	
Calcasieu Plant ^[1]	Increase hours, heat input	Unknown	Yes	15.83 ppmvd @ 15% O ₂	Annual Avg.
Emporia Energy Center – GE LM6000PC Units	N/A	No	No	Not Comparable	
Emporia Energy Center – GE 7FA	No (New in 2007) Added Tuning Requirements in 2013	Yes	No (New Unit) Yes (Engine Type)	39 lb/hr	Stack test for compliance at full load
Doswell Energy Center	Turbine Relocation	Yes	Yes	4.0 ppmvd @ 15% O ₂ (0.00713 lb/MMBtu) (14.0 lb/hr)	3-hr Avg.(2016) 1-hr Avg (2018)
Waverly Facility - 2017	Relaxed synthetic minor limits	Yes	Potentially	9 ppm @loads 60% or higher	30-day Rolling Avg.
Waverly Facility - 2018	Increase heat input	Yes	Potentially	9 ppm @loads 60% or higher	30-day Rolling Avg.
Cameron LNG Facility	No – New	Compressor Turbines	No	Not Comparable	
Mustang Station	Increase hours	Yes, 2013 install	Potentially	9.0 ppmvd @ 15% O ₂	3-hr Rolling Avg.

Site	Modification?	GE Frame 7 Turbine?	Comparable?	CO Emission Limit	Averaging Period
Jackson County Generators	No	No, Siemens F5	No	Not Comparable	
Ector County Energy Center	No (New in 2014), increased hours in 2020	Yes	Potentially	9.0 ppmvd @ 15% O ₂	3-hr Rolling Avg.

^[1] PSD Permit No. PSD-LA-746 issued on December 21, 2011 listed a BACT limit for CO of 15.0 ppmvd @ 15% O₂. However, this permit was requested for revocation in a 2012 Title V Renewal Application. PSD Permit No. PSD-LA-798 was issued on June 1, 2015 and established the BACT limit for CO as 15.83 ppmvd @ 15% O₂.

As detailed in Table 5-13, potentially comparable engines combusting natural gas have CO emission limits ranging from 4.0 – 15.83 ppmvd at 15% O₂. Multiple units are subject to a 9 ppm CO limit, which is equivalent to GE’s guarantee for the WCP turbines when utilizing good combustion process design, good combustion practices, and pipeline quality natural gas. Although the lowest BACT limit for CO identified in Table 5-13 is 4.0 ppmvd at 15% O₂ based on a one hour averaging period, WCP does not anticipate that the existing turbine units at the facility are capable of achieving this rate. **WCP proposes a BACT limit for CO of 9 ppmvd at 15% O₂ on a 3-hr averaging basis when firing natural gas, excluding periods of startup and shutdown.** WCP anticipates conducting performance testing to document continuous compliance with the proposed CO BACT limit using a 3-hr averaging period.

5.8.6.2 Selection of Emission Limits for CO BACT – Fuel Oil Firing

Table 5-14 includes a CO RBLC database entry for turbine units combusting fuel oil which are potentially comparable to the existing units at the WCP facility.

Table 5-14. Fuel Oil Simple-Cycle Combustion Turbine CO RBLC Data for Potentially Modified Units

Facility Name	State	Permit Issuance	System Size	Turbine Model	CO Emission Limit ^[1]	Units ^[1]	Averaging Period ^[1]	Notes
Wolverine Power	MI	6/29/2011	540 MMBtu/hr Heat Input	Unknown	0.045	lb/MMBtu	Test protocol will specify avg. time	One ULSD fired turbine generator which will be used to start the plant when there is no power available from the electric grid and the plant must be brought back into service. Turbine utilizes good combustion control technology.
Waverly Facility ^[2]	WV	1/23/2017	1,571 MMBtu/hr for Each Turbine	GE 7FA	20.0	ppm @ loads of 60% or higher	30-day Rolling Avg.	Two GE Model 7FA turbines which are capable of combusting natural gas and firing fuel oil as back-up. The combustion turbines employ the use of good combustion practices as a control method. In this permitting action PSD only applies to the modified combustion turbines based on the relaxation of an original synthetic minor permit issued in 1999. Project also involves previous installation of turbocharging. All BACT emission limits are given without turbocharging and startup/shutdown emissions are not included.
Waverly Power Plant ^[2]	WV	3/13/2018	167.8 MW with 2,013 MMBtu/hr Heat Input for Each Turbine	GE 7FA.004	20.0	ppm @ loads of 60% or higher	30-day Rolling Avg.	Two GE Model 7FA turbines which are capable of combusting natural gas and firing fuel oil as back-up. The combustion turbines employ the use of good combustion practices as a control method. Modification to existing PSD Permit (R14-0034, RBLC Number WV-0027) to add advanced gas path technology to the turbines that was defined as a change in the method of operation that resulted in a major modification to the turbines.

^[1] Please note that the Emission Limit and Averaging Periods for each RBLC entry was cross referenced with the associated air permit for each entry, as available. Corrections were made as necessary, to ensure that emission limits and averaging periods were consistent with the air permits associated with each RBLC entry.

^[2] Facility did not have a RBLC database entry for CO associated with the turbine unit for fuel oil firing. However, upon further review of associated permits, permit applications, and other available documentation, it was determined that established BACT limits for CO existed for the associated turbine units when firing fuel oil. The established BACT limits for CO were added to this table.

5.8.6.2.1 Summary Fuel Oil CO BACT

The anticipated BACT for CO when firing fuel oil would be combustion process design and good combustion practices. Table 5-15 summarizes whether the RBLC listing was actually for a modification of an existing unit, if the turbine involved was a GE Frame 7 turbine, and whether the facilities in Table 5-14 are comparable to the WCP units based on these factors.

Table 5-15. Unit Comparability for CO Assessment – Fuel Oil Firing

Site	Modification?	GE Frame 7 Turbine?	Comparable?	CO Emission Limit	Averaging Period
Wolverine Power	No – New	Unknown	No	Project Voided – Facility Was Not Built	
Waverly Facility - 2017	Relaxed synthetic minor limits	Yes	Potentially	20 ppmvd	30-day Rolling Avg.
Waverly Facility - 2018	Increase heat input	Yes	Potentially	20 ppmvd	30-day Rolling Avg.

As can be noted in Table 5-15, the potentially comparable turbine units are subject to CO limits of 20 ppm at 15% O₂. This limit is also consistent with the BACT limitation for CO of 20 ppmvd at 15% O₂ on a rolling 3-hour averaging basis for the Hill County Generating Facility which can be referenced in Appendix C. Although the turbine units at the Hill County Generating Facility are proposed for construction and therefore cannot necessarily be considered directly comparable to the WCP turbine units, it is worth noting the similarities between the CO BACT limitations for the newer state-of-the-art turbines proposed at that facility and the CO BACT limitations for the potentially comparable units in Table 5-15. As such, **WCP proposes a CO BACT emission limit for each simple-cycle system of 20 ppmvd at 15% O₂ on a 3-hr averaging basis when firing fuel oil, excluding periods of startup and shutdown.** WCP anticipates conducting performance testing to document continuous compliance with the proposed CO BACT limit using a 3-hr averaging period.

5.8.6.3 Secondary BACT Limit – CO

The proposed primary BACT limits of 9.0 ppmvd and 20 ppmvd for natural gas and fuel oil firing, respectively, do not apply during periods of startup/shutdown. Secondary BACT limits are required given that the non-steady state operations during periods of startup and shutdown result in a substantially different CO emissions profile as the combustion units are not operating in an ideal mode for managing combustion characteristics. WCP therefore proposes a secondary CO BACT limit per turbine of 70.9 tpy to ensure the minimization of emissions during startup/shutdown periods.

5.9 Combustion Turbines VOC Assessment

This section contains a review of pollutant formation, possible control technologies, and the ranking and selection of such controls with associated emission limits, for proposed BACT for VOC emissions from each combustion turbine. The following sections details the “top down” BACT review, as well as the control technology and emission limits that are selected as BACT for VOC.

5.9.1 VOC Formation – Combustion Turbines

VOC from combustion turbines is a by-product of incomplete combustion. Conditions leading to incomplete combustion can include insufficient oxygen availability, poor fuel/air mixing, reduced combustion-temperature, reduced combustion gas residence time, and load reduction.

5.9.2 Identification of VOC Control Technologies – Combustion Turbines (Step 1)

Candidate control options identified from the RBLC search and the literature review include those classified as pollution reduction techniques such as oxidation catalyst and combustion process design and good combustion practices.

5.9.2.1 Oxidation Catalysts

An oxidation catalyst is a post-combustion technology wherein the products of combustion are introduced to a catalytic bed prompting the VOC to react with oxygen present in the exhaust stream, converting to carbon dioxide and water vapor. The overall control efficiency of such systems on VOC constituents is dependent on the individual VOC components. For example, research completed by U.S. EPA as part of MACT rulemakings found that control of formaldehyde emissions typically exceed 90%, but other pollutants such as benzene may not see any beneficial reductions. Hence, the overall range of VOC control can vary substantially.¹⁷⁶

5.9.2.2 EM_xTM/SCONO_xTM

EM_xTM (the second-generation of the SCONO_x NO_x Absorber Technology) is a multi-pollutant control technology that utilizes a coated oxidation catalyst to remove both NO_x and CO, as well as VOC without a reagent, discussed in Section 5.6.2.4.

5.9.2.3 Combustion Process Design and Good Combustion Practices

To minimize incomplete combustion and the resulting formation of VOC, this control technology includes proper equipment design, proper operation, and good combustion practices. Proper equipment design is important in minimizing incomplete combustion by allowing for sufficient residence time at high temperature as well as turbulence to mitigate incomplete mixing. Proper operation and good combustion practices provide additional VOC control via the use of gaseous fuels for good mixing and proper combustion techniques such as optimizing the air to fuel ratio.

5.9.3 Elimination of Technically Infeasible VOC Control Options – Combustion Turbines (Step 2)

The second step in the BACT process is the elimination of technically infeasible control options based on process-specific conditions that prohibit implementation of the control, or the lack of commercial demonstration of achievability.

5.9.3.1 Oxidation Catalyst

Catalytic oxidizers typically operate within a temperature range between 600 to 800°F.¹⁷⁷ Given the exhaust temperature of utility-scale simple-cycle combustion turbines is typically in excess of 1,000°F, use of

¹⁷⁶ U.S. EPA Office of Air Quality Planning and Standards Memorandum, *Hazardous Air Pollutant (HAP) Emission Control Technology for New Stationary Combustion Turbines*, August 21, 2001.

¹⁷⁷ U.S. EPA, CATC Fact Sheet for Catalytic Incineration, EPA-452/F-03-018. Available at: www.epa.gov/ttn/catc/dir1/fcataly.pdf

oxidation catalyst could be considered technically infeasible, although the possibility of utilizing tempering air to reduce the inlet exhaust temperature, at substantial costs, exists. Therefore, oxidation catalyst is considered technically feasible for installation on the Facility's combustion turbines and will be considered further in Step 4 to evaluate cost effectiveness.

5.9.3.2 *EM_xTM/SCONO_xTM*

The EM_xTM/SCONO_xTM catalyst system is a post-combustion technology that utilizes a proprietary oxidation catalyst and absorption technology using a single catalyst (potassium carbonate) for removal of NO_x, CO, and VOC without the use of ammonia. As summarized by Illinois EPA in their project summary for the Jackson Energy Center PSD permit, the EM_xTM/SCONO_xTM catalyst system has operated successfully on several smaller, natural gas-fired combined-cycle units, but there are engineering challenges with applying this technology to larger plants with full scale operation.¹⁷⁸ Additionally, the operating range of the catalyst is 300 to 700°F, well below the exhaust temperature for simple-cycle combustion turbines.¹⁷⁹

Consequently, it is concluded that EM_xTM/SCONO_xTM is not technically feasible for control of VOC emissions from the WCP turbines.

5.9.3.3 *Combustion Process Design and Good Combustion Practices*

This represents the base case for design and operation of the simple-cycle combustion turbines.

5.9.4 **Summary and Ranking of Remaining VOC Controls – Combustion Turbines (Step 3)**

As detailed in the Step 2 analysis for VOC per Section 5.9.3, the only add-on control technically feasible to reduce emissions below the base case (Combustion Process Design and Good Combustion Practices) is oxidation catalyst. As a technically feasible control option, it must be evaluated further in the BACT process.

5.9.5 **Evaluation of Most Stringent VOC Controls – Combustion Turbines (Step 4)**

Oxidation catalyst is the highest ranking potentially feasible control technology for both natural gas and fuel oil combustion in the turbines. The estimated cost of controlling VOC using oxidation catalyst for the WCP turbines is more than \$32K per ton of VOC removed based on the detailed cost analysis provided in Appendix D, developed using the methods outline by the U.S. EPA in the OAQPS guidance manual.¹⁸⁰ Similar to the technical challenges discussed for SCR for NO_x emissions reductions and use of an oxidation catalyst system for CO emission reductions, estimated costs are high given the high volume of tempering air that would be required to reduce the turbine exhaust temperatures to an acceptable range for operation of an oxidation catalyst. Therefore, WCP concludes that an oxidation catalyst is not cost effective and is not considered BACT for the Facility's turbines

¹⁷⁸ Application No. 17040013, *Project Summary for a Construction Permit Application from Jackson Generation, LLC, for an Electrical Generating Facility in Elwood, Illinois*, issued by the Illinois EPA for the public comment period beginning on September 21, 2018. Discussion related to selection of BACT for emissions of NO_x, Attachment B pages 14.

¹⁷⁹ U.S. EPA Office of Air and Radiation, *Final Technical Support Document (TSD) for the Cross-State Air Pollution Rule for the 2008 Ozone NAAQS: Assessment of Non-EGU NO_x Emission Controls, Cost of Controls, and Time for Compliance Final TSD*, August 2016, Appendix A, Page 3-5. Docket ID No. EPA-HQ-OAR-2015-0500.

¹⁸⁰ U.S. EPA, *OAQPS Control Cost Manual*, 6th edition, EPA 452/B-02-001, July 2002.

http://www.epa.gov/ttn/catc/dir1/c_allchs.pdf

For more details on the updating of the control cost manual see <https://www.epa.gov/economic-and-cost-analysis-air-pollution-regulations/cost-reports-and-guidance-air-pollution>

Therefore, combustion process design and good combustion practices represent BACT for the Facility's combustion turbines for VOC.

5.9.6 Selection of Emission Limits and Controls for VOC BACT – Combustion Turbines (Step 5)

The simple-cycle combustion turbines are not presently subject to a VOC emission limit and NSPS Subpart KKKK does not establish emission standards for VOC. Accordingly, a BACT floor for VOC does not exist.

As the selected BACT for VOC emissions relies on the combustion process design and good combustion practices, WCP searched U.S. EPA's RBLC database for modifications of similar units at other facilities to determine what has been established as a BACT emission requirement for comparable operations. Numerous entries for natural gas or fuel oil simple-cycle combustion turbines are provided in the RBLC summary table in Appendix C. Review of the RBLC entries confirms that BACT for VOC emissions are typically combustion process design and good combustion practices for similarly sized simple-cycle combustion turbines. "Good combustion practices" typically refers to practices inherent in the routine operation and maintenance of the generating unit, such as automated operating systems and periodic tuning of the turbines.

Once the technology is established, an emission limitation must be proposed, and review of the RBLC entries provides an indication of what has been considered appropriate BACT emission limitations for potentially similar units as those being modified by WCP. As discussed previously, the following qualifying criteria were relied upon in review of the RBLC entries per Appendix C to identify potentially comparable units to the WCP turbines:

- ▶ Turbine is existing and proposed a modification; exclude units proposed for initial construction;
- ▶ Control method does not include control technologies which have been deemed to be infeasible (i.e., Oxidation Catalyst, EM_xTM/SCONO_xTM);
- ▶ Units are similar GE Frame 7 units; and
- ▶ Units are utilized for the purposes of power generation and not utilized for other purposes such as compression.

This review has been conducted on a fuel-specific basis, detailed in the following sections.

5.9.6.1 Selection of Emission Limits for VOC BACT - Natural Gas Firing

Table 5-16 includes VOC RBLC database entries for turbine units combusting natural gas which are potentially comparable to the existing units at the WCP facility.

Table 5-16. Natural Gas Fired Simple-Cycle Combustion Turbine VOC RBLC Data for Potentially Modified Units

Facility Name	State	Permit Issuance	System Size	Turbine Model	VOC Emission Limit ^[1]	Units ^[1]	Averaging Period ^[1]	Notes
Calcasieu Plant	LA	12/21/2011	1,900 MMBtu/hr Heat Input for Each Turbine	Unknown	3.0	ppmvd @ 15% O ₂	-	Two simple-cycle combustion turbines of unknown make and model utilizing DLN combustors. VOC emission limit excludes periods of startup and shutdown. PSD was triggered due to relaxation of a federally enforceable condition limiting potential emissions below major stationary source thresholds; subsequently revoked. According to the PSD permit issued in 2015, emissions of VOC were not above PSD modification thresholds.
Westar Energy – Emporia Energy Center	KS	3/18/2013	405 MMBtu/hr Heat Input for Each Turbine	GE LM6000 PC Sprint	5.8	lb/hr	At full load	Four GE LM6000 PC Sprint natural gas fired simple-cycle turbines which are considered aeroderivative turbines. VOC emission limit excludes periods of startup, shutdown, or malfunction. Turbines utilize efficient combustion/design technology for control of VOC.
Westar Energy – Emporia Energy Center	KS	3/18/2013	1,780 MMBtu/hr Heat Input for Each Turbine	GE 7FA	3.2	lb/hr	At full load	Three GE 7FA natural gas fired simple-cycle turbines which utilize DLN burners for control. VOC emission limit excludes periods of startup, shutdown, or malfunction. Turbines utilize efficient combustion/design technology for control of VOC.
Doswell Energy Center ^[2]	VA	10/4/2016	1,961 MMBtu/hr for Each Turbine	GE Frame 7FA	3.57E-04 (0.7 lb/hr)	lb/MMBtu	-	Authorization to add two 170 MW GE 7FA.03 natural gas fired, simple-cycle combustion turbines (CT-2 and CT-3) at the Doswell Energy Center (DEC) equipped with low NO _x burners. Both CT-2 and CT-3 were proposed to be brought to DEC from an existing permitted site in Desoto, Florida. They are both similar in age and capability to the existing 190.5 MW GE 7FA.03 simple-cycle combustion turbine (CT-1) at the facility. The turbines utilize good combustion practices as a control method. CT-1 was added in a PSD permit dated April 7, 2000 and last amended on September 30, 2013. Permit issued on May 31, 2018 updated the VOC emission limit for CT-2 and CT-3 to 2 ppmvd @ 15% O ₂ (3.3 lb/hr) on a 1-hr averaging basis.
Puente Power	CA	10/13/2016	262 MW	Unknown	2.0	ppmvd @ 15% O ₂ as methane	1-hr Avg.	One 262 MW gas turbine.
Cameron LNG Facility	LA	2/17/2017	1,069 MMBtu/hr Heat Input for Each Turbine	Unknown	1.6	ppmvd @ 15% O ₂	3-hr Avg.	Gas turbines which utilize DLN burners and good combustion practices as control.
Mustang Station ^[2]	TX	8/16/2017	163 MW	GE 7FA	2.0	ppmvd @ 15% O ₂	-	One 163 MW GE 7FA turbine (Unit No. 6) which was constructed in 2013 and utilizes DLN burners. Turbine uses good combustion practices as a control method. Permit involved increasing the turbine hours of operation to 3,000 hours per year.
Jackson County Generators	TX	1/26/2018	230 MW for Each Turbine	Unknown	2.0	ppmvd @ 15% O ₂	-	Four natural gas fired simple-cycle combustion turbines which utilizes DLN burners and good combustion practices as control methods.

Facility Name	State	Permit Issuance	System Size	Turbine Model	VOC Emission Limit ^[1]	Units ^[1]	Averaging Period ^[1]	Notes
Ector County Energy Station ^[2]	TX	8/17/2020	Unknown	Unknown	2.0	ppmvd @ 15% O ₂	-	Two simple-cycle gas turbines equipped with DLN burners for control. Turbine uses good combustion practices as a control method.

^[1] Please note that the Emission Limit and Averaging Periods for each RBLC entry was cross referenced with the associated air permit for each entry, as available. Corrections were made as necessary, to ensure that emission limits and averaging periods were consistent with the air permits associated with each RBLC entry.

^[2] Facility did not have a RBLC database entry for VOC associated with the turbine unit for natural gas firing. However, upon further review of associated permits, permit applications, and other available documentation, it was determined that established BACT limits for VOC existed for the associated turbine units when firing natural gas. The established BACT limits for VOC were added to this table.

The RBLC entries detailed in Table 5-16 includes potential modifications at facilities which were discussed in Section 5.6.6.1. Many of the RBLC database entries have been conservatively included in Table 5-16 as they could not be ruled out as units proposed for construction based on information presented in the RBLC database entry alone. As was previously stated, further review of available air permits, permit applications, and other facility documentation proved that many of the turbine units associated with these RBLC database entries are not comparable to the WCP turbine units.

A review of the proposed control technologies for these facilities shows that use of good combustion practices and pipeline quality natural gas are common requirements for VOC BACT. WCP already incorporates the use of good combustion practices and utilizes pipeline quality natural gas as fuel for the existing turbine systems. WCP will continue to utilize those controls as BACT when firing natural gas in the turbines.

As was discussed in detail in Section 5.6.6.1, there are various factors as to why, even with the use of the same control technologies, the emissions limits presented for the facilities in Table 5-16 are not necessarily directly comparable to the WCP units. Table 5-17 summarizes whether the RBLC listing was actually for a modification of an existing unit, if the turbine involved was a GE Frame 7 turbine, and whether the facilities in Table 5-16 are comparable to the WPC units based on these factors.

Table 5-17. Unit Comparability for VOC Assessment – Natural Gas Firing

Site	Modification?	GE Frame 7 Turbine?	Comparable?	VOC Emission Limit	Averaging Period
Calcasieu Plant ^[1]	Increase hours, heat input	Unknown	Yes	N/A – Did not exceed PSD threshold per 2015 PSD permit; ultimately revoked	
Emporia Energy Center – GE LM6000PC Units	N/A	No	No	Not Comparable	
Emporia Energy Center – GE 7FA	No (New in 2007) Added Tuning Requirements in 2013	Yes	No (New Unit) Yes (Engine Type)	3.2 lb/hr (0.0018 lb/MMBtu)	Stack test for compliance at full load
Doswell Energy Center ^[2]	Turbine Relocation	Yes	Yes	2 ppmvd @ 15% O ₂	1-hr Avg.
Puente Power	No - New	Yes	No	Application Revoked	
Cameron LNG Facility	No – New	Compressor Turbines	No	Not Comparable	
Mustang Station	Increase hours	Yes, 2013 install	Potentially	2 ppmvd @ 15% O ₂	-
Jackson County Generators	No	No, Siemens F5	No	Not Comparable	

Site	Modification?	GE Frame 7		VOC Emission Limit	Averaging Period
		Turbine?	Comparable?		
Ector County Energy Center	No (New in 2014), increased hours in 2020	Yes	Potentially	2 ppmvd @ 15% O ₂	-

^[1] PSD Permit No. PSD-LA-746 issued on December 21, 2011 listed a BACT limit for VOC of 3.0 ppmvd @ 15% O₂. However, this permit was requested for revocation in a 2012 Title V Renewal Application. PSD Permit No. PSD-LA-798 was issued on June 1, 2015 and determined that emissions of VOC were not above PSD significant levels; therefore, BACT is not applicable for VOC for the Calcasieu Plant.

^[2] The PSD permit for the Doswell Energy Center issued on October 4, 2016 incorporated a VOC BACT limit of 3.57E-04 lb/MMBtu (0.7 lb/hr) for the natural gas fired simple-cycle turbines (CT-2 and CT-3). However, per a revised PSD Permit issued on May 31, 2018, the VOC BACT limit was updated to 2 ppmvd @ 15% O₂ (3.3 lb/hr) on a 1-hr averaging basis. This is also consistent with the PSD permit issued on July 30, 2018.

As detailed in Table 5-17, potentially comparable engines combusting natural gas have VOC limits of 3.2 lb/hr, equivalent to 0.0018 lb/MMBtu and 2 ppmvd @ 15% O₂. GE’s guarantee for the WCP turbines when utilizing good combustion process design, good combustion practices, and pipeline quality natural gas is 1.4 ppmvd at 15% O₂; equivalent to 0.00446 lb/MMBtu. Additional research identified a Texas BACT document establishing 2.0 ppmvd as BACT for simple-cycle natural gas combustion turbines.¹⁸¹ For compliance assurance purposes, **WCP therefore proposes a BACT limit of 2.0 ppmvd at 15% O₂, excluding periods of startup and shutdown**, to be demonstrated via stack testing.¹⁸²

5.9.6.2 Selection of Emission Limits for VOC BACT – Fuel Oil Firing

Table 5-18 includes VOC RBLIC database entries for turbine units combusting fuel oil which may be potentially comparable to the existing units at the WCP facility.

¹⁸¹ Summary spreadsheet *Current BACT for All Combustion Units*, accessed January 27, 2021. <https://www.tceq.texas.gov/assets/public/permitting/air/Guidance/NewSourceReview/bact/bact-combustion.xlsx>

¹⁸² Method 25A for the determination of volatile organic compounds.

Table 5-18. Fuel Oil Fired Simple-Cycle Combustion Turbine VOC RBLC Data for Potentially Modified Units

Facility Name	State	Permit Issuance	System Size	Turbine Model	VOC Emission Limit ^[1]	Units ^[1]	Averaging Period ^[1]	Notes
Wolverine Power ^[2]	MI	6/29/2011	540 MMBtu/hr Heat Input	Unknown	-	-	-	One ULSD fired turbine generator which will be used to start the plant when there is no power available from the electric grid and the plant must be brought back into service. Turbine utilizes good combustion control technology.

^[1] Please note that the Emission Limit and Averaging Periods for each RBLC entry was cross referenced with the associated air permit for each entry, as available. Corrections were made as necessary, to ensure that emission limits and averaging periods were consistent with the air permits associated with each RBLC entry.

^[2] Facility did not have a RBLC database entry for VOC associated with the turbine unit for fuel oil firing. However, upon further review of associated permits, permit applications, and other available documentation, it was determined that established BACT limits for VOC existed for the associated turbine units when firing fuel oil. The established BACT limits for VOC were added to this table.

As can be referenced in Table 5-18, Wolverine Power is the only facility with turbine units which are potentially comparable to the WCP units. However, the turbines at the Wolverine Power facility are not subject to a BACT limit for VOC, but rather must comply by utilizing good combustion control technology to mitigate emissions of VOC. Furthermore, as was stated in Section 5.6.6.2.1, plans for the Wolverine Power project were discontinued in 2013 and the facility was never built.

The anticipated BACT for VOC when firing fuel oil would be combustion process design and good combustion practices. Based on BACT limitations for VOC at a similar facility which incorporates the use of dual-fuel fired turbine units, **WCP proposes a BACT limit for VOC of 5.0 ppmvd at 15% O₂, excluding periods of startup and shutdown**, with compliance demonstrated via stack testing.¹⁸³

5.10 Fuel Oil Storage Tank VOC Assessment

WCP is proposing to construct and operate a new vertical fixed roof tank which will store fuel oil and have a capacity of 2.5 million gallons. Annual emissions resulting from the storage tank have been estimated in Appendix B and are not expected to exceed 0.66 tons per year. Given the low magnitude of emissions from the proposed fuel oil storage tank, WCP proposes that the tank be subject to work practice and design standards in lieu of an emission limitation.

Due to the low vapor pressure of fuel oil and minimal estimated annual emissions from the proposed storage tank, a vapor collection and control device for control of emissions will not be utilized. Additionally, carbon adsorption systems are generally not effective for control of low concentrations of VOC which would be generated by a diesel storage tank. The use of floating roofs are also not considered effective for controlling VOC emissions from liquids having low vapor pressures such as diesel.¹⁸⁴ Given the capital costs involved with installation of add-on controls for reduction of less than 1 tpy of emissions, a traditional cost effectiveness analysis would demonstrate a substantial \$/ton pollutant removed value, concluding installation of control is not cost effective.

For this small source of VOC emissions, WCP is proposing to incorporate the use of submerged fill systems in the fuel oil storage tank to minimize emissions of VOC resulting from splashing of product loaded. A fill pipe opening will be submerged below the tank's liquid surface level, thereby ensuring that liquid turbulence is mitigated during loading, resulting in minimal emissions into the vapor space above the liquid surface. Another method which WCP will utilize to control emissions from the fuel oil storage tank is to minimize product temperature via the use of light-colored paint for the tank shell and roof. Evaporative losses can be minimized significantly via the appropriate condition and color selection of a storage tank's shell and roof. Evaporative losses have a strong relationship with temperature of liquid product stored; therefore, reducing liquid product temperature can minimize evaporative losses. Solar radiation will increase the temperature of the liquid in a storage tank, but the extent of the temperature increase is determined by the color and condition of the paint on the tank walls and roof. Paints having a low solar absorptance (i.e., light colored tanks) will heat up less than paints with high solar absorptance (i.e., dark colored tanks). White paint, for

¹⁸³ Part 70 Operating Permit Amendment No. 4911-157-0034-V-04-1 issued by Georgia EPD for the Dahlberg Combustion Turbine Electric Generating Plant, effective May 14, 2010. Amendment resulted from a PSD permit application for installation of four simple cycle dual-fuel combustion turbines.

¹⁸⁴ *Preliminary Determination & Statement of Basis – Outer Continental Shelf Air Permit Modification OCS-EPA-R4012-M1 for Statoil Gulf Services, LLC – Desota Canyon Lease Blocks*, issued by the U.S. EPA Region 4 on July 9, 2014. Discussion related to BACT analysis for storage tanks, Section 6.5 page 29.

example, is highly reflective and typically used to minimize the tank's ambient temperature, which, in turn, reduces standing losses.¹⁸⁵

WCP has determined that BACT for the proposed fuel oil storage tank will be the use of good maintenance practices in accordance with manufacturer specifications, use of a submerged fill pipe for product loading, and selection of tank roof and shell paint colors which have low solar absorptance.

5.11 Combustion Turbines GHG Assessment

This section contains a high-level review of pollutant formation and possible control technologies for the combustion turbine systems. Though the primary GHG emissions from natural gas and fuel oil combustion in the combustion turbine systems are CO₂, GHG BACT is discussed separately for CH₄ and N₂O.

CO₂ production from combustion occurs in theory by a reaction between carbon in any fuel and oxygen in the air and proceeds stoichiometrically (for every 12 pounds of carbon burned, 44 pounds of CO₂ is emitted).¹⁸⁶ CH₄ can be emitted when natural gas and fuel oil are not burned completely in combustion.¹⁸⁷ The last primary component for calculating greenhouse gas emissions (in addition to CO₂ and CH₄) is N₂O. N₂O formation is limited during complete gas and oil combustion situations, as most oxides of nitrogen will tend to oxidize completely to NO₂, which is not a GHG.¹⁸⁸

Please note that the GHG BACT assessment presents a unique challenge with respect to the evaluation of BACT for CO₂ and CH₄ emissions. The technologies that are most frequently used to control emissions of CH₄ in hydrocarbon-rich streams (e.g., flares and thermal oxidizers) actually convert CH₄ emissions to CO₂ emissions. Consequently, the reduction of one GHG (i.e., CH₄) results in a simultaneous increase in emissions of another GHG (i.e., CO₂).

5.11.1 Turbine Systems CO₂ BACT

The following section presents BACT evaluations for CO₂ emissions from the modified turbine systems.

5.11.1.1 Identification of Potential CO₂ Control Technologies (Step 1)

WCP searched for potentially applicable emission control technologies for CO₂ from combustion turbines by researching the U.S. EPA control technology database, guidance from U.S. EPA and other sources as described in Section 5.4.1 of this report, technical literature, control equipment vendor information, state permitting authority files, and by using process knowledge and engineering experience. The RBLC lists technologies and corresponding emission limits that have been approved by regulatory agencies in permit actions. These results are summarized in Appendix C, detailing emission levels proposed for similar types of emissions units. Based on the RBLC search, no add-on control methods for GHGs were described for any of

¹⁸⁵ Eric Stricklin. "Evaporative Losses From Storage Tanks," Chesapeake Operating, Inc. <http://technokontrol.com/pdf/evaporation/evaporation-loss-measurement.pdf>. (accessed January 26, 2021).

¹⁸⁶ *NC Greenhouse Gas (GHG) Inventory Instructions for Voluntary Reporting, November 2009*. Prepared by the North Carolina Division of Air Quality. https://files.nc.gov/ncdeq/Air%20Quality/inventory/forms/GHG_Emission_Inventory_Instructions_Nov2009_Voluntary.pdf

¹⁸⁷ AP-42, Chapter 1, Section 4, *Natural Gas Combustion, July 1998*. Chapter 1, Section 3, *Fuel Oil Combustion, July 1998*.

¹⁸⁸ *NC Greenhouse Gas (GHG) Inventory Instructions for Voluntary Reporting, November 2009*. Prepared by the North Carolina Division of Air Quality. https://files.nc.gov/ncdeq/Air%20Quality/inventory/forms/GHG_Emission_Inventory_Instructions_Nov2009_Voluntary.pdf

the facilities. Many facilities listed a variant of good combustion practices, efficient operation, state-of-the-art technology (for greenfield sites), or low emitting fuels (e.g., pipeline-quality natural gas). Although not mentioned in the RBLC for any sites, energy storage technologies such as batteries are deemed to fall outside the scope of this analysis since they would essentially redefine the source.

WCP used a combination of published resources and general knowledge of industry practices to generate a list of potential controls for CO₂ emitted from combustion turbine systems. WCP excluded options such as battery storage or solar power generation from the GHG control technology assessment as they would redefine the business purpose of the proposed projects: WCP Sandersville proposes to operate as a natural gas and fuel oil-fired electric generating facility utilizing simple-cycle combustion turbines, maximizing utilization of the existing assets in a relatively steady-state mode of operation, with normal anticipated variations based on supply needs. U.S. EPA has affirmed that evaluation of control options or lower-emitting GHG processes, such as solar power, that would fundamentally redefine the source is not a requirement of the BACT review in their response to comments on the proposed Palmdale Hybrid Power Project, subsequently upheld in an order denying review of the PSD permit.¹⁸⁹

The following potential CO₂ control strategies were considered as part of this BACT analysis:

- ▶ Carbon Capture and Storage (CCS); and
- ▶ Efficient Turbine Operation and Good Combustion, Operating, and Maintenance Practices.

These control technologies are briefly discussed in the following sections. Other CO₂ control technologies such as use of alternative fuels (with lower GHG emissions) were not considered because they were not within the scope of the projects. Additionally, natural gas (which has the lowest GHG emissions of any fossil fuel) is the primary fuel that will be utilized by the turbines, with fuel oil usage being limited to 500 hr/yr.

5.11.1.1.1 Carbon Capture and Storage

CCS, also known as CO₂ sequestration, involves cooling, separation and capture of CO₂ emissions from the flue gas prior to being emitted from the stack, compression of the captured CO₂, transportation of the compressed CO₂ via pipeline, and finally injection and long-term geologic storage of the captured CO₂. For CCS to be technically feasible, all three components needed for CCS must be technically feasible; carbon capture and compression, transport, and storage.

The first phase in CCS is to separate and capture the CO₂ gas from the exhaust stream, and then to compress the CO₂ to a supercritical condition.¹⁹⁰ Since most storage locations for CO₂ are greater than 800

¹⁸⁹ U.S. EPA Environmental Appeals Board decision, *In re: City of Palmdale (Palmdale Hybrid Power Project)*. PSD Appeal No. 11-07, p. 727, decided September 17, 2012, citing U.S. EPA Region 9, *Responses to Public Comments on the Proposed Prevention of Significant Deterioration Permit for the Palmdale Hybrid Power Project* at 3 (Oct. 2011).

"Finally, we [EPA] note that the incorporation of the solar power generation into the BACT analysis for this facility [Palmdale] does not imply that other sources must necessarily consider alternative scenarios involving renewable energy generation in their BACT analyses. In this particular case, the solar component was a part of the applicant's Project as proposed in its PSD permit application. Therefore, requiring the applicant to utilize, and thus construct, the solar component as a requirement of BACT did not fundamentally redefine the source. EPA has stated that an applicant need not consider control options that would fundamentally redefine the source. However, it is expected that each applicant consider all possible methods to reduce GHG emissions from the source that are within the scope of the proposed project."

¹⁹⁰ Supercritical means that the CO₂ has properties of both a liquid and a gas. Supercritical CO₂ is dense like a liquid but has a viscosity like a gas. For additional details see <https://www.netl.doe.gov/coal/carbon-storage/faqs/carbon-storage-faqs>

meters deep, where the natural temperatures and pressures are greater than the critical point for CO₂, to inject CO₂ to those depths requires pressurizing the captured CO₂ to a supercritical state.

CO₂ capture can be performed via solvents or sorbents. The choice of the precise process varies with the properties of the exhaust stream. CO₂ separation has been well demonstrated in the oil and gas industries, but the characteristics of those streams are very different from a turbine system exhaust. Most combustion tests and projects have been on exhaust streams from coal combustion, which has more highly concentrated CO₂ than exhaust from natural gas and fuel oil combustion, or on natural gas combined-cycle systems. Existing CO₂ capture technologies have not been demonstrated in the context of capturing CO₂ from simple-cycle combustion turbines, regardless of industry use, as they have higher exit gas temperatures and lower cycle efficiencies, which negatively affects the ability of the CCS systems to control CO₂ emissions.¹⁹¹

Once separated, CO₂ must be compressed to supercritical conditions for transport and storage. There are no technical challenges with compressing CO₂ to those levels, but specialized technologies with high operating energy requirements are necessary. The CO₂ could be compressed to supercritical either before or after transport.

For phase two, CO₂ would be transported to a repository. Transport options could include pipeline or truck. Specialized designs may be required for CO₂ pipelines, particularly if supercritical CO₂ is being transported. Transport of CO₂ by pipeline is a demonstrated technology, but currently most CO₂ pipelines are in rural areas. Obtaining right-of-way in developed areas is difficult.

Various CO₂ storage methods have been proposed, though only geologic storage is achievable currently. Geologic storage involves injecting CO₂ into deep subsurface formations for long-term storage. Typical storage locations would be deep saline aquifers as well as depleted or un-mineable coal seams. Captured CO₂ could also potentially be used for enhanced oil recovery via injection into oil fields.

5.11.1.1.2 Efficient Turbine Operation and Good Combustion, Operating, and Maintenance Practices

As the baseline of most analyses, pollutant formation can be most cost-effectively minimized by efficient turbine operation and good combustion, operating, and maintenance practices. One example of an efficient way to generate electricity from a natural gas and fuel oil-fired source is the use of a combined cycle design.¹⁹²

Within combustion units, operators can control the localized peak combustion temperature and combustion stoichiometry to achieve efficient fuel combustion. Outside of the unit, energy loss can be minimized by providing sufficient insulation to the combustion units and associated duct work.

For the purposes of this GHG control technology assessment, it is important to note that good operating practices includes periodic maintenance by abiding by an operations and maintenance (O&M) plan. Maintaining the combustion units to the designed combustion efficiency and operating parameters is important for energy efficiency related requirements and efficient operation.

¹⁹¹ *Carbon Capture Opportunities for Natural Gas Fired Power Systems*, US Department of Energy. accessed January 2021. https://www.energy.gov/sites/prod/files/2017/01/f34/Carbon%20Capture%20Opportunities%20for%20Natural%20Gas%20Fired%20Power%20Systems_0.pdf

¹⁹² <http://needtoknow.nas.edu/energy/energy-sources/fossil-fuels/natural-gas/>

5.11.1.2 Elimination of Technically Infeasible CO₂ Control Options – Turbine Systems (Step 2)

5.11.1.2.1 Carbon Capture and Storage

CCS involves cooling, separation and capture of CO₂ from the flue gas prior to the flue gas being emitted from the stack, compression of the captured CO₂, transportation of the compressed CO₂ via pipeline, and finally injection and long-term geologic storage of the captured CO₂. For CCS to be technically feasible, all three components (carbon capture and compression, transport, and storage) must be technically feasible.

It should be noted that there is little to no research that has been completed on the implementation of CCS systems on simple cycle turbines, nor on turbines that utilize fuel oil. Though the lack of research is due to general industry understanding that it is impossible to utilize a CCS system on a simple cycle turbine, the technical feasibility is still conservatively examined in this section. However, due to this lack of research on simple cycle or fuel-oil fired turbines, the technical feasibility in this section is completed using data collected on CCS systems installed on natural gas combined cycle turbines.

Carbon Capture

In the Interagency Task Force report on CCS technologies, a number of pre- and post-combustion CCS projects are discussed in detail; however, many of these projects are in formative stages of development and are predominantly power plant demonstration projects (and mainly slip stream projects).¹⁹³ Currently, only two options appear to be feasible for capture of CO₂ from the flue gas from the turbine systems: Post-Combustion Solvent Capture and Stripping and Post-Combustion Membranes. In one 2009 M.I.T. study conducted for the Clean Air Task Force, it was noted that "To date, all commercial post-combustion CO₂ capture plants use chemical absorption processes with monoethanolamine (MEA)-based solvents."¹⁹⁴

A review of the U.S. Department of Energy's (DoE) National Energy Laboratory's (NETL) research and development awards related to post-combustion capture of CO₂ indicates that moving from pilot scale tests at coal-fired power plants to large-scale commercial operations remains a focus.¹⁹⁵ For example, an ongoing project focused on implementation of a membrane capture process at Basin Electric's Dry Fork Station in Wyoming details pilot scale testing completed related to membranes and outlines the study parameters to develop a path to commercialization for a coal-fired utility.¹⁹⁶ Note that the economic feasibility of membrane-technology is presently being studied with regard to retrofitting an existing natural gas combined-cycle combustion turbine operation, Elk Hills Power Plant, located in the middle of the Elk Hills Oil

¹⁹³ *Report of the Interagency Task Force on Carbon Capture and Storage*, August 2010, Section III, pages. 27-52. https://www.energy.gov/sites/prod/files/2013/04/f0/CCSTaskForceReport2010_0.pdf

¹⁹⁴ Herzog, Meldon, Hatton, *Advanced Post-Combustion CO₂ Capture*, April 2009, page 7. https://sequestration.mit.edu/pdf/Advanced_Post_Combustion_CO2_Capture.pdf

¹⁹⁵ Website reviewed January 2021: <https://netl.doe.gov/node/2476?list=Post-Combustion%20Capture>

¹⁹⁶ *Commerical-Scale Front-End Engineering Design Study for Membrane Technology and Research's Membrane Carbon Dioxide Capture Process*, U.S. Department of Energy, National Energy Technology Laboratory, Fact Sheet for Project Number FE0031846, start date October 1, 2019.

https://netl.doe.gov/projects/plp-download.aspx?id=20071&filename=FE0031846_MTR_Polaris%20FEED_tech%20sheet.pdf

Field, providing options for carbon storage as well as for enhanced oil recovery.¹⁹⁷ Review of the DoE's research projects do not indicate any activity related to fuel oil combustion sources.¹⁹⁸ Although absorption technologies are currently available that may be adaptable to flue gas streams of similar character to the flue gas from the turbine systems, to WCP's knowledge, the technology has never been commercially demonstrated for flue gas control in natural gas fired turbine operations.¹⁹⁹

Presuming carbon capture is feasible, prior to sending the CO₂ stream to the appropriate storage site, it is necessary to compress the CO₂ from near atmospheric pressure to pipeline pressure (around 2,000 psia). The compression of the CO₂ would require a large auxiliary power load, resulting in additional fuel (and CO₂ emissions) to generate the same amount of power.²⁰⁰ The auxiliary power load could be handled by installation of a separate system to solely support CO₂ compression, or alternatively be supported by reducing the available energy for sale, relying on the energy generating systems to instead meet the power needs of the compression system. This is often referred to as an "energy penalty" for operation of the CO₂ compression system.

Carbon Transport

The next step in CCS is the transport of the captured and compressed CO₂ to a suitable location for storage. This would typically be via pipeline. Pipeline transport is available and demonstrated, although costly, technology. Short CO₂ pipelines have been constructed from power plants to proposed injection wells. However, these pipelines are dedicated use for the power plants and are unavailable for other industrial sites.

Since there are no other CO₂ pipelines in the area, WCP would need to construct a CO₂ pipeline to a storage location if it were to pursue carbon sequestration as a CO₂ control option.²⁰¹ While it may be technically feasible to construct a CO₂ pipeline, considerations regarding the land use and availability need to be made. For the purposes of this analysis, it is conservatively assumed that a shortest distance pipeline can be built from a potential sequestration site to a potential carbon storage location. Realistically, a longer pipeline would be required to address land use and right-of-way considerations.

Carbon Storage

Capture of the CO₂ stream and transport are not sufficient control technologies by themselves but require the additional step of permanent storage. After separation and transport, storage could involve sequestering

¹⁹⁷ *Front-End Engineering Design Study for Retrofit Post-Combustion Carbene Capture on a Natural Gas Combined Cycle Power Plant*, U.S. Department of Energy, National Energy Technology Laboratory, Fact Sheet for Project Number FE0031842, start date October 1, 2019.

https://netl.doe.gov/projects/plp-download.aspx?id=20050&filename=FE0031842_EPRI%20FEED_tech%20sheet.pdf

¹⁹⁸ Website reviewed January 2021: <https://netl.doe.gov/node/2476?list=Post-Combustion%20Capture>

¹⁹⁹ Application No. 17040013, *Project Summary for a Construction Permit Application from Jackson Generation, LLC, for an Electrical Generating Facility in Elwood, Illinois*, issued by the Illinois EPA for the public comment period beginning on September 21, 2018. Discussion related to selection of BACT for GHG emissions, Attachment B page 62.

²⁰⁰ *Report of the Interagency Task Force on Carbon Capture and Storage*, August 2010, page 29.
https://www.energy.gov/sites/prod/files/2013/04/f0/CCSTaskForceReport2010_0.pdf

²⁰¹ *A Review of the CO₂ Pipeline Infrastructure in the U.S.*, National Energy Technology Laboratory, Office of Fossil Energy, U.S. Department of Energy, April 2015. DOE/NETL-2014/1681.
https://www.energy.gov/sites/prod/files/2015/04/f22/QR%20Analysis%20-%20A%20Review%20of%20the%20CO2%20Pipeline%20Infrastructure%20in%20the%20U.S._0.pdf

the CO₂ through various means such as enhanced oil recovery, injection into saline aquifers, and sequestration in un-minable coal seams, each of which are discussed as follows:

- ▶ Enhanced Oil Recovery (EOR): EOR involves injecting CO₂ into a depleted oil field underground, which increases the reservoir pressure, dissolves the CO₂ in the crude oil (thus reducing its viscosity) and enables the oil to flow more freely through the formation with the decreased viscosity and increased pressure. A portion of the injected CO₂ would flow to the surface with the oil and be captured, separated, and then re-injected. At the end of EOR, the CO₂ would be stored in the depleted oil field.
- ▶ Saline Aquifers: Deep saline aquifers have the potential to store post-capture CO₂ deep underground below impermeable cap rock.
- ▶ Un-Mineable Coal Seams: Additional storage is possible by injecting the CO₂ into un-mineable coal seams. This has been used successfully to recover coal bed methane. Recovering methane is enhanced by injecting CO₂ or nitrogen into the coal bed, which adsorbs onto the coal surface thereby releasing methane.

There are additional methods of sequestration such as direct ocean injection of CO₂ and algae capture and sequestration (and subsequent conversion to fuel); however, these methods are not as widely documented in the literature for industrial scale applications. As such, while capture-only technologies may be technologically available at a small-scale, the limiting factor is the availability of a mechanism for WCP to permanently store the captured CO₂.


NETL's Carbon Capture and Storage Database provides a summary of potential storage locations.²⁰² According to the database, the Black Warrior Basin of Alabama is the closest sequestration site where a test well has been drilled. The Black Warrior Basin, located Northeast of Tuscaloosa, Alabama is a pilot-scale Southeast Regional Carbon Sequestration Partnership (SECARB) CO₂ sequestration project site that has achieved an injection of 278 tons of CO₂ with the potential to sequester 1.12 to 2.32 Gigatonnes (Gt) of CO₂.²⁰³ The injection location is a mature coalbed methane reservoir within the Blue Creek Coal Degasification Field in Tuscaloosa County, Alabama. Figure 5-1 is a map of possible sequestration formations that have gone through SECARB's Phase II Validation program.²⁰⁴ The Black Warrior Basin, listed as the Coal Seam Project near Tuscaloosa, AL on Figure 5-1, is the closest pilot or large-scale CO₂ sequestration project site to WCP Sandersville and is approximately 246 miles from the Facility.

²⁰² Carbon Capture and Storage Database maintained by the NETL, accessed January 2021 at <https://www.netl.doe.gov/coal/carbon-storage/worldwide-ccs-database>

²⁰³ *Black Warrior Basin Coal Seam Project*, SECARB. Summary document at <http://www.secarbon.org/files/black-warrior-basin.pdf>

²⁰⁴ http://www.secarbon.org/index.php?page_id=8

Figure 5-1. Map of Potential Carbon Sequestration Sites



WCP has concluded that CCS technology is not technically feasible at this time, based on the discussions provided. However, despite the significant technical challenges discussed earlier in implementing CCS technology on turbine systems of this size, WCP is including CCS in Step 3 of this analysis, although realistically technical feasibility is still unlikely.

5.11.1.2.2 Efficient Turbine Operation and Good Combustion, Operating, and Maintenance Practices

One way to efficiently generate electricity from a natural gas or fuel oil fuel source is the use of a combined-cycle turbine design.²⁰⁵ However, usage of combined-cycle technology is not feasible for this project, as it will remove the turbine's capability to perform its function as a quick starting unit. For the purposes of BACT consideration, combined-cycle and simple-cycle turbines are not considered to be the same source type. Therefore, the use of combined-cycle technology is not being considered as a way of increasing efficiency as it fundamentally changes the scope of the project, and will not be evaluated beyond this step. The EPA Environmental Appeals Board (EAB) affirmed the determination that simple-cycle and combined-cycle

²⁰⁵ <http://needtoknow.nas.edu/energy/energy-sources/fossil-fuels/natural-gas/>

technologies are different source types for BACT determination in its response to comments on a PSD permit application for the Pio Pico Energy Center in August 2013.²⁰⁶

Efficient turbine operation coupled with good combustion, operating, and maintenance practices are a potential control option for optimizing the fuel efficiency of the combustion turbines. Combustion turbines typically operate in a lean pre-mix mode to ensure an effective staging of air/fuel ratios in the turbine to maximize fuel efficiency and minimize incomplete combustion. Furthermore, the turbine systems are sufficiently automated to ensure optimal fuel combustion and efficient operation leaving virtually no need for operator tuning of these aspects of operation.

Therefore, CCS and efficient turbine operation coupled with good combustion, operating, and maintenance practices are evaluated further for CO₂ BACT purposes.

5.11.1.3 Summary and Ranking of Remaining CO₂ Controls (Step 3)

The remaining control methods are listed below, in descending order of the expected CO₂ reductions.

- Carbon capture and storage (CCS), 90% reduction²⁰⁷
- Efficient Turbine Operation and Good Combustion, Operating, and Maintenance Practices, reduction efficiency is not applicable.

5.11.1.4 Evaluation of Most Stringent CO₂ Control Technologies (Step 4)

5.11.1.4.1 Carbon Capture and Storage

As the most stringent control option available, CCS would be considered BACT, barring the consideration of its energy, environmental, and/or economic impacts. However, for the reasons outlined in this section, this option should not be relied upon as BACT and the next most stringent alternative should be evaluated.

The use of CCS would be prohibitive to the project, as the cost of installing and maintaining the system will greatly exceed the benefit of any GHG emission reductions the system will offer. The costs associated with the system include capital costs, such as the installation of a pipeline for conveyance and the actual installation of the system, and the operation and maintenance costs of carbon capture, transport, and storage. Detailed cost calculations are provided in Appendix D, with a brief summary herein.

The first capital cost for consideration is the cost associated with the installation of a pipeline from the Sandersville site to the nearest carbon sequestration site. Currently, there exist no carbon storage sites in the state of Georgia, and the site closest to Sandersville is the Black Warrior Basin located near Birmingham, Alabama. If the shortest possible pipeline between these sites were to be installed, 246 miles of pipeline

²⁰⁶ EAB responded to comments that BACT for a simple-cycle turbine should require a combined-cycle configuration as BACT. In the written response to the appeal, EAB wrote:

"Mr. Simpson and Sierra Club have not demonstrated that the Region clearly erred in eliminating combined-cycle gas turbines in step 2 of its BACT analysis for greenhouse gases, or that the issue otherwise warrants review or remand. In particular, the Board concludes that the Region did not define "source type" too narrowly in step 2, nor did the Region clearly err when it referenced the power purchase agreement and related documents in its analysis."

²⁰⁷ *Estimating Carbon Dioxide Transport and Storage Costs*, National Energy Technology Laboratory, U.S. DOE, DOE/NETL-2010/1447, Page 9, March 2010.

would be installed, crossing from Georgia into Alabama.²⁰⁸ In addition, one injection well will need to be installed at the basin. Costs involved include an initial site screening, purchasing of injection equipment, well construction, and liability insurance.

As previously discussed, evaluation of costs for CCS systems for natural gas combustion have focused on combined-cycle units. Hence, for purposes of this evaluation, use of cost information related to a natural gas combined-cycle energy facility have been relied upon. Capital costs for carbon capture are calculated based on the difference between a natural gas combined-cycle energy facility with and without capture in terms of \$/kW (net). Total plant capital cost for a turbine with no CCS capture is estimated as 780 \$/kW, while total plant capital cost for a turbine with CCS is estimated as 1,984 \$/kW.²⁰⁹ As evidenced by these values, the cost of installing a system with CCS capture is greater than double the cost of installing one without. The estimated capital cost for installing the CCS system for the affected turbines by calculating the capital cost for each scenario and taking the difference to calculate the additional cost from the installation of the system.

When the aforementioned costs are summed, the total capital costs for installing a CCS system are greater than \$1 billion. This cost alone is clearly prohibitive to the installation of the system but does not yet take operating and maintenance costs into account.

There are several costs related to the ongoing operation and maintenance of a CCS system that are not accounted for in the capital cost, including:

- Operating and maintenance costs for the CCS system such as labor, property taxes, and insurance, as well as costs to purchase the water and chemicals (including an MEA solvent) used in the system itself.
- The pipeline to transport the compressed gas to the storage site has a fixed operation and maintenance costs.²¹⁰
- The actual storage of the gas at a chosen location requires pore space acquisition, daily expenses, consumables, surface maintenance, and subsurface maintenance.²¹¹

²⁰⁸ Distance from the facility to the nearest potential CO₂ sequestration facility (Black Warrior Basin) per the Southeast Regional Carbon Sequestration Partnership (SECARB), conservatively assuming the shortest distance as the pipeline route. Note that this site utilized an injection well as part of SECARB's Phase I study, but that injection well has reverted back to its original use for coalbed methane production.

http://secarbon.org/index.php?page_id=8; and

<http://secarbon.org/files/black-warrior-basin.pdf>

²⁰⁹ *Cost and Performance Baseline for Fossil Energy Plants Volume 1: Bituminous Coal and Natural Gas to Electricity*, September 2019, Exhibit 5-17, Case B31A Total Plant Cost Details (page 526) and Exhibit 5-31. Case B31B Total Plant Cost Details (page 545).

https://www.netl.doe.gov/projects/files/CostAndPerformanceBaselineForFossilEnergyPlantsVol1BitumCoalAndNGtoElectBBRRev4-1_092419.pdf

²¹⁰ *Carbon Dioxide Transport and Storage Costs in NETL Studies*, March 2013 DOE/NETL-2013/1614, Exhibit 2.

²¹¹ *Estimating Carbon Dioxide Transport and Storage Costs*, March 2010 National Energy Technology laboratory, U.S. DOE, DOE/NETL-2010/1447, Table 3, March 2010.

<http://www.canadiancleanpowercoalition.com/pdf/CTS11%20-%20QGESstransport.pdf>

Based on the calculations completed for these costs, the total annualized cost for operation and maintenance of the CCS system will exceed \$235 million. The resulting annualized total capital and operating cost per ton of CO₂ controlled is approximately \$170 per ton.

The overall costs of installing and operating the CCS system are clearly prohibitive to completing the project, both in terms of absolute costs and cost effectiveness on a \$/ton pollutant removed basis. Given the negative economic considerations, as well as the technical challenges associated with implementing CCS on a simple-cycle turbine, it is deemed infeasible and eliminated as a viable option for BACT.

5.11.1.5 Selection of CO₂ BACT (Step 5)

CO₂ BACT for these projects includes efficient turbine operation coupled with good combustion, operating, and maintenance practices. As mentioned previously, the resulting BACT standard is an emission limit unless technological or economical limitations of the measurement methodology would make the imposition of an emissions standard infeasible, in which case a work practice or operating standard can be imposed.

BACT determinations for similar simple-cycle generating units, as detailed in the RBLC summary tables in Appendix C denote energy efficiency, good design and good combustion practices as BACT. Post-combustion capture and sequestration of CO₂ is not required. BACT limits for natural gas and fuel oil simple-cycle units can be found expressed in terms of lb/MWh, Btu/kWh, or tons, typically with a 12-month rolling total averaging period.

Due to the inherent intermittent usage of the turbine systems, it is most effective to set a BACT limit for tons of CO₂e emitted over a 12-month rolling total averaging period for the units at the WCP Sandersville facility. To calculate the BACT limit, emission factors for fuel combustion were based on U.S. EPA default fuel combustion emission factors found in 40 CFR Part 98 Subpart C, Tables C-1 and C-2, converted from units of kg/MMBtu to lb/MMBtu.

The maximum annual operating capacity for each type of fuel was calculated based on the fuel input capacities for each fuel type. The natural gas heat input capacity per turbine is 1,766 MMBtu/hr. Presuming 3,000 hours per year on natural gas per turbine, the facility has a maximum annual operating capacity of 21.2 million MMBtu/yr from natural gas. The fuel oil heat input capacity per turbine is 1,890 MMBtu/hr. With 500 hours per year per turbine for fuel oil combustion, the facility has a maximum annual operating capacity of 3.8 million MMBtu/yr from fuel oil.

As detailed in Appendix C, multiplying the U.S. EPA emission factors by the maximum annual operating capacity for each type of fuel yields maximum potential emissions of 1,240,760 tons of CO₂e/year from natural gas combustion and 309,228 tons of CO₂e/year from fuel oil combustion. Summing these together yields potential CO₂e emissions of 1,549,988 tpy from the turbine systems combined. As such, WCP Sandersville is proposing a BACT limit of **387,497 tpy** of CO₂e on a 12-month rolling averaging period for each turbine unit.

Based on a review of the RBLC database, this BACT limit is comparable to other limits that have been established for facilities with similar systems in place. As such, WCP Sandersville believes it is appropriate to comply with PSD requirements.

Compliance with the proposed BACT limit will be demonstrated by monitoring fuel consumption. Specifically, the monthly CO₂e emissions will be calculated based on the monthly fuel use, the CO₂, CH₄, and N₂O emission factors from 40 CFR Part 98 Subpart C, Tables C-1 and C-2, and the current GWPs from Subpart A

to 40 CFR 98 (1 for CO₂, 25 for CH₄, and 298 for N₂O). These calculations will be performed on a monthly basis to ensure that the 12-month rolling total tons per year emission limit is not exceeded.

Through this proposed BACT limit, WCP limits the maximum fuel consumption and CO₂e emissions, effectively requiring efficient operation at the design heat rate, when operating at 100% load (as inefficient turbine operation would require additional fuel consumption which is undesirable from an operator's perspective).

5.11.2 Turbine Systems CH₄ BACT

CH₄ emissions from the natural gas and fuel oil-fired combustion turbines form as a result of incomplete combustion of hydrocarbons present in the natural gas fuel.

5.11.2.1 Identification of Potential CH₄ Control Technologies (Step 1)

The only available control options for minimizing CH₄ emissions from the combustion turbine systems are efficient turbine operation coupled with good combustion, operating, and maintenance practices to minimize unburned fuel. Oxidation catalysts are not considered available for reducing CH₄ emissions because oxidizing the very low concentrations of CH₄ present in the combustion turbine's exhaust would require much higher temperatures, residence times, and catalyst loadings than those offered commercially for CO oxidation catalysts. For these reasons, catalyst providers do not offer products for reducing CH₄ emissions from gas-fired combustion turbines.

5.11.2.2 Technically Infeasible CH₄ Control Options (Step 2)

Efficient turbine operation coupled with good combustion, operating, and maintenance practices are the only technically feasible control options for reducing CH₄ emissions from the combustion turbines.

5.11.2.3 Summary and Ranking of Remaining CH₄ Control Technologies (Step 3)

Since efficient turbine operation coupled with good combustion, operating, and maintenance practices are evaluated in the remaining steps of the BACT analysis, no ranking of control options is required.

5.11.2.4 Evaluation of Most Stringent CH₄ Control Technologies (Step 4)

No adverse energy, environment, or economic impacts are associated with efficient turbine operation and good combustion, operating, and maintenance practices for reducing CH₄ emissions from the combustion turbine.

5.11.2.5 Selection of CH₄ BACT (Step 5)

Efficient turbine design and good combustion, operating, and maintenance practices are the selected control options for minimizing CH₄ emissions from the combustion turbine systems. WCP has determined that a numerical limit for CH₄ is unnecessary and that the work practices required for CO₂ BACT (i.e., monthly fuel consumption monitoring and emissions calculations), and efficient turbine operation coupled with good combustion, operating, and maintenance practices, are sufficient for CH₄ BACT, in addition to the aforementioned CO₂e limit as proposed in Section 5.11.1.5. The CH₄ portion of the proposed CO₂e BACT limit will be calculated based on the emission factor from 40 CFR Part 98 Subpart C and the GWP of 25 (per 40 CFR 98 Subpart A, rule effective January 1, 2014).

5.11.3 Turbine Systems N₂O BACT

For the proposed projects, the contribution of N₂O to the total CO₂e emissions is trivial and therefore should not warrant a detailed BACT review. Nevertheless, the additional information provided supports the rationale that the proposed projects meet BACT for contributions of N₂O to CO₂e.

A tradeoff between NO_x and N₂O emissions from the combustion turbines exists when developing a combustion control strategy which influences the BACT selection process. There are five (5) primary pathways of NO_x production in gas-fired combustion turbine combustion processes: thermal NO_x, prompt NO_x, NO_x from N₂O intermediate reactions, fuel NO_x, and NO_x formed through reburning. For turbines using DLN combustors, the N₂O pathway is an important mechanism of NO_x formation. Flame radicals produced in the high temperature and pressure DLN combustion zone react with the N₂O molecule, creating N₂ and NO.²¹² In premixed gas flames, N₂O is primarily formed in the flame front or oxidation zone. Once formed, the N₂O is readily destroyed due to the relatively high concentration of H radicals, and therefore, the N₂O emissions from premixed gas flames like DLN combustor flames are found experimentally to be very small (generally less than 1 ppm). However, any mechanisms which decrease the H atom concentration in the N₂O formation zone can increase N₂O emissions. These mechanisms include lowering the flame combustion temperature, air-to-fuel staging, and injection of ammonia, urea, or other amine or cyanide species into the exhaust stream which are all common NO_x control measures.²¹³ Therefore, there is a tradeoff between NO_x and N₂O emissions when developing a combustion control strategy which influences the BACT selection process.

5.11.3.1 Identification of Potential N₂O Control Technologies (Step 1)

N₂O catalysts are a potential control option, as these have been used in nitric/adipic acid plant applications to minimize N₂O emissions.²¹⁴ Through this technology, tail gas from the nitric acid production process is routed to a reactor vessel with a N₂O catalyst followed by ammonia injection and a NO_x catalyst.

5.11.3.2 Technically Infeasible N₂O Control Options (Step 2)

N₂O catalyst providers do not offer products to control N₂O emissions from gas-fired combustion turbines due to the very low N₂O concentrations present in exhaust streams (approximately 5 ppm).²¹⁵ In comparison, the application of a catalyst in the nitric acid industry sector has been effective due to the high (1,000-2,000 ppm) N₂O concentration in the exhaust stream.

With N₂O catalysts eliminated, good combustion practice is the only available control option.

Good combustion practices are technically feasible control options for reducing N₂O emissions from the combustion turbines.

²¹² Angello, L., Electric Power Research Institute, *Fuel Composition Impacts on Combustion Turbine Operability*, March 2006.

²¹³ American Petroleum Institute, *Compendium of Greenhouse Gas Emissions Methodologies for the Oil and Gas Industry*, February 2004.

²¹⁴ *N₂O Emissions from Adipic Acid and Nitric Acid Production*, written by Heike Mainhardt (ICF Incorporated) and reviewed by Dina Kruger (U.S. EPA). http://www.ipcc-nggip.iges.or.jp/public/gp/bgp/3_2_Adipic_Acid_Nitric_Acid_Production.pdf

²¹⁵ *Emissions of Nitrous Oxide from Combustion Sources*, in *Progress and Energy and Combustion Science* 18(6): pages 529-552, December 1992, found at: https://www.researchgate.net/publication/223546823_Emissions_of_nitrous_oxide_from_combustion_sources

5.11.3.3 Summary and Ranking of Remaining N₂O Control Technologies (Step 3)

Since good combustion practices are evaluated in the remaining steps of the BACT analysis, no ranking of control options is required.

5.11.3.4 Evaluation of Most Stringent N₂O Control Technologies (Step 4)

As indicated in U.S. EPA's guidance on GHG BACT, GHG control strategies may have the potential to produce higher criteria pollutants as in the case of the competing NO_x and N₂O combustion control strategies for WCP's combustion turbine systems. In such cases, the guidance suggests that the applicant should consider the effects of increases in emissions of other regulated pollutants that may result from the use of that GHG control strategy, and based on this analysis, the permitting authority can determine whether or not the application of that GHG control strategy is appropriate given the potential increases in other pollutants.²¹⁶

Given the low N₂O emissions relative to NO_x emissions from the combustion turbine systems and U.S. EPA's continued concern over adverse impacts from ozone formation due to NO_x and VOC emissions, WCP does not consider it appropriate to control the combustion processes of the combustion turbine to specifically reduce N₂O emissions due to the counteractive increase in NO_x emissions. Therefore, good combustion practice for the specific purpose of minimizing N₂O formation is eliminated on the basis of adverse criteria pollutant impacts.


5.11.3.5 Selection of N₂O BACT (Step 5)

Efficient turbine design and general good combustion, operating, and maintenance practices are the selected control options for reducing N₂O emissions from the combustion turbines. WCP has determined that a numerical limit for N₂O emissions is unnecessary and that the work practices required for CO₂ BACT (i.e., monthly fuel consumption monitoring and emissions calculations), and efficient turbine operation coupled with good combustion, operating, and maintenance practices, are sufficient for N₂O BACT, in addition to the aforementioned CO₂e limit as proposed in Section 5.11.1.5. The N₂O portion of the proposed CO₂e BACT limit will be calculated based on the emission factor from 40 CFR Part 98 Subpart C and the GWP of 298 (per 40 CFR 98 Subpart A, rule effective January 1, 2014).


²¹⁶ PSD and Title V permitting Guidance for Greenhouse Gases. March 2011, page 39.

APPENDIX A. AREA MAP AND PROCESS FLOW DIAGRAM

Appendix A-1. Area Map
Washington County Power, LLC - Sandersville, Washington County , Georgia




UTM Easting (m)
All Coordinates shown in UTM Coordinates,
Zone 17, NAD 83 Datum



Legend

- Process/Process Equipment
- ▶ Air Flow
- ▶ Air Emissions



**Washington County Power, LLC
Sandersville, GA**

Appendix A-2. Process Flow Diagram



200101.0039
January 2021

APPENDIX B. EMISSION CALCULATIONS

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-1. Historical Combustion Turbine Heat Inputs¹

Month	T1 - Combustion Turbine No. 1 (MMBtu/mo.)	T2 - Combustion Turbine No. 2 (MMBtu/mo.)	T3 - Combustion Turbine No. 3 (MMBtu/mo.)	T4 - Combustion Turbine No. 4 (MMBtu/mo.)
Jun-11	91,812	111,102	112,819	110,662
Jul-11	67,805	84,607	84,990	60,092
Aug-11	109,101	136,071	156,681	111,833
Sep-11	14,714	80,365	77,645	21,573
Oct-11	1,909	25,063	29,392	1,879
Nov-11	3,908	63,429	87,342	-
Dec-11	24,115	56,339	55,443	20,213
Jan-12	-	26,176	29,098	-
Feb-12	-	29,153	28,839	-
Mar-12	150,690	37,508	64,335	-
Apr-12	362,834	53,247	91,107	102,506
May-12	144,729	79,526	94,150	105,571
Jun-12	70,522	60,567	191,175	90,143
Jul-12	200,920	97,697	261,287	166,686
Aug-12	8,039	79,958	83,104	39,458
Sep-12	-	43,236	63,247	-
Oct-12	55.00	41.00	49	50
Nov-12	-	31,002	9,550	-
Dec-12	-	-	-	-
Jan-13	2,041	-	-	-
Feb-13	-	-	-	-
Mar-13	1,053	1,151	931	3,359
Apr-13	11,265	47,847	19,704	1,840
May-13	-	-	-	-
Jun-13	21,008	34,615	12,784	33,950
Jul-13	295,932	102,463	194,042	388,883
Aug-13	-	10,800	10,662	-
Sep-13	-	22,238	9,096	-
Oct-13	3,494	54,781	54,503	1,911
Nov-13	9,901	29,194	21,241	-
Dec-13	-	-	-	-
Jan-14	-	139.0	1,978	-
Feb-14	-	-	10,287	-
Mar-14	29,155	872.0	1,124	1,001
Apr-14	-	14,058	31,136	-
May-14	-	20,461	23,895	-
Jun-14	13,092	23,547	23,705	36,301
Jul-14	-	15,716	24,295	-
Aug-14	32,518	37,297	9,075	32,220
Sep-14	18,011	13,385	13,745	-
Oct-14	14,425	42,810	43,120	14,377
Nov-14	13,948	36,261	32,902	8,123
Dec-14	-	-	-	-
Jan-15	-	-	2,003	1,822
Feb-15	-	33,556	-	-
Mar-15	1,751	13,086	1,021	1,795
Apr-15	-	-	-	-
May-15	81,419	59,147	71,588	81,507
Jun-15	186,588	46,928	33,749	183,588
Jul-15	236,173	127,366	154,240	215,068
Aug-15	19,127	11,629	47,327	-
Sep-15	76,538	56,281	36,191	37,038
Oct-15	16,124	1,716	1,667	1,630
Nov-15	115,601	6,663	-	101,283
Dec-15	-	-	-	-

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-1. Historical Combustion Turbine Heat Inputs¹

Month	T1 - Combustion Turbine No. 1 (MMBtu/mo.)	T2 - Combustion Turbine No. 2 (MMBtu/mo.)	T3 - Combustion Turbine No. 3 (MMBtu/mo.)	T4 - Combustion Turbine No. 4 (MMBtu/mo.)
Jan-16	-	71,034	43,400	-
Feb-16	-	-	-	-
Mar-16	1,626	118,452	70,238	854.0
Apr-16	-	169,627	158,005	-
May-16	-	6,588	41,573	15,838
Jun-16	32,227	85,782	85,200	22,896
Jul-16	-	51,224	7,179	41,330
Aug-16	-	28,672	-	-
Sep-16	-	76,214	55,625	-
Oct-16	17,675	87,576	41,360	17,324
Nov-16	-	14,697	17,247	-
Dec-16	-	10,965	11,048	-
Jan-17	-	-	-	-
Feb-17	-	-	-	-
Mar-17	878.0	70,338	22,081	1,137
Apr-17	-	93,307	93,171	-
May-17	19,289	79,128	66,118	19,327
Jun-17	-	9,681	7,866	-
Jul-17	57,070	78,655	77,164	57,575
Aug-17	-	127,906	110,791	-
Sep-17	-	116,749	107,540	-
Oct-17	1,106	19,593	1,003	1,012
Nov-17	-	11,934	11,299	-
Dec-17	-	-	-	-
Jan-18	-	-	-	-
Feb-18	-	-	-	-
Mar-18	1,080	5,349	6,226	929.0
Apr-18	-	14,064	39,563	-
May-18	39,336	35,367	9,703	64,982
Jun-18	95,006	57,977	55,837	117,506
Jul-18	17,985	45,619	29,060	-
Aug-18	-	50,946	50,746	-
Sep-18	33,730	64,877	59,041	60,709
Oct-18	27,214	79,106	108,821	53,586
Nov-18	-	-	-	-
Dec-18	-	10,790	11,060	-
Jan-19	-	-	-	-
Feb-19	-	-	-	-
Mar-19	979.0	1,392	1,035	1,073
Apr-19	-	7,073	6,855	-
May-19	34,615	22,820	12,309	-
Jun-19	77,554	35,423	35,235	51,823
Jul-19	37,239	141,423	138,330	191,935
Aug-19	104,086	118,577	116,818	-
Sep-19	217,892	174,599	172,044	249,492
Oct-19	85,573	95,217	92,952	104,699
Nov-19	-	21,958	9,388	-
Dec-19	954.0	1,087	1,030	1,055
Jan-20	-	-	-	-
Feb-20	-	-	-	-
Mar-20	41,652	1,087	1,073	977.0
Apr-20	-	-	-	-
May-20	-	-	-	-
Jun-20	24,613	80,186	60,452	13,174

1. Heat inputs represent historically measured site data.

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-2. Historically Monitored Emissions¹

Month	T1 - Combustion Turbine No. 1			T2 - Combustion Turbine No. 2			T3 - Combustion Turbine No. 3			T4 - Combustion Turbine No. 4		
	NO _x (tons/mo.)	SO ₂ (tons/mo.)	CO ₂ (tons/mo.)	NO _x (tons/mo.)	SO ₂ (tons/mo.)	CO ₂ (tons/mo.)	NO _x (tons/mo.)	SO ₂ (tons/mo.)	CO ₂ (tons/mo.)	NO _x (tons/mo.)	SO ₂ (tons/mo.)	CO ₂ (tons/mo.)
Jun-11	2.00	-	5,456	2.60	-	6,603	2.20	-	6,704	2.20	-	6,577
Jul-11	1.50	-	4,030	1.90	-	5,028	1.70	-	5,051	1.30	-	3,571
Aug-11	2.50	-	6,484	3.20	-	8,086	3.20	-	9,311	2.50	-	6,646
Sep-11	0.40	-	874	1.80	-	4,776	1.50	-	4,615	0.60	-	1,282
Oct-11	0.20	-	113	0.60	-	1,489	0.60	-	1,747	0.10	-	112
Nov-11	0.20	-	232	1.40	-	3,769	1.80	-	5,191	-	-	-
Dec-11	0.60	-	1,433	1.40	-	3,348	1.20	-	3,295	0.40	-	1,201
Jan-12	-	-	-	0.70	-	1,556	0.70	-	1,729	-	-	-
Feb-12	-	-	-	0.80	-	1,733	0.70	-	1,714	-	-	-
Mar-12	3.40	-	8,956	0.90	-	2,229	1.20	-	3,824	-	-	-
Apr-12	6.30	0.10	21,563	1.20	-	3,164	1.70	-	5,414	2.00	-	6,092
May-12	2.40	-	8,601	1.70	-	4,726	1.60	-	5,595	1.50	-	6,274
Jun-12	1.40	-	4,191	1.30	-	3,600	3.60	0.10	11,362	1.60	-	5,357
Jul-12	3.60	0.10	11,940	2.00	-	5,806	4.60	0.10	15,528	2.80	0.10	9,906
Aug-12	0.10	-	478	1.70	-	4,752	1.50	-	4,939	0.60	-	2,345
Sep-12	-	-	-	0.90	-	2,570	1.20	-	3,759	-	-	-
Oct-12	-	-	3	-	-	2	-	-	3	-	-	3
Nov-12	-	-	-	0.70	-	1,843	0.20	-	568	-	-	-
Dec-12	-	-	-	-	-	-	-	-	-	-	-	-
Jan-13	0.10	-	121	-	-	-	-	-	-	-	-	-
Feb-13	-	-	-	-	-	-	-	-	-	-	-	-
Mar-13	0.10	-	63	0.10	-	68	0.10	-	55	0.20	-	200
Apr-13	0.20	-	670	1.10	-	2,844	0.40	-	1,171	0.10	-	109
May-13	-	-	-	-	-	-	-	-	-	-	-	-
Jun-13	0.40	-	1,249	0.70	-	2,057	0.20	-	760	0.60	-	2,018
Jul-13	5.10	0.10	17,586	2.00	-	6,090	3.20	0.10	11,532	6.60	0.10	23,110
Aug-13	-	-	-	0.20	-	642	0.20	-	634	-	-	-
Sep-13	-	-	-	0.50	-	1,322	0.20	-	541	-	-	-
Oct-13	0.10	-	208	1.20	-	3,256	1.10	-	3,239	0.10	-	114
Nov-13	0.20	-	588	0.60	-	1,735	0.40	-	1,262	-	-	-
Dec-13	-	-	-	-	-	-	-	-	-	-	-	-
Jan-14	-	-	-	-	-	8	0.10	-	118	-	-	-
Feb-14	-	-	-	-	-	-	0.20	-	612	-	-	-
Mar-14	0.60	-	1,733	0.10	-	52	0.10	-	67	-	-	60
Apr-14	-	-	-	0.30	-	836	0.60	-	1,850	-	-	-
May-14	-	-	-	0.50	-	1,216	0.50	-	1,420	-	-	-
Jun-14	0.20	-	778	0.50	-	1,399	0.40	-	1,409	0.60	-	2,157
Jul-14	-	-	-	0.40	-	934	0.50	-	1,444	-	-	-
Aug-14	0.60	-	1,933	0.90	-	2,216	0.20	-	539	0.60	-	1,915
Sep-14	0.30	-	1,071	0.30	-	795	0.30	-	817	-	-	-
Oct-14	0.30	-	857	1.00	-	2,544	0.90	-	2,562	0.30	-	854
Nov-14	0.30	-	829	0.90	-	2,155	0.70	-	1,956	0.20	-	483
Dec-14	-	-	-	-	-	-	-	-	-	-	-	-
Jan-15	-	-	-	-	-	-	0.10	-	119	0.10	-	108
Feb-15	-	-	-	0.90	-	1,994	-	-	-	-	-	-
Mar-15	0.10	-	104	0.40	-	778	0.10	-	61	0.10	-	107
Apr-15	-	-	-	-	-	-	-	-	-	-	-	-
May-15	1.40	-	4,839	1.40	-	3,515	1.50	-	4,255	1.40	-	4,844
Jun-15	3.10	0.10	11,089	1.10	-	2,789	0.60	-	2,006	3.20	0.10	10,910
Jul-15	4.10	0.10	14,035	2.80	-	7,569	3.00	-	9,167	3.80	0.10	12,781
Aug-15	0.30	-	1,137	0.30	-	691	0.90	-	2,813	-	-	-
Sep-15	1.20	-	4,548	1.20	-	3,345	0.80	-	2,151	0.50	-	2,201
Oct-15	0.30	-	958	-	-	102	-	-	99	0.10	-	97
Nov-15	1.90	-	6,870	0.20	-	396	-	-	-	1.60	-	6,020
Dec-15	-	-	-	-	-	-	-	-	-	-	-	-
Jan-16	-	-	-	2.10	-	4,222	1.10	-	2,579	-	-	-
Feb-16	-	-	-	-	-	-	-	-	-	-	-	-
Mar-16	0.10	-	97	2.70	-	7,040	1.40	-	4,174	0.10	-	51
Apr-16	-	-	-	4.80	0.10	10,081	3.20	-	9,390	-	-	-
May-16	-	-	-	0.10	-	392	0.90	-	2,471	0.20	-	941
Jun-16	0.50	-	1,915	3.40	-	5,098	1.60	-	5,064	0.40	-	1,360
Jul-16	-	-	-	1.30	-	3,045	0.10	-	427	0.60	-	2,456
Aug-16	-	-	-	0.70	-	1,704	-	-	-	-	-	-
Sep-16	-	-	-	1.90	-	4,529	1.10	-	3,306	-	-	-
Oct-16	0.30	-	1,050	2.30	-	5,204	1.10	-	2,458	0.30	-	1,030
Nov-16	-	-	-	0.40	-	873	0.40	-	1,025	-	-	-
Dec-16	-	-	-	0.30	-	652	0.30	-	657	-	-	-
Jan-17	-	-	-	-	-	-	-	-	-	-	-	-
Feb-17	-	-	-	-	-	-	-	-	-	-	-	-
Mar-17	-	-	52	1.90	-	4,180	0.60	-	1,312	0.10	-	68
Apr-17	-	-	-	2.30	-	5,546	2.20	-	5,537	-	-	-
May-17	0.40	-	1,146	2.00	-	4,702	1.60	-	3,929	0.30	-	1,148
Jun-17	-	-	-	0.30	-	575	0.20	-	468	-	-	-
Jul-17	1.00	-	3,392	1.90	-	4,674	2.70	-	4,586	0.80	-	3,422
Aug-17	-	-	-	2.90	-	7,602	2.40	-	6,585	-	-	-
Sep-17	-	-	-	2.80	-	6,938	2.50	-	6,391	-	-	-
Oct-17	0.10	-	66	0.50	-	1,164	0.10	-	60	0.10	-	60
Nov-17	-	-	-	0.30	-	709	0.30	-	672	-	-	-
Dec-17	-	-	-	-	-	-	-	-	-	-	-	-

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-2. Historically Monitored Emissions¹

Month	T1 - Combustion Turbine No. 1			T2 - Combustion Turbine No. 2			T3 - Combustion Turbine No. 3			T4 - Combustion Turbine No. 4		
	NO _x (tons/mo.)	SO ₂ (tons/mo.)	CO ₂ (tons/mo.)	NO _x (tons/mo.)	SO ₂ (tons/mo.)	CO ₂ (tons/mo.)	NO _x (tons/mo.)	SO ₂ (tons/mo.)	CO ₂ (tons/mo.)	NO _x (tons/mo.)	SO ₂ (tons/mo.)	CO ₂ (tons/mo.)
Jan-18	-	-	-	-	-	-	-	-	-	-	-	-
Feb-18	-	-	-	-	-	-	-	-	-	-	-	-
Mar-18	-	-	64	0.20	-	318	0.20	-	370	0.10	-	55
Apr-18	-	-	-	0.40	-	836	0.80	-	2,351	-	-	-
May-18	0.80	-	2,338	0.80	-	2,102	0.20	-	577	1.10	-	3,861
Jun-18	1.50	-	5,646	1.30	-	3,445	1.20	-	3,319	1.50	-	6,984
Jul-18	0.30	-	1,069	1.00	-	2,711	0.60	-	1,727	-	-	-
Aug-18	-	-	-	1.10	-	3,028	1.10	-	3,016	-	-	-
Sep-18	0.60	-	2,004	1.50	-	3,855	1.30	-	3,509	0.90	-	3,608
Oct-18	0.50	-	1,617	1.80	-	4,701	2.50	-	6,467	0.70	-	3,185
Nov-18	-	-	-	-	-	-	-	-	-	-	-	-
Dec-18	-	-	-	0.30	-	641	0.30	-	657	-	-	-
Jan-19	-	-	-	-	-	-	-	-	-	-	-	-
Feb-19	-	-	-	-	-	-	-	-	-	-	-	-
Mar-19	-	-	58	0.10	-	83	-	-	62	-	-	64
Apr-19	-	-	-	0.20	-	420	0.20	-	407	-	-	-
May-19	0.60	-	2,057	0.50	-	1,356	0.30	-	731	-	-	-
Jun-19	1.20	-	4,609	0.80	-	2,105	0.70	-	2,094	0.60	-	3,080
Jul-19	0.60	-	2,213	3.00	-	8,404	2.80	-	8,221	2.50	0.10	11,408
Aug-19	1.60	-	6,186	2.50	-	7,047	2.30	-	6,942	-	-	-
Sep-19	3.80	0.10	12,948	3.90	0.10	10,377	3.70	0.10	10,225	3.30	0.10	14,826
Oct-19	1.50	-	5,085	2.10	-	5,658	2.00	-	5,524	1.50	-	6,222
Nov-19	-	-	-	0.60	-	1,305	0.30	-	558	-	-	-
Dec-19	0.10	-	57	0.10	-	65	0.10	-	61	0.10	-	63
Jan-20	-	-	-	-	-	-	-	-	-	-	-	-
Feb-20	-	-	-	-	-	-	-	-	-	-	-	-
Mar-20	0.80	-	2,475	0.10	-	65	-	-	64	0.10	-	58
Apr-20	-	-	-	-	-	-	-	-	-	-	-	-
May-20	-	-	-	-	-	-	-	-	-	-	-	-
Jun-20	0.40	-	1,463	1.90	-	4,765	1.30	-	3,592	0.20	-	783

1. Emissions data represent historically measured site data (CEMS units).

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-3. Emission Factors for Turbine Combustion of Natural Gas

Pollutant	Emission Factor (lb/MMBtu)	Emission Factor Basis
SO ₂	6.00E-04	See Note 1
NO _x	3.00E-02	See Note 2
CO	1.82E-02	See Note 2
Total PM	1.37E-02	See Notes 1, 3
Filterable PM	9.00E-03	See Note 1
Condensable PM	4.70E-03	See Note 3
Total PM ₁₀	1.37E-02	See Notes 1, 3, 4
Total PM _{2.5}	1.37E-02	See Notes 1, 3, 4
VOC	6.37E-03	See Note 2
Sulfuric Acid Mist (H ₂ SO ₄)	4.00E-04	See Note 1
<i>GHGs</i>		
CO ₂	116.98	See Note 5
CH ₄	2.20E-03	See Note 5
N ₂ O	2.20E-04	See Note 5
CO ₂ e	117.10	See Note 6

1. Emission factors for natural gas combustion are obtained from the emission limitations in the currently effective Major Source Operating Permit No. 301-0073 for the Calhoun Energy Center (a similar facility). SO₂ factor is the default emission rate for pipeline natural gas from 40 CFR 75, Appendix D, Section 2.3.1.1

2. NO_x/CO/VOC Rate (lb/MMBtu) = Concentration (ppm, or lb-mole pollutant/10⁶ lb-mol air) * Molecular Weight (lb /lb-mol) * Flow (dscfm) * 60 min/hr / Ideal Volume (ft³ air/lb-mol air) / Turbine Heat Input (MMBtu/hr); where

NO _x Molecular Weight	46.01	lb NO _x /lb-mol NO _x
CO Molecular Weight	28.01	lb CO/lb-mol CO
VOC Molecular Weight	44	lb VOC/lb-mol NH ₃
Turbine Flow rate	820,699	dscfm
Volume _{ideal}	385.5	ft ³ air/lb-mol air
Turbine Heat Input	1,766	MMBtu/hr
NO _x Conc. (ppm)	9	BACT selection
CO Conc. (ppm)	9	BACT selection
VOC Conc. (ppm)	2	BACT selection

3. Emission factors for natural gas are from AP-42 Ch. 3.1 Stationary Gas Turbines, Table 3.1-2a (April 2000).

4. Emissions of PM₁₀ and PM_{2.5} are assumed to be equivalent to emissions of total PM.

5. Based on EPA default factors in 40 CFR Part 98 Subpart C Tables C-1 and C-2, effective January 1, 2014, for Natural Gas. Emission factors were converted from units of kg/MMBtu to lb/MMBtu by multiplying the factors by 2.2046 lb/kg.

6. The CO₂e factor is calculated based on the emission factors for CO₂, CH₄, and N₂O and the global warming potential (GWP) for each pollutant per 40 CFR 98, Subpart A, Table A-1:

CO ₂ :	1
CH ₄ :	25
N ₂ O:	298

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-4. Emission Factors for Turbine Combustion of Fuel Oil

Pollutant	Emission Factor (lb/MMBtu)	Emission Factor Basis
SO ₂	1.50E-03	See Note 1
NO _x	1.40E-01	See Note 2
CO	4.05E-02	See Note 2
Total PM	1.42E-02	See Note 3
Filterable PM	7.00E-03	See Note 4
Condensable PM	7.20E-03	See Note 5
Total PM ₁₀	1.42E-02	See Notes 3, 6
Total PM _{2.5}	1.42E-02	See Notes 3, 6
VOC	1.59E-02	See Note 2
Lead	1.40E-05	See Note 5
Sulfuric Acid Mist (H ₂ SO ₄)	3.90E-03	See Note 1
<i>GHGs</i>		
CO ₂	163.05	See Note 7
CH ₄	6.61E-03	See Note 7
N ₂ O	1.32E-03	See Note 7
CO ₂ e	163.61	See Note 8

- SO₂ and H₂SO₄ emission factor is based on the combustion of Ultra Low Sulfur Diesel.
- NO_x/CO/VOC Rate (lb/MMBtu) = Concentration (ppm, or lb-mole pollutant/10⁶ lb-mol air) * Molecular Weight (lb /lb-mol) * Flow (dscfm) * 60 min/hr / Ideal Volume (ft³ air/lb-mol air) / Turbine Heat Input (MMBtu/hr); where

NO _x Molecular Weight	46.01	lb NO _x /lb-mol NO _x
CO Molecular Weight	28.01	lb CO/lb-mol CO
VOC Molecular Weight	44	lb VOC/lb-mol NH ₃
Turbine Flow rate	878,148	dscfm
Volume _{ideal}	385.5	ft ³ air/lb-mol air
Turbine Heat Input	1,890	MMBtu/hr
NO _x Conc. (ppm)	42	BACT Selection
CO Conc. (ppm)	20	BACT Selection
VOC Conc. (ppm)	5	BACT Selection

- Emission factor for Total PM is based on site-specific data and proposed BACT limit.
- Emission factor for Filterable PM is the delta between the Total PM and Condensable PM emission factors.
- Emission factors for fuel oil are from AP-42 Ch. 3.1 Stationary Gas Turbines, Table 3.1-2a (April 2000).
- Emissions of PM₁₀ and PM_{2.5} are assumed to be equivalent to emissions of total PM.
- Based on EPA default factors in 40 CFR Part 98 Subpart C Tables C-1 and C-2, effective January 1, 2014, for Petroleum Products/Distillate Fuel Oil No. 2. Emission factors were converted from units of kg/MMBtu to lb/MMBtu by multiplying the factors by 2.2046 lb/kg.
- The CO₂e factor is calculated based on the emission factors for CO₂, CH₄, and N₂O and the global warming potential (GWP) for each pollutant per 40 CFR 98, Subpart A, Table A-1:
 - CO₂: 1
 - CH₄: 25
 - N₂O: 298

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-5. Emission Factors for Turbine Startup/Shutdown Operations

Pollutant	Emission Factors¹ (lb/MMBtu)	Operation Hours/ Events²
<i>Startup/Shutdown Natural Gas</i>		
NO _x	0.05	300 hrs natural gas
CO	0.03	
VOC	0.01	
<i>Startup/Shutdown Fuel Oil</i>		
NO _x	0.25	50 hrs fuel oil
CO	0.07	
VOC	0.03	

1. Startup/shutdown emission factors based on review and engineering analysis of existing source operational data for SUSD activities.
2. Assumes approximately 10% of estimated operating time per turbine is considered for SUSD activities.

Table B-6. Fuel Heater Emission Factors

Pollutant	Emission Factor (lb/MMscf)	Emission Factor Basis
SO ₂	1.43	See Note 1
NO _x	100.00	See Note 2
CO	84.00	See Note 2
Total PM	7.60	See Note 2
Condensable PM	5.70	See Note 2
Filterable PM	1.90	See Note 2
Total PM ₁₀	7.60	See Notes 2, 3
Total PM _{2.5}	7.60	See Notes 2, 3
VOC	5.50	See Note 2
Lead	5.00E-04	See Note 2
H ₂ SO ₄	3.28E-01	See Note 4
<i>GHGs</i>		
CO ₂	119,317	See Note 5
CH ₄	2.25	See Note 5
N ₂ O	2.25E-01	See Note 5
CO ₂ e	119,440	See Note 6

1. Emission factor calculated based on the assumption that sulfur content in natural gas is 0.50 grains/100 scf. Emission factor calculated as follows:
Emission Factor (lb/MMscf) = (0.5 grains sulfur/100 scf) / (7,000 grains sulfur/lb-mol S) * (64 lb-mol SO₂) / (32 lb-mol S)
2. Emission factors obtained from AP-42 Ch. 1.4 Natural Gas Combustion, Tables 1.4-1 & 2 (July 1998).
3. Emissions of PM₁₀ and PM_{2.5} are assumed to be equivalent to emissions of total PM.
4. Emission factor calculated using the assumption that sulfur content in natural gas is 0.50 grains/100 scf and a 15% oxidation rate. Emission factor calculated as follows:
Emission Factor (lb/MMscf) = (0.5 grains sulfur/100 scf) / (7,000 grains sulfur/lb-mol S) * (98 lb-mol H₂SO₄) / (32 lb-mol S) * 0.15
- 5., Based on EPA default factors in 40 CFR Part 98 Subpart C Tables C-1 and C-2, effective January 1, 2014, for Natural Gas. Emission factors were converted from units of kg/MMBtu to lb/MMscf as follows:
Emission Factor (lb/MMscf) = Emission Factor (kg/MMBtu) * 2.2046 (lb/kg) * 1,020 (MMBtu/MMscf)
6. The CO₂e factor is calculated based on the emission factors for CO₂, CH₄, and N₂O and the global warming potential (GWP) for each pollutant per 40 CFR 98, Subpart A, Table A-1:
CO₂: 1
CH₄: 25
N₂O: 298

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-7. Historical Actual Monthly Emissions from Combustion Turbine No. 1 (tons/month)^{1,2}

Month	T1 - Combustion Turbine No. 1										
	Filterable PM	Condensable PM	Total PM	Total PM ₁₀	Total PM _{2.5}	SO ₂	NO _x	CO	VOC	Sulfuric Acid Mist (H ₂ SO ₄)	CO ₂ e ³
Jun-11	0.41	0.22	0.63	0.63	0.63	-	2.00	0.84	0.29	0.02	5,462
Jul-11	0.31	0.16	0.46	0.46	0.46	-	1.50	0.62	0.22	0.01	4,034
Aug-11	0.49	0.26	0.75	0.75	0.75	-	2.50	0.99	0.35	0.02	6,490
Sep-11	0.07	0.03	0.10	0.10	0.10	-	0.40	0.13	0.05	2.94E-03	875
Oct-11	0.01	4.49E-03	0.01	0.01	0.01	-	0.20	0.02	0.01	3.82E-04	114
Nov-11	0.02	0.01	0.03	0.03	0.03	-	0.20	0.04	0.01	7.82E-04	232
Dec-11	0.11	0.06	0.17	0.17	0.17	-	0.60	0.22	0.08	4.82E-03	1,435
Jan-12	-	-	-	-	-	-	-	-	-	-	-
Feb-12	-	-	-	-	-	-	-	-	-	-	-
Mar-12	0.68	0.35	1.03	1.03	1.03	-	3.40	1.37	0.48	0.03	8,965
Apr-12	1.63	0.85	2.49	2.49	2.49	0.10	6.30	3.31	1.15	0.07	21,585
May-12	0.65	0.34	0.99	0.99	0.99	-	2.40	1.32	0.46	0.03	8,610
Jun-12	0.32	0.17	0.48	0.48	0.48	-	1.40	0.64	0.22	0.01	4,195
Jul-12	0.90	0.47	1.38	1.38	1.38	0.10	3.60	1.83	0.64	0.04	11,952
Aug-12	0.04	0.02	0.06	0.06	0.06	-	0.10	0.07	0.03	1.61E-03	478
Sep-12	-	-	-	-	-	-	-	-	-	-	-
Oct-12	2.48E-04	1.29E-04	3.77E-04	3.77E-04	3.77E-04	-	-	5.01E-04	1.75E-04	1.10E-05	3
Nov-12	-	-	-	-	-	-	-	-	-	-	-
Dec-12	-	-	-	-	-	-	-	-	-	-	-
Jan-13	0.01	4.80E-03	0.01	0.01	0.01	-	0.10	0.02	0.01	4.08E-04	121
Feb-13	-	-	-	-	-	-	-	-	-	-	-
Mar-13	4.74E-03	2.47E-03	0.01	0.01	0.01	-	0.10	0.01	3.35E-03	2.11E-04	63
Apr-13	0.05	0.03	0.08	0.08	0.08	-	0.20	0.10	0.04	2.25E-03	670
May-13	-	-	-	-	-	-	-	-	-	-	-
Jun-13	0.09	0.05	0.14	0.14	0.14	-	0.40	0.19	0.07	4.20E-03	1,250
Jul-13	1.33	0.70	2.03	2.03	2.03	0.10	5.10	2.70	0.94	0.06	17,604
Aug-13	-	-	-	-	-	-	-	-	-	-	-
Sep-13	-	-	-	-	-	-	-	-	-	-	-
Oct-13	0.02	0.01	0.02	0.02	0.02	-	0.10	0.03	0.01	6.99E-04	208
Nov-13	0.04	0.02	0.07	0.07	0.07	-	0.20	0.09	0.03	1.98E-03	589
Dec-13	-	-	-	-	-	-	-	-	-	-	-
Jan-14	-	-	-	-	-	-	-	-	-	-	-
Feb-14	-	-	-	-	-	-	-	-	-	-	-
Mar-14	0.13	0.07	0.20	0.20	0.20	-	0.60	0.27	0.09	0.01	1,734
Apr-14	-	-	-	-	-	-	-	-	-	-	-
May-14	-	-	-	-	-	-	-	-	-	-	-
Jun-14	0.06	0.03	0.09	0.09	0.09	-	0.20	0.12	0.04	2.62E-03	779
Jul-14	-	-	-	-	-	-	-	-	-	-	-
Aug-14	0.15	0.08	0.22	0.22	0.22	-	0.60	0.30	0.10	0.01	1,934
Sep-14	0.08	0.04	0.12	0.12	0.12	-	0.30	0.16	0.06	3.60E-03	1,072
Oct-14	0.06	0.03	0.10	0.10	0.10	-	0.30	0.13	0.05	2.89E-03	858
Nov-14	0.06	0.03	0.10	0.10	0.10	-	0.30	0.13	0.04	2.79E-03	830
Dec-14	-	-	-	-	-	-	-	-	-	-	-
Jan-15	-	-	-	-	-	-	-	-	-	-	-
Feb-15	-	-	-	-	-	-	-	-	-	-	-
Mar-15	0.01	4.11E-03	0.01	0.01	0.01	-	0.10	0.02	0.01	3.50E-04	104
Apr-15	-	-	-	-	-	-	-	-	-	-	-
May-15	0.37	0.19	0.56	0.56	0.56	-	1.40	0.74	0.26	0.02	4,844
Jun-15	0.84	0.44	1.28	1.28	1.28	0.10	3.10	1.70	0.59	0.04	11,100
Jul-15	1.06	0.56	1.62	1.62	1.62	0.10	4.10	2.15	0.75	0.05	14,049
Aug-15	0.09	0.04	0.13	0.13	0.13	-	0.30	0.17	0.06	3.83E-03	1,138
Sep-15	0.34	0.18	0.52	0.52	0.52	-	1.20	0.70	0.24	0.02	4,553
Oct-15	0.07	0.04	0.11	0.11	0.11	-	0.30	0.15	0.05	3.22E-03	959
Nov-15	0.52	0.27	0.79	0.79	0.79	-	1.90	1.05	0.37	0.02	6,877
Dec-15	-	-	-	-	-	-	-	-	-	-	-
Jan-16	-	-	-	-	-	-	-	-	-	-	-
Feb-16	-	-	-	-	-	-	-	-	-	-	-
Mar-16	0.01	3.82E-03	0.01	0.01	0.01	-	0.10	0.01	0.01	3.25E-04	97
Apr-16	-	-	-	-	-	-	-	-	-	-	-
May-16	-	-	-	-	-	-	-	-	-	-	-
Jun-16	0.15	0.08	0.22	0.22	0.22	-	0.50	0.29	0.10	0.01	1,917
Jul-16	-	-	-	-	-	-	-	-	-	-	-
Aug-16	-	-	-	-	-	-	-	-	-	-	-
Sep-16	-	-	-	-	-	-	-	-	-	-	-
Oct-16	0.08	0.04	0.12	0.12	0.12	-	0.30	0.16	0.06	3.54E-03	1,051
Nov-16	-	-	-	-	-	-	-	-	-	-	-
Dec-16	-	-	-	-	-	-	-	-	-	-	-

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-7. Historical Actual Monthly Emissions from Combustion Turbine No. 1 (tons/month)^{1,2}

Month	T1 - Combustion Turbine No. 1										
	Filterable PM	Condensable PM	Total PM	Total PM ₁₀	Total PM _{2.5}	SO ₂	NO _x	CO	VOC	Sulfuric Acid Mist (H ₂ SO ₄)	CO ₂ e ³
Jan-17	-	-	-	-	-	-	-	-	-	-	-
Feb-17	-	-	-	-	-	-	-	-	-	-	-
Mar-17	3.95E-03	2.06E-03	0.01	0.01	0.01	-	-	0.01	2.79E-03	1.76E-04	52
Apr-17	-	-	-	-	-	-	-	-	-	-	-
May-17	0.09	0.05	0.13	0.13	0.13	-	0.40	0.18	0.06	3.86E-03	1,147
Jun-17	-	-	-	-	-	-	-	-	-	-	-
Jul-17	0.26	0.13	0.39	0.39	0.39	-	1.00	0.52	0.18	0.01	3,396
Aug-17	-	-	-	-	-	-	-	-	-	-	-
Sep-17	-	-	-	-	-	-	-	-	-	-	-
Oct-17	4.98E-03	2.60E-03	0.01	0.01	0.01	-	0.10	0.01	3.52E-03	2.21E-04	66
Nov-17	-	-	-	-	-	-	-	-	-	-	-
Dec-17	-	-	-	-	-	-	-	-	-	-	-
Jan-18	-	-	-	-	-	-	-	-	-	-	-
Feb-18	-	-	-	-	-	-	-	-	-	-	-
Mar-18	4.86E-03	2.54E-03	0.01	0.01	0.01	-	-	0.01	3.44E-03	2.16E-04	64
Apr-18	-	-	-	-	-	-	-	-	-	-	-
May-18	0.18	0.09	0.27	0.27	0.27	-	0.80	0.36	0.13	0.01	2,340
Jun-18	0.43	0.22	0.65	0.65	0.65	-	1.50	0.87	0.30	0.02	5,652
Jul-18	0.08	0.04	0.12	0.12	0.12	-	0.30	0.16	0.06	3.60E-03	1,070
Aug-18	-	-	-	-	-	-	-	-	-	-	-
Sep-18	0.15	0.08	0.23	0.23	0.23	-	0.60	0.31	0.11	0.01	2,006
Oct-18	0.12	0.06	0.19	0.19	0.19	-	0.50	0.25	0.09	0.01	1,619
Nov-18	-	-	-	-	-	-	-	-	-	-	-
Dec-18	-	-	-	-	-	-	-	-	-	-	-
Jan-19	-	-	-	-	-	-	-	-	-	-	-
Feb-19	-	-	-	-	-	-	-	-	-	-	-
Mar-19	4.41E-03	2.30E-03	0.01	0.01	0.01	-	-	0.01	3.12E-03	1.96E-04	58
Apr-19	-	-	-	-	-	-	-	-	-	-	-
May-19	0.16	0.08	0.24	0.24	0.24	-	0.60	0.32	0.11	0.01	2,059
Jun-19	0.35	0.18	0.53	0.53	0.53	-	1.20	0.71	0.25	0.02	4,614
Jul-19	0.17	0.09	0.26	0.26	0.26	-	0.60	0.34	0.12	0.01	2,215
Aug-19	0.47	0.24	0.71	0.71	0.71	-	1.60	0.95	0.33	0.02	6,192
Sep-19	0.98	0.51	1.49	1.49	1.49	0.10	3.80	1.99	0.69	0.04	12,961
Oct-19	0.39	0.20	0.59	0.59	0.59	-	1.50	0.78	0.27	0.02	5,091
Nov-19	-	-	-	-	-	-	-	-	-	-	-
Dec-19	4.29E-03	2.24E-03	0.01	0.01	0.01	-	0.10	0.01	3.04E-03	1.91E-04	57
Jan-20	-	-	-	-	-	-	-	-	-	-	-
Feb-20	-	-	-	-	-	-	-	-	-	-	-
Mar-20	0.19	0.10	0.29	0.29	0.29	-	0.80	0.38	0.13	0.01	2,478
Apr-20	-	-	-	-	-	-	-	-	-	-	-
May-20	-	-	-	-	-	-	-	-	-	-	-
Jun-20	0.11	0.06	0.17	0.17	0.17	-	0.40	0.22	0.08	4.92E-03	1,464

1. Excluding SO₂ and NO_x, Baseline Emissions calculated as follows:

$$\text{Baseline Emissions [ton/month]} = \text{Turbine Heat Input [MMBtu/month]} \times \text{Natural Gas Combustion Emission Factor [lb/MMBtu]} / 2,000 \text{ [lb/ton]}$$

2. Baseline Emissions of SO₂, NO_x, and CO₂ were obtained from historical data provided by Washington County Power.

3. Baseline emissions of CO₂e are calculated using the historical CO₂ emission data provided by Washington County Power, AP-42 Ch. 3.1, Table 3.1-2a (April 2000) emission factors for CH₄ and N₂O, and global warming potentials for CH₄ and N₂O from 40 CFR 98, Subpart A, Table A-1. The Baseline Emissions for CO₂e were calculated as follows:
Baseline Emissions [ton/month] = CO₂ Baseline Emissions [ton/month] + Turbine Heat Input [MMBtu/month] × (CH₄ Emission Factor [lb/MMBtu] × 25 + N₂O Emission Factor [lb/MMBtu] × 298) / 2,000 [lb/ton]

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-8. Historical Actual Monthly Emissions from Combustion Turbine No. 2 (tons/month)^{1,2}

Month	T2 - Combustion Turbine No. 2										
	Filterable PM	Condensable PM	Total PM	Total PM ₁₀	Total PM _{2.5}	SO ₂	NO _x	CO	VOC	Sulfuric Acid Mist (H ₂ SO ₄)	CO ₂ e ³
Jun-11	0.50	0.26	0.76	0.76	0.76	-	2.60	1.01	0.35	0.02	6,609
Jul-11	0.38	0.20	0.58	0.58	0.58	-	1.90	0.77	0.27	0.02	5,033
Aug-11	0.61	0.32	0.93	0.93	0.93	-	3.20	1.24	0.43	0.03	8,094
Sep-11	0.36	0.19	0.55	0.55	0.55	-	1.80	0.73	0.26	0.02	4,781
Oct-11	0.11	0.06	0.17	0.17	0.17	-	0.60	0.23	0.08	0.01	1,491
Nov-11	0.29	0.15	0.43	0.43	0.43	-	1.40	0.58	0.20	0.01	3,773
Dec-11	0.25	0.13	0.39	0.39	0.39	-	1.40	0.51	0.18	0.01	3,352
Jan-12	0.12	0.06	0.18	0.18	0.18	-	0.70	0.24	0.08	0.01	1,557
Feb-12	0.13	0.07	0.20	0.20	0.20	-	0.80	0.27	0.09	0.01	1,734
Mar-12	0.17	0.09	0.26	0.26	0.26	-	0.90	0.34	0.12	0.01	2,231
Apr-12	0.24	0.13	0.36	0.36	0.36	-	1.20	0.49	0.17	0.01	3,167
May-12	0.36	0.19	0.54	0.54	0.54	-	1.70	0.73	0.25	0.02	4,731
Jun-12	0.27	0.14	0.41	0.41	0.41	-	1.30	0.55	0.19	0.01	3,603
Jul-12	0.44	0.23	0.67	0.67	0.67	-	2.00	0.89	0.31	0.02	5,812
Aug-12	0.36	0.19	0.55	0.55	0.55	-	1.70	0.73	0.25	0.02	4,757
Sep-12	0.19	0.10	0.30	0.30	0.30	-	0.90	0.39	0.14	0.01	2,572
Oct-12	1.85E-04	9.64E-05	2.81E-04	2.81E-04	2.81E-04	-	-	3.74E-04	1.30E-04	8.20E-06	2
Nov-12	0.14	0.07	0.21	0.21	0.21	-	0.70	0.28	0.10	0.01	1,844
Dec-12	-	-	-	-	-	-	-	-	-	-	-
Jan-13	-	-	-	-	-	-	-	-	-	-	-
Feb-13	-	-	-	-	-	-	-	-	-	-	-
Mar-13	0.01	2.70E-03	0.01	0.01	0.01	-	0.10	0.01	3.66E-03	2.30E-04	68
Apr-13	0.22	0.11	0.33	0.33	0.33	-	1.10	0.44	0.15	0.01	2,846
May-13	-	-	-	-	-	-	-	-	-	-	-
Jun-13	0.16	0.08	0.24	0.24	0.24	-	0.70	0.32	0.11	0.01	2,059
Jul-13	0.46	0.24	0.70	0.70	0.70	-	2.00	0.93	0.33	0.02	6,096
Aug-13	0.05	0.03	0.07	0.07	0.07	-	0.20	0.10	0.03	2.16E-03	642
Sep-13	0.10	0.05	0.15	0.15	0.15	-	0.50	0.20	0.07	4.45E-03	1,323
Oct-13	0.25	0.13	0.38	0.38	0.38	-	1.20	0.50	0.17	0.01	3,259
Nov-13	0.13	0.07	0.20	0.20	0.20	-	0.60	0.27	0.09	0.01	1,737
Dec-13	-	-	-	-	-	-	-	-	-	-	-
Jan-14	6.26E-04	3.27E-04	9.52E-04	9.52E-04	9.52E-04	-	-	1.27E-03	4.42E-04	2.78E-05	8
Feb-14	-	-	-	-	-	-	-	-	-	-	-
Mar-14	3.92E-03	2.05E-03	0.01	0.01	0.01	-	0.10	0.01	2.78E-03	1.74E-04	52
Apr-14	0.06	0.03	0.10	0.10	0.10	-	0.30	0.13	0.04	2.81E-03	836
May-14	0.09	0.05	0.14	0.14	0.14	-	0.50	0.19	0.07	4.09E-03	1,217
Jun-14	0.11	0.06	0.16	0.16	0.16	-	0.50	0.21	0.07	4.71E-03	1,401
Jul-14	0.07	0.04	0.11	0.11	0.11	-	0.40	0.14	0.05	3.14E-03	935
Aug-14	0.17	0.09	0.26	0.26	0.26	-	0.90	0.34	0.12	0.01	2,219
Sep-14	0.06	0.03	0.09	0.09	0.09	-	0.30	0.12	0.04	2.68E-03	796
Oct-14	0.19	0.10	0.29	0.29	0.29	-	1.00	0.39	0.14	0.01	2,547
Nov-14	0.16	0.09	0.25	0.25	0.25	-	0.90	0.33	0.12	0.01	2,157
Dec-14	-	-	-	-	-	-	-	-	-	-	-
Jan-15	-	-	-	-	-	-	-	-	-	-	-
Feb-15	0.15	0.08	0.23	0.23	0.23	-	0.90	0.31	0.11	0.01	1,996
Mar-15	0.06	0.03	0.09	0.09	0.09	-	0.40	0.12	0.04	2.62E-03	778
Apr-15	-	-	-	-	-	-	-	-	-	-	-
May-15	0.27	0.14	0.41	0.41	0.41	-	1.40	0.54	0.19	0.01	3,518
Jun-15	0.21	0.11	0.32	0.32	0.32	-	1.10	0.43	0.15	0.01	2,792
Jul-15	0.57	0.30	0.87	0.87	0.87	-	2.80	1.16	0.41	0.03	7,577
Aug-15	0.05	0.03	0.08	0.08	0.08	-	0.30	0.11	0.04	2.33E-03	692
Sep-15	0.25	0.13	0.39	0.39	0.39	-	1.20	0.51	0.18	0.01	3,348
Oct-15	0.01	4.03E-03	0.01	0.01	0.01	-	-	0.02	0.01	3.43E-04	102
Nov-15	0.03	0.02	0.05	0.05	0.05	-	0.20	0.06	0.02	1.33E-03	396
Dec-15	-	-	-	-	-	-	-	-	-	-	-
Jan-16	0.32	0.17	0.49	0.49	0.49	-	2.10	0.65	0.23	0.01	4,226
Feb-16	-	-	-	-	-	-	-	-	-	-	-
Mar-16	0.53	0.28	0.81	0.81	0.81	-	2.70	1.08	0.38	0.02	7,047
Apr-16	0.76	0.40	1.16	1.16	1.16	0.10	4.80	1.55	0.54	0.03	10,091
May-16	0.03	0.02	0.05	0.05	0.05	-	0.10	0.06	0.02	1.32E-03	392
Jun-16	0.39	0.20	0.59	0.59	0.59	-	3.40	0.78	0.27	0.02	5,103
Jul-16	0.23	0.12	0.35	0.35	0.35	-	1.30	0.47	0.16	0.01	3,048
Aug-16	0.13	0.07	0.20	0.20	0.20	-	0.70	0.26	0.09	0.01	1,706
Sep-16	0.34	0.18	0.52	0.52	0.52	-	1.90	0.69	0.24	0.02	4,534
Oct-16	0.39	0.21	0.60	0.60	0.60	-	2.30	0.80	0.28	0.02	5,210
Nov-16	0.07	0.03	0.10	0.10	0.10	-	0.40	0.13	0.05	2.94E-03	874
Dec-16	0.05	0.03	0.08	0.08	0.08	-	0.30	0.10	0.03	2.19E-03	652

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-8. Historical Actual Monthly Emissions from Combustion Turbine No. 2 (tons/month)^{1,2}

Month	T2 - Combustion Turbine No. 2										
	Filterable PM	Condensable PM	Total PM	Total PM ₁₀	Total PM _{2.5}	SO ₂	NO _x	CO	VOC	Sulfuric Acid Mist (H ₂ SO ₄)	CO ₂ e ³
Jan-17	-	-	-	-	-	-	-	-	-	-	-
Feb-17	-	-	-	-	-	-	-	-	-	-	-
Mar-17	0.32	0.17	0.48	0.48	0.48	-	1.90	0.64	0.22	0.01	4,185
Apr-17	0.42	0.22	0.64	0.64	0.64	-	2.30	0.85	0.30	0.02	5,551
May-17	0.36	0.19	0.54	0.54	0.54	-	2.00	0.72	0.25	0.02	4,707
Jun-17	0.04	0.02	0.07	0.07	0.07	-	0.30	0.09	0.03	1.94E-03	576
Jul-17	0.35	0.18	0.54	0.54	0.54	-	1.90	0.72	0.25	0.02	4,679
Aug-17	0.58	0.30	0.88	0.88	0.88	-	2.90	1.17	0.41	0.03	7,609
Sep-17	0.53	0.27	0.80	0.80	0.80	-	2.80	1.06	0.37	0.02	6,945
Oct-17	0.09	0.05	0.13	0.13	0.13	-	0.50	0.18	0.06	3.92E-03	1,165
Nov-17	0.05	0.03	0.08	0.08	0.08	-	0.30	0.11	0.04	2.39E-03	710
Dec-17	-	-	-	-	-	-	-	-	-	-	-
Jan-18	-	-	-	-	-	-	-	-	-	-	-
Feb-18	-	-	-	-	-	-	-	-	-	-	-
Mar-18	0.02	0.01	0.04	0.04	0.04	-	0.20	0.05	0.02	1.07E-03	318
Apr-18	0.06	0.03	0.10	0.10	0.10	-	0.40	0.13	0.04	2.81E-03	837
May-18	0.16	0.08	0.24	0.24	0.24	-	0.80	0.32	0.11	0.01	2,104
Jun-18	0.26	0.14	0.40	0.40	0.40	-	1.30	0.53	0.18	0.01	3,449
Jul-18	0.21	0.11	0.31	0.31	0.31	-	1.00	0.42	0.15	0.01	2,714
Aug-18	0.23	0.12	0.35	0.35	0.35	-	1.10	0.46	0.16	0.01	3,031
Sep-18	0.29	0.15	0.44	0.44	0.44	-	1.50	0.59	0.21	0.01	3,859
Oct-18	0.36	0.19	0.54	0.54	0.54	-	1.80	0.72	0.25	0.02	4,706
Nov-18	-	-	-	-	-	-	-	-	-	-	-
Dec-18	0.05	0.03	0.07	0.07	0.07	-	0.30	0.10	0.03	2.16E-03	642
Jan-19	-	-	-	-	-	-	-	-	-	-	-
Feb-19	-	-	-	-	-	-	-	-	-	-	-
Mar-19	0.01	3.27E-03	0.01	0.01	0.01	-	0.10	0.01	4.43E-03	2.78E-04	83
Apr-19	0.03	0.02	0.05	0.05	0.05	-	0.20	0.06	0.02	1.41E-03	421
May-19	0.10	0.05	0.16	0.16	0.16	-	0.50	0.21	0.07	4.56E-03	1,358
Jun-19	0.16	0.08	0.24	0.24	0.24	-	0.80	0.32	0.11	0.01	2,107
Jul-19	0.64	0.33	0.97	0.97	0.97	-	3.00	1.29	0.45	0.03	8,413
Aug-19	0.53	0.28	0.81	0.81	0.81	-	2.50	1.08	0.38	0.02	7,054
Sep-19	0.79	0.41	1.20	1.20	1.20	0.10	3.90	1.59	0.56	0.03	10,387
Oct-19	0.43	0.22	0.65	0.65	0.65	-	2.10	0.87	0.30	0.02	5,664
Nov-19	0.10	0.05	0.15	0.15	0.15	-	0.60	0.20	0.07	4.39E-03	1,306
Dec-19	4.89E-03	2.55E-03	0.01	0.01	0.01	-	0.10	0.01	3.46E-03	2.17E-04	65
Jan-20	-	-	-	-	-	-	-	-	-	-	-
Feb-20	-	-	-	-	-	-	-	-	-	-	-
Mar-20	4.89E-03	2.55E-03	0.01	0.01	0.01	-	0.10	0.01	3.46E-03	2.17E-04	65
Apr-20	-	-	-	-	-	-	-	-	-	-	-
May-20	-	-	-	-	-	-	-	-	-	-	-
Jun-20	0.36	0.19	0.55	0.55	0.55	-	1.90	0.73	0.26	0.02	4,770

1. Excluding SO₂ and NO_x, Baseline Emissions calculated as follows:

$$\text{Baseline Emissions [ton/month]} = \text{Turbine Heat Input [MMBtu/month]} \times \text{Natural Gas Combustion Emission Factor [lb/MMBtu]} / 2,000 \text{ [lb/ton]}$$

2. Baseline Emissions of SO₂, NO_x, and CO₂ were obtained from historical data provided by Washington County Power.

3. Baseline emissions of CO₂e are calculated using the historical CO₂ emission data provided by Washington County Power, AP-42 Ch. 3.1, Table 3.1-2a (April 2000) emission factors for CH₄ and N₂O, and global warming potentials for CH₄ and N₂O from 40 CFR 98, Subpart A, Table A-1. The Baseline Emissions for CO₂e were calculated as follows:
Baseline Emissions [ton/month] = CO₂ Baseline Emissions [ton/month] + Turbine Heat Input [MMBtu/month] x (CH₄ Emission Factor [lb/MMBtu] x 25 + N₂O Emission Factor [lb/MMBtu] x 298) / 2,000 [lb/ton]

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-9. Historical Actual Monthly Emissions from Combustion Turbine No. 3 (tons/month)^{1,2}

Month	T3 - Combustion Turbine No. 3										
	Filterable PM	Condensable PM	Total PM	Total PM ₁₀	Total PM _{2.5}	SO ₂	NO _x	CO	VOC	Sulfuric Acid Mist (H ₂ SO ₄)	CO ₂ e ³
Jun-11	0.51	0.27	0.77	0.77	0.77	-	2.20	1.03	0.36	0.02	6,711
Jul-11	0.38	0.20	0.58	0.58	0.58	-	1.70	0.77	0.27	0.02	5,056
Aug-11	0.71	0.37	1.07	1.07	1.07	-	3.20	1.43	0.50	0.03	9,321
Sep-11	0.35	0.18	0.53	0.53	0.53	-	1.50	0.71	0.25	0.02	4,619
Oct-11	0.13	0.07	0.20	0.20	0.20	-	0.60	0.27	0.09	0.01	1,748
Nov-11	0.39	0.21	0.60	0.60	0.60	-	1.80	0.80	0.28	0.02	5,196
Dec-11	0.25	0.13	0.38	0.38	0.38	-	1.20	0.51	0.18	0.01	3,298
Jan-12	0.13	0.07	0.20	0.20	0.20	-	0.70	0.27	0.09	0.01	1,731
Feb-12	0.13	0.07	0.20	0.20	0.20	-	0.70	0.26	0.09	0.01	1,716
Mar-12	0.29	0.15	0.44	0.44	0.44	-	1.20	0.59	0.20	0.01	3,827
Apr-12	0.41	0.21	0.62	0.62	0.62	-	1.70	0.83	0.29	0.02	5,420
May-12	0.42	0.22	0.64	0.64	0.64	-	1.60	0.86	0.30	0.02	5,601
Jun-12	0.86	0.45	1.31	1.31	1.31	0.10	3.60	1.74	0.61	0.04	11,373
Jul-12	1.18	0.61	1.79	1.79	1.79	0.10	4.60	2.38	0.83	0.05	15,544
Aug-12	0.37	0.20	0.57	0.57	0.57	-	1.50	0.76	0.26	0.02	4,944
Sep-12	0.28	0.15	0.43	0.43	0.43	-	1.20	0.58	0.20	0.01	3,763
Oct-12	2.21E-04	1.15E-04	3.36E-04	3.36E-04	3.36E-04	-	-	4.47E-04	1.56E-04	9.80E-06	3
Nov-12	0.04	0.02	0.07	0.07	0.07	-	0.20	0.09	0.03	1.91E-03	568
Dec-12	-	-	-	-	-	-	-	-	-	-	-
Jan-13	-	-	-	-	-	-	-	-	-	-	-
Feb-13	-	-	-	-	-	-	-	-	-	-	-
Mar-13	4.19E-03	2.19E-03	0.01	0.01	0.01	-	0.10	0.01	2.96E-03	1.86E-04	55
Apr-13	0.09	0.05	0.13	0.13	0.13	-	0.40	0.18	0.06	3.94E-03	1,172
May-13	-	-	-	-	-	-	-	-	-	-	-
Jun-13	0.06	0.03	0.09	0.09	0.09	-	0.20	0.12	0.04	2.56E-03	760
Jul-13	0.87	0.46	1.33	1.33	1.33	0.10	3.20	1.77	0.62	0.04	11,544
Aug-13	0.05	0.03	0.07	0.07	0.07	-	0.20	0.10	0.03	2.13E-03	634
Sep-13	0.04	0.02	0.06	0.06	0.06	-	0.20	0.08	0.03	1.82E-03	541
Oct-13	0.25	0.13	0.37	0.37	0.37	-	1.10	0.50	0.17	0.01	3,242
Nov-13	0.10	0.05	0.15	0.15	0.15	-	0.40	0.19	0.07	4.25E-03	1,264
Dec-13	-	-	-	-	-	-	-	-	-	-	-
Jan-14	0.01	4.65E-03	0.01	0.01	0.01	-	0.10	0.02	0.01	3.96E-04	118
Feb-14	0.05	0.02	0.07	0.07	0.07	-	0.20	0.09	0.03	2.06E-03	612
Mar-14	0.01	2.64E-03	0.01	0.01	0.01	-	0.10	0.01	3.58E-03	2.25E-04	67
Apr-14	0.14	0.07	0.21	0.21	0.21	-	0.60	0.28	0.10	0.01	1,852
May-14	0.11	0.06	0.16	0.16	0.16	-	0.50	0.22	0.08	4.78E-03	1,422
Jun-14	0.11	0.06	0.16	0.16	0.16	-	0.40	0.22	0.08	4.74E-03	1,410
Jul-14	0.11	0.06	0.17	0.17	0.17	-	0.50	0.22	0.08	4.86E-03	1,445
Aug-14	0.04	0.02	0.06	0.06	0.06	-	0.20	0.08	0.03	1.82E-03	540
Sep-14	0.06	0.03	0.09	0.09	0.09	-	0.30	0.13	0.04	2.75E-03	818
Oct-14	0.19	0.10	0.30	0.30	0.30	-	0.90	0.39	0.14	0.01	2,565
Nov-14	0.15	0.08	0.23	0.23	0.23	-	0.70	0.30	0.10	0.01	1,958
Dec-14	-	-	-	-	-	-	-	-	-	-	-
Jan-15	0.01	4.71E-03	0.01	0.01	0.01	-	0.10	0.02	0.01	4.01E-04	119
Feb-15	-	-	-	-	-	-	-	-	-	-	-
Mar-15	4.59E-03	2.40E-03	0.01	0.01	0.01	-	0.10	0.01	3.25E-03	2.04E-04	61
Apr-15	-	-	-	-	-	-	-	-	-	-	-
May-15	0.32	0.17	0.49	0.49	0.49	-	1.50	0.65	0.23	0.01	4,259
Jun-15	0.15	0.08	0.23	0.23	0.23	-	0.60	0.31	0.11	0.01	2,008
Jul-15	0.69	0.36	1.06	1.06	1.06	-	3.00	1.41	0.49	0.03	9,176
Aug-15	0.21	0.11	0.32	0.32	0.32	-	0.90	0.43	0.15	0.01	2,815
Sep-15	0.16	0.09	0.25	0.25	0.25	-	0.80	0.33	0.12	0.01	2,153
Oct-15	0.01	3.92E-03	0.01	0.01	0.01	-	-	0.02	0.01	3.33E-04	99
Nov-15	-	-	-	-	-	-	-	-	-	-	-
Dec-15	-	-	-	-	-	-	-	-	-	-	-
Jan-16	0.20	0.10	0.30	0.30	0.30	-	1.10	0.40	0.14	0.01	2,582
Feb-16	-	-	-	-	-	-	-	-	-	-	-
Mar-16	0.32	0.17	0.48	0.48	0.48	-	1.40	0.64	0.22	0.01	4,179
Apr-16	0.71	0.37	1.08	1.08	1.08	-	3.20	1.44	0.50	0.03	9,400
May-16	0.19	0.10	0.28	0.28	0.28	-	0.90	0.38	0.13	0.01	2,473
Jun-16	0.38	0.20	0.58	0.58	0.58	-	1.60	0.78	0.27	0.02	5,069
Jul-16	0.03	0.02	0.05	0.05	0.05	-	0.10	0.07	0.02	1.44E-03	427
Aug-16	-	-	-	-	-	-	-	-	-	-	-
Sep-16	0.25	0.13	0.38	0.38	0.38	-	1.10	0.51	0.18	0.01	3,309
Oct-16	0.19	0.10	0.28	0.28	0.28	-	1.10	0.38	0.13	0.01	2,461
Nov-16	0.08	0.04	0.12	0.12	0.12	-	0.40	0.16	0.05	3.45E-03	1,026
Dec-16	0.05	0.03	0.08	0.08	0.08	-	0.30	0.10	0.04	2.21E-03	657

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-9. Historical Actual Monthly Emissions from Combustion Turbine No. 3 (tons/month)^{1,2}

Month	T3 - Combustion Turbine No. 3										
	Filterable PM	Condensable PM	Total PM	Total PM ₁₀	Total PM _{2.5}	SO ₂	NO _x	CO	VOC	Sulfuric Acid Mist (H ₂ SO ₄)	CO ₂ e ³
Jan-17	-	-	-	-	-	-	-	-	-	-	-
Feb-17	-	-	-	-	-	-	-	-	-	-	-
Mar-17	0.10	0.05	0.15	0.15	0.15	-	0.60	0.20	0.07	4.42E-03	1,314
Apr-17	0.42	0.22	0.64	0.64	0.64	-	2.20	0.85	0.30	0.02	5,543
May-17	0.30	0.16	0.45	0.45	0.45	-	1.60	0.60	0.21	0.01	3,933
Jun-17	0.04	0.02	0.05	0.05	0.05	-	0.20	0.07	0.03	1.57E-03	468
Jul-17	0.35	0.18	0.53	0.53	0.53	-	2.70	0.70	0.25	0.02	4,590
Aug-17	0.50	0.26	0.76	0.76	0.76	-	2.40	1.01	0.35	0.02	6,591
Sep-17	0.48	0.25	0.74	0.74	0.74	-	2.50	0.98	0.34	0.02	6,397
Oct-17	4.51E-03	2.36E-03	0.01	0.01	0.01	-	0.10	0.01	3.19E-03	2.01E-04	60
Nov-17	0.05	0.03	0.08	0.08	0.08	-	0.30	0.10	0.04	2.26E-03	672
Dec-17	-	-	-	-	-	-	-	-	-	-	-
Jan-18	-	-	-	-	-	-	-	-	-	-	-
Feb-18	-	-	-	-	-	-	-	-	-	-	-
Mar-18	0.03	0.01	0.04	0.04	0.04	-	0.20	0.06	0.02	1.25E-03	370
Apr-18	0.18	0.09	0.27	0.27	0.27	-	0.80	0.36	0.13	0.01	2,354
May-18	0.04	0.02	0.07	0.07	0.07	-	0.20	0.09	0.03	1.94E-03	577
Jun-18	0.25	0.13	0.38	0.38	0.38	-	1.20	0.51	0.18	0.01	3,322
Jul-18	0.13	0.07	0.20	0.20	0.20	-	0.60	0.26	0.09	0.01	1,729
Aug-18	0.23	0.12	0.35	0.35	0.35	-	1.10	0.46	0.16	0.01	3,019
Sep-18	0.27	0.14	0.40	0.40	0.40	-	1.30	0.54	0.19	0.01	3,513
Oct-18	0.49	0.26	0.75	0.75	0.75	-	2.50	0.99	0.35	0.02	6,473
Nov-18	-	-	-	-	-	-	-	-	-	-	-
Dec-18	0.05	0.03	0.08	0.08	0.08	-	0.30	0.10	0.04	2.21E-03	658
Jan-19	-	-	-	-	-	-	-	-	-	-	-
Feb-19	-	-	-	-	-	-	-	-	-	-	-
Mar-19	4.66E-03	2.43E-03	0.01	0.01	0.01	-	-	0.01	3.29E-03	2.07E-04	62
Apr-19	0.03	0.02	0.05	0.05	0.05	-	0.20	0.06	0.02	1.37E-03	408
May-19	0.06	0.03	0.08	0.08	0.08	-	0.30	0.11	0.04	2.46E-03	732
Jun-19	0.16	0.08	0.24	0.24	0.24	-	0.70	0.32	0.11	0.01	2,096
Jul-19	0.62	0.33	0.95	0.95	0.95	-	2.80	1.26	0.44	0.03	8,230
Aug-19	0.53	0.27	0.80	0.80	0.80	-	2.30	1.07	0.37	0.02	6,949
Sep-19	0.77	0.40	1.18	1.18	1.18	0.10	3.70	1.57	0.55	0.03	10,235
Oct-19	0.42	0.22	0.64	0.64	0.64	-	2.00	0.85	0.30	0.02	5,529
Nov-19	0.04	0.02	0.06	0.06	0.06	-	0.30	0.09	0.03	1.88E-03	558
Dec-19	4.64E-03	2.42E-03	0.01	0.01	0.01	-	0.10	0.01	3.28E-03	2.06E-04	61
Jan-20	-	-	-	-	-	-	-	-	-	-	-
Feb-20	-	-	-	-	-	-	-	-	-	-	-
Mar-20	4.83E-03	2.52E-03	0.01	0.01	0.01	-	-	0.01	3.41E-03	2.15E-04	64
Apr-20	-	-	-	-	-	-	-	-	-	-	-
May-20	-	-	-	-	-	-	-	-	-	-	-
Jun-20	0.27	0.14	0.41	0.41	0.41	-	1.30	0.55	0.19	0.01	3,596

1. Excluding SO₂ and NO_x, Baseline Emissions calculated as follows:

$$\text{Baseline Emissions [ton/month]} = \text{Turbine Heat Input [MMBtu/month]} \times \text{Natural Gas Combustion Emission Factor [lb/MMBtu]} / 2,000 \text{ [lb/ton]}$$

2. Baseline Emissions of SO₂, NO_x, and CO₂ were obtained from historical data provided by Washington County Power.

3. Baseline emissions of CO₂e are calculated using the historical CO₂ emission data provided by Washington County Power, AP-42 Ch. 3.1, Table 3.1-2a (April 2000) emission factors for CH₄ and N₂O, and global warming potentials for CH₄ and N₂O from 40 CFR 98, Subpart A, Table A-1. The Baseline Emissions for CO₂e were calculated as follows:
Baseline Emissions [ton/month] = CO₂ Baseline Emissions [ton/month] + Turbine Heat Input [MMBtu/month] x (CH₄ Emission Factor [lb/MMBtu] x 25 + N₂O Emission Factor [lb/MMBtu] x 298) / 2,000 [lb/ton]

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-10. Historical Actual Monthly Emissions from Combustion Turbine No. 4 (tons/month)^{1,2}

Month	T4 - Combustion Turbine No. 4										
	Filterable PM	Condensable PM	Total PM	Total PM ₁₀	Total PM _{2.5}	SO ₂	NO _x	CO	VOC	Sulfuric Acid Mist (H ₂ SO ₄)	CO ₂ e ³
Jun-11	0.50	0.26	0.76	0.76	0.76	-	2.20	1.01	0.35	0.02	6,583
Jul-11	0.27	0.14	0.41	0.41	0.41	-	1.30	0.55	0.19	0.01	3,575
Aug-11	0.50	0.26	0.77	0.77	0.77	-	2.50	1.02	0.36	0.02	6,653
Sep-11	0.10	0.05	0.15	0.15	0.15	-	0.60	0.20	0.07	4.31E-03	1,283
Oct-11	0.01	4.42E-03	0.01	0.01	0.01	-	0.10	0.02	0.01	3.76E-04	112
Nov-11	-	-	-	-	-	-	-	-	-	-	-
Dec-11	0.09	0.05	0.14	0.14	0.14	-	0.40	0.18	0.06	4.04E-03	1,203
Jan-12	-	-	-	-	-	-	-	-	-	-	-
Feb-12	-	-	-	-	-	-	-	-	-	-	-
Mar-12	-	-	-	-	-	-	-	-	-	-	-
Apr-12	0.46	0.24	0.70	0.70	0.70	-	2.00	0.93	0.33	0.02	6,098
May-12	0.48	0.25	0.72	0.72	0.72	-	1.50	0.96	0.34	0.02	6,280
Jun-12	0.41	0.21	0.62	0.62	0.62	-	1.60	0.82	0.29	0.02	5,363
Jul-12	0.75	0.39	1.14	1.14	1.14	0.10	2.80	1.52	0.53	0.03	9,916
Aug-12	0.18	0.09	0.27	0.27	0.27	-	0.60	0.36	0.13	0.01	2,347
Sep-12	-	-	-	-	-	-	-	-	-	-	-
Oct-12	2.25E-04	1.18E-04	3.43E-04	3.43E-04	3.43E-04	-	-	4.56E-04	1.59E-04	1.00E-05	3
Nov-12	-	-	-	-	-	-	-	-	-	-	-
Dec-12	-	-	-	-	-	-	-	-	-	-	-
Jan-13	-	-	-	-	-	-	-	-	-	-	-
Feb-13	-	-	-	-	-	-	-	-	-	-	-
Mar-13	0.02	0.01	0.02	0.02	0.02	-	0.20	0.03	0.01	6.72E-04	200
Apr-13	0.01	4.32E-03	0.01	0.01	0.01	-	0.10	0.02	0.01	3.68E-04	110
May-13	-	-	-	-	-	-	-	-	-	-	-
Jun-13	0.15	0.08	0.23	0.23	0.23	-	0.60	0.31	0.11	0.01	2,020
Jul-13	1.75	0.91	2.66	2.66	2.66	0.10	6.60	3.55	1.24	0.08	23,134
Aug-13	-	-	-	-	-	-	-	-	-	-	-
Sep-13	-	-	-	-	-	-	-	-	-	-	-
Oct-13	0.01	4.49E-03	0.01	0.01	0.01	-	0.10	0.02	0.01	3.82E-04	114
Nov-13	-	-	-	-	-	-	-	-	-	-	-
Dec-13	-	-	-	-	-	-	-	-	-	-	-
Jan-14	-	-	-	-	-	-	-	-	-	-	-
Feb-14	-	-	-	-	-	-	-	-	-	-	-
Mar-14	4.50E-03	2.35E-03	0.01	0.01	0.01	-	-	0.01	3.19E-03	2.00E-04	60
Apr-14	-	-	-	-	-	-	-	-	-	-	-
May-14	-	-	-	-	-	-	-	-	-	-	-
Jun-14	0.16	0.09	0.25	0.25	0.25	-	0.60	0.33	0.12	0.01	2,159
Jul-14	-	-	-	-	-	-	-	-	-	-	-
Aug-14	0.14	0.08	0.22	0.22	0.22	-	0.60	0.29	0.10	0.01	1,917
Sep-14	-	-	-	-	-	-	-	-	-	-	-
Oct-14	0.06	0.03	0.10	0.10	0.10	-	0.30	0.13	0.05	2.88E-03	855
Nov-14	0.04	0.02	0.06	0.06	0.06	-	0.20	0.07	0.03	1.62E-03	483
Dec-14	-	-	-	-	-	-	-	-	-	-	-
Jan-15	0.01	4.28E-03	0.01	0.01	0.01	-	0.10	0.02	0.01	3.64E-04	108
Feb-15	-	-	-	-	-	-	-	-	-	-	-
Mar-15	0.01	4.22E-03	0.01	0.01	0.01	-	0.10	0.02	0.01	3.59E-04	107
Apr-15	-	-	-	-	-	-	-	-	-	-	-
May-15	0.37	0.19	0.56	0.56	0.56	-	1.40	0.74	0.26	0.02	4,849
Jun-15	0.83	0.43	1.26	1.26	1.26	0.10	3.20	1.67	0.58	0.04	10,921
Jul-15	0.97	0.51	1.47	1.47	1.47	0.10	3.80	1.96	0.68	0.04	12,794
Aug-15	-	-	-	-	-	-	-	-	-	-	-
Sep-15	0.17	0.09	0.25	0.25	0.25	-	0.50	0.34	0.12	0.01	2,203
Oct-15	0.01	3.83E-03	0.01	0.01	0.01	-	0.10	0.01	0.01	3.26E-04	97
Nov-15	0.46	0.24	0.69	0.69	0.69	-	1.60	0.92	0.32	0.02	6,026
Dec-15	-	-	-	-	-	-	-	-	-	-	-
Jan-16	-	-	-	-	-	-	-	-	-	-	-
Feb-16	-	-	-	-	-	-	-	-	-	-	-
Mar-16	3.84E-03	2.01E-03	0.01	0.01	0.01	-	0.10	0.01	2.72E-03	1.71E-04	51
Apr-16	-	-	-	-	-	-	-	-	-	-	-
May-16	0.07	0.04	0.11	0.11	0.11	-	0.20	0.14	0.05	3.17E-03	942
Jun-16	0.10	0.05	0.16	0.16	0.16	-	0.40	0.21	0.07	4.58E-03	1,362
Jul-16	0.19	0.10	0.28	0.28	0.28	-	0.60	0.38	0.13	0.01	2,458
Aug-16	-	-	-	-	-	-	-	-	-	-	-
Sep-16	-	-	-	-	-	-	-	-	-	-	-
Oct-16	0.08	0.04	0.12	0.12	0.12	-	0.30	0.16	0.06	3.46E-03	1,031
Nov-16	-	-	-	-	-	-	-	-	-	-	-
Dec-16	-	-	-	-	-	-	-	-	-	-	-

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-10. Historical Actual Monthly Emissions from Combustion Turbine No. 4 (tons/month) ^{1,2}

Month	T4 - Combustion Turbine No. 4										
	Filterable PM	Condensable PM	Total PM	Total PM ₁₀	Total PM _{2.5}	SO ₂	NO _x	CO	VOC	Sulfuric Acid Mist (H ₂ SO ₄)	CO ₂ e ³
Jan-17	-	-	-	-	-	-	-	-	-	-	-
Feb-17	-	-	-	-	-	-	-	-	-	-	-
Mar-17	0.01	2.67E-03	0.01	0.01	0.01	-	0.10	0.01	3.62E-03	2.27E-04	68
Apr-17	-	-	-	-	-	-	-	-	-	-	-
May-17	0.09	0.05	0.13	0.13	0.13	-	0.30	0.18	0.06	3.87E-03	1,150
Jun-17	-	-	-	-	-	-	-	-	-	-	-
Jul-17	0.26	0.14	0.39	0.39	0.39	-	0.80	0.52	0.18	0.01	3,425
Aug-17	-	-	-	-	-	-	-	-	-	-	-
Sep-17	-	-	-	-	-	-	-	-	-	-	-
Oct-17	4.55E-03	2.38E-03	0.01	0.01	0.01	-	0.10	0.01	3.22E-03	2.02E-04	60
Nov-17	-	-	-	-	-	-	-	-	-	-	-
Dec-17	-	-	-	-	-	-	-	-	-	-	-
Jan-18	-	-	-	-	-	-	-	-	-	-	-
Feb-18	-	-	-	-	-	-	-	-	-	-	-
Mar-18	4.18E-03	2.18E-03	0.01	0.01	0.01	-	0.10	0.01	2.96E-03	1.86E-04	55
Apr-18	-	-	-	-	-	-	-	-	-	-	-
May-18	0.29	0.15	0.45	0.45	0.45	-	1.10	0.59	0.21	0.01	3,865
Jun-18	0.53	0.28	0.80	0.80	0.80	-	1.50	1.07	0.37	0.02	6,991
Jul-18	-	-	-	-	-	-	-	-	-	-	-
Aug-18	-	-	-	-	-	-	-	-	-	-	-
Sep-18	0.27	0.14	0.42	0.42	0.42	-	0.90	0.55	0.19	0.01	3,612
Oct-18	0.24	0.13	0.37	0.37	0.37	-	0.70	0.49	0.17	0.01	3,188
Nov-18	-	-	-	-	-	-	-	-	-	-	-
Dec-18	-	-	-	-	-	-	-	-	-	-	-
Jan-19	-	-	-	-	-	-	-	-	-	-	-
Feb-19	-	-	-	-	-	-	-	-	-	-	-
Mar-19	4.83E-03	2.52E-03	0.01	0.01	0.01	-	-	0.01	3.41E-03	2.15E-04	64
Apr-19	-	-	-	-	-	-	-	-	-	-	-
May-19	-	-	-	-	-	-	-	-	-	-	-
Jun-19	0.23	0.12	0.35	0.35	0.35	-	0.60	0.47	0.16	0.01	3,083
Jul-19	0.86	0.45	1.31	1.31	1.31	0.10	2.50	1.75	0.61	0.04	11,419
Aug-19	-	-	-	-	-	-	-	-	-	-	-
Sep-19	1.12	0.59	1.71	1.71	1.71	0.10	3.30	2.27	0.79	0.05	14,841
Oct-19	0.47	0.25	0.72	0.72	0.72	-	1.50	0.95	0.33	0.02	6,228
Nov-19	-	-	-	-	-	-	-	-	-	-	-
Dec-19	4.75E-03	2.48E-03	0.01	0.01	0.01	-	0.10	0.01	3.36E-03	2.11E-04	63
Jan-20	-	-	-	-	-	-	-	-	-	-	-
Feb-20	-	-	-	-	-	-	-	-	-	-	-
Mar-20	4.40E-03	2.30E-03	0.01	0.01	0.01	-	0.10	0.01	3.11E-03	1.95E-04	58
Apr-20	-	-	-	-	-	-	-	-	-	-	-
May-20	-	-	-	-	-	-	-	-	-	-	-
Jun-20	0.06	0.03	0.09	0.09	0.09	-	0.20	0.12	0.04	2.63E-03	784

1. Excluding SO₂ and NO_x, Baseline Emissions calculated as follows:

$$\text{Baseline Emissions [ton/month]} = \text{Turbine Heat Input [MMBtu/month]} \times \text{Natural Gas Combustion Emission Factor [lb/MMBtu]} / 2,000 \text{ [lb/ton]}$$

2. Baseline Emissions of SO₂, NO_x, and CO₂ were obtained from historical data provided by Washington County Power.

3. Baseline emissions of CO₂e are calculated using the historical CO₂ emission data provided by Washington County Power, AP-42 Ch. 3.1, Table 3.1-2a (April 2000) emission factors for CH₄ and N₂O, and global warming potentials for CH₄ and N₂O from 40 CFR 98, Subpart A, Table A-1. The Baseline Emissions for CO₂e were calculated as follows:
Baseline Emissions [ton/month] = CO₂ Baseline Emissions [ton/month] + Turbine Heat Input [MMBtu/month] x (CH₄ Emission Factor [lb/MMBtu] x 25 + N₂O Emission Factor [lb/MMBtu] x 298) / 2,000 [lb/ton]

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-11. Historical Actual Monthly Emissions from Turbines (tons/month)

Month	Combustion Turbine Nos. 1 - 4										
	Filterable PM	Condensable PM	Total PM	Total PM ₁₀	Total PM _{2.5}	SO ₂	NO _x	CO	VOC	Sulfuric Acid Mist (H ₂ SO ₄)	CO ₂ e
Jun-11	1.92	1.00	2.92	2.92	2.92	-	9.00	3.89	1.36	0.09	25,366
Jul-11	1.34	0.70	2.04	2.04	2.04	-	6.40	2.71	0.95	0.06	17,698
Aug-11	2.31	1.21	3.52	3.52	3.52	-	11.40	4.68	1.63	0.10	30,558
Sep-11	0.87	0.46	1.33	1.33	1.33	-	4.30	1.77	0.62	0.04	11,559
Oct-11	0.26	0.14	0.40	0.40	0.40	-	1.50	0.53	0.19	0.01	3,465
Nov-11	0.70	0.36	1.06	1.06	1.06	-	3.40	1.41	0.49	0.03	9,202
Dec-11	0.70	0.37	1.07	1.07	1.07	-	3.60	1.42	0.50	0.03	9,287
Jan-12	0.25	0.13	0.38	0.38	0.38	-	1.40	0.50	0.18	0.01	3,288
Feb-12	0.26	0.14	0.40	0.40	0.40	-	1.50	0.53	0.18	0.01	3,450
Mar-12	1.14	0.59	1.73	1.73	1.73	-	5.50	2.30	0.80	0.05	15,023
Apr-12	2.74	1.43	4.18	4.18	4.18	0.10	11.20	5.56	1.94	0.12	36,270
May-12	1.91	1.00	2.90	2.90	2.90	-	7.20	3.87	1.35	0.08	25,222
Jun-12	1.86	0.97	2.82	2.82	2.82	0.10	7.90	3.76	1.31	0.08	24,534
Jul-12	3.27	1.71	4.98	4.98	4.98	0.30	13.00	6.62	2.31	0.15	43,225
Aug-12	0.95	0.49	1.44	1.44	1.44	-	3.90	1.92	0.67	0.04	12,526
Sep-12	0.48	0.25	0.73	0.73	0.73	-	2.10	0.97	0.34	0.02	6,335
Oct-12	8.78E-04	4.58E-04	1.34E-03	1.34E-03	1.34E-03	-	-	1.78E-03	6.21E-04	3.90E-05	12
Nov-12	0.18	0.10	0.28	0.28	0.28	-	0.90	0.37	0.13	0.01	2,412
Dec-12	-	-	-	-	-	-	-	-	-	-	-
Jan-13	0.01	4.80E-03	0.01	0.01	0.01	-	0.10	0.02	0.01	4.08E-04	121
Feb-13	-	-	-	-	-	-	-	-	-	-	-
Mar-13	0.03	0.02	0.04	0.04	0.04	-	0.50	0.06	0.02	1.30E-03	386
Apr-13	0.36	0.19	0.55	0.55	0.55	-	1.80	0.74	0.26	0.02	4,798
May-13	-	-	-	-	-	-	-	-	-	-	-
Jun-13	0.46	0.24	0.70	0.70	0.70	-	1.90	0.93	0.33	0.02	6,089
Jul-13	4.42	2.31	6.72	6.72	6.72	0.30	16.90	8.95	3.12	0.20	58,378
Aug-13	0.10	0.05	0.15	0.15	0.15	-	0.40	0.20	0.07	4.29E-03	1,277
Sep-13	0.14	0.07	0.21	0.21	0.21	-	0.70	0.29	0.10	0.01	1,864
Oct-13	0.52	0.27	0.79	0.79	0.79	-	2.50	1.05	0.37	0.02	6,823
Nov-13	0.27	0.14	0.41	0.41	0.41	-	1.20	0.55	0.19	0.01	3,589
Dec-13	-	-	-	-	-	-	-	-	-	-	-
Jan-14	0.01	4.97E-03	0.01	0.01	0.01	-	0.10	0.02	0.01	4.23E-04	126
Feb-14	0.05	0.02	0.07	0.07	0.07	-	0.20	0.09	0.03	2.06E-03	612
Mar-14	0.14	0.08	0.22	0.22	0.22	-	0.80	0.29	0.10	0.01	1,913
Apr-14	0.20	0.11	0.31	0.31	0.31	-	0.90	0.41	0.14	0.01	2,689
May-14	0.20	0.10	0.30	0.30	0.30	-	1.00	0.40	0.14	0.01	2,639
Jun-14	0.43	0.23	0.66	0.66	0.66	-	1.70	0.88	0.31	0.02	5,749
Jul-14	0.18	0.09	0.27	0.27	0.27	-	0.90	0.36	0.13	0.01	2,380
Aug-14	0.50	0.26	0.76	0.76	0.76	-	2.30	1.01	0.35	0.02	6,610
Sep-14	0.20	0.11	0.31	0.31	0.31	-	0.90	0.41	0.14	0.01	2,685
Oct-14	0.52	0.27	0.79	0.79	0.79	-	2.50	1.05	0.37	0.02	6,825
Nov-14	0.41	0.21	0.62	0.62	0.62	-	2.10	0.83	0.29	0.02	5,428
Dec-14	-	-	-	-	-	-	-	-	-	-	-
Jan-15	0.02	0.01	0.03	0.03	0.03	-	0.20	0.03	0.01	7.65E-04	228
Feb-15	0.15	0.08	0.23	0.23	0.23	-	0.90	0.31	0.11	0.01	1,996
Mar-15	0.08	0.04	0.12	0.12	0.12	-	0.70	0.16	0.06	3.53E-03	1,050
Apr-15	-	-	-	-	-	-	-	-	-	-	-
May-15	1.32	0.69	2.01	2.01	2.01	-	5.70	2.68	0.93	0.06	17,470
Jun-15	2.03	1.06	3.09	3.09	3.09	0.20	8.00	4.11	1.43	0.09	26,821
Jul-15	3.30	1.72	5.02	5.02	5.02	0.20	13.70	6.68	2.33	0.15	43,596
Aug-15	0.35	0.18	0.53	0.53	0.53	-	1.50	0.71	0.25	0.02	4,645
Sep-15	0.93	0.48	1.41	1.41	1.41	-	3.70	1.88	0.66	0.04	12,257
Oct-15	0.10	0.05	0.14	0.14	0.14	-	0.40	0.19	0.07	4.23E-03	1,258
Nov-15	1.01	0.53	1.53	1.53	1.53	-	3.70	2.04	0.71	0.04	13,299
Dec-15	-	-	-	-	-	-	-	-	-	-	-
Jan-16	0.51	0.27	0.78	0.78	0.78	-	3.20	1.04	0.36	0.02	6,808
Feb-16	-	-	-	-	-	-	-	-	-	-	-
Mar-16	0.86	0.45	1.31	1.31	1.31	-	4.30	1.74	0.61	0.04	11,373
Apr-16	1.47	0.77	2.24	2.24	2.24	0.10	8.00	2.99	1.04	0.07	19,491
May-16	0.29	0.15	0.44	0.44	0.44	-	1.20	0.58	0.20	0.01	3,807
Jun-16	1.02	0.53	1.55	1.55	1.55	-	5.90	2.06	0.72	0.05	13,451
Jul-16	0.45	0.23	0.68	0.68	0.68	-	2.00	0.91	0.32	0.02	5,933
Aug-16	0.13	0.07	0.20	0.20	0.20	-	0.70	0.26	0.09	0.01	1,706
Sep-16	0.59	0.31	0.90	0.90	0.90	-	3.00	1.20	0.42	0.03	7,843
Oct-16	0.74	0.39	1.12	1.12	1.12	-	4.00	1.49	0.52	0.03	9,752
Nov-16	0.14	0.08	0.22	0.22	0.22	-	0.80	0.29	0.10	0.01	1,900
Dec-16	0.10	0.05	0.15	0.15	0.15	-	0.60	0.20	0.07	4.40E-03	1,310

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-11. Historical Actual Monthly Emissions from Turbines (tons/month)

Month	Combustion Turbine Nos. 1 - 4										
	Filterable PM	Condensable PM	Total PM	Total PM ₁₀	Total PM _{2.5}	SO ₂	NO _x	CO	VOC	Sulfuric Acid Mist (H ₂ SO ₄)	CO _{2e}
Jan-17	-	-	-	-	-	-	-	-	-	-	-
Feb-17	-	-	-	-	-	-	-	-	-	-	-
Mar-17	0.42	0.22	0.65	0.65	0.65	-	2.60	0.86	0.30	0.02	5,618
Apr-17	0.84	0.44	1.28	1.28	1.28	-	4.50	1.70	0.59	0.04	11,094
May-17	0.83	0.43	1.26	1.26	1.26	-	4.30	1.68	0.59	0.04	10,937
Jun-17	0.08	0.04	0.12	0.12	0.12	-	0.50	0.16	0.06	3.51E-03	1,044
Jul-17	1.22	0.64	1.85	1.85	1.85	-	6.40	2.47	0.86	0.05	16,090
Aug-17	1.07	0.56	1.64	1.64	1.64	-	5.30	2.18	0.76	0.05	14,200
Sep-17	1.01	0.53	1.54	1.54	1.54	-	5.30	2.04	0.71	0.04	13,343
Oct-17	0.10	0.05	0.16	0.16	0.16	-	0.80	0.21	0.07	4.54E-03	1,351
Nov-17	0.10	0.05	0.16	0.16	0.16	-	0.60	0.21	0.07	4.65E-03	1,382
Dec-17	-	-	-	-	-	-	-	-	-	-	-
Jan-18	-	-	-	-	-	-	-	-	-	-	-
Feb-18	-	-	-	-	-	-	-	-	-	-	-
Mar-18	0.06	0.03	0.09	0.09	0.09	-	0.50	0.12	0.04	2.72E-03	808
Apr-18	0.24	0.13	0.37	0.37	0.37	-	1.20	0.49	0.17	0.01	3,190
May-18	0.67	0.35	1.02	1.02	1.02	-	2.90	1.36	0.48	0.03	8,886
Jun-18	1.47	0.77	2.24	2.24	2.24	-	5.50	2.98	1.04	0.07	19,413
Jul-18	0.42	0.22	0.63	0.63	0.63	-	1.90	0.84	0.29	0.02	5,513
Aug-18	0.46	0.24	0.70	0.70	0.70	-	2.20	0.93	0.32	0.02	6,049
Sep-18	0.98	0.51	1.50	1.50	1.50	-	4.30	1.99	0.69	0.04	12,990
Oct-18	1.21	0.63	1.84	1.84	1.84	-	5.50	2.45	0.86	0.05	15,986
Nov-18	-	-	-	-	-	-	-	-	-	-	-
Dec-18	0.10	0.05	0.15	0.15	0.15	-	0.60	0.20	0.07	4.37E-03	1,300
Jan-19	-	-	-	-	-	-	-	-	-	-	-
Feb-19	-	-	-	-	-	-	-	-	-	-	-
Mar-19	0.02	0.01	0.03	0.03	0.03	-	0.10	0.04	0.01	8.96E-04	266
Apr-19	0.06	0.03	0.10	0.10	0.10	-	0.40	0.13	0.04	2.79E-03	829
May-19	0.31	0.16	0.48	0.48	0.48	-	1.40	0.64	0.22	0.01	4,149
Jun-19	0.90	0.47	1.37	1.37	1.37	-	3.30	1.82	0.64	0.04	11,900
Jul-19	2.29	1.20	3.49	3.49	3.49	0.10	8.90	4.64	1.62	0.10	30,277
Aug-19	1.53	0.80	2.33	2.33	2.33	-	6.40	3.10	1.08	0.07	20,196
Sep-19	3.66	1.91	5.58	5.58	5.58	0.40	14.70	7.42	2.59	0.16	48,425
Oct-19	1.70	0.89	2.59	2.59	2.59	-	7.10	3.45	1.20	0.08	22,512
Nov-19	0.14	0.07	0.21	0.21	0.21	-	0.90	0.29	0.10	0.01	1,864
Dec-19	0.02	0.01	0.03	0.03	0.03	-	0.40	0.04	0.01	8.25E-04	245
Jan-20	-	-	-	-	-	-	-	-	-	-	-
Feb-20	-	-	-	-	-	-	-	-	-	-	-
Mar-20	0.20	0.11	0.31	0.31	0.31	-	1.00	0.41	0.14	0.01	2,665
Apr-20	-	-	-	-	-	-	-	-	-	-	-
May-20	-	-	-	-	-	-	-	-	-	-	-
Jun-20	0.80	0.42	1.22	1.22	1.22	-	3.80	1.63	0.57	0.04	10,614

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-12. Selection of Baseline (tpy)¹

Start Month	End Month	Combustion Turbine Baseline Emissions										
		Filterable PM	Condensable PM	Total PM	Total PM ₁₀	Total PM _{2.5}	SO ₂	NO _x	CO	VOC	Sulfuric Acid Mist (H ₂ SO ₄)	CO ₂ e
Jun-11	- May-13	10.77	5.62	16.39	16.39	16.39	0.25	48.30	21.82	7.62	0.48	142,369
Jul-11	- Jun-13	10.04	5.24	15.28	15.28	15.28	0.25	44.75	20.34	7.10	0.45	132,730
Aug-11	- Jul-13	11.58	6.05	17.63	17.63	17.63	0.40	50.00	23.46	8.19	0.51	153,070
Sep-11	- Aug-13	10.47	5.47	15.94	15.94	15.94	0.40	44.50	21.21	7.41	0.47	138,429
Oct-11	- Sep-13	10.10	5.28	15.38	15.38	15.38	0.40	42.70	20.47	7.15	0.45	133,582
Nov-11	- Oct-13	10.23	5.34	15.57	15.57	15.57	0.40	43.20	20.73	7.24	0.45	135,261
Dec-11	- Nov-13	10.02	5.23	15.25	15.25	15.25	0.40	42.10	20.30	7.09	0.45	132,455
Jan-12	- Dec-13	9.67	5.05	14.72	14.72	14.72	0.40	40.30	19.59	6.84	0.43	127,811
Feb-12	- Jan-14	9.55	4.99	14.53	14.53	14.53	0.40	39.65	19.35	6.75	0.42	126,230
Mar-12	- Feb-14	9.44	4.93	14.37	14.37	14.37	0.40	39.00	19.13	6.68	0.42	124,811
Apr-12	- Mar-14	8.95	4.67	13.62	13.62	13.62	0.40	36.65	18.12	6.33	0.40	118,256
May-12	- Apr-14	7.68	4.01	11.68	11.68	11.68	0.35	31.50	15.55	5.43	0.34	101,465
Jun-12	- May-14	6.82	3.56	10.38	10.38	10.38	0.35	28.40	13.82	4.82	0.30	90,174
Jul-12	- Jun-14	6.11	3.19	9.30	9.30	9.30	0.30	25.30	12.38	4.32	0.27	80,781
Aug-12	- Jul-14	4.57	2.38	6.95	6.95	6.95	0.15	19.25	9.25	3.23	0.20	60,359
Sep-12	- Aug-14	4.34	2.27	6.61	6.61	6.61	0.15	18.45	8.80	3.07	0.19	57,401
Oct-12	- Sep-14	4.20	2.20	6.40	6.40	6.40	0.15	17.85	8.52	2.97	0.19	55,576
Nov-12	- Oct-14	4.46	2.33	6.79	6.79	6.79	0.15	19.10	9.04	3.16	0.20	58,983
Dec-12	- Nov-14	4.58	2.39	6.97	6.97	6.97	0.15	19.70	9.27	3.24	0.20	60,490
Jan-13	- Dec-14	4.58	2.39	6.97	6.97	6.97	0.15	19.70	9.27	3.24	0.20	60,490
Feb-13	- Jan-15	4.58	2.39	6.97	6.97	6.97	0.15	19.75	9.28	3.24	0.20	60,543
Mar-13	- Feb-15	4.66	2.43	7.09	7.09	7.09	0.15	20.20	9.43	3.29	0.21	61,541
Apr-13	- Mar-15	4.68	2.44	7.12	7.12	7.12	0.15	20.30	9.48	3.31	0.21	61,873
May-13	- Apr-15	4.50	2.35	6.85	6.85	6.85	0.15	19.40	9.11	3.18	0.20	59,474
Jun-13	- May-15	5.16	2.69	7.85	7.85	7.85	0.15	22.25	10.45	3.65	0.23	68,209
Jul-13	- Jun-15	5.94	3.10	9.05	9.05	9.05	0.25	25.30	12.04	4.20	0.26	78,575
Aug-13	- Jul-15	5.38	2.81	8.20	8.20	8.20	0.20	23.70	10.91	3.81	0.24	71,184
Sep-13	- Aug-15	5.51	2.88	8.39	8.39	8.39	0.20	24.25	11.17	3.90	0.24	72,868
Oct-13	- Sep-15	5.91	3.08	8.99	8.99	8.99	0.20	25.75	11.96	4.18	0.26	78,065
Nov-13	- Oct-15	5.69	2.97	8.67	8.67	8.67	0.20	24.70	11.54	4.03	0.25	75,282
Dec-13	- Nov-15	6.06	3.17	9.23	9.23	9.23	0.20	25.95	12.28	4.29	0.27	80,137
Jan-14	- Dec-15	6.06	3.17	9.23	9.23	9.23	0.20	25.95	12.28	4.29	0.27	80,137
Feb-14	- Jan-16	6.31	3.30	9.61	9.61	9.61	0.20	27.50	12.79	4.47	0.28	83,478
Mar-14	- Feb-16	6.29	3.29	9.58	9.58	9.58	0.20	27.40	12.75	4.45	0.28	83,172
Apr-14	- Mar-16	6.65	3.47	10.12	10.12	10.12	0.20	29.15	13.47	4.70	0.30	87,902
May-14	- Apr-16	7.28	3.80	11.09	11.09	11.09	0.25	32.70	14.76	5.15	0.32	96,304
Jun-14	- May-16	7.33	3.83	11.16	11.16	11.16	0.25	32.80	14.85	5.18	0.33	96,888
Jul-14	- Jun-16	7.62	3.98	11.60	11.60	11.60	0.25	34.90	15.44	5.39	0.34	100,739
Aug-14	- Jul-16	7.75	4.05	11.80	11.80	11.80	0.25	35.45	15.71	5.48	0.34	102,515
Sep-14	- Aug-16	7.57	3.95	11.52	11.52	11.52	0.25	34.65	15.33	5.35	0.34	100,063
Oct-14	- Sep-16	7.76	4.05	11.82	11.82	11.82	0.25	35.70	15.73	5.49	0.35	102,642
Nov-14	- Oct-16	7.87	4.11	11.99	11.99	11.99	0.25	36.45	15.95	5.57	0.35	104,106
Dec-14	- Nov-16	7.74	4.04	11.78	11.78	11.78	0.25	35.80	15.68	5.48	0.34	102,342
Jan-15	- Dec-16	7.79	4.07	11.86	11.86	11.86	0.25	36.10	15.78	5.51	0.35	102,997
Feb-15	- Jan-17	7.78	4.06	11.85	11.85	11.85	0.25	36.00	15.77	5.50	0.35	102,883
Mar-15	- Feb-17	7.71	4.02	11.73	11.73	11.73	0.25	35.55	15.61	5.45	0.34	101,885
Apr-15	- Mar-17	7.88	4.11	11.99	11.99	11.99	0.25	36.50	15.96	5.57	0.35	104,169
May-15	- Apr-17	8.30	4.33	12.63	12.63	12.63	0.25	38.75	16.81	5.87	0.37	109,716
Jun-15	- May-17	8.05	4.21	12.26	12.26	12.26	0.25	38.05	16.31	5.69	0.36	106,449
Jul-15	- Jun-17	7.08	3.70	10.77	10.77	10.77	0.15	34.30	14.34	5.01	0.31	93,561
Aug-15	- Jul-17	6.04	3.15	9.19	9.19	9.19	0.05	30.65	12.23	4.27	0.27	79,808
Sep-15	- Aug-17	6.40	3.34	9.74	9.74	9.74	0.05	32.55	12.96	4.53	0.28	84,585
Oct-15	- Sep-17	6.44	3.36	9.80	9.80	9.80	0.05	33.35	13.05	4.55	0.29	85,128
Nov-15	- Oct-17	6.44	3.36	9.81	9.81	9.81	0.05	33.55	13.05	4.56	0.29	85,175
Dec-15	- Nov-17	5.99	3.13	9.12	9.12	9.12	0.05	32.00	12.14	4.24	0.27	79,216
Jan-16	- Dec-17	5.99	3.13	9.12	9.12	9.12	0.05	32.00	12.14	4.24	0.27	79,216
Feb-16	- Jan-18	5.73	2.99	8.73	8.73	8.73	0.05	30.40	11.62	4.06	0.25	75,813
Mar-16	- Feb-18	5.73	2.99	8.73	8.73	8.73	0.05	30.40	11.62	4.06	0.25	75,813
Apr-16	- Mar-18	5.34	2.79	8.12	8.12	8.12	0.05	28.50	10.81	3.77	0.24	70,530
May-16	- Apr-18	4.72	2.46	7.18	7.18	7.18	0.00	25.10	9.56	3.34	0.21	62,380
Jun-16	- May-18	4.91	2.56	7.48	7.48	7.48	0.00	25.95	9.95	3.47	0.22	64,919
Jul-16	- Jun-18	5.14	2.68	7.82	7.82	7.82	0.00	25.75	10.41	3.63	0.23	67,901
Aug-16	- Jul-18	5.12	2.67	7.79	7.79	7.79	0.00	25.70	10.37	3.62	0.23	67,690
Sep-16	- Aug-18	5.28	2.76	8.04	8.04	8.04	0.00	26.45	10.71	3.74	0.23	69,862
Oct-16	- Sep-18	5.48	2.86	8.34	8.34	8.34	0.00	27.10	11.10	3.88	0.24	72,436
Nov-16	- Oct-18	5.72	2.98	8.70	8.70	8.70	0.00	27.85	11.58	4.04	0.25	75,553
Dec-16	- Nov-18	5.64	2.95	8.59	8.59	8.59	0.00	27.45	11.43	3.99	0.25	74,603
Jan-17	- Dec-18	5.64	2.95	8.59	8.59	8.59	0.00	27.45	11.43	3.99	0.25	74,598
Feb-17	- Jan-19	5.64	2.95	8.59	8.59	8.59	0.00	27.45	11.43	3.99	0.25	74,598
Mar-17	- Feb-19	5.64	2.95	8.59	8.59	8.59	0.00	27.45	11.43	3.99	0.25	74,598
Apr-17	- Mar-19	5.44	2.84	8.28	8.28	8.28	0.00	26.20	11.02	3.85	0.24	71,922
May-17	- Apr-19	5.05	2.64	7.69	7.69	7.69	0.00	24.15	10.24	3.57	0.22	66,789
Jun-17	- May-19	4.80	2.50	7.30	7.30	7.30	0.00	22.70	9.72	3.39	0.21	63,395
Jul-17	- Jun-19	5.21	2.72	7.92	7.92	7.92	0.00	24.10	10.55	3.68	0.23	68,823
Aug-17	- Jul-19	5.74	3.00	8.74	8.74	8.74	0.05	25.35	11.63	4.06	0.26	75,917
Sep-17	- Aug-19	5.97	3.12	9.09	9.09	9.09	0.05	25.90	12.09	4.22	0.27	78,915
Oct-17	- Sep-19	7.30	3.81	11.11	11.11	11.11	0.25	30.60	14.78	5.16	0.32	96,456
Nov-17	- Oct-19	8.10	4.23	12.32	12.32	12.32	0.25	33.75	16.40	5.73	0.36	107,036
Dec-17	- Nov-19	8.11	4.24	12.35	12.35	12.35	0.25	33.90	16.44	5.74	0.36	107,277
Jan-18	- Dec-19	8.12	4.24	12.37	12.37	12.37	0.25	34.10	16.46	5.75	0.36	107,400
Feb-18	- Jan-20	8.12	4.24	12.37	12.37	12.37	0.25	34.10	16.46	5.75	0.36	107,400
Mar-18	- Feb-20	8.12	4.24	12.37	12.37	12.37	0.25	34.10	16.46	5.75	0.36	107,400
Apr-18	- Mar-20	8.19	4.28	12.47	12.47	12.47	0.25	34.35	16.60	5.80	0.36	108,328
May-18	- Apr-20	8.07	4.22	12.29	12.29	12.29	0.25	33.75	16.36	5.71	0.36	106,733
Jun-18	- May-20	7.74	4.04	11.78	11.78	11.78	0.25	32.30	15.68	5.47	0.34	102,290
Jul-18	- Jun-20	7.40	3.87	11.27	11.27	11.27	0.25	31.45	15.00	5.24	0.33	97,890
Max Annual Baseline Emissions:	11.58	6.05	17.63	17.63	17.63	0.40	50.00	23.46	8.19	0.51	153,070	
Period Start:	Aug-11	Aug-11	Aug-11	Aug-11	Aug-11	Aug-11	Aug-11	Aug-11	Aug-11	Aug-11	Aug-11	
Period End:	Jul-13	Jul-13	Jul-13	Jul-13	Jul-13	Jul-13	Jul-13	Jul-13	Jul-13	Jul-13	Jul-13	

1. Annual baseline emissions are estimated from Table B-11 and represent the sum of the total emissions during the 24-month baseline period divided by 2.

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-13. Projected Actual Emissions from Turbines Nos. 1 - 4

Pollutant	T1 - Combustion Turbine No. 1 (tpy)	T2 - Combustion Turbine No. 2 (tpy)	T3 - Combustion Turbine No. 3 (tpy)	T4 - Combustion Turbine No. 4 (tpy)	Projected Actual Turbine Emissions (tpy)
SO ₂	2.30	2.30	2.30	2.30	9.19
NO _x	152.73	152.73	152.73	152.73	610.94
CO	70.86	70.86	70.86	70.86	283.44
Total PM	43.00	43.00	43.00	43.00	172.00
Filterable PM	27.15	27.15	27.15	27.15	108.59
Condensable PM	15.85	15.85	15.85	15.85	63.41
Total PM ₁₀	43.00	43.00	43.00	43.00	172.00
Total PM _{2.5}	43.00	43.00	43.00	43.00	172.00
VOC	25.61	25.61	25.61	25.61	102.45
Lead	0.01	0.01	0.01	0.01	0.03
Sulfuric Acid Mist (H ₂ SO ₄)	1.07	1.07	1.07	1.07	4.26
CO ₂ e	387,496	387,496	387,496	387,496	1,549,985

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Simple Cycle Unit Operating Parameters - Natural Gas Combustion

Heat Input	1,766	MMBtu/hr	
Operating Hours	2,700	hrs/yr	NO _x , CO, VOC
	3000	hrs/yr	Other Pollutants

Table B-14. Projected Actual Criteria Pollutant Emissions from Turbine No. 1 Natural Gas Combustion

Pollutant	Emission Factor¹ (lb/MMBtu)	Potential Hourly Emissions² (lb/hr)	Potential Annual Emissions³ (tpy)
SO ₂	6.00E-04	1.06	1.59
NO _x	3.00E-02	52.89	71.41
CO	1.82E-02	32.20	43.47
Total PM	1.37E-02	24.19	36.29
Filterable PM	9.00E-03	15.89	23.84
Condensable PM	4.70E-03	8.30	12.45
Total PM ₁₀	1.37E-02	24.19	36.29
Total PM _{2.5}	1.37E-02	24.19	36.29
VOC	6.37E-03	11.24	15.17
Sulfuric Acid Mist (H ₂ SO ₄)	4.00E-04	0.71	1.06
<u>GHGs</u>			
CO ₂	116.98	206,580	309,870
CH ₄	2.20E-03	3.89	5.84
N ₂ O	2.20E-04	0.39	0.58
CO ₂ e	117.10	206,793	310,190

1. See Table B-3 for details on emission factors for turbines combusting natural gas.
2. Potential Emissions (lb/hr) = Emission Factor (lbs/MMBtu) * Heat Input (MMBtu/hr)
3. Pollutant Emissions (tpy) = Potential Hourly Emissions (lb/hr) * Operating Limit (hr/yr) / 2,000 (lb/ton)

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Simple Cycle Unit Operating Parameters - Fuel Oil Combustion

Heat Input	1,890	MMBtu/hr	
Turbine Operating Hours	450	hrs/yr	NO _x , CO, VOC
	500	hrs/yr	Other Pollutants

Table B-15. Projected Actual Criteria Pollutant Emissions from Turbine No. 1 Fuel Oil Combustion

Pollutant	Emission Factor¹ (lb/MMBtu)	Potential Hourly Emissions² (lb/hr)	Potential Annual Emissions³ (tpy)
SO ₂	1.50E-03	2.84	0.71
NO _x	1.40E-01	264.12	59.43
CO	4.05E-02	76.57	17.23
Total PM	1.42E-02	26.84	6.71
Filterable PM	7.00E-03	13.23	3.31
Condensable PM	7.20E-03	13.61	3.40
Total PM ₁₀	1.42E-02	26.838	6.71
Total PM _{2.5}	1.42E-02	26.84	6.71
VOC	1.59E-02	30.07	6.77
Sulfuric Acid Mist (H ₂ SO ₄)	1.40E-05	0.03	0.01
<i>GHGs</i>			
CO ₂	163.05	308,169	77,042
CH ₄	6.61E-03	12.50	3.13
N ₂ O	1.32E-03	2.50	0.63
CO ₂ e	163.61	309,226	77,307

1. See Table B-4 for details on emission factors for turbines combusting ULSD.
2. Potential Emissions (lb/hr) = Emission Factor (lbs/MMBtu) * Maximum Heat Input Capacity (MMBtu/hr)
3. Pollutant Emissions (tpy) = Potential Hourly Emissions (lb/hr) * Operating Limit (hr/yr) / 2,000 (lb/ton)

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Startup/Shutdown Operating Parameters

Heat Input Natural Gas SUSD Hour	1,478	MMBtu/hr
Hours of Natural Gas SUSD	300	hrs/yr
Heat Input Fuel Oil SUSD Hour	1,582	MMBtu/hr
Hours of Fuel Oil SUSD	50	hrs/yr

Table B-16. Projected Actual Emissions from Turbine No. 1 Startup/Shutdown Operations

Pollutant	Emission Factor ¹ (lb/MMBtu)	Operation Hours/ Events ²	Potential Emissions ³	
			(lb/hr)	(tpy)
<i>Normal Operation Period⁴</i>				
NO _x	--	--	264.12	130.83
CO	--	--	76.57	60.70
VOC	--	--	30.07	21.94
<i>Startup/Shutdown Period Natural Gas</i>				
NO _x	0.0539	300 hrs natural gas	79.68	11.95
CO	0.0328		48.51	7.28
VOC	0.0115		16.93	2.54
<i>Startup/Shutdown Period Fuel Oil</i>				
NO _x	0.25	50 hrs fuel oil	397.94	9.95
CO	0.0729		115.36	2.88
VOC	0.03		45.30	1.13
<i>Annual Emissions⁵</i>				
NO _x	--	--	--	152.73
CO	--	--	--	70.86
VOC	--	--	--	25.61

1. Startup/shutdown emission factors based on engineering analysis of available facility data.
2. Washington County Power anticipates 300 hrs/yr of startup/shutdown activities on natural gas and 50 hrs/yr of startup/shutdown activities on fuel oil. Therefore, normal operation excludes startup/shutdown events. As each separate startup or shutdown requires less than 30 minutes of time, it is presumed that a shutdown and a startup event combined is the equivalent of 1 hour. Therefore, 300 startup/shutdown events is presumed to require 300 total hours of time per system.
3. Potential Emissions for Startup/Shutdown Period (tpy) = Emission Factor (lb/MMBtu) * Heat Input (MMBtu/hr) / 2,000 (lbs/ton)
4. Hourly emissions for the Normal Operation Period are based on the maximum hourly emission rate for turbine combustion of natural gas and fuel oil. Annual emissions for the Normal Operation Period are based on the sum of annual emission rates for turbine combustion of natural gas and fuel oil.
5. Annual emissions are the sum of emissions under normal operation period and startup/shutdown period.

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-17. Project Actual Criteria Pollutant Emissions from Combustion Turbine No. 1

Pollutant	Annual Emissions (tpy)
SO₂	2.30
NO_x	152.73
CO	70.86
Total PM	43.00
Filterable PM	27.15
Condensable PM	15.85
Total PM₁₀	43.00
Total PM_{2.5}	43.00
VOC	25.61
Sulfuric Acid Mist (H₂SO₄)	1.07
GHGs	387,496

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Simple Cycle Unit Operating Parameters - Natural Gas Combustion

Heat Input	1,766	MMBtu/hr
Turbine Operating Hours	3,000	hrs/yr

Table B-18. Projected Actual HAP Emissions from Turbine No. 1 Natural Gas Combustion

Pollutant	Emission Factor¹ (lb/MMBtu)	Average Hourly Emissions² (lb/hr)	Annual Emissions³ (tpy)
1,3-Butadiene	4.30E-07	7.59E-04	1.14E-03
Acetaldehyde	4.00E-05	0.07	0.11
Acrolein	6.40E-06	0.01	0.02
Benzene	1.20E-05	0.02	0.03
Ethylbenzene	3.20E-05	0.06	0.08
Formaldehyde	7.10E-04	1.25	1.88
Naphthalene	1.30E-06	2.30E-03	3.44E-03
PAH	2.20E-06	3.89E-03	0.01
Propylene oxide	2.90E-05	0.05	0.08
Toluene	1.30E-04	0.23	0.34
Xylenes	6.40E-05	0.11	0.17

1. Emission factors for natural gas are from AP-42 Ch. 3.1 Stationary Gas Turbines, Table 3.1-3 (April 2000).
2. Potential Emissions (lb/hr) = Emission Factor (lbs/MMBtu) * Heat Input (MMBtu/hr)
3. Pollutant Emissions (tpy) = Potential Hourly Emissions (lb/hr) * Operating Limit (hr/yr) / 2,000 (lb/ton)

Simple Cycle Unit Operating Parameters - Fuel Oil Combustion

Heat Input	1,890	MMBtu/hr
Turbine Operating Hours	500	hrs/yr

Table B-19. Projected Actual HAP Emissions from Turbine No. 1 Fuel Oil Combustion

Pollutant	Emission Factor¹ (lb/MMBtu)	Average Hourly Emissions² (lb/hr)	Annual Emissions³ (tpy)
1,3-Butadiene	1.60E-05	0.03	0.01
Arsenic	1.10E-05	0.02	0.01
Benzene	5.50E-05	0.10	0.03
Beryllium	3.10E-07	5.86E-04	1.46E-04
Cadmium	4.80E-06	0.01	2.27E-03
Chromium	1.10E-05	0.02	0.01
Formaldehyde	2.80E-04	0.53	0.13
Lead	1.40E-05	0.03	0.01
Manganese	7.90E-04	1.49	0.37
Mercury	1.20E-06	2.27E-03	5.67E-04
Naphthalene	3.50E-05	0.07	0.02
Nickel	4.60E-06	0.01	2.17E-03
PAH	4.00E-05	0.08	0.02
Selenium	2.50E-05	0.05	0.01

1. Emission factors for natural gas are from AP-42 Ch. 3.1 Stationary Gas Turbines, Tables 3.1-4 and 3.1-5 (April 2000).
2. Potential Emissions (lb/hr) = Emission Factor (lbs/MMBtu) * Heat Input (MMBtu/hr)
3. Pollutant Emissions (tpy) = Potential Hourly Emissions (lb/hr) * Operating Limit (hr/yr) / 2,000 (lb/ton)

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-20. Projected Actual HAP Emissions from Combustion Turbine No. 1

Pollutant	Annual Emissions (tpy)
1,3-Butadiene	0.01
Acetaldehyde	0.11
Acrolein	0.02
Arsenic	0.01
Benzene	0.06
Beryllium	1.46E-04
Cadmium	2.27E-03
Chromium	0.01
Ethylbenzene	0.08
Formaldehyde	2.01
Lead	0.01
Manganese	0.37
Mercury	5.67E-04
Naphthalene	0.02
Nickel	2.17E-03
PAH	0.02
Propylene oxide	0.08
Selenium	0.01
Toluene	0.34
Xylenes	0.17

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Simple Cycle Unit Operating Parameters - Natural Gas Combustion

Heat Input	1,766	MMBtu/hr	
Operating Hours	2,700	hrs/yr	NO _x , CO, VOC
	3000	hrs/yr	Other Pollutants

Table B-21. Projected Actual Criteria Pollutant Emissions from Turbine No. 2 Natural Gas Combustion

Pollutant	Emission Factor¹ (lb/MMBtu)	Potential Hourly Emissions² (lb/hr)	Potential Annual Emissions³ (tpy)
SO ₂	6.00E-04	1.06	1.59
NO _x	3.00E-02	52.89	71.41
CO	1.82E-02	32.20	43.47
Total PM	1.37E-02	24.19	36.29
Filterable PM	9.00E-03	15.89	23.84
Condensable PM	4.70E-03	8.30	12.45
Total PM ₁₀	1.37E-02	24.19	36.29
Total PM _{2.5}	1.37E-02	24.19	36.29
VOC	6.37E-03	11.24	15.17
Sulfuric Acid Mist (H ₂ SO ₄)	4.00E-04	0.71	1.06
<u>GHGs</u>			
CO ₂	116.98	206,580	309,870
CH ₄	2.20E-03	3.89	5.84
N ₂ O	2.20E-04	0.39	0.58
CO ₂ e	117.10	206,793	310,190

1. See Table B-3 for details on emission factors for turbines combusting natural gas.
2. Potential Emissions (lb/hr) = Emission Factor (lbs/MMBtu) * Heat Input (MMBtu/hr)
3. Pollutant Emissions (tpy) = Potential Hourly Emissions (lb/hr) * Operating Limit (hr/yr) / 2,000 (lb/ton)

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Simple Cycle Unit Operating Parameters - Fuel Oil Combustion

Heat Input	1,890	MMBtu/hr	
Turbine Operating Hours	450	hrs/yr	NO _x , CO, VOC
	500	hrs/yr	Other Pollutants

Table B-22. Projected Actual Criteria Pollutant Emissions from Turbine No. 2 Fuel Oil Combustion

Pollutant	Emission Factor¹ (lb/MMBtu)	Potential Hourly Emissions² (lb/hr)	Potential Annual Emissions³ (tpy)
SO ₂	1.50E-03	2.84	0.71
NO _x	1.40E-01	264.12	59.43
CO	4.05E-02	76.57	17.23
Total PM	1.42E-02	26.84	6.71
Filterable PM	7.00E-03	13.23	3.31
Condensable PM	7.20E-03	13.61	3.40
Total PM ₁₀	1.42E-02	26.838	6.71
Total PM _{2.5}	1.42E-02	26.84	6.71
VOC	1.59E-02	30.07	6.77
Sulfuric Acid Mist (H ₂ SO ₄)	1.40E-05	0.03	0.01
<i>GHGs</i>			
CO ₂	163.05	308,169	77,042
CH ₄	0.007	12.50	3.13
N ₂ O	0.001	2.50	0.63
CO ₂ e	163.61	309,226	77,307

1. See Table B-4 for details on emission factors for turbines combusting ULSD.
2. Potential Emissions (lb/hr) = Emission Factor (lbs/MMBtu) * Maximum Heat Input Capacity (MMBtu/hr)
3. Pollutant Emissions (tpy) = Potential Hourly Emissions (lb/hr) * Operating Limit (hr/yr) / 2,000 (lb/ton)

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Startup/Shutdown Operating Parameters

Heat Input Natural Gas SUSD Hour	1,478	MMBtu/hr
Hours of Natural Gas SUSD	300	hrs/yr
Heat Input Fuel Oil SUSD Hour	1,582	MMBtu/hr
Hours of Fuel Oil SUSD	50	hrs/yr

Table B-23. Projected Actual Emissions from Turbine No. 2 Startup/Shutdown Operations

Pollutant	Emission Factor ¹ (lb/MMBtu)	Operation Hours/ Events ²	Potential Emissions ³	
			(lb/hr)	(tpy)
<i>Normal Operation Period⁴</i>				
NO _x	--	--	264.12	130.83
CO	--	--	76.57	60.70
VOC	--	--	30.07	21.94
<i>Startup/Shutdown Period Natural Gas</i>				
NO _x	0.05	300 hrs natural gas	79.68	11.95
CO	0.03		48.51	7.28
VOC	0.01		16.93	2.54
<i>Startup/Shutdown Period Fuel Oil</i>				
NO _x	0.25	50 hrs fuel oil	397.94	9.95
CO	0.07		115.36	2.88
VOC	0.03		45.30	1.13
<i>Annual Emissions⁵</i>				
NO _x	--	--	--	152.73
CO	--	--	--	70.86
VOC	--	--	--	25.61

1. Startup/shutdown emission factors based on engineering analysis of available facility data.
2. Washington County Power anticipates 300 hrs/yr of startup/shutdown activities on natural gas and 50 hrs/yr of startup/shutdown activities on fuel oil. Therefore, normal operation excludes startup/shutdown events. As each separate startup or shutdown requires less than 30 minutes of time, it is presumed that a shutdown and a startup event combined is the equivalent of 1 hour. Therefore, 300 startup/shutdown events is presumed to require 300 total hours of time per system.
3. Potential Emissions for Startup/Shutdown Period (tpy) = Emission Factor (lb/MMBtu) * Heat Input (MMBtu/hr) / 2,000 (lbs/ton)
4. Hourly emissions for the Normal Operation Period are based on the maximum hourly emission rate for turbine combustion of natural gas and fuel oil. Annual emissions for the Normal Operation Period are based on the sum of annual emission rates for turbine combustion of natural gas and fuel oil.
5. Annual emissions are the sum of emissions under normal operation period and startup/shutdown period.

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-24. Project Actual Criteria Pollutant Emissions from Combustion Turbine No. 2

Pollutant	Annual Emissions (tpy)
SO₂	2.30
NO_x	152.73
CO	70.86
Total PM	43.00
Filterable PM	27.15
Condensable PM	15.85
Total PM₁₀	43.00
Total PM_{2.5}	43.00
VOC	25.61
Sulfuric Acid Mist (H₂SO₄)	1.07
GHGs	387,496

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Simple Cycle Unit Operating Parameters - Natural Gas Combustion

Heat Input	1,766	MMBtu/hr
Turbine Operating Hours	3,000	hrs/yr

Table B-25. Projected Actual HAP Emissions from Turbine No. 2 Natural Gas Combustion

Pollutant	Emission Factor¹ (lb/MMBtu)	Average Hourly Emissions² (lb/hr)	Annual Emissions³ (tpy)
1,3-Butadiene	4.30E-07	7.59E-04	1.14E-03
Acetaldehyde	4.00E-05	0.07	0.11
Acrolein	6.40E-06	0.01	0.02
Benzene	1.20E-05	0.02	0.03
Ethylbenzene	3.20E-05	0.06	0.08
Formaldehyde	7.10E-04	1.25	1.88
Naphthalene	1.30E-06	2.30E-03	3.44E-03
PAH	2.20E-06	3.89E-03	0.01
Propylene oxide	2.90E-05	0.05	0.08
Toluene	1.30E-04	0.23	0.34
Xylenes	6.40E-05	0.11	0.17

1. Emission factors for natural gas are from AP-42 Ch. 3.1 Stationary Gas Turbines, Table 3.1-3 (April 2000).

2. Potential Emissions (lb/hr) = Emission Factor (lbs/MMBtu) * Heat Input (MMBtu/hr)

3. Pollutant Emissions (tpy) = Potential Hourly Emissions (lb/hr) * Operating Limit (hr/yr) / 2,000 (lb/ton)

Simple Cycle Unit Operating Parameters - Fuel Oil Combustion

Heat Input	1,890	MMBtu/hr
Turbine Operating Hours	500	hrs/yr

Table B-26. Projected Actual HAP Emissions from Turbine No. 2 Fuel Oil Combustion

Pollutant	Emission Factor¹ (lb/MMBtu)	Average Hourly Emissions² (lb/hr)	Annual Emissions³ (tpy)
1,3-Butadiene	1.60E-05	0.03	0.01
Arsenic	1.10E-05	0.02	0.01
Benzene	5.50E-05	0.10	0.03
Beryllium	3.10E-07	5.86E-04	1.46E-04
Cadmium	4.80E-06	0.01	2.27E-03
Chromium	1.10E-05	0.02	0.01
Formaldehyde	2.80E-04	0.53	0.13
Lead	1.40E-05	0.03	0.01
Manganese	7.90E-04	1.49	0.37
Mercury	1.20E-06	2.27E-03	5.67E-04
Naphthalene	3.50E-05	0.07	0.02
Nickel	4.60E-06	0.01	2.17E-03
PAH	4.00E-05	0.08	0.02
Selenium	2.50E-05	0.05	0.01

1. Emission factors for natural gas are from AP-42 Ch. 3.1 Stationary Gas Turbines, Tables 3.1-4 and 3.1-5 (April 2000).

2. Potential Emissions (lb/hr) = Emission Factor (lbs/MMBtu) * Heat Input (MMBtu/hr)

3. Pollutant Emissions (tpy) = Potential Hourly Emissions (lb/hr) * Operating Limit (hr/yr) / 2,000 (lb/ton)

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-27. Projected Actual HAP Emissions from Combustion Turbine No. 2

Pollutant	Annual Emissions (tpy)
1,3-Butadiene	0.01
Acetaldehyde	0.11
Acrolein	0.02
Arsenic	0.01
Benzene	0.06
Beryllium	1.46E-04
Cadmium	2.27E-03
Chromium	0.01
Ethylbenzene	0.08
Formaldehyde	2.01
Lead	0.01
Manganese	0.37
Mercury	5.67E-04
Naphthalene	0.02
Nickel	2.17E-03
PAH	0.02
Propylene oxide	0.08
Selenium	0.01
Toluene	0.34
Xylenes	0.17

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Simple Cycle Unit Operating Parameters - Natural Gas Combustion

Heat Input	1,766	MMBtu/hr	
Operating Hours	2,700	hrs/yr	NO _x , CO, VOC
	3000	hrs/yr	Other Pollutants

Table B-28. Projected Actual Criteria Pollutant Emissions from Turbine No. 3 Natural Gas Combustion

Pollutant	Emission Factor¹ (lb/MMBtu)	Potential Hourly Emissions² (lb/hr)	Potential Annual Emissions³ (tpy)
SO ₂	6.00E-04	1.06	1.59
NO _x	3.00E-02	52.89	71.41
CO	1.82E-02	32.20	43.47
Total PM	1.37E-02	24.19	36.29
Filterable PM	9.00E-03	15.89	23.84
Condensable PM	4.70E-03	8.30	12.45
Total PM ₁₀	1.37E-02	24.19	36.29
Total PM _{2.5}	1.37E-02	24.19	36.29
VOC	6.37E-03	11.24	15.17
Sulfuric Acid Mist (H ₂ SO ₄)	4.00E-04	0.71	1.06
<u>GHGs</u>			
CO ₂	116.98	206,580	309,870
CH ₄	2.20E-03	3.89	5.84
N ₂ O	2.20E-04	0.39	0.58
CO ₂ e	117.10	206,793	310,190

1. See Table B-3 for details on emission factors for turbines combusting natural gas.
2. Potential Emissions (lb/hr) = Emission Factor (lbs/MMBtu) * Heat Input (MMBtu/hr)
3. Pollutant Emissions (tpy) = Potential Hourly Emissions (lb/hr) * Operating Limit (hr/yr) / 2,000 (lb/ton)

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Simple Cycle Unit Operating Parameters - Fuel Oil Combustion

Heat Input	1,890	MMBtu/hr	
Turbine Operating Hours	450	hrs/yr	NOx, CO, VOC
	500	hrs/yr	Other Pollutants

Table B-29. Projected Actual Criteria Pollutant Emissions from Turbine No. 3 Fuel Oil Combustion

Pollutant	Emission Factor¹ (lb/MMBtu)	Potential Hourly Emissions² (lb/hr)	Potential Annual Emissions³ (tpy)
SO ₂	1.50E-03	2.84	0.71
NO _x	1.40E-01	264.12	59.43
CO	4.05E-02	76.57	17.23
Total PM	1.42E-02	26.84	6.71
Filterable PM	7.00E-03	13.23	3.31
Condensable PM	7.20E-03	13.61	3.40
Total PM ₁₀	1.42E-02	26.838	6.71
Total PM _{2.5}	1.42E-02	26.84	6.71
VOC	1.59E-02	30.07	6.77
Sulfuric Acid Mist (H ₂ SO ₄)	1.40E-05	0.03	0.01
<i>GHGs</i>			
CO ₂	163.05	308,169	77,042
CH ₄	0.007	12.50	3
N ₂ O	0.001	2.50	1
CO ₂ e	163.61	309,226	77,307

1. See Table B-4 for details on emission factors for turbines combusting ULSD.
2. Potential Emissions (lb/hr) = Emission Factor (lbs/MMBtu) * Maximum Heat Input Capacity (MMBtu/hr)
3. Pollutant Emissions (tpy) = Potential Hourly Emissions (lb/hr) * Operating Limit (hr/yr) / 2,000 (lb/ton)

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Startup/Shutdown Operating Parameters

Heat Input Natural Gas SUSD Hour	1,478	MMBtu/hr
Hours of Natural Gas SUSD	300	hrs/yr
Heat Input Fuel Oil SUSD Hour	1,582	MMBtu/hr
Hours of Fuel Oil SUSD	50	hrs/yr

Table B-30. Projected Actual Emissions from Turbine No. 3 Startup/Shutdown Operations

Pollutant	Emission Factor ¹ (lb/MMBtu)	Operation Hours/ Events ²	Potential Emissions ³	
			(lb/hr)	(tpy)
<i>Normal Operation Period⁴</i>				
NO _x	--	--	264.12	130.83
CO	--	--	76.57	60.70
VOC	--	--	30.07	21.94
<i>Startup/Shutdown Period Natural Gas</i>				
NO _x	0.05	300 hrs natural gas	79.68	11.95
CO	0.03		48.51	7.28
VOC	0.01		16.93	2.54
<i>Startup/Shutdown Period Fuel Oil</i>				
NO _x	0.25	50 hrs fuel oil	397.94	9.95
CO	0.07		115.36	2.88
VOC	0.03		45.30	1.13
<i>Annual Emissions⁵</i>				
NO _x	--	--	--	152.73
CO	--	--	--	70.86
VOC	--	--	--	25.61

1. Startup/shutdown emission factors based on engineering analysis of available facility data.
2. Washington County Power anticipates 300 hrs/yr of startup/shutdown activities on natural gas and 50 hrs/yr of startup/shutdown activities on fuel oil. Therefore, normal operation excludes startup/shutdown events. As each separate startup or shutdown requires less than 30 minutes of time, it is presumed that a shutdown and a startup event combined is the equivalent of 1 hour. Therefore, 300 startup/shutdown events is presumed to require 300 total hours of time per system.
3. Potential Emissions for Startup/Shutdown Period (tpy) = Emission Factor (lb/MMBtu) * Heat Input (MMBtu/hr) / 2,000 (lbs/ton)
4. Hourly emissions for the Normal Operation Period are based on the maximum hourly emission rate for turbine combustion of natural gas and fuel oil. Annual emissions for the Normal Operation Period are based on the sum of annual emission rates for turbine combustion of natural gas and fuel oil.
5. Annual emissions are the sum of emissions under normal operation period and startup/shutdown period.

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-31. Project Actual Criteria Pollutant Emissions from Combustion Turbine No. 3

Pollutant	Annual Emissions (tpy)
SO₂	2.30
NO_x	152.73
CO	70.86
Total PM	43.00
Filterable PM	27.15
Condensable PM	15.85
Total PM₁₀	43.00
Total PM_{2.5}	43.00
VOC	25.61
Sulfuric Acid Mist (H₂SO₄)	1.07
GHGs	387,496

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Simple Cycle Unit Operating Parameters - Natural Gas Combustion

Heat Input	1,766	MMBtu/hr
Turbine Operating Hours	3,000	hrs/yr

Table B-32. Projected Actual HAP Emissions from Turbine No. 3 Natural Gas Combustion

Pollutant	Emission Factor¹ (lb/MMBtu)	Average Hourly Emissions² (lb/hr)	Annual Emissions³ (tpy)
1,3-Butadiene	4.30E-07	7.59E-04	1.14E-03
Acetaldehyde	4.00E-05	0.07	0.11
Acrolein	6.40E-06	0.01	0.02
Benzene	1.20E-05	0.02	0.03
Ethylbenzene	3.20E-05	0.06	0.08
Formaldehyde	7.10E-04	1.25	1.88
Naphthalene	1.30E-06	2.30E-03	3.44E-03
PAH	2.20E-06	3.89E-03	0.01
Propylene oxide	2.90E-05	0.05	0.08
Toluene	1.30E-04	0.23	0.34
Xylenes	6.40E-05	0.11	0.17

1. Emission factors for natural gas are from AP-42 Ch. 3.1 Stationary Gas Turbines, Table 3.1-3 (April 2000).

2. Potential Emissions (lb/hr) = Emission Factor (lbs/MMBtu) * Heat Input (MMBtu/hr)

3. Pollutant Emissions (tpy) = Potential Hourly Emissions (lb/hr) * Operating Limit (hr/yr) / 2,000 (lb/ton)

Simple Cycle Unit Operating Parameters - Fuel Oil Combustion

Heat Input	1,890	MMBtu/hr
Turbine Operating Hours	500	hrs/yr

Table B-33. Projected Actual HAP Emissions from Turbine No. 3 Fuel Oil Combustion

Pollutant	Emission Factor¹ (lb/MMBtu)	Average Hourly Emissions² (lb/hr)	Annual Emissions³ (tpy)
1,3-Butadiene	1.60E-05	0.03	0.01
Arsenic	1.10E-05	0.02	0.01
Benzene	5.50E-05	0.10	0.03
Beryllium	3.10E-07	5.86E-04	1.46E-04
Cadmium	4.80E-06	0.01	2.27E-03
Chromium	1.10E-05	0.02	0.01
Formaldehyde	2.80E-04	0.53	0.13
Lead	1.40E-05	0.03	0.01
Manganese	7.90E-04	1.49	0.37
Mercury	1.20E-06	2.27E-03	5.67E-04
Naphthalene	3.50E-05	0.07	0.02
Nickel	4.60E-06	0.01	2.17E-03
PAH	4.00E-05	0.08	0.02
Selenium	2.50E-05	0.05	0.01

1. Emission factors for natural gas are from AP-42 Ch. 3.1 Stationary Gas Turbines, Tables 3.1-4 and 3.1-5 (April 2000).

2. Potential Emissions (lb/hr) = Emission Factor (lbs/MMBtu) * Heat Input (MMBtu/hr)

3. Pollutant Emissions (tpy) = Potential Hourly Emissions (lb/hr) * Operating Limit (hr/yr) / 2,000 (lb/ton)

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-34. Projected Actual HAP Emissions from Combustion Turbine No. 3

Pollutant	Annual Emissions (tpy)
1,3-Butadiene	0.01
Acetaldehyde	0.11
Acrolein	0.02
Arsenic	0.01
Benzene	0.06
Beryllium	1.46E-04
Cadmium	2.27E-03
Chromium	0.01
Ethylbenzene	0.08
Formaldehyde	2.01
Lead	0.01
Manganese	0.37
Mercury	5.67E-04
Naphthalene	0.02
Nickel	2.17E-03
PAH	0.02
Propylene oxide	0.08
Selenium	0.01
Toluene	0.34
Xylenes	0.17

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Simple Cycle Unit Operating Parameters - Natural Gas Combustion

Heat Input	1,766	MMBtu/hr	
Operating Hours	2,700	hrs/yr	NO _x , CO, VOC
	3000	hrs/yr	Other Pollutants

Table B-35. Projected Actual Criteria Pollutant Emissions from Turbine No. 4 Natural Gas Combustion

Pollutant	Emission Factor¹ (lb/MMBtu)	Potential Hourly Emissions² (lb/hr)	Potential Annual Emissions³ (tpy)
SO ₂	6.00E-04	1.06	1.59
NO _x	3.00E-02	52.89	71.41
CO	1.82E-02	32.20	43.47
Total PM	1.37E-02	24.19	36.29
Filterable PM	9.00E-03	15.89	23.84
Condensable PM	4.70E-03	8.30	12.45
Total PM ₁₀	1.37E-02	24.19	36.29
Total PM _{2.5}	1.37E-02	24.19	36.29
VOC	6.37E-03	11.24	15.17
Sulfuric Acid Mist (H ₂ SO ₄)	4.00E-04	0.71	1.06
<u>GHGs</u>			
CO ₂	116.98	206,580	309,870
CH ₄	2.20E-03	3.89	5.84
N ₂ O	2.20E-04	0.39	0.58
CO ₂ e	117.10	206,793	310,190

1. See Table B-3 for details on emission factors for turbines combusting natural gas.
2. Potential Emissions (lb/hr) = Emission Factor (lbs/MMBtu) * Heat Input (MMBtu/hr)
3. Pollutant Emissions (tpy) = Potential Hourly Emissions (lb/hr) * Operating Limit (hr/yr) / 2,000 (lb/ton)

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Simple Cycle Unit Operating Parameters - Fuel Oil Combustion

Heat Input	1,890	MMBtu/hr	
Turbine Operating Hours	450	hrs/yr	NOx, CO, VOC
	500	hrs/yr	Other Pollutants

Table B-36. Projected Actual Criteria Pollutant Emissions from Turbine No. 4 Fuel Oil Combustion

Pollutant	Emission Factor¹ (lb/MMBtu)	Potential Hourly Emissions² (lb/hr)	Potential Annual Emissions³ (tpy)
SO ₂	1.50E-03	2.84	0.71
NO _x	1.40E-01	264.12	59.43
CO	4.05E-02	76.57	17.23
Total PM	1.42E-02	26.84	6.71
Filterable PM	7.00E-03	13.23	3.31
Condensable PM	7.20E-03	13.61	3.40
Total PM ₁₀	1.42E-02	26.838	6.71
Total PM _{2.5}	1.42E-02	26.84	6.71
VOC	1.59E-02	30.07	6.77
Sulfuric Acid Mist (H ₂ SO ₄)	1.40E-05	0.03	0.01
<i>GHGs</i>			
CO ₂	163.05	308,169	77,042
CH ₄	0.007	12.50	3.13
N ₂ O	0.001	2.50	0.63
CO ₂ e	163.61	309,226	77,307

1. See Table B-4 for details on emission factors for turbines combusting ULSD.
2. Potential Emissions (lb/hr) = Emission Factor (lbs/MMBtu) * Maximum Heat Input Capacity (MMBtu/hr)
3. Pollutant Emissions (tpy) = Potential Hourly Emissions (lb/hr) * Operating Limit (hr/yr) / 2,000 (lb/ton)

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Startup/Shutdown Operating Parameters

Heat Input Natural Gas SUSD Hour	1,478	MMBtu/hr
Hours of Natural Gas SUSD	300	hrs/yr
Heat Input Fuel Oil SUSD Hour	1,582	MMBtu/hr
Hours of Fuel Oil SUSD	50	hrs/yr

Table B-37. Projected Actual Emissions from Turbine No. 4 Startup/Shutdown Operations

Pollutant	Emission Factor ¹ (lb/MMBtu)	Operation Hours/ Events ²	Potential Emissions ³	
			(lb/hr)	(tpy)
<i>Normal Operation Period⁴</i>				
NO _x	--	--	264.12	130.83
CO	--	--	76.57	60.70
VOC	--	--	30.07	21.94
<i>Startup/Shutdown Period Natural Gas</i>				
NO _x	0.05	300 hrs natural gas	79.68	11.95
CO	0.03		48.51	7.28
VOC	0.01		16.93	2.54
<i>Startup/Shutdown Period Fuel Oil</i>				
NO _x	0.25	50 hrs fuel oil	397.94	9.95
CO	0.07		115.36	2.88
VOC	0.03		45.30	1.13
<i>Annual Emissions⁵</i>				
NO _x	--	--	--	152.73
CO	--	--	--	70.86
VOC	--	--	--	25.61

1. Startup/shutdown emission factors based on engineering analysis of available facility data.
2. Washington County Power anticipates 300 hrs/yr of startup/shutdown activities on natural gas and 50 hrs/yr of startup/shutdown activities on fuel oil. Therefore, normal operation excludes startup/shutdown events. As each separate startup or shutdown requires less than 30 minutes of time, it is presumed that a shutdown and a startup event combined is the equivalent of 1 hour. Therefore, 300 startup/shutdown events is presumed to require 300 total hours of time per system.
3. Potential Emissions for Startup/Shutdown Period (tpy) = Emission Factor (lb/MMBtu) * Heat Input (MMBtu/hr) / 2,000 (lbs/ton)
4. Hourly emissions for the Normal Operation Period are based on the maximum hourly emission rate for turbine combustion of natural gas and fuel oil. Annual emissions for the Normal Operation Period are based on the sum of annual emission rates for turbine combustion of natural gas and fuel oil.
5. Annual emissions are the sum of emissions under normal operation period and startup/shutdown period.

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-38. Project Actual Criteria Pollutant Emissions from Combustion Turbine No. 4

Pollutant	Annual Emissions (tpy)
SO₂	2.30
NO_x	152.73
CO	70.86
Total PM	43.00
Filterable PM	27.15
Condensable PM	15.85
Total PM₁₀	43.00
Total PM_{2.5}	43.00
VOC	25.61
Sulfuric Acid Mist (H₂SO₄)	1.07
GHGs	387,496

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Simple Cycle Unit Operating Parameters - Natural Gas Combustion

Heat Input	1,766	MMBtu/hr
Turbine Operating Hours	3,000	hrs/yr

Table B-39. Projected Actual HAP Emissions from Turbine No. 4 Natural Gas Combustion

Pollutant	Emission Factor¹ (lb/MMBtu)	Average Hourly Emissions² (lb/hr)	Annual Emissions³ (tpy)
1,3-Butadiene	4.30E-07	7.59E-04	1.14E-03
Acetaldehyde	4.00E-05	0.07	0.11
Acrolein	6.40E-06	0.01	0.02
Benzene	1.20E-05	0.02	0.03
Ethylbenzene	3.20E-05	0.06	0.08
Formaldehyde	7.10E-04	1.25	1.88
Naphthalene	1.30E-06	2.30E-03	3.44E-03
PAH	2.20E-06	3.89E-03	0.01
Propylene oxide	2.90E-05	0.05	0.08
Toluene	1.30E-04	0.23	0.34
Xylenes	6.40E-05	0.11	0.17

1. Emission factors for natural gas are from AP-42 Ch. 3.1 Stationary Gas Turbines, Table 3.1-3 (April 2000).

2. Potential Emissions (lb/hr) = Emission Factor (lbs/MMBtu) * Heat Input (MMBtu/hr)

3. Pollutant Emissions (tpy) = Potential Hourly Emissions (lb/hr) * Operating Limit (hr/yr) / 2,000 (lb/ton)

Simple Cycle Unit Operating Parameters - Fuel Oil Combustion

Heat Input	1,890	MMBtu/hr
Turbine Operating Hours	500	hrs/yr

Table B-40. Projected Actual HAP Emissions from Turbine No. 4 Fuel Oil Combustion

Pollutant	Emission Factor¹ (lb/MMBtu)	Average Hourly Emissions² (lb/hr)	Annual Emissions³ (tpy)
1,3-Butadiene	1.60E-05	0.03	0.01
Arsenic	1.10E-05	0.02	0.01
Benzene	5.50E-05	0.10	0.03
Beryllium	3.10E-07	5.86E-04	1.46E-04
Cadmium	4.80E-06	0.01	2.27E-03
Chromium	1.10E-05	0.02	0.01
Formaldehyde	2.80E-04	0.53	0.13
Lead	1.40E-05	0.03	0.01
Manganese	7.90E-04	1.49	0.37
Mercury	1.20E-06	2.27E-03	5.67E-04
Naphthalene	3.50E-05	0.07	0.02
Nickel	4.60E-06	0.01	2.17E-03
PAH	4.00E-05	0.08	0.02
Selenium	2.50E-05	0.05	0.01

1. Emission factors for natural gas are from AP-42 Ch. 3.1 Stationary Gas Turbines, Tables 3.1-4 and 3.1-5 (April 2000).

2. Potential Emissions (lb/hr) = Emission Factor (lbs/MMBtu) * Heat Input (MMBtu/hr)

3. Pollutant Emissions (tpy) = Potential Hourly Emissions (lb/hr) * Operating Limit (hr/yr) / 2,000 (lb/ton)

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-41. Projected Actual HAP Emissions from Combustion Turbine No. 4

Pollutant	Annual Emissions (tpy)
1,3-Butadiene	0.01
Acetaldehyde	0.11
Acrolein	0.02
Arsenic	0.01
Benzene	0.06
Beryllium	1.46E-04
Cadmium	2.27E-03
Chromium	0.01
Ethylbenzene	0.08
Formaldehyde	2.01
Lead	0.01
Manganese	0.37
Mercury	5.67E-04
Naphthalene	0.02
Nickel	2.17E-03
PAH	0.02
Propylene oxide	0.08
Selenium	0.01
Toluene	0.34
Xylenes	0.17

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Fuel Oil Storage Tank Operating Parameters

Storage Components	Ultra Low-Sulfur Diesel	
Max Daily Operating	24	hours/day
Annual Operating Hours	8,760	hours/year
Tank Type	VFRT	
Tank Capacity	2,500,000	gallons
Tank Annual Throughput	30,000,000	gallons/yr

Table B-42. Fuel Oil Storage Tank Emissions

Pollutant	TankESP Output Losses (lb)	Potential Annual Emissions (tpy)
VOC	1,329.23	0.66
Benzene	2.62	1.31E-03
Ethylbenzene	4.07	2.03E-03
Hexane	0.52	2.62E-04
Naphthalene	0.62	3.10E-04
Toluene	30.65	1.53E-02
Xylene	79.29	3.96E-02

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-43. Historical Operating Hours for Turbines and Natural Gas Preheaters¹

Year	Combustion Turbine No. 1 (hr/yr)	Combustion Turbine No. 2 (hr/yr)	Combustion Turbine No. 3 (hr/yr)	Combustion Turbine No. 4 (hr/yr)	Heaters No. 1 (hr/yr)	Heaters No. 2 (hrs/yr)	Turbine Totals (hr/yr)	Heater Totals (hrs)
2015	530	258	255	456	502	657	1,499	1,159
2016	40	498	364	74	606	578	976	1,184
2017	60	415	346	59	440	428	880	868
2018	166	258	264	225	399	460	913	859
2019	399	427	411	422	752	754	1,659	1,507
Average:	239	371	328	247	540	576	1,185	1,115

1. Historical hours of operation for Turbines as previously reported.

Hours of Operation - Turbines

Proposed: 12,000 hours (3,000 hours of natural gas combustion proposed for each turbine)
 (4 Turbines Total)
 Annual Average: 1,185 hours
 (2015 - 2020)
 Ratio = Proposed/Annual Average
 = 10.12

Associated Increase =
(2 Heaters Total) Proposed - Annual Average
 = **10,176 hours**
 ~ **5,088 hours per Heater**

Hours of Operation - Heaters

Annual Average: 1,115 hours
 (2015 - 2020)
 Ratio: 10.12
 Proposed = Heaters Annual Average * Ratio
 (2 Heaters Total)
 = 11,291 hours

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Fuel Heater Operating Parameters

Fuel Type	Natural Gas	
Fuel Heating Value	1,020	Btu/scf
No. of Heaters	2	
Sulfur Content of Fuel (S)	0.50	gr/100 scf
Operating Hours Increase	5,088	hrs/yr
Nominal Heat Input	10.10	MMBtu/hr
Hourly Fuel Usage	0.0099	MMscf/hr

Table B-44. Associated Emissions Increases of Criteria Pollutants from Fuel Heaters (Nos.

Pollutant	Emission Factor¹ (lb/MMscf)	Potential Hourly Emissions² (lb/hr)	Potential Annual Emissions³ (tpy)
SO ₂	1.43	0.03	0.07
NO _x	100.00	1.98	5.04
CO	84.00	1.66	4.23
Total PM	7.60	0.15	0.38
Condensable PM	5.70	0.11	0.29
Filterable PM	1.90	0.04	0.10
PM ₁₀	7.60	0.15	0.38
PM _{2.5}	7.60	0.15	0.38
VOC	5.50	0.11	0.28
H ₂ SO ₄	0.33	0.01	0.02
<u>GHGs</u>			
CO ₂	119,317	2,363	6,011
CH ₄	2.25	0.04	0.11
N ₂ O	0.22	4.45E-03	0.01
CO ₂ e	119,440	2,365	6,017

1. See Table B-6 for details on emission factors for external natural gas combustion.
2. Potential Emissions (lb/hr) = Emission Factor (lbs/MMscf) * Fuel Usage (MMscf/hr) * No. of Heaters
3. Pollutant Emissions (tpy) = Potential Hourly Emissions (lb/hr) * Operating Limit (hr/yr) / 2,000 (lb/ton)

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-45. Associated Emissions Increases of HAPs from Fuel Heaters (Nos. 1 and 2)

Pollutant	Emission Factor¹ (lb/MMscf)	Potential Hourly Emissions² (lb/hr)	Potential Annual Emissions³ (tpy)
Arsenic	2.00E-04	3.96E-06	1.01E-05
Benzene	2.10E-03	4.16E-05	1.06E-04
Beryllium	1.20E-05	2.38E-07	6.05E-07
Cadmium	1.10E-03	2.18E-05	5.54E-05
Chromium	1.40E-03	2.77E-05	7.05E-05
Cobalt	8.40E-05	1.66E-06	4.23E-06
Dichlorobenzene	1.20E-03	2.38E-05	6.05E-05
Formaldehyde	7.50E-02	1.49E-03	3.78E-03
Hexane	1.80	0.04	0.09
Lead	5.00E-04	9.90E-06	2.52E-05
Manganese	3.80E-04	7.53E-06	1.91E-05
Mercury	2.60E-04	5.15E-06	1.31E-05
Naphthalene	6.10E-04	1.21E-05	3.07E-05
Nickel	2.10E-03	4.16E-05	1.06E-04
POM	6.98E-04	1.38E-05	3.52E-05
Selenium	2.40E-05	4.75E-07	1.21E-06
Toluene	3.40E-03	6.73E-05	1.71E-04

1. Emission factors obtained from AP-42 Ch. 1.4 Natural Gas Combustion, Tables 1.4-2, 1.4-3, and 1.4-4 (July 1998).
2. Potential Emissions (lb/hr) = Emission Factor (lbs/MMscf) * Fuel Usage (MMscf/hr) * No. of Heaters
3. Pollutant Emissions (tpy) = Potential Hourly Emissions (lb/hr) * Operating Limit (hr/yr) / 2,000 (lb/ton)

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-46. Project Associated Units Emissions Increases

Pollutant	Emissions Increases from Heaters (tpy)	Associated Units Emissions Increases (tpy)
Filterable PM	0.10	0.10
Total PM ₁₀	0.38	0.38
Total PM _{2.5}	0.38	0.38
SO ₂	0.07	0.07
NO _x	5.04	5.04
VOC	0.28	0.28
CO	4.23	4.23
CO ₂ e	6,017	6,017.37
Lead	2.52E-05	2.52E-05
Sulfuric Acid Mist	1.65E-02	0.02

**Appendix B - Turbines Modification NSR Evaluation
Washington County Power - Sandersville Facility**

Table B-47. Project PSD Emissions Increase Evaluation

Pollutant	A	B	C	D	E	F	PSD Significant	
	Modified Unit Baseline Emissions (tpy) ¹	Modified Unit Projected Actual Emissions (tpy) ¹	New Unit Potential Emissions (tpy) ²	Emissions Increase from New & Modified Units (D = C + B - A) (tpy) ³	Associated Units Emissions Increases (tpy)	Project Emissions Increases (F = D + E) (tpy) ⁴	Emission Rate (tpy)	PSD Triggered? (Yes/No)
Filterable PM	11.58	108.59	--	97.02	0.10	97.11	25	Yes
Total PM ₁₀	17.63	172.00	--	154.38	0.38	154.76	15	Yes
Total PM _{2.5}	17.63	172.00	--	154.38	0.38	154.76	10	Yes
SO ₂	0.40	9.19	--	8.79	0.07	8.86	40	No
NO _x	50.00	610.94	--	560.94	5.04	565.97	40	Yes
VOC	8.19	102.45	0.66	94.93	0.28	95.21	40	Yes
CO	23.46	283.44	--	259.98	4.23	264.21	100	Yes
CO ₂ e	153,070	1,549,985	--	1,396,914	6,017	1,402,932	75,000	Yes
Lead	--	0.03	--	0.03	2.52E-05	0.03	0.60	No
Sulfuric Acid Mist	0.51	4.26	--	3.75	0.02	3.77	7.00	No

1. The four existing site turbines are the modified units with respect to this PSD assessment.
2. The fuel oil storage tank is a new unit with respect to this PSD assessment.
3. Emissions Increase from New and Modified Units (tpy) = New Unit Potential Emissions (tpy) + Modified Unit Projected Actual Emissions (tpy) - Modified Unit Baseline Emissions (tpy)
4. Project Emissions Increases (tpy) = Emissions Increase from New and Modified Units (tpy) + Associated Units Emissions Increases (tpy)

APPENDIX C. RBLC SEARCH RESULTS

RBLC SEARCH RESULTS – NO_x

Appendix C - RBL Search Results
Washington County Power, LLC

Table C-1. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - NO_x

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel	Throughput	Throughput Units	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
PANDA SHERMAN POWER STATION	PANDA SHERMAN POWER LLC	GRAYSON	TX	2/3/2010	A combined-cycle power plant producing a nominal 600 MW with two Siemens SGT6-5000F (501F) or two GE 7FA gas turbines.	State permit 87225	Natural Gas-fired Turbines	16.210	Natural Gas	600	MW	2 Siemens SGT6-5000F or 2 GE Frame 7FA. Both capable of combined or simple cycle operation. 468 MMBtu/hr duct burners.	Nitrogen Oxides (NOx)	Dry low NOx combustors and Selective Catalytic Reduction	9.00	PPMVD	@ 15% O ₂ , ROLLING 24-HR AVG, SIMPLE CYCLE
DAHLBERG COMBUSTION TURBINE ELECTRIC GENERATING FACILITY	SOUTHERN POWER COMPANY	JACKSON	GA	5/14/2010	PLANT DAHLBERG HAS PROPOSED TO CONSTRUCT AND OPERATE FOUR ADDITIONAL SIMPLE-CYCLE COMBUSTION TURBINES (SOURCE CODES: CT11-CT14) AND ONE FUEL OIL STORAGE TANK. THE PROPOSED PROJECT WILL HAVE A NOMINAL GENERATING CAPACITY OF 760 MW. THE FACILITY IS CURRENTLY PERMITTED TO OPERATE 10 DUAL-FUELED SIMPLE-CYCLE CTG's. AFTER THE EXPANSION, THE FACILITY WILL HAVE A TOTAL NOMINAL GENERATING CAPACITY OF 1530 MW.		SIMPLE CYCLE COMBUSTION TURBINE - ELECTRIC GENERATING PLANT	15.110	NATURAL GASE	1,530	MW	THE PROCESS USES FUEL OIL FOR BACKUP AT THE RATE OF 2129 MMBUT/H	Nitrogen Oxides (NOx)	DRY LOW NOX BURNERS (FIRING NATURAL GAS), WATER INJECTION (FIRING FUEL OIL).	9.00	PPM@15%O ₂	3 HOUR AVERAGE/CONDITION 3.3.23
DAHLBERG COMBUSTION TURBINE ELECTRIC GENERATING FACILITY	SOUTHERN POWER COMPANY	JACKSON	GA	5/14/2010	PLANT DAHLBERG HAS PROPOSED TO CONSTRUCT AND OPERATE FOUR ADDITIONAL SIMPLE-CYCLE COMBUSTION TURBINES (SOURCE CODES: CT11-CT14) AND ONE FUEL OIL STORAGE TANK. THE PROPOSED PROJECT WILL HAVE A NOMINAL GENERATING CAPACITY OF 760 MW. THE FACILITY IS CURRENTLY PERMITTED TO OPERATE 10 DUAL-FUELED SIMPLE-CYCLE CTG's. AFTER THE EXPANSION, THE FACILITY WILL HAVE A TOTAL NOMINAL GENERATING CAPACITY OF 1530 MW.		SIMPLE CYCLE COMBUSTION TURBINE - ELECTRIC GENERATING PLANT	15.110	NATURAL GASE	1,530	MW	THE PROCESS USES FUEL OIL FOR BACKUP AT THE RATE OF 2129 MMBUT/H	Nitrogen Oxides (NOx)	DRY LOW NOx BURNERS (FIRING NATURAL GAS), WATER INJECTION (FIRING FUEL OIL).	297.00	T/YR	12 CONSECUTIVE MONTH AVERAGE /CONDITION
PUEBLO AIRPORT GENERATING STATION	BLACK HILLS ELECTRIC GENERATION, LLC	PUEBLO	CO	7/22/2010	Combustion turbine power plant	New power plant consisting of 7 combustion turbines	Three simple cycle combustion turbines	15.110	natural gas	800	MMBTU/H	Three GE, LMS100PA, natural gas-fired, simple cycle CTG rated at 799.7 MMBtu per hour each, based on HHV.	Nitrogen Oxides (NOx)	Good combustor design, Water Injection and Selective Catalytic Reduction (SCR)	5.00	PPMVD AT 15% O ₂	1-HR AVE
HOWARD DOWN STATION	VINELAND MUNICIPAL ELECTRIC UTILITY (VMEU)	CUMBERLAND	NJ	9/16/2010			SIMPLE CYCLE (NO WASTE HEAT RECOVERY)(25 MW)	15.110	NATURAL GAS	5,000	MMFT3/YR	THE PROCESS CONSISTS OF ONE NEW TRENT 60 SIMPLE CYCLE COMBUSTION TURBINE. THE TURBINE WILL GENERATE 64 MW OF ELECTRICITY USING NATURAL GAS AS A PRIMARY FUEL (UP TO 8760 HOURS PER YEAR), WITH A BACKUP FUEL OF ULTRA LOW SULFUR DIESEL FUEL (ULSD) WHICH CAN ONLY BE COMBUSTED FOR A MAXIMUM OF 500 HOURS PER YEAR AND ONLY DURING NATURAL GAS CURTAILMENT. THE MAXIMUM HEAT INPUT RATE WHILE COMBUSTING NATURAL GAS IS 590 MMBTU/HR AND THE MAXIMUM HEAT INPUT RATE WHILE COMBUSTING ULSD IS 568 MMBTU/HR. THE TURBINE WILL UTILIZE WATER INJECTION AND SELECTIVE CATALYTIC REDUCTION TO CONTROL NOX EMISSION AND A CATALYTIC OXIDIZER TO CONTROL CO AND VOC EMISSION.	Nitrogen Oxides (NOx)	THE TURBINE WILL UTILIZE WATER INJECTION AND SELECTIVE CATALYTIC REDUCTION (SCR) TO CONTROL NOX EMISSION AND USE CLEAN FUELS NATURAL GAS AND ULTRA LOW SULFUR DISTILLATE OIL TO MINIMIZE NOX EMISSIONS	2.50	PPMVD@15% O ₂	3HR ROLLING AVERAGE BASED ON 1-HR BLOCK
CUNNINGHAM POWER PLANT	SOUTHWESTERN PUBLIC SERVICE CO.	LEA	NM	5/2/2011	Electric steam generating facility providing commercial electric power using natural gas fired boilers and turbines.	Simple Cycle Combustion Turbines. Permit revises the NOx BACT ppmvd limit for turbines established in permit PSD-NM-622-M2 issued 2-10-97 because turbines have not been able to meet NOx BACT limits. No modification or change to mass emissions. Former NOx BACT was at 15 ppmvd w/out power augmentation (normal mode) and 25 ppmvd w/ power augmentation (see RBL ID NM-0028). Entry also clarifies the existing CO, SOx, and PM BACT.	Normal Mode (without Power Augmentation)	15.110	natural gas	-			Nitrogen Dioxide (NO2)	Dry Low NOx Burners Type K & Good Combustion Practice	21.00	PPMVD	HOURLY
CUNNINGHAM POWER PLANT	SOUTHWESTERN PUBLIC SERVICE CO.	LEA	NM	5/2/2011	Electric steam generating facility providing commercial electric power using natural gas fired boilers and turbines.	Simple Cycle Combustion Turbines. Permit revises the NOx BACT ppmvd limit for turbines established in permit PSD-NM-622-M2 issued 2-10-97 because turbines have not been able to meet NOx BACT limits. No modification or change to mass emissions. Former NOx BACT was at 15 ppmvd w/out power augmentation (normal mode) and 25 ppmvd w/ power augmentation (see RBL ID NM-0028). Entry also clarifies the existing CO, SOx, and PM BACT.	Power Augmentation	15.110	natural gas	-		Increase power output by lowering the outlet air temperature through water injection into the compressor.	Nitrogen Dioxide (NO2)	Dry Low NOx burners, Type K. Good Combustion Practices as defined in the permit.	30.00	PPMVD	HOURLY
CALCASIEU PLANT	ENTERGY GULF STATES LA LLC	CALCASIEU	LA	12/21/2011	320 MW POWER PLANT COMPRISED OF 2 NATURAL GAS-FIRED SIMPLE CYCLE COMBUSTION TURBINES.	APPLICATION ACCEPTED RECEIVED DATE = DATE OF ADMINISTRATIVE COMPLETENESS PSD TRIGGERED DUE TO RELAXATION OF A FEDERALLY-ENFORCEABLE CONDITION LIMITING POTENTIAL EMISSIONS BELOW MAJOR STATIONARY SOURCE THRESHOLDS.	TURBINE EXHAUST STACK NO. 1 & NO. 2	15.110	NATURAL GAS	1,900	MM BTU/H EACH		Nitrogen Oxides (NOx)	DRY LOW NOX COMBUSTORS	240.00	LB/H	HOURLY MAXIMUM
YORK GENERATION FACILITY	YORK PLANT HOLDINGS, LLC	YORK COUNTY	PA	3/1/2012	This plan approval will allow for the construction and temporary operation of two new combustion turbines at the facility.		COMBUSTION TURBINE, DUAL FUEL, T01 and T02 (2 Units)	15.900	Natural Gas	634	MMBTU/H	The combined number of hours of operation for both turbines shall not exceed 6000 hours per each consecutive 12-month period. The combined number of hours of distillate fuel oil firing for both turbines shall not exceed 1700 hours per each consecutive 12-month period. The liquid distillate fuel oil fired in the combustion turbines shall be ultra low sulfur kerosene - maximum sulfur content of 15 ppm or ultra low sulfur diesel (ULSD) - maximum sulfur content of 15 ppm (as defined in ASTM standard D975 Table 1). In addition to operational limits, air emissions will be minimized by Catalytic Oxidizer for CO control and Water injection followed by Selective Catalytic Reduction system utilizing aqueous ammonia for NOx control.	Nitrogen Oxides (NOx)	In addition to operational limitations, air emissions will be minimized by the following additional control equipment: a. Water injection followed by Selective Catalytic Reduction System (SCR) utilizing aqueous ammonia for NOx control; b. Catalytic oxidizer for CO control	2.50	PPMVD	BASED ON 3-HOUR AVERAGE, ROLLING BY 1-HR

Appendix C - RBL Search Results
Washington County Power, LLC

Table C-1. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - NO_x

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel	Throughput	Throughput Units	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
CEDAR BAYOU ELECTRIC GENERATION STATION	NRG TEXAS POWER	CHAMBERS	TX	9/12/2012	NRG is proposing to construct an additional electric power generation station at the existing site. The project will include two power blocks that can be operated in simple cycle or combined cycle modes. This entry is for the simple cycle operation. Each power block will contain a CTG with duct burners and HRSG. Three options were proposed: Siemens Model F5, GE7FA, and Mitsubishi Heavy Industry G Frame. The units will produce between 215-263 MW each.		Simple Cycle Combustion Turbines	15.110	Natural Gas	225	MW	The gas turbines will be one of three options: (1) Two Siemens Model F5 (SF5) CTGs each rated at nominal capability of 225 megawatts (MW). (2) Two General Electric Model 7FA (GE7FA) CTGs each rated at nominal capability of 215 MW. (3) Two Mitsubishi Heavy Industry G Frame (MH1501G) CTGs each rated at a nominal electric output of 263 MW.	Nitrogen Oxides (NOx)	DLN	9.00	PPM	3HR. ROLLING AVG.
PIO PICO ENERGY CENTER	PIO PICO ENERGY CENTER, LLC	OTAY MESA	CA	11/19/2012	CONSTRUCTION OF THREE GENERAL ELECTRIC (GE) LMS100 NATURAL GAS-FIRED COMBUSTION TURBINE-GENERATORS (CTGS) RATED AT 100 MW EACH. THE PROJECT WILL HAVE AN ELECTRICAL OUTPUT OF 300 MW.	NOTE: PERMIT ISSUED 11/19/2012. ENVIRONMENTAL APPEALS BOARD REMANDED THE PM BACT ANALYSIS TO REGION 9 ON 8/2/2013. FINAL PERMIT ISSUED ON 2/28/2014. ONE PETITION FILED IN 9TH CIRCUIT FEDERAL COURT CHALLENGING THE FINAL PERMIT DECISION. THIS LAWSUIT WAS DISMISSED ON 6/17/2014 IN RESPONSE TO PETITIONERS MOTION FOR VOLUNTARY DISMISSAL.	COMBUSTION TURBINES (NORMAL OPERATION)	15.110	NATURAL GAS	300	MW	Three simple cycle combustion turbine generators (CTG). Each CTG rated at 100 MW (nominal net).	Nitrogen Oxides (NOx)	WATER INJECTION, SCR	2.50	PPMVD	@15% O2, 1-HR AVG
PIO PICO ENERGY CENTER	PIO PICO ENERGY CENTER, LLC	OTAY MESA	CA	11/19/2012	CONSTRUCTION OF THREE GENERAL ELECTRIC (GE) LMS100 NATURAL GAS-FIRED COMBUSTION TURBINE-GENERATORS (CTGS) RATED AT 100 MW EACH. THE PROJECT WILL HAVE AN ELECTRICAL OUTPUT OF 300 MW.	NOTE: PERMIT ISSUED 11/19/2012. ENVIRONMENTAL APPEALS BOARD REMANDED THE PM BACT ANALYSIS TO REGION 9 ON 8/2/2013. FINAL PERMIT ISSUED ON 2/28/2014. ONE PETITION FILED IN 9TH CIRCUIT FEDERAL COURT CHALLENGING THE FINAL PERMIT DECISION. THIS LAWSUIT WAS DISMISSED ON 6/17/2014 IN RESPONSE TO PETITIONERS MOTION FOR VOLUNTARY DISMISSAL.	COMBUSTION TURBINES (STARTUP & SHUTDOWN PERIODS)	15.110	NATURAL GAS	300	MW	Three simple cycle combustion turbine generators (CTG). Each CTG rated at 100 MW (nominal net).	Nitrogen Oxides (NOx)	water injection and SCR system	22.50	LB/H	STARTUP EVENTS
R.M. HESKETT STATION	MONTANA-DAKOTA UTILITIES CO.	MORTON	ND	2/22/2013	Addition of a natural gas-fired turbine (Unit 3) to an existing coal-fired power plant. The turbine will be used for supplying peak power and is rated at 986 MMBtu/hr and 88 MWe at average site conditions.		Combustion Turbine	15.110	Natural gas	986	MMBTU/H	Turbine is a GE Model PG 7121 (7EA) used as a peaking unit.	Nitrogen Oxides (NOx)	Dry low-NOx combustion (DLN)	9.00	PPMVD @15% O2	4 H.R.A. WHEN > 50MWE AND > 0 DEGREES F
WESTAR ENERGY - EMPORIA ENERGY CENTER	WESTAR ENERGY	LYON	KS	3/18/2013	The Westar Energy - Emporia Energy Center (Source ID: 1110046) is a fossil fuel power generation facility located in Emporia, Kansas.	This PSD permit with tracking number C-10656 is a modification of PSD permits C-9132 (issued on 5/5/2011) and C-7072 (issued 4/17/2007).	GE LM6000PC SPRINT Simple cycle combustion turbine	15.110	Pipeline quality natural gas	405	MMBTU/hr		Nitrogen Oxides (NOx)	water injection	25.00	PPMVD	24-HR ROLLING AVE, CORRECTED TO 15% O2
WESTAR ENERGY - EMPORIA ENERGY CENTER	WESTAR ENERGY	LYON	KS	3/18/2013	The Westar Energy - Emporia Energy Center (Source ID: 1110046) is a fossil fuel power generation facility located in Emporia, Kansas.	This PSD permit with tracking number C-10656 is a modification of PSD permits C-9132 (issued on 5/5/2011) and C-7072 (issued 4/17/2007).	GE LM6000PC SPRINT Simple cycle combustion turbine	15.110	Pipeline quality natural gas	405	MMBTU/hr		Nitrogen Dioxide (NO2)	dry low NOx burners and fire only pipeline natural gas	9.00	PPMVD	24-HR ROLLING AVE, CORRECTED TO 15% O2
WESTAR ENERGY - EMPORIA ENERGY CENTER	WESTAR ENERGY	LYON	KS	3/18/2013	The Westar Energy - Emporia Energy Center (Source ID: 1110046) is a fossil fuel power generation facility located in Emporia, Kansas.	This PSD permit with tracking number C-10656 is a modification of PSD permits C-9132 (issued on 5/5/2011) and C-7072 (issued 4/17/2007).	GE 7FA Simple Cycle Combustion Turbine	15.110	Pipeline quality natural gas	1,780	MMBTU/HR		Nitrogen Oxides (NOx)	dry low NOx burners and fire only pipeline natural gas	9.00	PPMVD	24-HR ROLLING AVE, CORRECTED TO 15% O2
ECTOR COUNTY ENERGY CENTER	INVENERGY THERMAL DEVELOPMENT LLC	ECTOR	TX	5/13/2013	The proposed project is for two natural gas fired simple cycle CTGs. The proposed models include GE7FA.03 and GE7FA.05. They have an output of 165-193 MW. The new CTGs will operate as peaking units and will be limited to 2500 hours per year of operation each.		Simple Cycle Combustion Turbines	15.110	natural gas	180	MW		Nitrogen Oxides (NOx)	Dry low NOx combustor	9.00	PPMVD	15%O2, 3HR ROLLING BASIS
PIONEER GENERATING STATION	BASIN ELECTRIC POWER COOPERATIVE	WILLIAMS	ND	5/14/2013	Three GE LM6000 PC SPRINT natural gas fired turbines used to generate electricity for peak periods.	The permit was for the addition of 2 turbines to the station. Since a synthetic minor limit was relaxed for the first unit, BACT was required for all three turbines.	Natural gas-fired turbines	15.110	Natural gas	451	MMBTU/H	Rating is for each turbine.	Nitrogen Oxides (NOx)	Water injection plus SCR	5.00	PPMVD	4 HR. ROLLING AVERAGE EXCEPT FOR STARTUP
LONESOME CREEK GENERATING STATION	BASIN ELECTRIC POWER COOP.	MCKENZIE	ND	9/16/2013	Three natural gas fired simple cycle turbines used to generate electricity for peak power demand. The turbines are GE LM6000 PF Sprint units with a nominal capacity of 45 MW each.		Natural Gas Fired Simple Cycle Turbines	15.110	Natural gas	412	MMBTU/H	The heat input is for a single unit.	Nitrogen Oxides (NOx)	SCR	5.00	PPMVD	4 HOUR ROLLING AVERAGE EXCEPT STARTUP
GUADALUPE GENERATING STATION	GUADALUPE POWER PARTNERS LP	GUADALUPE	TX	10/4/2013	Installing two natural gas-fired simple-cycle peaking combustion turbine generators. The two CTGs will produce between 383 and 454 MW combined. Four models are approved: GE7FA.03, GE7FA.04, GE7FA.05, or Siemens SW 5000F5.		(2) simple cycle turbines	16.110	natural gas	190	MW	Four models are approved: GE7FA.03, GE7FA.04, GE7FA.05, or Siemens SW 5000F5. 383 MW to 454 MW total plant capacity.	Nitrogen Oxides (NOx)	DLN burners, limited operation	9.00	PPMVD	@15% O2, 3 HOUR ROLLING AVG
RENAISSANCE POWER LLC	LS POWER DEVELOPMENT LLC	MONTCALM	MI	11/1/2013	For technical questions regarding this permit, please contact the permit engineer, Melissa Byrnes, at 517-284-6790. Thank you.	Other facility-wide pollutants not listed below (tpy): PM10=211.19+ PM2.5=205.24+ Lead=0.0027+ CO2e=5,398,441+ Sulfuric Acid Mist=5.67+	FG-CTG1-4 Natural gas fueled combined cycle combustion turbine generators (CTG)	15.210	Natural gas	2,147	MMBTU/H	FG-CTG1-4: Four natural gas fired CTGs with each turbine containing a heat recovery steam generator (HRSG) to operate in combined cycle. Two CTGs (with HRSGs) are connected to one steam turbine generator. Each CTG is equipped with a dry low NOx (DLN) burner, a selective catalytic reduction (SCR) system, and a catalytic oxidation system. The throughput capacity is 2,147 MMBtu/hr for each CTG. The turbines are existing simple cycle turbines that will be retrofitted to be combined cycle units.	Nitrogen Oxides (NOx)	Dry Low NOx burners (DLN) and Selective Catalytic Reduction (SCR) system.	2.00	PPMVD	3-H ROLL AVG., EXCEPT STARTUP/SHUTDOWN
RENAISSANCE POWER LLC	LS POWER DEVELOPMENT LLC	MONTCALM	MI	11/1/2013	For technical questions regarding this permit, please contact the permit engineer, Melissa Byrnes, at 517-284-6790. Thank you.	Other facility-wide pollutants not listed below (tpy): PM10=211.19+ PM2.5=205.24+ Lead=0.0027+ CO2e=5,398,441+ Sulfuric Acid Mist=5.67+	FG-CTG/DB1-4 Natural gas fueled combined cycle combustion turbine generators; duct burner on HRSG	15.210	Natural gas	2,807	MMBTU/H	Four natural gas-fired CTGs with each turbine containing a heat recovery steam generator (HRSG) to operate in combined cycle. The two CTGs (with HRSGs) are connected to one steam turbine generator. Each CTG is equipped with a dry low NOx (DLN) burner and a selective catalytic reduction (SCR) system, and a catalytic oxidation system. Additionally, the HRSG is operated with a natural gas fired duct burner during supplemental firing. The turbines are existing simple cycle turbines which will be retrofitted to be combined cycle. Operational restriction is 4000 hrs/year that each DB can operate.	Nitrogen Oxides (NOx)	Dry low NOx burner (DLN) and selective catalytic reduction system (SCR).	2.00	PPMVD	3-H ROLL AVG., EXCEPT STARTUP/SHUTDOWN

Appendix C - RBL Search Results
Washington County Power, LLC

Table C-1. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - NO_x

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel	Throughput	Throughput Units	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
RENAISSANCE POWER LLC	LS POWER DEVELOPMENT LLC	MONTCALM	MI	11/1/2013	For technical questions regarding this permit, please contact the permit engineer, Melissa Byrnes, at 517-284-6790. Thank you.	Other facility-wide pollutants not listed below (tpy): PM10=211.19+ PM2.5=205.24+ Lead=0.0027+ CO2e=5,398,441+ Sulfuric Acid Mist=5.67+	FG-CTG1-4 Startup/Shutdown	15.210	Natural gas	2,147	MMBTU/H	Four natural gas-fired CTGs operating in startup/shutdown mode.	Nitrogen Oxides (NO _x)	Dry low NO _x burners (DLN) and selective catalytic reduction (SCR) system.	176.90	PPH	EACH CTG W/O DB; HR LIMIT DURING STARTUP
TROUTDALE ENERGY CENTER, LLC	TROUTDALE ENERGY CENTER, LLC	MULTNOMAH	OR	3/5/2014	Troutdale Energy Center (TEC) proposes to construct and operate a 653 megawatt (MW) electric generating plant in Troutdale, Oregon. TEC proposes to generate electricity with three natural gas-fired turbines, one of which will be a combined-cycle unit with duct burner and heat recovery steam generator.		GE LMS-100 combustion turbines, simple cycle with water injection	15.110	natural gas	1,690	MMBTU/H		Nitrogen Oxides (NO _x)	Utilize water injection when combusting natural gas or ULSD; Utilize selective catalytic reduction (SCR) with aqueous ammonia injection at all times except during startup and shutdown; Limit the time in startup or shutdown.	2.50	PPMDV AT 15% O ₂	3-HR ROLLING AVERAGE ON NG
TROUTDALE ENERGY CENTER, LLC	TROUTDALE ENERGY CENTER, LLC	MULTNOMAH	OR	3/5/2014	Troutdale Energy Center (TEC) proposes to construct and operate a 653 megawatt (MW) electric generating plant in Troutdale, Oregon. TEC proposes to generate electricity with three natural gas-fired turbines, one of which will be a combined-cycle unit with duct burner and heat recovery steam generator.		GE LMS-100 combustion turbines, simple cycle with water injection	15.110	natural gas	1,690	MMBTU/H		Nitrogen Oxides (NO _x)	Utilize water injection when combusting natural gas or ULSD; Utilize selective catalytic reduction (SCR) with aqueous ammonia injection at all times except during startup and shutdown; Limit the time in startup or shutdown.	2.50	PPMDV AT 15% O ₂	3-HR ROLLING AVERAGE ON NG
LAUDERDALE PLANT	FLORIDA POWER & LIGHT	BROWARD	FL	4/22/2014	Large natural gas- and oil-fired power facility, consisting of four combined cycle units, and many combustion turbines. Small peaking units being replaced with larger combustion turbines.	In this project, 24 peaking turbines from the Lauderdale facility are being replaced with five 200 MW combustion turbines at Lauderdale. The turbines will fire primarily natural gas, but may also fire ULSD fuel oil. Triggers PSD for NO _x , PM, CO, VOC, and GHG. GHG permit issued by US EPA Region 4. Technical evaluation available at http://arm-permit2k.dep.state.fl.us/nontv/0110037.011.A.C.D.ZIP	Five 200-MW combustion turbines	15.110	Natural gas	2,000	MMBtu/hr (approx)	Throughput could vary slightly (+/- 120 MMBtu/hr) depending on final selection of turbine model and firing of natural gas or oil. Primary fuel is expected to be gas. Each turbine limited to 3300 hrs per rolling 12-month period. Of these 3300 hrs, no more than 500 may use ULSD fuel oil.	Nitrogen Oxides (NO _x)	Required to employ dry low-NO _x technology and wet injection. Water injection must be used when firing ULSD.	9.00	PPMVD @ 15% O ₂	24-HR BLOCK AVG. BY CEMS (NAT GAS)
ANTELOPE ELK ENERGY CENTER	GOLDEN SPREAD ELECTRIC COOPERATIVE, INC.	HALE	TX	4/22/2014	GSEC is proposing to build three additional new CTGs at the existing Antelope Elk Energy Center. The new facility will provide primarily peaking and intermediate power needs. The new units will be GE 7F5-Series gas turbines in simple cycle application, rated at 202 MW. Each turbine will operate a maximum of 4,572 hours per year.		Combustion Turbine-Generator(CTG)	15.110	Natural Gas	202	MW	Simple Cycle	Nitrogen Oxides (NO _x)	DLN	9.00	PPM	15% O ₂ , 3 HR. ROLLING AVG.
ANTELOPE ELK ENERGY CENTER	GOLDEN SPREAD ELECTRIC COOPERATIVE INC	HALE	TX	4/22/2014	Golden Spread Electric Cooperative (GSEC) currently owns and operates Antelope Station (now renamed Antelope Elk Energy Center), a 168 MW generating facility made up of 18 quick start Wärtsilä engines. GSEC is proposing to build a new combustion turbine-generator (CTG) facility at Antelope Station, while the 18 Wärtsilä engines will remain and continue to be authorized by TCEQ Standard Permit. The new turbine-generator will provide primarily peaking and intermediate power needs in a highly cyclical operation. The CTG will produce approximately 100 - 200 MW of electricity, depending on loading and ambient temperature.		combustion turbine	15.110	natural gas	202	MW	new GE 7FA 5-Series gas turbine in a simple cycle application, with a maximum electric output of 202 megawatts (MW) and a maximum design capacity of 1,941 million British thermal units per hour (MMBtu/hr). The turbine will operate a maximum of 4,572 hours per year.	Nitrogen Oxides (NO _x)	DLN combustors	9.00	PPMVD	@15% O ₂ , 3-HR ROLLING AVERAGE
ECTOR COUNTY ENERGY CENTER	INVENERGY THERMAL DEVELOPMENT LLC	ECTOR	TX	8/1/2014	The proposed project is to construct and operate two natural gas-fired simple-cycle combustion turbine generators (CTGs) at the Ector County Energy Center (ECEC), located approximately 20 miles northwest of Odessa, Texas, in Ector County.		(2) combustion turbines	15.110	natural gas	180	MW	(2) GE 7FA.03, 2500 hours of operation per year each	Nitrogen Oxides (NO _x)	DLN combustors	9.00	PPMVD	@15% O ₂ , 3-HR ROLLING AVG
ROANOK'S PRAIRIE GENERATING STATION	TENASKA ROANOK'S PRAIRIE PARTNERS (TRPP), LLC	GRIMES	TX	9/22/2014	The proposed project is to construct and operate the RPPGS comprised of three new simple cycle combustion turbine generators (CTG), fueled by pipeline quality natural gas. The new CTGs will be peaking units, designed to operate during periods of high electric demand. The three CTGs will produce between 507 and 694 MW of electricity combined, depending on ambient temperature and the model of combustion turbine (CT) selected. The applicant is considering three models of CTs; one model will be selected and the permit revised to reflect the selection before construction begins. The three CT models are: (1) General Electric 7FA.04; (2) General Electric 7FA.05; or (3) Siemens SGT6- 5000F.		(2) simple cycle turbines	15.110	natural gas	600	MW	The three possible CT models are: (1) General Electric 7FA.04; (2) General Electric 7FA.05; or (3) Siemens SGT6- 5000F. will operate 2,920 hours per year at full load for each CT	Nitrogen Oxides (NO _x)	DLN combustors	9.00	PPMVD	@15% O ₂ , 3-HR ROLLING AVG
PUEBLO AIRPORT GENERATING STATION	BLACK HILLS ELECTRIC GENERATION, LLC	PUEBLO	CO	12/11/2014	Electric generation	Permit modification to convert startup and shutdown BACT limits to an hourly basis (from event based).	Turbines - two simple cycle gas	15.110	natural gas	800	MMBTU/H each	GE LMS100PA, natural gas fired, simple cycle, combustion turbine.	Nitrogen Oxides (NO _x)	SCR and dry low NO _x burners	23.00	LB/H	1-HR AVE / STARTUP AND SHUTDOWN
SR BERTRON ELECTRIC GENERATION STATION	NRG TEXAS POWER	HARRIS	TX	12/19/2014	NRG is proposing to construct an additional electric power generation station at the existing site. The project will include two power blocks that can be operated in simple cycle or combined cycle modes. This entry is for the simple cycle operation. Each power block will contain a CTG with duct burners and HRSG. Three options were proposed: Siemens Model F5, GE7Fa, and Mitsubishi Heavy Industry G Frame. The new units will produce between 215-263 MW each.		Simple cycle natural gas turbines	15.110	Natural Gas	225	MW		Nitrogen Oxides (NO _x)	DLN	9.00	PPM	3HR ROLLING AVG.
INDECK WHARTON ENERGY CENTER	INDECK WHARTON, L.L.C.	WHARTON	TX	2/2/2015	Indeck Wharton, L.L.C. proposes to install three new natural gas fired combustion turbine generators (CTGs). The CTGs will either be the General Electric 7FA (~214 MW each) or the Siemens SGT6-5000F (~227 MW each), operating as peaking units in simple cycle mode.		(3) combustion turbines	15.110	natural gas	220	MW	The CTGs will either be the General Electric 7FA (~214 MW each) or the Siemens SGT6-5000F (~227 MW each), operating as peaking units in simple cycle mode	Nitrogen Oxides (NO _x)	DLN combustors	9.00	PPMVD	@15% O ₂ , 3-HR ROLLING AVERAGE

Appendix C - RBL Search Results
Washington County Power, LLC

Table C-1. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - NO_x

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel	Throughput	Throughput Units	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
CLEAR SPRINGS ENERGY CENTER (CSEC)	NAVASOTA SOUTH PEAKERS OPERATING COMPANY II, LLC.	GUADALUPE	TX	5/8/2015	Navasota South Peakers Operating Company II LLC. proposes to install three new natural gas fired combustion turbine generators (CTGs). The CTGs will be the General Electric 7FA.04 (~214 MW each; manufacturer's output at baseload, ISO at 183 MW), operating as peaking units in simple cycle.		Simple Cycle Turbine	15.110	natural gas	183	MW	The CTGs will be three General Electric 7FA.04 (~183 MW each for a total of 550 MW), operating as peaking units in simple cycle mode. Each turbine will be limited to 2,500 hours of operation per year. The new CTGs will use dry low-NO _x (DLN) burners and may employ evaporative cooling for power enhancement.	Nitrogen Oxides (NO _x)	dry low-NO _x (DLN) burners	9.00	PPMVD @ 15% O ₂	3-HR AVERAGE
ANTELOPE ELK ENERGY CENTER	GOLDEN SPREAD ELECTRIC COOPERATIVE, INC.	HALE	TX	5/12/2015	Golden Spread Electric Cooperative, Inc. (GSEC) is requesting authorization for three additional simple cycle electric generating plants at an existing site to meet increased energy demand in the area. The generating equipment consists of three new GE 7F5-Series natural gas-fired combustion turbine generators (CTGs). Each turbine has a maximum electric output of 202 MW.		Simple Cycle Turbine & Generator	15.110	natural gas	202	MW	3 additional GE 7F 5-Series Combustion Turbine Generators	Nitrogen Oxides (NO _x)	Dry Low NO _x burners	9.00	PPMVD AT 15% O ₂	
ROLLING HILLS GENERATING, LLC		VINTON	OH	5/20/2015	Electrical services	Note: The proposed modification was not installed. Chapter 31 major modification to convert four of the existing five simple cycle peaking units, SW501F turbines nominally rated at 209 megawatts (MW) each, to combined cycle configuration consisting of two 2x1 combined cycle blocks, the addition of four heat recovery steam generators (HRSGs), each of which will be equipped with duct burners, and two steam turbine generators. Permit includes 2 options for the units. Siemens Westinghouse Power Corp. SW501F, (Scenario 1: 200 MW, with 2022 MMBtu/hr input & 550 MMBtu/hr duct burner. Scenario 2: 207.5 MW with 2144 MMBtu/hr input & 550 MMBtu/hr duct burner.) combined cycle natural gas fired turbine with Dry Low-NO _x combusters, SCR and duct burner. Emissions increase noted below is for scenario 1. Scenario 2 = 5101.7 CO, 449.31 NO _x , 346.8 PM and 600.62 VOC.	Combustion Turbines, Scenario 1 (4, identical) (P001, P002, P004, P005)	15.210	Natural gas	2,022	MMBTU/H	Scenario 1 only. Other scenario added as separate process. Siemens Westinghouse Power Corp. SW501F, (Scenario 1: 200 MW, with 2022 MMBtu/hr input & 550 MMBtu/hr duct burner. Scenario 2: 207.5 MW with 2144 MMBtu/hr input & 550 MMBtu/hr duct burner.) combined cycle natural gas fired turbine with Dry Low-NO _x combusters, SCR and duct burner.	Nitrogen Oxides (NO _x)	dry-low NO _x (DLN) burner and selective catalytic reduction (SCR)	14.70	LB/H	WITHOUT DUCT BURNERS. SEE NOTES.
ROLLING HILLS GENERATING, LLC		VINTON	OH	5/20/2015	Electrical services	Note: The proposed modification was not installed. Chapter 31 major modification to convert four of the existing five simple cycle peaking units, SW501F turbines nominally rated at 209 megawatts (MW) each, to combined cycle configuration consisting of two 2x1 combined cycle blocks, the addition of four heat recovery steam generators (HRSGs), each of which will be equipped with duct burners, and two steam turbine generators. Permit includes 2 options for the units. Siemens Westinghouse Power Corp. SW501F, (Scenario 1: 200 MW, with 2022 MMBtu/hr input & 550 MMBtu/hr duct burner. Scenario 2: 207.5 MW with 2144 MMBtu/hr input & 550 MMBtu/hr duct burner.) combined cycle natural gas fired turbine with Dry Low-NO _x combusters, SCR and duct burner. Emissions increase noted below is for scenario 1. Scenario 2 = 5101.7 CO, 449.31 NO _x , 346.8 PM and 600.62 VOC.	Combustion Turbines, Scenario 2 (4, identical) (P001, P002, P004, P005)	15.210	Natural gas	2,144	MMBTU/H	Scenario 1 only. Other scenario added as separate process. Siemens Westinghouse Power Corp. SW501F, (Scenario 1: 200 MW, with 2022 MMBtu/hr input & 550 MMBtu/hr duct burner. Scenario 2: 207.5 MW with 2144 MMBtu/hr input & 550 MMBtu/hr duct burner.) combined cycle natural gas fired turbine with Dry Low-NO _x combusters, SCR and duct burner.	Nitrogen Oxides (NO _x)	dry-low NO _x (DLN) burner and selective catalytic reduction (SCR)	15.60	LB/H	WITHOUT DUCT BURNERS. SEE NOTES.
LAUDERDALE PLANT	FLORIDA POWER & LIGHT	BROWARD	FL	8/25/2015	Large natural gas- and oil-fired power facility, consisting of four combined cycle units, and many combustion turbines. Small peaking units being replaced with larger combustion turbines.	Re-affirmed BACT determinations in Permit No. 0110037-011-AC. Also, new GHG BACT determination. Technical evaluation available at https://arm-permit2k.dep.state.fl.us/nontv/0110037.013.AC.D.ZIP	Five 200-MW combustion turbines	15.110	Natural gas	2,100	MMBTU/hr (approx)	Five simple cycle GE 7F.05 turbines. Max of 3390 hours per year per turbine. Of the 3390 hours per year, up to 500 hour may be on ULSD fuel oil.	Nitrogen Oxides (NO _x)	Dry-low-NO _x combustion system. Wet injection when firing ULSD.	9.00	PPMVD@15% O ₂	24-HR BLOCK AVERAGE
PORT MYERS PLANT	FLORIDA POWER & LIGHT (FPL)	LEE	FL	9/10/2015	Electric power plant, consists of a 6-on-2 combined-cycle unit (Units 2A through 2F) and two modern simple-cycle combustion turbines. Primary fuel is natural gas. Also includes 12 gas turbines (63 MW each) for peaking, introduced into service in 1974. This project entails decommissioning 10 of the 12 peaking turbines. They will be replaced with two new GE 7F.05 turbines, each with nominal capacity of 200 MW	Technical evaluation available at https://arm-permit2k.dep.state.fl.us/nontv/0710002.022.AC.D.ZIP	Combustion Turbines	15.110	Natural gas	2,262	MMBTU/hr gas	Two GE 7F.05 turbines, approximately 200 MW each. Natural-gas is primary fuel. Permitted 3390 hr/yr of operation, of which no more than 500 hr may be on fuel oil. Dry Low-NO _x , with wet injection for oil firing.	Nitrogen Oxides (NO _x)	DLN and wet injection (for ULSD operation)	9.00	PPMVD@15% O ₂	GAS FIRING, 24-HR BLOCK AVG
SHAWNEE ENERGY CENTER	SHAWNEE ENERGY CENTER, LLC	HILL	TX	10/9/2015	Electric Generating Utility: The project will consist of four gas fired combustion turbines (CTGs). The CTGs are fueled with pipeline quality natural gas and will operate in simple cycle mode. The gas turbines will be one of two options.		Simple cycle turbines greater than 25 megawatts (MW)	15.110	natural gas	230	MW	Siemens Model SGT6-5000 F5ee & 230 MW or Second turbine option: General Electric Model 7FA.05TP & 227 MW	Nitrogen Oxides (NO _x)	Dry Low NO _x burners	9.00	PPMVD @ 15% O ₂	
NACOGDOCHES POWER ELECTRIC GENERATING PLANT	NACOGDOCHES POWER, LLC	NACOGDOCHES	TX	10/14/2015	Nacogdoches Power, LLC is requesting authorization for one natural gas fired, simple cycle combustion turbine generator (CTG). The CTG will be a Siemens F5 and have a nominal electric output of 232 megawatts (MW).		Natural Gas Simple Cycle Turbine (>25 MW)	15.110	natural gas	232	MW	One Siemens F5 simple cycle combustion turbine generator	Nitrogen Oxides (NO _x)	Dry Low NO _x burners, good combustion practices, limited operations	9.00	PPMVD @ 15% O ₂	
VAN ALSTYNE ENERGY CENTER (VAEC)	NAVASOTA NORTH COUNTRY PEAKERS OPERATING COMPANY I	GRAYSON	TX	10/27/2015	Navasota North Country Peakers Operating Company I LLC. proposes to install three new natural gas fired combustion turbine generators (CTGs). The CTGs will be the General Electric 7FA.04 (~214 MW each; manufacturer's output at baseload, ISO at 183 MW), operating as peaking units in simple cycle.		Simple Cycle Turbine	15.110	natural gas	183	MW	The CTGs will be three General Electric 7FA.04 (~183 MW each for a total of 550 MW), operating as peaking units in simple cycle mode. Each turbine will be limited to 2,500 hours of operation per year. The new CTGs will use dry low-NO _x (DLN) burners and may employ evaporative cooling for power enhancement.	Nitrogen Oxides (NO _x)	DLN burners	9.00	PPMVD @ 15% O ₂	3-HR AVERAGE
UNION VALLEY ENERGY CENTER	NAVASOTA SOUTH PEAKERS OPERATING COMPANY I, LLC.	NIXON	TX	12/9/2015	three new natural gas fired combustion turbine generators (CTGs). The CTGs will be the General Electric 7FA.04 (~214 megawatt (MW) each; manufacturer's output at baseload, ISO at 183 MW), operating as peaking units in simple cycle		Simple Cycle Turbine	15.110	natural gas	183	MW	The CTGs will be three General Electric 7FA.04 (~183 MW each for a total of 550 MW), operating as peaking units in simple cycle mode. Each turbine will be limited to 2,500 hours of operation per year. The new CTGs will use dry low-NO _x (DLN) burners and may employ evaporative cooling for power enhancement.	Nitrogen Oxides (NO _x)	dry low NO _x burners	9.00	PPMVD @ 15% O ₂	3-HR ROLLING AVERAGE PEAK

Appendix C - RBL Search Results
Washington County Power, LLC

Table C-1. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - NO_x

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel	Throughput	Throughput Units	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
DECORDOVA STEAM ELECTRIC STATION	DECORDOVA II POWER COMPANY LLC	HOOD	TX	3/8/2016	The DeCordova Station will consist of two combustion turbine generators (CTGs) operating in simple cycle or combined cycle modes. The gas turbines will be one of two options: Siemens or General Electric.		Combined Cycle & Cogeneration	15.210	natural gas	231	MW	2 CTGs to operate in simple cycle & combined cycle modes. 231 MW (Siemens) or 210 MW (GE). Simple cycle operations limited to 2,500 hr/yr.	Nitrogen Oxides (NOx)	Selective Catalytic Reduction	2.00	PPM	
NECHES STATION	APEX TEXAS POWER LLC	CHEROKEE	TX	3/24/2016	either 4 simple cycle combustion turbine generators (CTGs) or two CTGs operating in simple cycle or combined cycle modes. The CTGs will be one of two options: Siemens or General Electric.		Large Combustion Turbines > 25 MW	15.110	natural gas	232	MW	4 Simple cycle CTGs, 2,500 hr/yr operational limitation. Facility will consist of either 232 MW (Siemens) or 220 MW (GE)	Nitrogen Oxides (NOx)	Dry low-NOx burners (DLN), good combustion practices	9.00	PPM	
NECHES STATION	APEX TEXAS POWER LLC	CHEROKEE	TX	3/24/2016	either 4 simple cycle combustion turbine generators (CTGs) or two CTGs operating in simple cycle or combined cycle modes. The CTGs will be one of two options: Siemens or General Electric.		Combined Cycle & Cogeneration	15.210	natural gas	231	MW	2 CTGs to operate in simple cycle & combined cycle modes. 231 MW (Siemens) or 210 MW (GE) Simple cycle operations limited to 2,500 hr/yr.	Nitrogen Oxides (NOx)	Selective Catalytic Reduction	2.00	PPM	
HILL COUNTY GENERATING FACILITY	BRAZOS ELECTRIC COOPERATIVE	HILL	TX	4/7/2016	Four simple cycle combustion turbine electric generators are proposed. Natural gas or ultra-low sulfur diesel fuel oil are the fuels. Turbine model options are: General Electric (GE) 7FA.03, GE 7FA.04, GE 7FA.05, and Siemes SGT6-5000(5)ee. Electric output is between 684 and 928 megawatts (MW).		Simple cycle turbine	15.110	natural gas	171	MW	Each combustion turbine is limited to 2,920 hours of annual operation, including startup and shutdown hours.	Nitrogen Oxides (NOx)	Emission controls consist of dry low-NOx combustors (DLN). DLN combustors use two stages of combustion, transitioning from initial startup with fuel and flame in the primary nozzles only, through a lean lean stage with fuel and flame in the primary and secondary nozzles, to fuel in the secondary stage only, extinguishing the primary flame, and in full operation, premix mode, with fuel to both nozzles, but flame only in the second stage. When natural gas and air are well-mixed before combustion, the flame temperature and resulting NOx emissions are greatly reduced compared to conventional diffusion flame combustion.	9.00	PPMVD @ 15% O2	3-HR ROLLING AVERAGE
HILL COUNTY GENERATING FACILITY	BRAZOS ELECTRIC COOPERATIVE	HILL	TX	4/7/2016	Four simple cycle combustion turbine electric generators are proposed. Natural gas or ultra-low sulfur diesel fuel oil are the fuels. Turbine model options are: General Electric (GE) 7FA.03, GE 7FA.04, GE 7FA.05, and Siemes SGT6-5000(5)ee. Electric output is between 684 and 928 megawatts (MW).		Simple cycle turbine	15.110	natural gas	171	MW	Each combustion turbine is limited to 2,920 hours of annual operation, including startup and shutdown hours.	Nitrogen Oxides (NOx)	Emission controls consist of dry low-NOx combustors (DLN). DLN combustors use two stages of combustion, transitioning from initial startup with fuel and flame in the primary nozzles only, through a lean lean stage with fuel and flame in the primary and secondary nozzles, to fuel in the secondary stage only, extinguishing the primary flame, and in full operation, premix mode, with fuel to both nozzles, but flame only in the second stage. When natural gas and air are well-mixed before combustion, the flame temperature and resulting NOx emissions are greatly reduced compared to conventional diffusion flame combustion.	9.00	PPMVD @ 15% O2	3-HR ROLLING AVERAGE
BAYONNNE ENERGY CENTER	BAYONNNE ENERGY CENTER LLC	HUDSON	NJ	8/26/2016	Facility consists of 8 existing Roll Royce Trent 60 WLE (64 MW) each. The facility is adding two more new Roll Royce Trent 60 WLE (66 MW) each	The facility has eight existing simple cycle combustion turbines Rolls Royce Trent turbine 64 MW each. This permit allows the construction and operation of two more Rolls Royce Trent (WLE) simple cycle combustion turbines 66 MW each. The turbines will be dual fired, with natural gas as primary fuel and ultra low sulfur distillate oil with less than or equal to 15% sulfur by weight. The turbines will have SCR and Oxidation catalyst for removal of NOx, CO and VOC.	Simple Cycle Stationary Turbines firing Natural gas	15.110	Natural Gas	2,143,980	MMBTU/YR	The Siemens/Rolls Royce Trent 60 wet low emissions (WLE) combustion turbine generators (CTGs) will each have a maximum heat input rate while combusting natural gas of 643 million British thermal units per hour (MMBtu/hr) (higher heating value [HHV]) at 100 percent (%) load, at International Organization for Standardization (ISO) conditions of 59 degrees Fahrenheit (°F) and 60% relative humidity, generating 66 MW. The maximum heat input rate on ULSD at ISO condition would be 533.50 MMBtu/hr (HHV). Each of the CTG will be equipped with Water Injection and Selective Catalytic Reduction System (SCR) to control Nitrogen Oxide (NOx) emissions and Oxidation Catalyst to control Carbon Monoxide (CO) and Volatile Organic Compounds (VOC) emissions. The CTGs will have continuous emissions monitoring systems (CEMS) for NOx and CO.	Nitrogen Oxides (NOx)	Selective Catalytic Reduction, water injection, use of natural gas a low NOx emitting fuel	2.50	PPMVD@15% O2	3 H ROLLING AV BASED ON ONE H BLOCK AV
INVENERGY NELSON EXPANSION LLC	INVENERGY	LEE	IL	9/27/2016	Peaking facility at an existing major source. The expansion will consist of two simple cycle combustion turbines and a fuel heater.		Two Simple Cycle Combustion Turbines	15.110	Natural Gas	190	MW	Two simple cycle combustion turbines used for peaking purposes and fired primarily on natural gas with ULSD as a secondary fuel.	Nitrogen Oxides (NOx)	Dry low-NOx combustion technology for natural gas and low-NOx combustion technology and water injection for ULSD.	0.03	LB/MMBTU	

Appendix C - RBLC Search Results
Washington County Power, LLC

Table C-1. RBLC Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - NO_x

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel	Throughput	Throughput Units	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
DOSWELL ENERGY CENTER	DOSWELL LIMITED PARTNERSHIP DOSWELL ENERGY CENTER	HANAOVER	VA	10/4/2016	The facility is currently composed of four Kraftwerk Union/Siemens (Model: V84.2) combined cycle turbine units each equipped with a duct burner and supporting equipment (auxiliary boiler, fire pump, emergency generator and fuel oil storage tanks) under one Prevention of Significant Deterioration (PSD) permit and one simple cycle turbine unit under another PSD permit. The combined cycle turbines were permitted in a PSD permit originally issued on May 4, 1990 and last amended on August 3, 2005. The 190.5 MW simple cycle combustion turbine (CT-1) was added in a separate PSD permit dated April 7, 2000 and last amended on September 30, 2013.	DEC is proposing to add two GE 7FA simple cycle combustion turbines (CT-2 and CT-3) at the Doswell Energy Center. DEC is moving CT-2 and CT-3 from an existing permitted site in Desoto, Florida. They are both GE Frame 7FA Combustion Turbines that are very similar in age and capability to the DEC CT-1 (GE 7FA.03). The CT-2 and CT-3 maximum heat input assumed for natural gas firing is 1,961.0 MMBtu/hr (HHV).	Two (2) GE 7FA simple cycle combustion turbines	15.110	Natural Gas	1,961	MMBTU/HR		Nitrogen Oxides (NOx)	Low NOx Burners/Combustion Technology	9.00	PPM	VD/12 MO ROLLING TOTAL
PUENTE POWER		VENTURA	CA	10/13/2016	Utility		Gas turbine	15.110	Natural gas	262	MW		Nitrogen Oxides (NOx)		2.50	PPMVD	1 HOUR@15%O2
WAVERLY FACILITY	PLEASANTS ENERGY, LLC	PLEASANTS	WV	1/23/2017	300 MW, natural gas fired, simple cycle peaking power facility	In this permitting action PSD only applies to the modified combustion turbines based on the relaxation of an original synthetic minor permit issued in 1999. Project also involves previous installation of turbo-charging. All BACT emission limits are given without turbocharging and startup/shutdown emissions are not included. Please contact above engineer for more information. There are two identical turbines but only one is listed.	GE Model 7FA Turbine	15.110	Natural Gas	1,571	mmbtu/hr	There are two identical units at the facility.	Nitrogen Oxides (NOx)	Dry Low-NOx Combustion System (DLNB), Water Injection	9.00	PPM	NATURAL GAS
CAMERON LNG FACILITY	CAMERON LNG LLC	CAMERON	LA	2/17/2017	a facility to liquefy natural gas for export (5 trains)	Permit PSD-LA-766, dated 10/1/13 for liquefaction trains 1,2, and 3 Permit PSD-LA-766(M1), dated 6/26/14, for minor changes; Permit PSD-LA-766(M2), dated 3/3/16, for train 4 and 5	Gas turbines (9 units)	15.110	natural gas	1,069	mm btu/hr		Nitrogen Oxides (NOx)	good combustion practices and dry low nox burners	15.00	PPMVD	@15%O2
GAINES COUNTY POWER PLANT	SOUTHWESTERN PUBLIC SERVICE COMPANY		TX	4/28/2017	constructed in phases, with natural gas-fired simple cycle combustion turbines (SCCTs) with dry low nitrogen oxide (NOx) burners (DLN) to be converted into 2-on-1 combined cycle combustion turbines (CCCTs) with selective catalytic reduction (SCRs), heat recovery steam generators (HRSGs, one per combustion turbine) and one steam turbine per two CCCTs. Federal control review only applies to the turbines and HRSGs.		Simple Cycle Turbine	15.110	natural gas	228	MW	Four Siemens SGT6-5000F5 natural gas fired combustion turbines	Nitrogen Oxides (NOx)	Dry Low NOx burners (control), natural gas, good combustion practices, limited operating hours (prevention)	9.00	PPMV	15% O2 3-H AVG
MUSTANG STATION	GOLDEN SPREAD ELECTRIC COOPERATIVE, INC.	YOAKUM	TX	8/16/2017	GE7FA combustion turbine (Unit 6) to increase the hours of operation to 3000 hours per year. The turbine construction was completed the first quarter of 2013 and initial firing began on April 1, 2013.		Simple Cycle Turbine	15.110	NATURAL GAS	163	MW	Unit 6 Turbine is limited to 3000 hours per year.	Nitrogen Oxides (NOx)	Dry low-NOx burners	9.00	PPMVD	
JACKSON COUNTY GENERATORS	SOUTHERN POWER	JACKSON	TX	1/26/2018	four natural gas-fired simple-cycle combustion turbines, five fuel gas heaters, and a firewater pump engine		Combustion Turbines	15.110	natural gas	920	MW	4 identical units, each limited to 2500 hours of operation per year	Nitrogen Oxides (NOx)	Dry low NOx burners	9.00	PPMVD	
JACKSON COUNTY GENERATORS	SOUTHERN POWER	JACKSON	TX	1/26/2018	four natural gas-fired simple-cycle combustion turbines, five fuel gas heaters, and a firewater pump engine		Combustion Turbines MSS	15.110	NATURAL GAS	-			Nitrogen Oxides (NOx)	Minimizing duration of startup/shutdown, using good air pollution control practices and safe operating practices.	0.01	TON/YR	
WAVERLY POWER PLANT	PLEASANTS ENERGY LLC	PLEASANTS	WV	3/13/2018	300 MW Simple-Cycle Peaking Plant	Modification to existing PSD Permit (R14-0034, RBLC Number WV-0027) to add "advanced gas path" technology to the turbines that was defined as a "change in the method of operation"; that resulted a major modification to the turbines.	GE 7FA.004 Turbine	15.110	Natural Gas	168	MW	This one entry is for both turbines as they are the same. Each turbine, after this modification, is a nominal 167.8 MW GE Model 7FA.004. Has oil-fire backup.	Nitrogen Oxides (NOx)	Dry LNB	69.00	LB/HR	
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WSHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG01 CO - Simple-Cycle Combustion Turbine 1 (Commissioning) [SCN0005]	15.110	Natural Gas	2,201	MM BTU/hr	Commissioning is a one-time event which occurs after construction and is not anticipated to exceed 180 days.	Nitrogen Oxides (NOx)	Pipeline quality natural gas & dry-low-NOX burners	240.00	LB/HR	HOURLY MAXIMUM
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WSHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG02 CO - Simple-Cycle Combustion Turbine 2 (Commissioning) [SCN0006]	15.110	natural gas	2,201	MM BTU/hr	Commissioning is a one-time event which occurs after construction and is not anticipated to exceed 180 days.	Nitrogen Oxides (NOx)	Pipeline quality natural gas & dry-low-NOX burners	240.00	LB/HR	HOURLY MAXIMUM
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WSHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG01 SUSD - Simple-Cycle Combustion Turbine 1 (Startup/Shutdown/Maintenance/Tuning/Runback) [EQT0019]	15.110	Natural Gas	2,201	MM BTU/hr	Limited to 600 hr/yr	Nitrogen Oxides (NOx)	Pipeline quality natural gas & dry-low-NOX burners	86.38	LB/HR	HOURLY MAXIMUM
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WSHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG02 SUSD - Simple-Cycle Combustion Turbine 2 (Startup/Shutdown/Maintenance/Tuning/Runback) [EQT0020]	15.110	Natural Gas	2,201	MM BTU/hr	limited to 600 hr/yr	Nitrogen Oxides (NOx)	Pipeline quality natural gas & dry-low-NOX burners	86.38	LB/HR	HOURLY MAXIMUM
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WSHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG01 NO - Simple-Cycle Combustion Turbine 1 (Normal Operations) [EQT0017]	15.110	Natural Gas	2,201	MM BTU/hr	Normal operations are based on 7000 hrs/yr	Nitrogen Oxides (NOx)	Pipeline quality natural gas & dry-low-NOX burners	9.00	PPMVD @15%O2	30-DAY ROLLING AVERAGE
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WSHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG02 NO - Simple-Cycle Combustion Turbine 2 (Normal Operations) [EQT0018]	15.110	Natural Gas	2,201	MM BTU/hr	Normal operations are based on 7000 hours per year	Nitrogen Oxides (NOx)	Pipeline quality natural gas & dry-low-NOX burners	9.00	PPMVD @15%O2	30-DAY ROLLING AVERAGE
DRIFTWOOD LNG FACILITY	DRIFTWOOD LNG LLC	CALCASIEU	LA	7/10/2018	Propose a new facility to liquefy natural gas for export		Compressor Turbines (20)	15.110	natural gas	540	mm btu/hr		Nitrogen Oxides (NOx)	DLN and SCR	5.00	PPMVD	@ 15% O2
CALCASIEU PASS LNG PROJECT	VENTURE GLOBAL CALCASIEU PASS, LLC	CAMERON	LA	9/21/2018	New Liquefied Natural Gas (LNG) production, storage, and export terminal.	Application Received September 2, 2015.	Simple Cycle Combustion Turbines (SCCT1 to SCCT3)	15.110	Natural Gas	927	MM BTU/h		Nitrogen Oxides (NOx)	Dry Low NOx Combustor Design, Good Combustion Practices, and Natural Gas Combustion.	9.00	PPMV	30 DAY ROLLING AVERAGE

Table C-1. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - NO_x

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel	Throughput	Throughput Units	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
RIO BRAVO PIPELINE FACILITY	RIO GRANDE LNG LLC	CAMERON	TX	12/17/2018	Natural gas processing and liquefied natural gas (LNG) export terminal		Refrigeration Compression Turbines	15.110	NATL GAS	967	MMBTU/HR	Twelve General Electric Frame 7EA simple cycle combustion turbines to serve as drivers for refrigeration and compression at the site. There are six process trains and there are two turbines per train. One each of the pairs of turbines has a downstream heat exchanger in the exhaust stream. The heat exchanger heats oil in a closed circuit for process uses elsewhere in the natural gas liquefaction system.	Nitrogen Oxides (NO _x)	Dry Low NO _x burners. Good combustion practices	9.00	PPMVD	15% O ₂
LBWL-ERICKSON STATION	LANSING BOARD OF WATER AND LIGHT	EATON	MI	12/21/2018	Natural gas combined-cycle power plant.	The proposed new plant will be replacing the electrical generating capacity of both BWL's existing coal-fired power plants. BWL intends to retire those coal-fired power plants from service by 2025. However, before they can be retired, the new natural gas power plant must be operational. Emissions in the area will increase for a short period if the new combined-cycle plant is built. However, there will be overall reductions in emissions when the existing coal fired power plants are taken out of service.	EUCTGHRSG2-A 667 MMBTU/H natural gas fired CTG with a HRSG.	15.210	Natural gas	667	MMBTU/H	EUCTGHRSG2 is a nominally rated 667 MMBTU/H natural gas fired CTG coupled with a HRSG. The HRSG is equipped with a natural gas fired duct burner rated at 204 MMBTU/h to provide heat for additional steam production. The CTG is capable of operating in combined-cycle mode where the exhaust is routed to the HRSG or in simple-cycle mode where the HRSG is bypassed. The HRSG is not capable of operating independently from the CTG. The CTG/HRSG is equipped with a DLNB, SCR and oxidation catalyst.	Nitrogen Oxides (NO _x)	Dry low NO _x burners and selective catalytic reduction for NO _x control.	3.00	PPM	PPMVD@15%O ₂ ; 24-HR AVG; SEE NOTES
LBWL-ERICKSON STATION	LANSING BOARD OF WATER AND LIGHT	EATON	MI	12/21/2018	Natural gas combined-cycle power plant.	The proposed new plant will be replacing the electrical generating capacity of both BWL's existing coal-fired power plants. BWL intends to retire those coal-fired power plants from service by 2025. However, before they can be retired, the new natural gas power plant must be operational. Emissions in the area will increase for a short period if the new combined-cycle plant is built. However, there will be overall reductions in emissions when the existing coal fired power plants are taken out of service.	EUCTGSC1-A nominally rated 667 MMBTU/hr natural gas-fired simple cycle CTG	15.110	Natural gas	667	MMBTU/H	A nominally rated 667 MMBTU/H natural gas-fired simple cycle CTG. The CTG will utilize DLNB and good combustion practices.	Nitrogen Oxides (NO _x)	Dry low NO _x burners (DLNB) and good combustion practices.	25.00	PPM	AT 15%O ₂ ;4-HR ROLL AVG; SEE NOTES BELOW
LBWL-ERICKSON STATION	LANSING BOARD OF WATER AND LIGHT	EATON	MI	12/21/2018	Natural gas combined-cycle power plant.	The proposed new plant will be replacing the electrical generating capacity of both BWL's existing coal-fired power plants. BWL intends to retire those coal-fired power plants from service by 2025. However, before they can be retired, the new natural gas power plant must be operational. Emissions in the area will increase for a short period if the new combined-cycle plant is built. However, there will be overall reductions in emissions when the existing coal fired power plants are taken out of service.	EUCTGHRSG1-A 667 MMBTU/H NG fired combustion turbine generator coupled with a heat recovery steam generator (HRSG)	15.210	Natural gas	667	MMBTU/H	A nominally rated 667 MMBTU/hr natural gas-fired combustion turbine generator (CTG) coupled with a heat recovery steam generator (HRSG). The HRSG is equipped with a natural gas-fired duct burner rated at 204 MMBTU/hr to provide heat for additional steam production. The CTG is capable of operating in combined-cycle mode where the exhaust is routed to the HRSG or in simple-cycle mode where the HRSG is bypassed. The HRSG is not capable of operating independently from the CTG. The CTG/HRSG is equipped with a dry low NO _x burner (DLNB), selective catalytic reduction (SCR) and oxidation catalyst.	Nitrogen Oxides (NO _x)	Dry low NO _x burners and selective catalytic reduction for NO _x control.	3.00	PPM	PPMVD@15%O ₂ ; 24-HR ROLL AVG; SEE NOTES
SABINE PASS LNG TERMINAL	SABINE PASS LNG LP AND SABINE PASS LIQUEFACTION LL	CAMERON	LA	9/6/2019	a terminal to import lng and liquefy/export natural gas Modification to add startup, shutdown, maintenance scenarios		gas turbines during startups, shutdowns, and maintenance	15.110	natural gas	-		during startups, shutdowns, and maintenance	Nitrogen Oxides (NO _x)	good combustion practices	96.00	PPMV	@ 15% O ₂
GAS TREATMENT PLANT	ALASKA GASLINE DEVELOPMENT CORPORATION	NORTH SLOPE BOROUGH	AK	8/13/2020	The Gas Treatment Plant (GTP) is part of one integrated liquefied natural gas (LNG) project to bring natural gas from Alaska's North Slope to international markets in the form of LNG, as well as for in-state deliveries in the form of natural gas. The GTP will take gas from the Prudhoe Bay Unit and the Point Thomson Unit and treat/process the gas, before it is sent 807 miles through a 42-inch diameter pipeline to a liquefaction facility in Nikiski on Alaska's Kenai Peninsula for export in foreign commerce. The emissions units at the stationary source will include cogeneration gas-fired turbines with supplemental firing duct burners for gas compression, simple cycle gas-fired turbines for power generation, gas-fired heaters for building and process heat, as well as flares for control of excess gas. In addition, the GTP will include a diesel-fired black start generator, several diesel-fired firewater pumps and emergency generators, and storage tanks for diesel and gasoline fuels.		Six (6) Simple Cycle Gas-Turbines (Power Generation)	15.110	Natural Gas	386	MMBTU/hr	EUs 25 -30 each provide 44 MW of power generation for the facility	Nitrogen Oxides (NO _x)	DLN combustors and Good Combustion Practices	15.00	PPMV @ 15% O ₂	3-HOUR AVERAGE
ECTOR COUNTY ENERGY CENTER	ECTOR COUNTY ENERGY CENTER LLC	ECTOR	TX	8/17/2020	increase the hours of operation for the two simple cycle gas turbines		Simple Cycle Turbines	15.110	natural gas	-			Nitrogen Oxides (NO _x)	Equipped with dry-low NO _x burners with best management practices and good combustion practices. Minimize the duration of startup and shutdown events to less than 60 minutes per event. Limit MSS by 140 lb/hr maximum allowable emission rate for each turbine.	9.00	PPMVD	3% O ₂ 3 HR AVG

Appendix C - RBL Search Results
Washington County Power, LLC

Table C-2. RBL Search Results for Large Fuel Oil Fired Turbines (Simple-Cycle) - NO_x

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel	Throughput	Throughput Units	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
WOLVERINE POWER	WOLVERINE POWER SUPPLY COOPERATIVE, INC.	PRESQUE ISLE	MI	6/29/2011	Coal-fired power plant.		Turbine generator (EUBLACKSTART)	15.190	Diesel	540	MMBTU/H	This is a turbine generator identified in the permit as EUBLACKSTART. It has a throughput capacity of 540MMBTU/HR which equates to 102 MW. The maximum operation was based on 500 hours per year.	Nitrogen Oxides (NO _x)		0.16	LB/MMBTU	TEST PROTOCOL
HILL COUNTY GENERATING FACILITY	BRAZOS ELECTRIC COOPERATIVE	HILL	TX	4/7/2016	Four simple cycle combustion turbine electric generators are proposed. Natural gas or ultra-low sulfur diesel fuel oil are the fuels. Turbine model options are: General Electric (GE) 7FA.03, GE 7FA.04, GE 7FA.05, and Siemes SGT6-5000(5)jee. Electric output is between 684 and 928 megawatts (MW).		Simple Cycle Turbine	15.190	ULTRA LOW SULFUR DIESEL	171	MW	LIQUID FUEL ONLY USED AS BACKUP TO NATURAL GAS Each combustion turbine is limited to 624,000 million Btu of annual firing because these are peaking units. Emission control firing ULSD adds water injection.	Nitrogen Oxides (NO _x)	DLN, WATER INJECTION	42.00	PPMVD @ 15% O ₂	3-HR ROLLING AVERAGE

RBLC SEARCH RESULTS – PM

Appendix C - RBL Search Results
Washington County Power, LLC

Table C-3. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - PM

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
DAHLBERG COMBUSTION TURBINE ELECTRIC GENERATING FACILITY (P)	SOUTHERN POWER COMPANY	JACKSON	GA	5/14/2010	PLANT DAHLBERG HAS PROPOSED TO CONSTRUCT AND OPERATE FOUR ADDITIONAL SIMPLE-CYCLE COMBUSTION TURBINES (SOURCE CODES: CT11-CT14) AND ONE FUEL OIL STORAGE TANK. THE PROPOSED PROJECT WILL HAVE A NOMINAL GENERATING CAPACITY OF 760 MW. THE FACILITY IS CURRENTLY PERMITTED TO OPERATE 10 DUAL-FUELED SIMPLE-CYCLE CTG'S. AFTER THE EXPANSION, THE FACILITY WILL HAVE A TOTAL NOMINAL GENERATING CAPACITY OF 1530 MW.		SIMPLE CYCLE COMBUSTION TURBINE - ELECTRIC GENERATING PLANT	15.110	Natural Gas	1530	MW	THE PROCESS USES FUEL OIL FOR BACKUP AT THE RATE OF 2129 MMBTU/H	Particulate matter, total PM10 (TPM10)	GOOD COMBUSTION PRACTICES PIPELINE QUALITY NATURAL GAS, ULTRA LOW SULFUR DISTILLATE FUEL	9.1	LB/H	3 HOUR AVERAGE/CONDITION 3.3.23
PUEBLO AIRPORT GENERATING STATION	BLACK HILLS ELECTRIC GENERATION, LLC	PUEBLO	CO	7/22/2010	Combustion turbine power plant	New power plant consisting of 7 combustion turbines	Three simple cycle combustion turbines	15.110	Natural Gas	799.7	MMBTU/H	Three GE, LMS100PA, natural gas-fired, simple cycle CTG rated at 799.7 MMBtu per hour each, based on HHV.	Particulate matter, total (TPM)	Use of pipeline quality natural gas and good combustor design	6.6	LB/H	AVE OVER STACK TEST LENGTH
PUEBLO AIRPORT GENERATING STATION	BLACK HILLS ELECTRIC GENERATION, LLC	PUEBLO	CO	7/22/2010	Combustion turbine power plant	New power plant consisting of 7 combustion turbines	Three simple cycle combustion turbines	15.110	Natural Gas	799.7	MMBTU/H	Three GE, LMS100PA, natural gas-fired, simple cycle CTG rated at 799.7 MMBtu per hour each, based on HHV.	Particulate matter, total PM10 (TPM10)	Use of pipeline quality natural gas and good combustor design	6.6	LB/H	AVE OVER STACK TEST LENGTH
HOWARD DOWN STATION	VINELAND MUNICIPAL ELECTRIC UTILITY (VMEU)	CUMBERLAND	NJ	9/16/2010			SIMPLE CYCLE (NO WASTE HEAT RECOVERY)(25 MW)	15.110	Natural Gas	5000	MMFT3/YR	THE PROCESS CONSISTS OF ONE NEW TRENT 60 SIMPLE CYCLE COMBUSTION TURBINE. THE TURBINE WILL GENERATE 64 MW OF ELECTRICITY USING NATURAL GAS AS A PRIMARY FUEL (UP TO 8760 HOURS PER YEAR), WITH A BACKUP FUEL OF ULTRA LOW SULFUR DIESEL FUEL (ULSD) WHICH CAN ONLY BE COMBUSTED FOR A MAXIMUM OF 500 HOURS PER YEAR AND ONLY DURING NATURAL GAS CURTAILMENT. THE MAXIMUM HEAT INPUT RATE WHILE COMBUSTING NATURAL GAS IS 590 MMBTU/HR AND THE MAXIMUM HEAT INPUT RATE WHILE COMBUSTING ULSD IS 568 MMBTU/HR. THE TURBINE WILL UTILIZE WATER INJECTION AND SELECTIVE CATALYTIC REDUCTION TO CONTROL NOX EMISSION AND A CATALYTIC OXIDIZER TO CONTROL CO AND VOC EMISSION.	Particulate matter, filterable PM10 (FPM10)	USE OF CLEAN BURNING FUELS; NATURAL GAS AS PRIMARY FUEL AND ULTRA LOW SULFUR DISTILLATE OIL WITH 15 PPM Sulfur BY WEIGHT AS BACKUP FUEL	5	LB/H	AVERAGE OF THREE TESTS
HOWARD DOWN STATION	VINELAND MUNICIPAL ELECTRIC UTILITY (VMEU)	CUMBERLAND	NJ	9/16/2010			SIMPLE CYCLE (NO WASTE HEAT RECOVERY)(25 MW)	15.110	Natural Gas	5000	MMFT3/YR	THE PROCESS CONSISTS OF ONE NEW TRENT 60 SIMPLE CYCLE COMBUSTION TURBINE. THE TURBINE WILL GENERATE 64 MW OF ELECTRICITY USING NATURAL GAS AS A PRIMARY FUEL (UP TO 8760 HOURS PER YEAR), WITH A BACKUP FUEL OF ULTRA LOW SULFUR DIESEL FUEL (ULSD) WHICH CAN ONLY BE COMBUSTED FOR A MAXIMUM OF 500 HOURS PER YEAR AND ONLY DURING NATURAL GAS CURTAILMENT. THE MAXIMUM HEAT INPUT RATE WHILE COMBUSTING NATURAL GAS IS 590 MMBTU/HR AND THE MAXIMUM HEAT INPUT RATE WHILE COMBUSTING ULSD IS 568 MMBTU/HR. THE TURBINE WILL UTILIZE WATER INJECTION AND SELECTIVE CATALYTIC REDUCTION TO CONTROL NOX EMISSION AND A CATALYTIC OXIDIZER TO CONTROL CO AND VOC EMISSION.	Particulate matter, filterable PM2.5 (FPM2.5)	USE OF CLEAN BURNING FUELS; NATURAL GAS AS PRIMARY FUEL AND ULTRA LOW SULFUR DISTILLATE OIL WITH 15 PPM Sulfur BY WEIGHT AS BACKUP FUEL	5	LB/H	AVERAGE OF THREE TESTS
PSEG FOSSIL LLC KEARNY GENERATING STATION	PSEG FOSSIL LLC	HUDSON	NJ	10/27/2010	PSEG FOSSIL LLC KEARNY GENERATING STATION IS AN EXISTING ELECTRICITY GENERATING STATION.	This project consists of six new identical General Electric LM6000 sprint simple cycle combustion turbines burning natural gas. Each turbine will have a heat input rate of 485 million British thermal units per hour (MMBtu/hr) based on the high heating value of fuel (HHV). The combined maximum electricity generated by the six turbines will be 294 MW based on 2,978 hours of operation per turbine per year. All six new turbines will have water injection along with Selective Catalytic Reduction (SCR) systems to reduce Nitrogen Oxide (NOx) emissions and an oxidation catalyst to reduce Carbon Monoxide (CO) emissions	SIMPLE CYCLE TURBINE	15.110	Natural Gas	8940000	MMBTU/year (HHV)	Throughput <= 8.94x10^6 MMBtu/year (HHV) combined for all six gas turbines. The 6 turbines are identical LM6000 simple cycle combustion turbines.	Particulate matter, total PM10 (TPM10)	Good combustion practice, Use of Clean Burning Fuel: Natural gas	6	LB/H	AVERAGE OF THREE TESTS

Appendix C - RBL Search Results
Washington County Power, LLC

Table C-3. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - PM

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
PSEG FOSSIL LLC KEARNY GENERATING STATION	PSEG FOSSIL LLC	HUDSON	NJ	10/27/2010	PSEG FOSSIL LLC KEARNY GENERATING STATION IS AN EXISTING ELECTRICITY GENERATING STATION.	This project consists of six new identical General Electric LM6000 sprint simple cycle combustion turbines burning natural gas. Each turbine will have a heat input rate of 485 million British thermal units per hour (MMBtu/hr) based on the high heating value of fuel (HHV). The combined maximum electricity generated by the six turbines will be 294 MW based on 2,978 hours of operation per turbine per year. All six new turbines will have water injection along with Selective Catalytic Reduction (SCR) systems to reduce Nitrogen Oxide (NOx) emissions and an oxidation catalyst to reduce Carbon Monoxide (CO) emissions	SIMPLE CYCLE TURBINE	15.110	Natural Gas	8940000	MMBtu/year (HHV)	Throughput <= 8.94x10 ⁶ MMBtu/year (HHV) combined for all six gas turbines. The 6 turbines are identical LM6000 simple cycle combustion turbines.	Particulate matter, total PM2.5 (TPM2.5)	Good combustion practice, Use of Clean Burning Fuel: Natural gas	6	LB/H	AVERAGE OF THREE TESTS
PSEG FOSSIL LLC KEARNY GENERATING STATION	PSEG FOSSIL LLC	HUDSON	NJ	10/27/2010	PSEG FOSSIL LLC KEARNY GENERATING STATION IS AN EXISTING ELECTRICITY GENERATING STATION.	This project consists of six new identical General Electric LM6000 sprint simple cycle combustion turbines burning natural gas. Each turbine will have a heat input rate of 485 million British thermal units per hour (MMBtu/hr) based on the high heating value of fuel (HHV). The combined maximum electricity generated by the six turbines will be 294 MW based on 2,978 hours of operation per turbine per year. All six new turbines will have water injection along with Selective Catalytic Reduction (SCR) systems to reduce Nitrogen Oxide (NOx) emissions and an oxidation catalyst to reduce Carbon Monoxide (CO) emissions	SIMPLE CYCLE TURBINE	15.110	Natural Gas	8940000	MMBtu/year (HHV)	Throughput <= 8.94x10 ⁶ MMBtu/year (HHV) combined for all six gas turbines. The 6 turbines are identical LM6000 simple cycle combustion turbines.	Particulate matter, filterable (FPM)	Good combustion practice, Use of Clean Burning Fuel: Natural gas	6	LB/H	AVERAGE OF THREE TESTS
CUNNINGHAM POWER PLANT	SOUTHWESTERN PUBLIC SERVICE CO.	LEA	NM	5/2/2011	Electric steam generating facility providing commercial electric power using natural gas fired boilers and turbines.	Simple Cycle Combustion Turbines. Permit revises the NOx BACT ppmvd limit for turbines established in permit PSD-NM-622-M2 issued 2-10-97 because turbines have not been able to meet NOx BACT limits. No modification or change to mass emissions. Former NOx BACT was at 15 ppmvd w/out power augmentation (normal mode) and 25 ppmvd w/ power augmentation (see RBL ID NM-0028). Entry also clarifies the existing CO, SOx, and PM BACT.	Normal Mode (without Power Augmentation)	15.110	natural gas	0			Particulate matter, filterable PM10(FPM10)	Good combustion practices as defined in the permit.	5.4	LB/H	HOURLY
CUNNINGHAM POWER PLANT	SOUTHWESTERN PUBLIC SERVICE CO.	LEA	NM	5/2/2011	Electric steam generating facility providing commercial electric power using natural gas fired boilers and turbines.	Simple Cycle Combustion Turbines. Permit revises the NOx BACT ppmvd limit for turbines established in permit PSD-NM-622-M2 issued 2-10-97 because turbines have not been able to meet NOx BACT limits. No modification or change to mass emissions. Former NOx BACT was at 15 ppmvd w/out power augmentation (normal mode) and 25 ppmvd w/ power augmentation (see RBL ID NM-0028). Entry also clarifies the existing CO, SOx, and PM BACT.	Power Augmentation	15.110	natural gas	0		Increase power output by lowering the outlet air temperatur through water injectinos into the compressor.	Particulate matter, filterable PM10(FPM10)	Good combustion practices as defined in the permit.	5.4	LB/H	HOURLY
CALCASIEU PLANT	ENERGY GULF STATES LA LLC	CALCASIEU	LA	12/21/2011	320 MW POWER PLANT COMPRISED OF 2 NATURAL GAS-FIRED SIMPLE CYCLE COMBUSTION TURBINES.	APPLICATION ACCEPTED RECEIVED DATE = DATE OF ADMINISTRATIVE COMPLETENESS PSD TRIGGERED DUE TO RELAXATION OF A FEDERALLY-ENFORCEABLE CONDITION LIMITING POTENTIAL EMISSIONS BELOW MAJOR STATIONARY SOURCE THRESHOLDS.	TURBINE EXHAUST STACK NO. 1 NO. 2	15.110	Natural Gas	1900	MM BTU/H EACH		Particulate matter, total PM2.5 (TPM2.5)	USE OF PIPELINE NATURAL GAS	17	LB/H	HOURLY MAXIMUM
CALCASIEU PLANT	ENERGY GULF STATES LA LLC	CALCASIEU	LA	12/21/2011	320 MW POWER PLANT COMPRISED OF 2 NATURAL GAS-FIRED SIMPLE CYCLE COMBUSTION TURBINES.	APPLICATION ACCEPTED RECEIVED DATE = DATE OF ADMINISTRATIVE COMPLETENESS PSD TRIGGERED DUE TO RELAXATION OF A FEDERALLY-ENFORCEABLE CONDITION LIMITING POTENTIAL EMISSIONS BELOW MAJOR STATIONARY SOURCE THRESHOLDS.	TURBINE EXHAUST STACK NO. 1 NO. 2	15.110	Natural Gas	1900	MM BTU/H EACH		Particulate matter, total PM10 (TPM10)	USE OF PIPELINE NATURAL GAS	17	LB/H	HOURLY MAXIMUM
CEDAR BAYOU ELECTRIC GENERATION STATION	NRG TEXAS POWER	CHAMBERS	TX	9/12/2012	NRG is proposing to construct an additional electric power generation station at the existing site. The project will include two power blocks that can be operated in simple cycle or combined cycle modes. This entry is for the simple cycle operation. Each power block will contain a CTG with duct burners and HRSG. Three options were proposed: Siemens Model F5, GE7Fa, and Mitsubishi Heavy Industry G Frame. The units will produce between 215-263 MW each.		Simple Cycle Combustion Turbines	15.110	Natural Gas	225	MW	The gas turbines will be one of three options: (1) Two Siemens Model F5 (SF5) CTGs each rated at nominal capability of 225 megawatts (MW). (2) Two General Electric Model 7FA (GE7FA) CTGs each rated at nominal capability of 215 MW. (3) Two Mitsubishi Heavy Industry G Frame (MH501G) CTGs each rated at a nominal electric output of 263 MW.	Particulate matter, filterable PM2.5 (FPM2.5)	Good Combustion Practices, Natural Gas	0		

Appendix C - RBL Search Results
Washington County Power, LLC

Table C-3. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - PM

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
PIO PICO ENERGY CENTER	PIO PICO ENERGY CENTER, LLC	OTAY MESA	CA	11/19/2012	CONSTRUCTION OF THREE GENERAL ELECTRIC (GE) LMS100 NATURAL GAS-FIRED COMBUSTION TURBINE-GENERATORS (CTGS) RATED AT 100 MW EACH. THE PROJECT WILL HAVE AN ELECTRICAL OUTPUT OF 300 MW.	NOTE: PERMIT ISSUED 11/19/2012. ENVIRONMENTAL APPEALS BOARD REMANDED THE PM BACT ANALYSIS TO REGION 9 ON 8/2/2013. FINAL PERMIT ISSUED ON 2/28/2014. ONE PETITION FILED IN 9TH CIRCUIT FEDERAL COURT CHALLENGING THE FINAL PERMIT DECISION. THIS LAWSUIT WAS DISMISSED ON 6/17/2014 IN RESPONSE TO PETITIONERS MOTION FOR VOLUNTARY DISMISSAL.	COMBUSTION TURBINES (NORMAL OPERATION)	15.110	Natural Gas	300	MW	Three simple cycle combustion turbine generators (CTG). Each CTG rated at 100 MW (nominal net).	Particulate matter, total (TPM)	PUC-QUALITY NATURAL GAS	0.0065	LB/MMBTU (HHV)	AT LOADS OF 80% OR HIGHER
PIO PICO ENERGY CENTER	PIO PICO ENERGY CENTER, LLC	OTAY MESA	CA	11/19/2012	CONSTRUCTION OF THREE GENERAL ELECTRIC (GE) LMS100 NATURAL GAS-FIRED COMBUSTION TURBINE-GENERATORS (CTGS) RATED AT 100 MW EACH. THE PROJECT WILL HAVE AN ELECTRICAL OUTPUT OF 300 MW.	NOTE: PERMIT ISSUED 11/19/2012. ENVIRONMENTAL APPEALS BOARD REMANDED THE PM BACT ANALYSIS TO REGION 9 ON 8/2/2013. FINAL PERMIT ISSUED ON 2/28/2014. ONE PETITION FILED IN 9TH CIRCUIT FEDERAL COURT CHALLENGING THE FINAL PERMIT DECISION. THIS LAWSUIT WAS DISMISSED ON 6/17/2014 IN RESPONSE TO PETITIONERS MOTION FOR VOLUNTARY DISMISSAL.	COMBUSTION TURBINES (NORMAL OPERATION)	15.110	Natural Gas	300	MW	Three simple cycle combustion turbine generators (CTG). Each CTG rated at 100 MW (nominal net).	Particulate matter, total PM10 (TPM10)	PUC-QUALITY NATURAL GAS	0.0065	LB/MMBTU (HHV)	AT LOADS OF 80% OR HIGHER
PIO PICO ENERGY CENTER	PIO PICO ENERGY CENTER, LLC	OTAY MESA	CA	11/19/2012	CONSTRUCTION OF THREE GENERAL ELECTRIC (GE) LMS100 NATURAL GAS-FIRED COMBUSTION TURBINE-GENERATORS (CTGS) RATED AT 100 MW EACH. THE PROJECT WILL HAVE AN ELECTRICAL OUTPUT OF 300 MW.	NOTE: PERMIT ISSUED 11/19/2012. ENVIRONMENTAL APPEALS BOARD REMANDED THE PM BACT ANALYSIS TO REGION 9 ON 8/2/2013. FINAL PERMIT ISSUED ON 2/28/2014. ONE PETITION FILED IN 9TH CIRCUIT FEDERAL COURT CHALLENGING THE FINAL PERMIT DECISION. THIS LAWSUIT WAS DISMISSED ON 6/17/2014 IN RESPONSE TO PETITIONER MOTION FOR VOLUNTARY DISMISSAL.	COMBUSTION TURBINES (NORMAL OPERATION)	15.110	Natural Gas	300	MW	Three simple cycle combustion turbine generators (CTG). Each CTG rated at 100 MW (nominal net).	Particulate matter, filterable PM2.5 (FPM2.5)	PUC-QUALITY NATURAL GAS	0.0065	LB/MMBTU (HHV)	AT LOADS OF 80% OR HIGHER
R.M. HESKETT STATION	MONTANA-DAKOTA UTILITIES CO.	MORTON	ND	2/22/2013	Addition of a natural gas-fired turbine (Unit 3) to an existing coal-fired power plant. The turbine will be used for supplying peak power and is rated at 986 MMBtu/hr and 88 MWe at average site conditions.		Combustion Turbine	15.110	Natural Gas	986	MMBTU/H	Turbine is a GE Model PG 7121 (7EA) used as a peaking unit.	Particulate matter, total PM10 (TPM10)	Good combustion practices.	7.3	LB/H	AVERAGE OF THREE TEST RUNS
R.M. HESKETT STATION	MONTANA-DAKOTA UTILITIES CO.	MORTON	ND	2/22/2013	Addition of a natural gas-fired turbine (Unit 3) to an existing coal-fired power plant. The turbine will be used for supplying peak power and is rated at 986 MMBtu/hr and 88 MWe at average site conditions.		Combustion Turbine	15.110	Natural gas	986	MMBTU/H	Turbine is a GE Model PG 7121 (7EA) used as a peaking unit.	Particulate matter, total PM2.5 (TPM2.5)	Good combustion practices.	7.3	LB/H	AVERAGE OF THREE TEST RUNS
WESTAR ENERGY - EMPORIA ENERGY CENTER	WESTAR ENERGY	LYON	KS	3/18/2013	The Westar Energy - Emporia Energy Center (Source ID: 1110046) is a fossil fuel power generation facility located in Emporia, Kansas.	This PSD permit with tracking number C-10656 is a modification of PSD permits C-9132 (issued on 5/5/2011) and C-7072 (issued 4/17/2007).	GE LM6000PC SPRINT Simple cycle combustion turbine	15.110	Pipeline quality natural gas	405.3	MMBTU/hr		Particulate matter, total PM10 (TPM10)	fire only pipeline quality natural gas	6	LB/HR	AT FULL LOAD
WESTAR ENERGY - EMPORIA ENERGY CENTER	WESTAR ENERGY	LYON	KS	3/18/2013	The Westar Energy - Emporia Energy Center (Source ID: 1110046) is a fossil fuel power generation facility located in Emporia, Kansas.	This PSD permit with tracking number C-10656 is a modification of PSD permits C-9132 (issued on 5/5/2011) and C-7072 (issued 4/17/2007).	GE LM6000PC SPRINT Simple cycle combustion turbine	15.110	Pipeline quality natural gas	405.3	MMBTU/hr		Particulate matter, total (TPM)	fire only pipeline quality natural gas	6	LB/HR	AT FULL LOAD
WESTAR ENERGY - EMPORIA ENERGY CENTER	WESTAR ENERGY	LYON	KS	3/18/2013	The Westar Energy - Emporia Energy Center (Source ID: 1110046) is a fossil fuel power generation facility located in Emporia, Kansas.	This PSD permit with tracking number C-10656 is a modification of PSD permits C-9132 (issued on 5/5/2011) and C-7072 (issued 4/17/2007).	GE 7FA Simple Cycle Combustion Turbine	15.110	Pipeline quality natural gas	1780	MMBTU/HR		Particulate matter, total PM10 (TPM10)	will fire only pipeline quality natural gas	18	LB/HR	
WESTAR ENERGY - EMPORIA ENERGY CENTER	WESTAR ENERGY	LYON	KS	3/18/2013	The Westar Energy - Emporia Energy Center (Source ID: 1110046) is a fossil fuel power generation facility located in Emporia, Kansas.	This PSD permit with tracking number C-10656 is a modification of PSD permits C-9132 (issued on 5/5/2011) and C-7072 (issued 4/17/2007).	GE 7FA Simple Cycle Combustion Turbine	15.110	Pipeline quality natural gas	1780	MMBTU/HR		Particulate matter, total (TPM)	will fire only pipeline quality natural gas	18	LB/HR	
ECTOR COUNTY ENERGY CENTER	INVENERGY THERMAL DEVELOPMENT LLC	ECTOR	TX	5/13/2013	The proposed project is for two natural gas fired simple cycle CTGs. The proposed models include GE7Fa.03 and GE7Fa.05. They have an output of 165-193 MW. The new CTGs will operate as peaking units and will be limited to 2500 hours per year of operation each.		Simple Cycle Combustion Turbines	15.110	Natural Gas	180	MW		Particulate matter, total PM2.5 (TPM2.5)	Firing pipeline quality natural gas and good combustion practices	0		
PIONEER GENERATING STATION	BASIN ELECTRIC POWER COOPERATIVE	WILLIAMS	ND	5/14/2013	Three GE LM6000 PC SPRINT natural gas fired turbines used to generate electricity for peak periods.	The permit was for the addition of 2 turbines to the station. Since a synthetic minor limit was relaxed for the first unit, BACT was required for all three turbines.	Natural gas-fired turbines	15.110	Natural gas	451	MMBTU/H	Rating is for each turbine.	Particulate matter, total PM2.5 (TPM2.5)		5.4	LB/H	
ANCHORAGE MUNICIPAL LIGHT & POWER	MUNICIPALITY OF ANCHORAGE	MATANUSKA	AK	6/6/2013	Electric Utility	Authorized two natural gas turbines each rated at 408 MMBtu/hr, one ULSD Caterpillar generator rated at 2,000 ekW, and one cooling tower rated at 30,400 gallons per minute	Combustion	16.110	Natural Gas	408	MMBTU/H	Natural Gas-fired combustion turbine rated at 408.2 MMBtu/hr	Particulate matter, total PM2.5 (TPM2.5)	Good operation and combustion practices	0.0066	LB/MMBTU	

Appendix C - RBL Search Results
Washington County Power, LLC

Table C-3. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - PM

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
LONESOME CREEK GENERATING STATION	BASIN ELECTRIC POWER COOP.	MCKENZIE	ND	9/16/2013	Three natural gas fired simple cycle turbines used to generate electricity for peak power demand. The turbines are GE LM6000 PF Sprint units with a nominal capacity of 45 MW each.		Natural Gas Fired Simple Cycle Turbines	15.110	Natural gas	412	MMBTU/H	The heat input is for a single unit.	Particulate matter, total PM2.5 (TPM2.5)		5	LB/H	AVERAGE OF THREE TEST RUNS
GUADALUPE GENERATING STATION	GUADALUPE POWER PARTNERS LP	GUADALUPE	TX	10/4/2013	Installing two natural gas-fired simple-cycle peaking combustion turbine generators. The two CTGs will produce between 383 and 454 MW combined. Four models are approved: GE7FA.03, GE7FA.04, GE7FA.05, or Siemens SW 5000F5.		(2) simple cycle turbines	16.110	Natural Gas	190	MW	Four models are approved: GE7FA.03, GE7FA.04, GE7FA.05, or Siemens SW 5000F5. 383 MW to 454 MW total plant capacity.	Particulate matter, total PM2.5 (TPM2.5)	natural gas fuel	0		
TROUTDALE ENERGY CENTER, LLC	TROUTDALE ENERGY CENTER, LLC	MULTNOMAH	OR	3/5/2014	Troutdale Energy Center (TEC) proposes to construct and operate a 653 megawatt (MW) electric generating plant in Troutdale, Oregon. TEC proposes to generate electricity with three natural gas-fired turbines, one of which will be a combined-cycle unit with duct burner and heat recovery steam generator.		GE LMS-100 combustion turbines, simple cycle with water injection	15.110	Natural Gas	1690	MMBTU/H		Particulate matter, total PM10 (TPM10)	Utilize only natural gas or ULSD fuel; Limit the time in startup or shutdown.	9.1	LB/H TOTAL PM	6-HR AVERAGE ON NG
ANTELOPE ELK ENERGY CENTER	GOLDEN SPREAD ELECTRIC COOPERATIVE, INC.	HALE	TX	4/22/2014	GSEC is proposing to build three additional new CTGs at the existing Antelope Elk Energy Center. The new facility will provide primarily peaking and intermediate power needs. The new units will be GE 7F5-Series gas turbines in simple cycle application, rated at 202 MW. Each turbine will operate a maximum of 4,572 hours per year.		Combustion Turbine-Generator(CTG)	15.110	Natural Gas	202	MW	Simple Cycle	Particulate matter, filterable PM2.5 (FPM2.5)	Pipeline quality natural gas; limited hours; Good combustion practices	0		
ANTELOPE ELK ENERGY CENTER	GOLDEN SPREAD ELECTRIC COOPERATIVE INC	HALE	TX	4/22/2014	Golden Spread Electric Cooperative (GSEC) currently owns and operates Antelope Station (now renamed Antelope Elk Energy Center), a 168 MW generating facility made up of 18 quick start engines. GSEC is proposing to build a new combustion turbine-generator (CTG) facility at Antelope Station, while the 18 engines will remain and continue to be authorized by TCEQ Standard Permit. The new turbine-generator will provide primarily peaking and intermediate power needs in a highly cyclical operation. The CTG will produce approximately 100 - 200 MW of electricity, depending on loading and ambient temperature.		combustion turbine	15.110	Natural Gas	202	MW	new GE 7FA 5-Series gas turbine in a simple cycle application, with a maximum electric output of 202 megawatts (MW) and a maximum design capacity of 1,941 million British thermal units per hour (MMBtu/hr). The turbine will operate a maximum of 4,572 hours per year.	Particulate matter, total PM2.5 (TPM2.5)		0		
PUEBLO AIRPORT GENERATING STATION	BLACK HILLS ELECTRIC GENERATION, LLC	PUEBLO	CO	5/30/2014	Power generation facility		Turbine - simple cycle gas	15.110	Natural Gas	375	MMBTU/H	One (1) General Electric, simple cycle, gas turbine electric generator, Unit 6 (CT08), model: LM6000, SN: N/A, rated at 375 MMBtu per hour.	Particulate matter, total PM10 (TPM10)	Firing of pipeline quality natural gas as defined in 40 CFR Part 72. Specifically, the owner or the operator shall demonstrate that the natural gas burned has total sulfur content less than 0.5 grains/100 SCF.	4.8	LB/H	3-HR AVE
PUEBLO AIRPORT GENERATING STATION	BLACK HILLS ELECTRIC GENERATION, LLC	PUEBLO	CO	5/30/2014	Power generation facility		Turbine - simple cycle gas	15.110	Natural Gas	375	MMBTU/H	One (1) General Electric, simple cycle, gas turbine electric generator, Unit 6 (CT08), model: LM6000, SN: N/A, rated at 375 MMBtu per hour.	Particulate matter, total PM2.5 (TPM2.5)	Firing of pipeline quality natural gas as defined in 40 CFR Part 72. Specifically, the owner or the operator shall demonstrate that the natural gas burned has total sulfur content less than 0.5 grains/100 SCF.	4.8	LB/H	3-HR AVE
ECTOR COUNTY ENERGY CENTER	INVENERGY THERMAL DEVELOPMENT LLC	ECTOR	TX	8/1/2014	The proposed project is to construct and operate two natural gas-fired simple-cycle combustion turbine generators (CTGs) at the Ector County Energy Center (ECEC), located approximately 20 miles northwest of Odessa, Texas, in Ector County.		(2) combustion turbines	15.110	Natural Gas	180	MW	(2) GE 7FA.03, 2500 hours of operation per year each	Particulate matter, total PM2.5 (TPM2.5)		0		
ROANOK PRAIRIE GENERATING STATION	TENASKA ROANOK PRAIRIE PARTNERS (TRPP), LLC	GRIMES	TX	9/22/2014	The proposed project is to construct and operate the RPPS comprised of three new simple cycle combustion turbine generators (CTG), fueled by pipeline quality natural gas. The new CTGs will be peaking units, designed to operate during periods of high electric demand. The three CTGs will produce between 507 and 694 MW of electricity combined, depending on ambient temperature and the model of combustion turbine (CT) selected. The applicant is considering three models of CTs; one model will be selected and the permit revised to reflect the selection before construction begins. The three CT models are: (1) General Electric 7FA.04; (2) General Electric 7FA.05; or (3) Siemens SGT6-5000F.		(2) simple cycle turbines	15.110	Natural Gas	600	MW	The three possible CT models are: (1) General Electric 7FA.04; (2) General Electric 7FA.05; or (3) Siemens SGT6-5000F. will operate 2,920 hours per year at full load for each CT	Particulate matter, total PM2.5 (TPM2.5)		0		

Appendix C - RBL Search Results
Washington County Power, LLC

Table C-3. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - PM

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
SR BERTRON ELECTRIC GENERATION STATION	NRG TEXAS POWER	HARRIS	TX	12/19/2014	NRG is proposing to construct an additional electric power generation station at the existing site. The project will include two power blocks that can be operated in simple cycle or combined cycle modes. This entry is for the simple cycle operation. Each power block will contain a CTG with duct burners and HRSG. Three options were proposed: Siemens Model F5, GE7Fa, and Mitsubishi Heavy Industry G Frame. The new units will produce between 215-263 MW each.		Simple cycle natural gas turbines	15.110	Natural Gas	225	MW		Particulate matter, filterable PM2.5 (FPM2.5)	Good Combustion Practices, natural gas	0		
INDECK WHARTON ENERGY CENTER	INDECK WHARTON, L.L.C.	WHARTON	TX	2/2/2015	Indeck Wharton, L.L.C. proposes to install three new natural gas fired combustion turbine generators (CTGs). The CTGs will either be the General Electric 7FA (~214 MW each) or the Siemens SGT6-5000F (~227 MW each), operating as peaking units in simple cycle mode.		(3) combustion turbines	15.110	Natural Gas	220	MW	The CTGs will either be the General Electric 7FA (~214 MW each) or the Siemens SGT6-5000F (~227 MW each), operating as peaking units in simple cycle mode	Particulate matter, total PM2.5 (TPM2.5)		0		
ANTELOPE ELK ENERGY CENTER	GOLDEN SPREAD ELECTRIC COOPERATIVE, INC.	HALE	TX	5/12/2015	Golden Spread Electric Cooperative, Inc. (GSEC) is requesting authorization for three additional simple cycle electric generating plants at an existing site to meet increased energy demand in the area. The generating equipment consists of three new GE 7F5-Series natural gas-fired combustion turbine generators (CTGs). Each turbine has a maximum electric output of 202 MW.		Simple Cycle Turbine Generator	15.110	Natural Gas	202	MW	3 additional GE 7F 5-Series Combustion Turbine Generators	Particulate matter, total PM2.5 (TPM2.5)	Pipeline quality natural gas; limited hours; good combustion practices.	0		
ANTELOPE ELK ENERGY CENTER	GOLDEN SPREAD ELECTRIC COOPERATIVE, INC.	HALE	TX	5/12/2015	Golden Spread Electric Cooperative, Inc. (GSEC) is requesting authorization for three additional simple cycle electric generating plants at an existing site to meet increased energy demand in the area. The generating equipment consists of three new GE 7F5-Series natural gas-fired combustion turbine generators (CTGs). Each turbine has a maximum electric output of 202 MW.		Simple Cycle Turbine Generator	15.110	Natural Gas	202	MW	3 additional GE 7F 5-Series Combustion Turbine Generators	Particulate matter, total PM10 (TPM10)	Pipeline quality natural gas; limited hours; good combustion practices.	0		
ANTELOPE ELK ENERGY CENTER	GOLDEN SPREAD ELECTRIC COOPERATIVE, INC.	HALE	TX	5/12/2015	Golden Spread Electric Cooperative, Inc. (GSEC) is requesting authorization for three additional simple cycle electric generating plants at an existing site to meet increased energy demand in the area. The generating equipment consists of three new GE 7F5-Series natural gas-fired combustion turbine generators (CTGs). Each turbine has a maximum electric output of 202 MW.		Simple Cycle Turbine Generator	15.110	Natural Gas	202	MW	3 additional GE 7F 5-Series Combustion Turbine Generators	Particulate matter, total (TPM)	Pipeline quality natural gas; limited hours; good combustion practices.	0		
LAUDERDALE PLANT	FLORIDA POWER & LIGHT	BROWARD	FL	8/25/2015	Large natural gas- and oil-fired power facility, consisting of four combined cycle units, and many combustion turbines. Small peaking units being replaced with larger combustion turbines.	Re-affirmed BACT determinations in Permit No. 0110037-011-AC. Also, new GHG BACT determination. Technical evaluation available at https://arm-permit2k.dep.state.fl.us/nontv/0110037.013.AC.D.ZIP	Five 200-MW combustion turbines	15.110	Natural Gas	2100	MMBtu/hr (approx)	Five simple cycle GE 7F.05 turbines. Max of 3390 hours per year per turbine. Of the 3390 hours per year, up to 500 hour may be on ULSD fuel oil.	Particulate matter, total (TPM)	Clean fuel prevents PM formation	2	GR. 5 / 100 SCF GAS	FUEL RECORD KEEPING
LAUDERDALE PLANT	FLORIDA POWER & LIGHT	BROWARD	FL	8/25/2015	Large natural gas- and oil-fired power facility, consisting of four combined cycle units, and many combustion turbines. Small peaking units being replaced with larger combustion turbines.	Re-affirmed BACT determinations in Permit No. 0110037-011-AC. Also, new GHG BACT determination. Technical evaluation available at https://arm-permit2k.dep.state.fl.us/nontv/0110037.013.AC.D.ZIP	Five 200-MW combustion turbines	15.110	Natural Gas	2100	MMBtu/hr (approx)	Five simple cycle GE 7F.05 turbines. Max of 3390 hours per year per turbine. Of the 3390 hours per year, up to 500 hour may be on ULSD fuel oil.	Particulate matter, total PM10 (TPM10)	Clean fuel prevents PM formation	2	GR. 5 / 100 SCF	FUEL RECORD KEEPING
LAUDERDALE PLANT	FLORIDA POWER & LIGHT	BROWARD	FL	8/25/2015	Large natural gas- and oil-fired power facility, consisting of four combined cycle units, and many combustion turbines. Small peaking units being replaced with larger combustion turbines.	Re-affirmed BACT determinations in Permit No. 0110037-011-AC. Also, new GHG BACT determination. Technical evaluation available at https://arm-permit2k.dep.state.fl.us/nontv/0110037.013.AC.D.ZIP	Five 200-MW combustion turbines	15.110	Natural Gas	2100	MMBtu/hr (approx)	Five simple cycle GE 7F.05 turbines. Max of 3390 hours per year per turbine. Of the 3390 hours per year, up to 500 hour may be on ULSD fuel oil.	Particulate matter, total PM2.5 (TPM2.5)	Clean fuel prevents PM formation	2	GR. 5 / 100 SCF	FUEL RECORD KEEPING
FORT MYERS PLANT	FLORIDA POWER & LIGHT (FPL)	LEE	FL	9/10/2015	Electric power plant, consists of a 6-on-2 combined-cycle unit (Units 2A through 2F) and two modern simple-cycle combustion turbines. Primary fuel is natural gas. Also includes 12 gas turbines (63 MW each) for peaking, introduced into service in 1974. This project entails decommissioning 10 of the 12 peaking turbines. They will be replaced with two new GE 7F.05 turbines, each with nominal capacity of 200 MW	Technical evaluation available at https://arm-permit2k.dep.state.fl.us/nontv/0710002.022.AC.D.ZIP	Combustion Turbines	15.110	Natural Gas	2262.4	MMBtu/hr gas	Two GE 7F.05 turbines, approximately 200 MW each. Natural-gas is primary fuel. Permitted 3390 hr/yr of operation, of which no more than 500 hr may be on fuel oil. Dry Low-NOx, with wet injection for oil firing.	Particulate matter, total (TPM)	Use of clean fuels, and annual VE test	2	GR. 5 / 100 SCF GAS	FOR NATURAL GAS

Appendix C - RBL Search Results
Washington County Power, LLC

Table C-3. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - PM

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
FORT MYERS PLANT	FLORIDA POWER & LIGHT (FPL)	LEE	FL	9/10/2015	Electric power plant, consists of a 6-on-2 combined-cycle unit (Units 2A through 2F) and two modern simple-cycle combustion turbines. Primary fuel is natural gas. Also includes 12 gas turbines (63 MW each) for peaking, introduced into service in 1974. This project entails decommissioning 10 of the 12 peaking turbines. They will be replaced with two new GE 7F.05 turbines, each with nominal capacity of 200 MW	Technical evaluation available at https://arm-permit2k.dep.state.fl.us/nontv/0710002.022.AC.D.ZIP	Combustion Turbines	15.110	Natural Gas	2262.4	MMBtu/hr gas	Two GE 7F.05 turbines, approximately 200 MW each. Natural-gas is primary fuel. Permitted 3390 hr/yr of operation, of which no more than 500 hr may be on fuel oil. Dry Low-NOx, with wet injection for oil firing.	Particulate matter, total PM10 (TPM10)	Use of clean fuels	2	GR 5 / 100 SCF GAS	FOR NATURAL GAS
FORT MYERS PLANT	FLORIDA POWER & LIGHT (FPL)	LEE	FL	9/10/2015	Electric power plant, consists of a 6-on-2 combined-cycle unit (Units 2A through 2F) and two modern simple-cycle combustion turbines. Primary fuel is natural gas. Also includes 12 gas turbines (63 MW each) for peaking, introduced into service in 1974. This project entails decommissioning 10 of the 12 peaking turbines. They will be replaced with two new GE 7F.05 turbines, each with nominal capacity of 200 MW	Technical evaluation available at https://arm-permit2k.dep.state.fl.us/nontv/0710002.022.AC.D.ZIP	Combustion Turbines	15.110	Natural gas	2262.4	MMBtu/hr gas	Two GE 7F.05 turbines, approximately 200 MW each. Natural-gas is primary fuel. Permitted 3390 hr/yr of operation, of which no more than 500 hr may be on fuel oil. Dry Low-NOx, with wet injection for oil firing.	Particulate matter, total PM2.5 (TPM2.5)	Use of clean fuels	2	GR 5 / 100 SCF GAS	FOR NATURAL GAS
SHAWNEE ENERGY CENTER	SHAWNEE ENERGY CENTER, LLC	HILL	TX	10/9/2015	Electric Generating Utility: The project will consist of four gas fired combustion turbines (CTGs). The CTGs are fueled with pipeline quality natural gas and will operate in simple cycle mode. The gas turbines will be one of two options.		Simple cycle turbines greater than 25 megawatts (MW)	15.110	Natural Gas	230	MW	Siemens Model SGT6-5000 F5ee 230 MW or Second turbine option: General Electric Model 7FA.05TP 227 MW	Particulate matter, total PM10 (TPM10)	Pipeline quality natural gas; limited hours; good combustion practices.	84.1	LB/HR	
SHAWNEE ENERGY CENTER	SHAWNEE ENERGY CENTER, LLC	HILL	TX	10/9/2015	Electric Generating Utility: The project will consist of four gas fired combustion turbines (CTGs). The CTGs are fueled with pipeline quality natural gas and will operate in simple cycle mode. The gas turbines will be one of two options.		Simple cycle turbines greater than 25 megawatts (MW)	15.110	Natural Gas	230	MW	Siemens Model SGT6-5000 F5ee 230 MW Second turbine option: General Electric Model 7FA.05TP 227 MW	Particulate matter, total PM2.5 (TPM2.5)	Pipeline quality natural gas; limited hours; good combustion practices.	84.1	LB/HR	
NACOGDOCHES POWER ELECTRIC GENERATING PLANT	NACOGDOCHES POWER, LLC	NACOGDOCHES	TX	10/14/2015	Nacogdoches Power, LLC is requesting authorization for one natural gas fired, simple cycle combustion turbine generator (CTG). The CTG will be a Siemens F5 and have a nominal electric output of 232 megawatts (MW).		Natural Gas Simple Cycle Turbine (25 MW)	15.110	Natural Gas	232	MW	One Siemens F5 simple cycle combustion turbine generator	Particulate matter, total (TPM)	Pipeline quality natural gas; limited hours; good combustion practices.	12.09	LB/HR	
NACOGDOCHES POWER ELECTRIC GENERATING PLANT	NACOGDOCHES POWER, LLC	NACOGDOCHES	TX	10/14/2015	Nacogdoches Power, LLC is requesting authorization for one natural gas fired, simple cycle combustion turbine generator (CTG). The CTG will be a Siemens F5 and have a nominal electric output of 232 megawatts (MW).		Natural Gas Simple Cycle Turbine (25 MW)	15.110	Natural Gas	232	MW	One Siemens F5 simple cycle combustion turbine generator	Particulate matter, total PM10 (TPM10)	Pipeline quality natural gas; limited hours; good combustion practices.	12.09	LB/HR	
NACOGDOCHES POWER ELECTRIC GENERATING PLANT	NACOGDOCHES POWER, LLC	NACOGDOCHES	TX	10/14/2015	Nacogdoches Power, LLC is requesting authorization for one natural gas fired, simple cycle combustion turbine generator (CTG). The CTG will be a Siemens F5 and have a nominal electric output of 232 megawatts (MW).		Natural Gas Simple Cycle Turbine (25 MW)	15.110	Natural Gas	232	MW	One Siemens F5 simple cycle combustion turbine generator	Particulate matter, total PM2.5 (TPM2.5)	Pipeline quality natural gas; limited hours; good combustion practices.	12.09	LB/HR	
VAN ALSTYNE ENERGY CENTER (VAEC)	NAVASOTA NORTH COUNTRY PEAKERS OPERATING COMPANY I	GRAYSON	TX	10/27/2015	Navasota North Country Peakers Operating Company I LLC. proposes to install three new natural gas fired combustion turbine generators (CTGs). The CTGs will be the General Electric 7FA.04 (~214 MW each; manufacturer's output at baseload, ISO at 183 MW), operating as peaking units in simple cycle.		Simple Cycle Turbine	15.110	Natural Gas	183	MW	The CTGs will be three General Electric 7FA.04 (~183 MW each for a total of 550 MW), operating as peaking units in simple cycle mode. Each turbine will be limited to 2,500 hours of operation per year. The new CTGs will use dry low-NOx (DLN) burners and may employ evaporative cooling for power enhancement.	Particulate matter, total PM10 (TPM10)	Pipeline Quality Natural Gas	8.6	LB/H	
VAN ALSTYNE ENERGY CENTER (VAEC)	NAVASOTA NORTH COUNTRY PEAKERS OPERATING COMPANY I	GRAYSON	TX	10/27/2015	Navasota North Country Peakers Operating Company I LLC. proposes to install three new natural gas fired combustion turbine generators (CTGs). The CTGs will be the General Electric 7FA.04 (~214 MW each; manufacturer's output at baseload, ISO at 183 MW), operating as peaking units in simple cycle.		Simple Cycle Turbine	15.110	Natural Gas	183	MW	The CTGs will be three General Electric 7FA.04 (~183 MW each for a total of 550 MW), operating as peaking units in simple cycle mode. Each turbine will be limited to 2,500 hours of operation per year. The new CTGs will use dry low-NOx (DLN) burners and may employ evaporative cooling for power enhancement.	Particulate matter, total PM2.5 (TPM2.5)	Pipeline Quality Natural Gas	8.6	LB/H	
UNION VALLEY ENERGY CENTER	NAVASOTA SOUTH PEAKERS OPERATING COMPANY I, LLC.	NIXON	TX	12/9/2015	three new natural gas fired combustion turbine generators (CTGs). The CTGs will be the General Electric 7FA.04 (~214 megawatt (MW) each; manufacturer's output at baseload, ISO at 183 MW), operating as peaking units in simple cycle		Simple Cycle Turbine	15.110	Natural Gas	183	MW	The CTGs will be three General Electric 7FA.04 (~183 MW each for a total of 550 MW), operating as peaking units in simple cycle mode. Each turbine will be limited to 2,500 hours of operation per year. The new CTGs will use dry low-NOx (DLN) burners and may employ evaporative cooling for power enhancement.	Particulate matter, total PM10 (TPM10)	pipeline quality natural gas, good combustion practices	8.6	LB/H	
UNION VALLEY ENERGY CENTER	NAVASOTA SOUTH PEAKERS OPERATING COMPANY I, LLC.	NIXON	TX	12/9/2015	three new natural gas fired combustion turbine generators (CTGs). The CTGs will be the General Electric 7FA.04 (~214 megawatt (MW) each; manufacturer's output at baseload, ISO at 183 MW), operating as peaking units in simple cycle		Simple Cycle Turbine	15.110	Natural Gas	183	MW	The CTGs will be three General Electric 7FA.04 (~183 MW each for a total of 550 MW), operating as peaking units in simple cycle mode. Each turbine will be limited to 2,500 hours of operation per year. The new CTGs will use dry low-NOx (DLN) burners and may employ evaporative cooling for power enhancement.	Particulate matter, total PM2.5 (TPM2.5)	pipeline quality natural gas, good combustion practices	8.6	LB/H	

Appendix C - RBL Search Results
Washington County Power, LLC

Table C-3. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - PM

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
DECORDOVA STEAM ELECTRIC STATION	DECORDOVA II POWER COMPANY LLC	HOOD	TX	3/8/2016	The DeCordova Station will consist of two combustion turbine generators (CTGs) operating in simple cycle or combined cycle modes. The gas turbines will be one of two options: Siemens or General Electric.		Combined Cycle & Cogeneration	15.210	natural gas	231	MW	2 CTGs to operate in simple cycle & combined cycle modes. 231 MW (Siemens) or 210 MW (GE). Simple cycle operations limited to 2,500 hr/yr.	Particulate matter, total < 10 Åµ (TPM10)	GOOD COMBUSTION PRACTICES AND LOW SULFUR FUEL	35.47	LB/H	
DECORDOVA STEAM ELECTRIC STATION	DECORDOVA II POWER COMPANY LLC	HOOD	TX	3/8/2016	The DeCordova Station will consist of two combustion turbine generators (CTGs) operating in simple cycle or combined cycle modes. The gas turbines will be one of two options: Siemens or General Electric.		Combined Cycle & Cogeneration	15.210	natural gas	231	MW	2 CTGs to operate in simple cycle & combined cycle modes. 231 MW (Siemens) or 210 MW (GE). Simple cycle operations limited to 2,500 hr/yr.	Particulate matter, total < 2.5 Åµ (TPM2.5)	GOOD COMBUSTION PRACTICES AND LOW SULFUR FUEL	35.47	LB/H	
NECHES STATION	APEX TEXAS POWER LLC	CHEROKEE	TX	3/24/2016	either 4 simple cycle combustion turbine generators (CTGs) or two CTGs operating in simple cycle or combined cycle modes. The CTGs will be one of two options: Siemens or General Electric.		Combined Cycle & Cogeneration	15.210	natural gas	231	MW	2 CTGs to operate in simple cycle & combined cycle modes. 231 MW (Siemens) or 210 MW (GE) Simple cycle operations limited to 2,500 hr/yr.	Particulate matter, total < 10 Åµ (TPM10)	GOOD COMBUSTION PRACTICES, LOW SULFUR FUEL	19.35	LB/H	
NECHES STATION	APEX TEXAS POWER LLC	CHEROKEE	TX	3/24/2016	either 4 simple cycle combustion turbine generators (CTGs) or two CTGs operating in simple cycle or combined cycle modes. The CTGs will be one of two options: Siemens or General Electric.		Combined Cycle & Cogeneration	15.210	natural gas	231	MW	2 CTGs to operate in simple cycle & combined cycle modes. 231 MW (Siemens) or 210 MW (GE) Simple cycle operations limited to 2,500 hr/yr.	Particulate matter, total < 2.5 Åµ (TPM2.5)	GOOD COMBUSTION PRACTICES AND LOW SULFUR FUEL	19.35	LB/H	
NECHES STATION	APEX TEXAS POWER LLC	CHEROKEE	TX	3/24/2016	either 4 simple cycle combustion turbine generators (CTGs) or two CTGs operating in simple cycle or combined cycle modes. The CTGs will be one of two options: Siemens or General Electric.		Large Combustion Turbines 25 MW	15.110	Natural Gas	232	MW	4 Simple cycle CTGs, 2,500 hr/yr operational limitation. Facility will consist of either 232 MW (Siemens) or 220 MW (GE)	Particulate matter, total PM10 (TPM10)	good combustion practices, low sulfur fuel	13.4	LB/H	
NECHES STATION	APEX TEXAS POWER LLC	CHEROKEE	TX	3/24/2016	either 4 simple cycle combustion turbine generators (CTGs) or two CTGs operating in simple cycle or combined cycle modes. The CTGs will be one of two options: Siemens or General Electric.		Large Combustion Turbines 25 MW	15.110	Natural Gas	232	MW	4 Simple cycle CTGs, 2,500 hr/yr operational limitation. Facility will consist of either 232 MW (Siemens) or 220 MW (GE)	Particulate matter, total PM2.5 (TPM2.5)	good combustion practices, low sulfur fuel	13.4	LB/H	
HILL COUNTY GENERATING FACILITY	BRAZOS ELECTRIC COOPERATIVE	HILL	TX	4/7/2016	Four simple cycle combustion turbine electric generators are proposed. Natural gas or ultra-low sulfur diesel fuel oil are the fuels. Turbine model options are: General Electric (GE) 7FA.03, GE 7FA.04, GE 7FA.05, and Siemes SGT6-5000(5)ee. Electric output is between 684 and 928 megawatts (MW).		Simple cycle turbine	15.110	Natural Gas	171	MW	Each combustion turbine is limited to 2,920 hours of annual operation, including startup and shutdown hours.	Particulate matter, total PM10 (TPM10)	Premixing of fuel and air enhances combustion efficiency and minimizes emissions.	14	LB/H	
HILL COUNTY GENERATING FACILITY	BRAZOS ELECTRIC COOPERATIVE	HILL	TX	4/7/2016	Four simple cycle combustion turbine electric generators are proposed. Natural gas or ultra-low sulfur diesel fuel oil are the fuels. Turbine model options are: General Electric (GE) 7FA.03, GE 7FA.04, GE 7FA.05, and Siemes SGT6-5000(5)ee. Electric output is between 684 and 928 megawatts (MW).		Simple cycle turbine	15.110	Natural Gas	171	MW	Each combustion turbine is limited to 2,920 hours of annual operation, including startup and shutdown hours.	Particulate matter, total PM2.5 (TPM2.5)	Premixing of fuel and air enhances combustion efficiency and minimizes emissions.	14	LB/H	
BAYONNE ENERGY CENTER	BAYONNE ENERGY CENTER LLC	HUDSON	NJ	8/26/2016	Facility consists of 8 existing Roll Royce Trent 60 WLE (64 MW) each. The facility is adding two more new Roll Royce Trent 60 WLE (66 MW) each	The facility has eight existing simple cycle combustion turbines Rolls Royce Trent turbine 64 MW each. This permit allows the construction and operation of two more Rolls Royce Trent (WLE) simple cycle combustion turbines 66 MW each. The turbines will be dual fired, with natural gas as primary fuel and ultra low sulfur distillate oil with less than or equal to 15% sulfur by weight. The turbines will have SCR and Oxidation catalyst for removal of NOx, CO and VOC.	Simple Cycle Stationary Turbines firing Natural gas	15.110	Natural Gas	2143980	MMBTU/YR	The Siemens/Rolls Royce Trent 60 wet low emissions (WLE) combustion turbine generators (CTGs) will each have a maximum heat input rate while combusting natural gas of 643 million British thermal units per hour (MMBtu/hr) (higher heating value [HHV]) at 100 percent (%) load, at International Organization for Standardization (ISO) conditions of 59 degrees Fahrenheit (°F) and 60% relative humidity, generating 66 MW. The maximum heat input rate on ULSD at ISO condition would be 533.50 MMBtu/hr (HHV). Each of the CTG will be equipped with Water Injection and Selective Catalytic Reduction System (SCR) to control Nitrogen Oxide (NOx) emissions and Oxidation Catalyst to control Carbon Monoxide (CO) and Volatile Organic Compounds (VOC) emissions. The CTGs will have continuous emissions monitoring systems (CEMs) for NOx and CO.	Particulate matter, filterable (FPM)	Use of Natural gas a clean burning fuel	5	LB/H	AV OF THREE ONE H STACK TESTS EVERY 5 YR

Appendix C - RBL Search Results
Washington County Power, LLC

Table C-3. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - PM

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
BAYONNNE ENERGY CENTER	BAYONNNE ENERGY CENTER LLC	HUDSON	NJ	8/26/2016	Facility consists of 8 existing Roll Royce Trent 60 WLE (64 MW) each. The facility is adding two more new Roll Royce Trent 60 WLE (66 MW) each	The facility has eight existing simple cycle combustion turbines Rolls Royce Trent turbine 64 MW each. This permit allows the construction and operation of two more Rolls Royce Trent (WLE) simple cycle combustion turbines 66 MW each. The turbines will be dual fired, with natural gas as primary fuel and ultra low sulfur distillate oil with less than or equal to 15% sulfur by weight. The turbines will have SCR and Oxidation catalyst for removal of NOx, CO and VOC.	Simple Cycle Stationary Turbines firing Natural gas	15.110	Natural Gas	2143980	MMBTU/YR	The Siemens/Rolls Royce Trent 60 wet low emissions (WLE) combustion turbine generators (CTGs) will each have a maximum heat input rate while combusting natural gas of 643 million British thermal units per hour (MMBtu/hr) (higher heating value [HHV]) at 100 percent (%) load, at International Organization for Standardization (ISO) conditions of 59 degrees Fahrenheit (°F) and 60% relative humidity, generating 66 MW. The maximum heat input rate on ULSD at ISO condition would be 533.50 MMBtu/hr (HHV). Each of the CTG will be equipped with Water Injection and Selective Catalytic Reduction System (SCR) to control Nitrogen Oxide (NOx) emissions and Oxidation Catalyst to control Carbon Monoxide (CO) and Volatile Organic Compounds (VOC) emissions. The CTGs will have continuous emissions monitoring systems (CEMs) for NOx and CO.	Particulate matter, total PM10 (TPM10)	Use of Natural gas a clean burning fuel	5	LB/H	AV OF THREE ONE H STACK TESTS EVERY 5 YR
BAYONNNE ENERGY CENTER	BAYONNNE ENERGY CENTER LLC	HUDSON	NJ	8/26/2016	Facility consists of 8 existing Roll Royce Trent 60 WLE (64 MW) each. The facility is adding two more new Roll Royce Trent 60 WLE (66 MW) each	The facility has eight existing simple cycle combustion turbines Rolls Royce Trent turbine 64 MW each. This permit allows the construction and operation of two more Rolls Royce Trent (WLE) simple cycle combustion turbines 66 MW each. The turbines will be dual fired, with natural gas as primary fuel and ultra low sulfur distillate oil with less than or equal to 15% sulfur by weight. The turbines will have SCR and Oxidation catalyst for removal of NOx, CO and VOC.	Simple Cycle Stationary Turbines firing Natural gas	15.110	Natural Gas	2143980	MMBTU/YR	The Siemens/Rolls Royce Trent 60 wet low emissions (WLE) combustion turbine generators (CTGs) will each have a maximum heat input rate while combusting natural gas of 643 million British thermal units per hour (MMBtu/hr) (higher heating value [HHV]) at 100 percent (%) load, at International Organization for Standardization (ISO) conditions of 59 degrees Fahrenheit (°F) and 60% relative humidity, generating 66 MW. The maximum heat input rate on ULSD at ISO condition would be 533.50 MMBtu/hr (HHV). Each of the CTG will be equipped with Water Injection and Selective Catalytic Reduction System (SCR) to control Nitrogen Oxide (NOx) emissions and Oxidation Catalyst to control Carbon Monoxide (CO) and Volatile Organic Compounds (VOC) emissions. The CTGs will have continuous emissions monitoring systems (CEMs) for NOx and CO.	Particulate matter, total PM2.5 (TPM2.5)	Use of natural gas a clean burning fuel	5	LB/H	AV OF THREE ONE H STACK TESTS EVERY 5 YR
INVENERGY NELSON EXPANSION LLC	INVENERGY	LEE	IL	9/27/2016	Peaking facility at an existing major source. The expansion will consist of two simple cycle combustion turbines and a fuel heater.		Two Simple Cycle Combustion Turbines	15.110	Natural Gas	190	MW	Two simple cycle combustion turbines used for peaking purposes and fired primarily on natural gas with ULSD as a secondary fuel.	Particulate matter, filterable (FPM)	turbine design and good combustion practices	0.0038	LB/MMBTU	3-HOUR BLOCK AVERAGE
INVENERGY NELSON EXPANSION LLC	INVENERGY	LEE	IL	9/27/2016	Peaking facility at an existing major source. The expansion will consist of two simple cycle combustion turbines and a fuel heater.		Two Simple Cycle Combustion Turbines	15.110	Natural Gas	190	MW	Two simple cycle combustion turbines used for peaking purposes and fired primarily on natural gas with ULSD as a secondary fuel.	Particulate matter, total PM10 (TPM10)	turbine design and good combustion practices	0.005	LB/MMBTU	3-HOUR BLOCK AVERAGE
INVENERGY NELSON EXPANSION LLC	INVENERGY	LEE	IL	9/27/2016	Peaking facility at an existing major source. The expansion will consist of two simple cycle combustion turbines and a fuel heater.		Two Simple Cycle Combustion Turbines	15.110	Natural Gas	190	MW	Two simple cycle combustion turbines used for peaking purposes and fired primarily on natural gas with ULSD as a secondary fuel.	Particulate matter, total PM2.5 (TPM2.5)	turbine design and good combustion practices	0.005	LB/MMBTU	3-HOUR BLOCK AVERAGE
DOSWELL ENERGY CENTER	DOSWELL LIMITED PARTNERSHIP DOSWELL ENERGY CENTER	HANAOVER	VA	10/4/2016	The facility is currently composed of four Kraftwerk Union/Siemens (Model: V84.2) combined cycle turbine units each equipped with a duct burner and supporting equipment (auxiliary boiler, fire pump, emergency generator and fuel oil storage tanks) under one Prevention of Significant Deterioration (PSD) permit and one simple cycle turbine unit under another PSD permit. The combined cycle turbines were permitted in a PSD permit originally issued on May 4, 1990 and last amended on August 3, 2005. The 190.5 MW simple cycle combustion turbine (CT-1) was added in a separate PSD permit dated April 7, 2000 and last amended on September 30, 2013.	DEC is proposing to add two GE 7FA simple cycle combustion turbines (CT-2 and CT-3) at the Doswell Energy Center. DEC is moving CT-2 and CT-3 from an existing permitted site in Desoto, Florida. They are both GE Frame 7FA Combustion Turbines that are very similar in age and capability to the DEC CT-1 (GE 7FA.03). The CT-2 and CT-3 maximum heat input assumed for natural gas firing is 1,961.0 MMBtu/hr (HHV).	Two (2) GE 7FA simple cycle combustion turbines	15.110	Natural Gas	1961	MMBTU/HR		Particulate matter, filterable (FPM)	Good combustion, operation and maintenance practices and use of pipeline quality natural gas	10	LB	H/12 MO ROLLING TOTAL

Table C-3. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - PM

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
DOSWELL ENERGY CENTER	DOSWELL LIMITED PARTNERSHIP DOSWELL ENERGY CENTER	HANAOVER	VA	10/4/2016	The facility is currently composed of four Kraftwerk Union/Siemens (Model: V84.2) combined cycle turbine units each equipped with a duct burner and supporting equipment (auxiliary boiler, fire pump, emergency generator and fuel oil storage tanks) under one Prevention of Significance Deterioration (PSD) permit and one simple cycle turbine unit under another PSD permit. The combined cycle turbines were permitted in a PSD permit originally issued on May 4, 1990 and last amended on August 3, 2005. The 190.5 MW simple cycle combustion turbine (CT-1) was added in a separate PSD permit dated April 7, 2000 and last amended on September 30, 2013.	DEC is proposing to add two GE 7FA simple cycle combustion turbines (CT-2 and CT-3) at the Doswell Energy Center. DEC is moving CT-2 and CT-3 from an existing permitted site in Desoto, Florida. They are both GE Frame 7FA Combustion Turbines that are very similar in age and capability to the DEC CT-1 (GE 7FA.03). The CT-2 and CT-3 maximum heat input assumed for natural gas firing is 1,961.0 MMBtu/hr (HHV).	Two (2) GE 7FA simple cycle combustion turbines	15.110	Natural Gas	1961	MMBTU/HR		Particulate matter, filterable PM10 (FPM10)	Good combustion, operation and maintenance practices and use of pipeline quality natural gas	12	LB	H/12 MO ROLLING TOTAL
DOSWELL ENERGY CENTER	DOSWELL LIMITED PARTNERSHIP DOSWELL ENERGY CENTER	HANAOVER	VA	10/4/2016	The facility is currently composed of four Kraftwerk Union/Siemens (Model: V84.2) combined cycle turbine units each equipped with a duct burner and supporting equipment (auxiliary boiler, fire pump, emergency generator and fuel oil storage tanks) under one Prevention of Significance Deterioration (PSD) permit and one simple cycle turbine unit under another PSD permit. The combined cycle turbines were permitted in a PSD permit originally issued on May 4, 1990 and last amended on August 3, 2005. The 190.5 MW simple cycle combustion turbine (CT-1) was added in a separate PSD permit dated April 7, 2000 and last amended on September 30, 2013.	DEC is proposing to add two GE 7FA simple cycle combustion turbines (CT-2 and CT-3) at the Doswell Energy Center. DEC is moving CT-2 and CT-3 from an existing permitted site in Desoto, Florida. They are both GE Frame 7FA Combustion Turbines that are very similar in age and capability to the DEC CT-1 (GE 7FA.03). The CT-2 and CT-3 maximum heat input assumed for natural gas firing is 1,961.0 MMBtu/hr (HHV).	Two (2) GE 7FA simple cycle combustion turbines	15.110	Natural Gas	1961	MMBTU/HR		Particulate matter, total PM2.5 (TPM2.5)	Good combustion, operation and maintenance practices and use of pipeline quality natural gas	12	LB	H/12 MO ROLLING TOTAL
WAVERLY FACILITY	PLEASANTS ENERGY, LLC	PLEASANTS	WV	1/23/2017	300 MW, natural gas fired, simple cycle peaking power facility	In this permitting action PSD only applies to the modified combustion turbines based on the relaxation of an original synthetic minor permit issued in 1999. Project also involves previous installation of turbo-charging. All BACT emission limits are given without turbocharging and startup/shutdown emissions are not included. Please contact above engineer for more information. There are two identical turbines but only one is listed.	GE Model 7FA Turbine	15.110	Natural Gas	1571	mmbtu/hr	There are two identical units at the facility.	Particulate matter, total PM2.5 (TPM2.5)	Inlet Air Filtration, Use of Natural Gas, Ultra-Low Sulfur Diesel	15	LB/HR	NATURAL GAS
CAMERON LNG FACILITY	CAMERON LNG LLC	CAMERON	LA	2/17/2017	A facility to liquefy natural gas for export (5 trains)	Permit PSD-LA-766, dated 10/1/13 for liquefaction trains 1,2, and 3 Permit PSD-LA-766(M1), dated 6/26/14, for minor changes; Permit PSD-LA-766(M2), dated 3/3/16, for train 4 and 5	Gas turbines (9 units)	15.110	Natural Gas	1069	mm btu/hr		Particulate matter, total PM10 (TPM10)	good combustion practices and fueled by natural gas	0.0076	LB/MM BTU	THREE ONE-HOUR TEST AVERAGE
CAMERON LNG FACILITY	CAMERON LNG LLC	CAMERON	LA	2/17/2017	A facility to liquefy natural gas for export (5 trains)	Permit PSD-LA-766, dated 10/1/13 for liquefaction trains 1,2, and 3 Permit PSD-LA-766(M1), dated 6/26/14, for minor changes; Permit PSD-LA-766(M2), dated 3/3/16, for train 4 and 5	Gas turbines (9 units)	15.110	Natural Gas	1069	mm btu/hr		Particulate matter, total PM2.5 (TPM2.5)	good combustion practices and fueled by natural gas	0.0076	LB/MM BTU	THREE ONE-HOUR TEST AVERAGE
GAINES COUNTY POWER PLANT	SOUTHWESTERN PUBLIC SERVICE COMPANY		TX	4/28/2017	constructed in phases, with natural gas-fired simple cycle combustion turbines (SCCTs) with dry low nitrogen oxide (NOx) burners (DLN) to be converted into 2-on-1 combined cycle combustion turbines (CCCTs) with selective catalytic reduction (SCRs), heat recovery steam generators (HRSGs), one per combustion turbine) and one steam turbine per two CCCTs. Federal control review only applies to the turbines and HRSGs.		Simple Cycle Turbine	15.110	Natural Gas	227.5	MW	Four Siemens SGT6-5000F5 natural gas fired combustion turbines	Particulate matter, total (TPM)	Pipeline quality natural gas; limited hours; good combustion practices	8.5	T/YR	
GAINES COUNTY POWER PLANT	SOUTHWESTERN PUBLIC SERVICE COMPANY		TX	4/28/2017	constructed in phases, with natural gas-fired simple cycle combustion turbines (SCCTs) with dry low nitrogen oxide (NOx) burners (DLN) to be converted into 2-on-1 combined cycle combustion turbines (CCCTs) with selective catalytic reduction (SCRs), heat recovery steam generators (HRSGs), one per combustion turbine) and one steam turbine per two CCCTs. Federal control review only applies to the turbines and HRSGs.		Simple Cycle Turbine	15.110	Natural Gas	227.5	MW	Four Siemens SGT6-5000F5 natural gas fired combustion turbines	Particulate matter, total PM10 (TPM10)	Pipeline quality natural gas; limited hours; good combustion practices	8.5	T/YR	
GAINES COUNTY POWER PLANT	SOUTHWESTERN PUBLIC SERVICE COMPANY		TX	4/28/2017	constructed in phases, with natural gas-fired simple cycle combustion turbines (SCCTs) with dry low nitrogen oxide (NOx) burners (DLN) to be converted into 2-on-1 combined cycle combustion turbines (CCCTs) with selective catalytic reduction (SCRs), heat recovery steam generators (HRSGs), one per combustion turbine) and one steam turbine per two CCCTs. Federal control review only applies to the turbines and HRSGs.		Simple Cycle Turbine	15.110	Natural Gas	227.5	MW	Four Siemens SGT6-5000F5 natural gas fired combustion turbines	Particulate matter, total PM2.5 (TPM2.5)	Pipeline quality natural gas; limited hours; good combustion practices	8.5	T/YR	

Appendix C - RBL Search Results
Washington County Power, LLC

Table C-3. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - PM

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
MUSTANG STATION	GOLDEN SPREAD ELECTRIC COOPERATIVE, INC.	YOAKUM	TX	8/16/2017	GE7FA combustion turbine (Unit 6) to increase the hours of operation to 3000 hours per year. The turbine construction was completed the first quarter of 2013 and initial firing began on April 1, 2013.		Simple Cycle Turbine	15.110	Natural Gas	162.8	MW	Unit 6 Turbine is limited to 3000 hours per year.	Particulate matter, total PM10 (TPM10)	Pipeline quality natural gas and good combustion practices	27	T/YR	
MUSTANG STATION	GOLDEN SPREAD ELECTRIC COOPERATIVE, INC.	YOAKUM	TX	8/16/2017	GE7FA combustion turbine (Unit 6) to increase the hours of operation to 3000 hours per year. The turbine construction was completed the first quarter of 2013 and initial firing began on April 1, 2013.		Simple Cycle Turbine	15.110	Natural Gas	162.8	MW	Unit 6 Turbine is limited to 3000 hours per year.	Particulate matter, total PM2.5 (TPM2.5)	Pipeline quality natural gas and good combustion practices	27	T/YR	
JACKSON COUNTY GENERATORS	SOUTHERN POWER	JACKSON	TX	1/26/2018	four natural gas-fired simple-cycle combustion turbines, five fuel gas heaters, and a firewater pump engine		Combustion Turbines	15.110	Natural Gas	920	MW	4 identical units, each limited to 2500 hours of operation per year	Particulate matter, filterable (FPM)	Use of pipeline quality natural gas and good combustion practices.	11.81	TON/YR	
JACKSON COUNTY GENERATORS	SOUTHERN POWER	JACKSON	TX	1/26/2018	four natural gas-fired simple-cycle combustion turbines, five fuel gas heaters, and a firewater pump engine		Combustion Turbines	15.110	Natural Gas	920	MW	4 identical units, each limited to 2500 hours of operation per year	Particulate matter, total PM10 (TPM10)	Use of pipeline quality natural gas and good combustion practices.	11.81	TON/YR	
JACKSON COUNTY GENERATORS	SOUTHERN POWER	JACKSON	TX	1/26/2018	four natural gas-fired simple-cycle combustion turbines, five fuel gas heaters, and a firewater pump engine		Combustion Turbines	15.110	Natural Gas	920	MW	4 identical units, each limited to 2500 hours of operation per year	Particulate matter, total PM2.5 (TPM2.5)	Use of pipeline quality natural gas and good combustion practices.	11.81	TON/YR	
JACKSON COUNTY GENERATORS	SOUTHERN POWER	JACKSON	TX	1/26/2018	four natural gas-fired simple-cycle combustion turbines, five fuel gas heaters, and a firewater pump engine		Combustion Turbines MSS	15.110	NATURAL GAS	0			Particulate matter, total (TPM)	Minimizing duration of startup/shutdown, using good air pollution control practices and safe operating practices.	0.01	TON/YR	
JACKSON COUNTY GENERATORS	SOUTHERN POWER	JACKSON	TX	1/26/2018	four natural gas-fired simple-cycle combustion turbines, five fuel gas heaters, and a firewater pump engine		Combustion Turbines MSS	15.110	NATURAL GAS	0			Particulate matter, total PM10 (TPM10)	Minimizing duration of startup/shutdown, using good air pollution control practices and safe operating practices.	0.01	TON/YR	
JACKSON COUNTY GENERATORS	SOUTHERN POWER	JACKSON	TX	1/26/2018	four natural gas-fired simple-cycle combustion turbines, five fuel gas heaters, and a firewater pump engine		Combustion Turbines MSS	15.110	NATURAL GAS	0			Particulate matter, total PM2.5 (TPM2.5)	Minimizing duration of startup/shutdown, using good air pollution control practices and safe operating practices.	0.01	TON/YR	
WAVERLY POWER PLANT	PLEASANTS ENERGY LLC	PLEASANTS	WV	3/13/2018	300 MW Simple-Cycle Peaking Plant	Modification to existing PSD Permit (R14-0034, RBL Number WV-0027) to add “advanced gas path“ technology to the turbines that was defined as a “change in the method of operation“; that resulted a major modification to the turbines.	GE 7FA.004 Turbine	15.110	Natural Gas	167.8	MW	This one entry is for both turbines as they are the same. Each turbine, after this modification, is a nominal 167.8 MW GE Model 7FA.004. Has oil-fire backup.	Particulate matter, total PM2.5 (TPM2.5)	Inlet air filtration.	15.09	LB/HR	
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WASHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG01 CO - Simple-Cycle Combustion Turbine 1 (Commissioning) [SCN0005]	15.110	Natural Gas	2201	MM BTU/hr	Commissioning is a one-time event which occurs after construction and is not anticipated to exceed 180 days.	Particulate matter, total PM10 (TPM10)	Good combustion practices and the use of low sulfur fuels (pipeline quality natural gas)	6.3	LB/HR	HOURLY MAXIMUM
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WASHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG01 CO - Simple-Cycle Combustion Turbine 1 (Commissioning) [SCN0005]	15.110	Natural Gas	2201	MM BTU/hr	Commissioning is a one-time event which occurs after construction and is not anticipated to exceed 180 days.	Particulate matter, total PM2.5 (TPM2.5)	Good combustion practices and the use of low sulfur fuels (pipeline quality natural gas)	6.3	LB/HR	HOURLY MAXIMUM
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WASHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG02 CO - Simple-Cycle Combustion Turbine 2 (Commissioning) [SCN0006]	15.110	Natural Gas	2201	MM BTU/hr	Commissioning is a one-time event which occurs after construction and is not anticipated to exceed 180 days.	Particulate matter, total PM10 (TPM10)	Good combustion practices and the use of low sulfur fuels (pipeline quality natural gas)	6.3	LB/HR	HOURLY MAXIMUM

Appendix C - RBL Search Results
Washington County Power, LLC

Table C-3. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - PM

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WASHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG02 CO - Simple-Cycle Combustion Turbine 2 (Commissioning) [SCN0006]	15.110	Natural Gas	2201	MM BTU/hr	Commissioning is a one-time event which occurs after construction and is not anticipated to exceed 180 days.	Particulate matter, total PM2.5 (TPM2.5)	Good combustion practices and the use of low sulfur fuels (pipeline quality natural gas)	6.3	LB/HR	HOURLY MAXIMUM
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WASHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG01 SUSD - Simple-Cycle Combustion Turbine 1 (Startup/Shutdown/Maintenance/Tuning/Runback) [EQT0019]	15.110	Natural Gas	2201	MM BTU/hr	Limited to 600 hr/yr	Particulate matter, total PM2.5 (TPM2.5)	Good combustion practices and the use of low sulfur fuels (pipeline quality natural gas)	6.3	LB/HR	HOURLY MAXIMUM
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WASHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG01 SUSD - Simple-Cycle Combustion Turbine 1 (Startup/Shutdown/Maintenance/Tuning/Runback) [EQT0019]	15.110	Natural Gas	2201	MM BTU/hr	Limited to 600 hr/yr	Particulate matter, total PM10 (TPM10)	Good combustion practices and the use of low sulfur fuels (pipeline quality natural gas)	6.3	LB/HR	HOURLY MAXIMUM
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WASHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG02 SUSD - Simple-Cycle Combustion Turbine 2 (Startup/Shutdown/Maintenance/Tuning/Runback) [EQT0020]	15.110	Natural Gas	2201	MM BTU/hr	limited to 600 hr/yr	Particulate matter, total PM2.5 (TPM2.5)	Good combustion practices and the use of low sulfur fuels (pipeline quality natural gas)	6.3	LB/HR	HOURLY MAXIMUM
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WASHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG02 SUSD - Simple-Cycle Combustion Turbine 2 (Startup/Shutdown/Maintenance/Tuning/Runback) [EQT0020]	15.110	Natural Gas	2201	MM BTU/hr	limited to 600 hr/yr	Particulate matter, total PM10 (TPM10)	Good combustion practices and the use of low sulfur fuels (pipeline quality natural gas)	6.3	LB/HR	HOURLY MAXIMUM
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WASHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG01 NO - Simple-Cycle Combustion Turbine 1 (Normal Operations) [EQT0017]	15.110	Natural Gas	2201	MM BTU/hr	Normal operations are based on 7000 hrs/yr	Particulate matter, total PM10 (TPM10)	Good combustion practices and the use of low sulfur fuels (pipeline quality natural gas)	6.3	LB/HR	HOURLY MAXIMUM
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WASHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG01 NO - Simple-Cycle Combustion Turbine 1 (Normal Operations) [EQT0017]	15.110	Natural Gas	2201	MM BTU/hr	Normal operations are based on 7000 hrs/yr	Particulate matter, total PM2.5 (TPM2.5)	Good combustion practices and the use of low sulfur fuels (pipeline quality natural gas)	6.3	LB/HR	HOURLY MAXIMUM
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WASHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG02 NO - Simple-Cycle Combustion Turbine 2 (Normal Operations) [EQT0018]	15.110	Natural Gas	2201	MM BTU/hr	Normal operations are based on 7000 hours per year	Particulate matter, total PM10 (TPM10)	Good combustion practices and the use of low sulfur fuels (pipeline quality natural gas)	6.3	LB/HR	HOURLY MAXIMUM
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WASHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG02 NO - Simple-Cycle Combustion Turbine 2 (Normal Operations) [EQT0018]	15.110	Natural Gas	2201	MM BTU/hr	Normal operations are based on 7000 hours per year	Particulate matter, total PM2.5 (TPM2.5)	Good combustion practices and the use of low sulfur fuels (pipeline quality natural gas)	6.3	LB/HR	HOURLY MAXIMUM
DRIFTWOOD LNG FACILITY	DRIFTWOOD LNG LLC	CALCASIEU	LA	7/10/2018	Propose a new facility to liquefy natural gas for export		Compressor Turbines (20)	15.110	Natural Gas	540	mm btu/hr		Particulate matter, total PM10 (TPM10)	Good Combustion Practices and Use of low sulfur facility fuel gas	0.0066	LB/MM BTU	

Table C-3. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - PM

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
DRIFTWOOD LNG FACILITY	DRIFTWOOD LNG LLC	CALCASIEU	LA	7/10/2018	Propose a new facility to liquefy natural gas for export		Compressor Turbines (20)	15.110	Natural Gas	540	mm btu/hr		Particulate matter, total PM2.5 (TPM2.5)	Good Combustion Practices and Use of low sulfur facility fuel gas	0.0066	LB/MM BTU	
CALCASIEU PASS LNG PROJECT	VENTURE GLOBAL CALCASIEU PASS, LLC	CAMERON	LA	9/21/2018	New Liquefied Natural Gas (LNG) production, storage, and export terminal.	Application Received September 2, 2015.	Simple Cycle Combustion Turbines (SCCT1 to SCCT3)	15.110	Natural Gas	927	MM BTU/h		Particulate matter, total PM10 (TPM10)	Exclusive Combustion of Fuel Gas and Good Combustion Practices, Including Proper Burner Design.	8	LB/H	3 HOUR AVERAGE
CALCASIEU PASS LNG PROJECT	VENTURE GLOBAL CALCASIEU PASS, LLC	CAMERON	LA	9/21/2018	New Liquefied Natural Gas (LNG) production, storage, and export terminal.	Application Received September 2, 2015.	Simple Cycle Combustion Turbines (SCCT1 to SCCT3)	15.110	Natural Gas	927	MM BTU/h		Particulate matter, total PM2.5 (TPM2.5)	Exclusive Combustion of Fuel Gas and Good Combustion Practices, Including Proper Burner Design.	8	LB/H	3 HOUR AVERAGE
RIO BRAVO PIPELINE FACILITY	RIO GRANDE LNG LLC	CAMERON	TX	12/17/2018	Natural gas processing and liquefied natural gas (LNG) export terminal		Refrigeration Compression Turbines	15.110	Natural Gas	967	MMBTU/HR	Twelve General Electric Frame 7EA simple cycle combustion turbines to serve as drivers for refrigeration and compression at the site. There are six process trains and there are two turbines per train. One each of the pairs of turbines has a downstream heat exchanger in the exhaust stream. The heat exchanger heats oil in a closed circuit for process uses elsewhere in the natural gas liquefaction system.	Particulate matter, filterable PM10 (FPM10)	Good combustion practices and use of pipeline quality natural gas.	7	LB/HR	
RIO BRAVO PIPELINE FACILITY	RIO GRANDE LNG LLC	CAMERON	TX	12/17/2018	Natural gas processing and liquefied natural gas (LNG) export terminal		Refrigeration Compression Turbines	15.110	Natural Gas	967	MMBTU/HR	Twelve General Electric Frame 7EA simple cycle combustion turbines to serve as drivers for refrigeration and compression at the site. There are six process trains and there are two turbines per train. One each of the pairs of turbines has a downstream heat exchanger in the exhaust stream. The heat exchanger heats oil in a closed circuit for process uses elsewhere in the natural gas liquefaction system.	Particulate matter, filterable PM2.5 (FPM2.5)	Good combustion practices and use of pipeline quality natural gas.	7	LB/HR	
LBWL--ERICKSON STATION	LANSING BOARD OF WATER AND LIGHT	EATON	MI	12/21/2018	Natural gas combined-cycle power plant.	The proposed new plant will be replacing the electrical generating capacity of both BWL's existing coal-fired power plants. BWL intends to retire those coal-fired power plants from service by 2025. However, before they can be retired, the new natural gas power plant must be operational. Emissions in the area will increase for a short period if the new combined-cycle plant is built. However, there will be overall reductions in emissions when the existing coal fired power plants are taken out of service.	EUCTGHRSG2--A 667 MMBTU/H natural gas fired CTG with a HRSG.	15.210	Natural gas	667	MMBTU/H	EUCTGHRSG2 is a nominally rated 667 MMBTU/H natural gas fired CTG coupled with a HRSG. The HRSG is equipped with a natural gas fired duct burner rated at 204 MMBTU/h to provide heat for additional steam production. The CTG is capable of operating in combined-cycle mode where the exhaust is routed to the HRSG or in simple-cycle mode where the HRSG is bypassed. The HRSG is not capable of operating independently from the CTG. The CTG/HRSG is equipped with a DLNB, SCR and oxidation catalyst.	Particulate matter, total $10 \mu\text{m}$ (TPM10)	Pipeline quality natural gas, inlet air conditioning, and good combustion practices.	6.02	LB/H	HOURLY
LBWL--ERICKSON STATION	LANSING BOARD OF WATER AND LIGHT	EATON	MI	12/21/2018	Natural gas combined-cycle power plant.	The proposed new plant will be replacing the electrical generating capacity of both BWL's existing coal-fired power plants. BWL intends to retire those coal-fired power plants from service by 2025. However, before they can be retired, the new natural gas power plant must be operational. Emissions in the area will increase for a short period if the new combined-cycle plant is built. However, there will be overall reductions in emissions when the existing coal fired power plants are taken out of service.	EUCTGHRSG2--A 667 MMBTU/H natural gas fired CTG with a HRSG.	15.210	Natural gas	667	MMBTU/H	EUCTGHRSG2 is a nominally rated 667 MMBTU/H natural gas fired CTG coupled with a HRSG. The HRSG is equipped with a natural gas fired duct burner rated at 204 MMBTU/h to provide heat for additional steam production. The CTG is capable of operating in combined-cycle mode where the exhaust is routed to the HRSG or in simple-cycle mode where the HRSG is bypassed. The HRSG is not capable of operating independently from the CTG. The CTG/HRSG is equipped with a DLNB, SCR and oxidation catalyst.	Particulate matter, total $2.5 \mu\text{m}$ (TPM2.5)	Pipeline quality natural gas, inlet air conditioning, and good combustion practices.	6.02	LB/H	HOURLY
LBWL--ERICKSON STATION	LANSING BOARD OF WATER AND LIGHT	EATON	MI	12/21/2018	Natural gas combined-cycle power plant.	The proposed new plant will be replacing the electrical generating capacity of both BWL's existing coal-fired power plants. BWL intends to retire those coal-fired power plants from service by 2025. However, before they can be retired, the new natural gas power plant must be operational. Emissions in the area will increase for a short period if the new combined-cycle plant is built. However, there will be overall reductions in emissions when the existing coal fired power plants are taken out of service.	EUCTGHRSG1--A 667 MMBTU/H NG fired combustion turbine generator coupled with a heat recovery steam generator (HRSG)	15.210	Natural gas	667	MMBTU/H	A nominally rated 667 MMBTU/hr natural gas-fired combustion turbine generator (CTG) coupled with a heat recovery steam generator (HRSG). The HRSG is equipped with a natural gas-fired duct burner rated at 204 MMBTU/hr to provide heat for additional steam production. The CTG is capable of operating in combined-cycle mode where the exhaust is routed to the HRSG or in simple-cycle mode where the HRSG is bypassed. The HRSG is not capable of operating independently from the CTG. The CTG/HRSG is equipped with a dry low NOx burner (DLNB), selective catalytic reduction (SCR) and oxidation catalyst.	Particulate matter, total $10 \mu\text{m}$ (TPM10)	Pipeline quality natural gas, inlet air conditioning, and good combustion practices.	6.02	LB/H	HOURLY

Table C-3. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - PM

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
LBWL--ERICKSON STATION	LANSING BOARD OF WATER AND LIGHT	EATON	MI	12/21/2018	Natural gas combined-cycle power plant.	The proposed new plant will be replacing the electrical generating capacity of both BWL's existing coal-fired power plants. BWL intends to retire those coal-fired power plants from service by 2025. However, before they can be retired, the new natural gas power plant must be operational. Emissions in the area will increase for a short period if the new combined-cycle plant is built. However, there will be overall reductions in emissions when the existing coal fired power plants are taken out of service.	EUCTGHRSG1-A 667 MMBTU/H NG fired combustion turbine generator coupled with a heat recovery steam generator (HRSG)	15.210	Natural gas	667	MMBTU/H	A nominally rated 667 MMBTU/hr natural gas-fired combustion turbine generator (CTG) coupled with a heat recovery steam generator (HRSG). The HRSG is equipped with a natural gas-fired duct burner rated at 204 MMBTU/hr to provide heat for additional steam production. The CTG is capable of operating in combined-cycle mode where the exhaust is routed to the HRSG or in simple-cycle mode where the HRSG is bypassed. The HRSG is not capable of operating independently from the CTG. The CTG/HRSG is equipped with a dry low NOx burner (DLNB), selective catalytic reduction (SCR) and oxidation catalyst.	Particulate matter, total <math>2.5 \mu\text{m}</math> (TPM2.5)	Pipeline quality natural gas, inlet air conditioning and good combustion practices.	6.02	LB/H	HOURLY
LBWL--ERICKSON STATION	LANSING BOARD OF WATER AND LIGHT	EATON	MI	12/21/2018	Natural gas combined-cycle power plant.	The proposed new plant will be replacing the electrical generating capacity of both BWL's existing coal-fired power plants. BWL intends to retire those coal-fired power plants from service by 2025. However, before they can be retired, the new natural gas power plant must be operational. Emissions in the area will increase for a short period if the new combined-cycle plant is built. However, there will be overall reductions in emissions when the existing coal fired power plants are taken out of service.	EUCTGSC1-A nominally rated 667 MMBTU/hr natural gas-fired simple cycle CTG	15.110	Natural Gas	667	MMBTU/H	A nominally rated 667 MMBTU/H natural gas-fired simple cycle CTG. The CTG will utilize DLNB and good combustion practices.	Particulate matter, total PM2.5 (TPM2.5)	Pipeline quality natural gas, inlet air conditioning and good combustion practices.	4.5	LB/H	HOURLY
LBWL--ERICKSON STATION	LANSING BOARD OF WATER AND LIGHT	EATON	MI	12/21/2018	Natural gas combined-cycle power plant.	The proposed new plant will be replacing the electrical generating capacity of both BWL's existing coal-fired power plants. BWL intends to retire those coal-fired power plants from service by 2025. However, before they can be retired, the new natural gas power plant must be operational. Emissions in the area will increase for a short period if the new combined-cycle plant is built. However, there will be overall reductions in emissions when the existing coal fired power plants are taken out of service.	EUCTGSC1-A nominally rated 667 MMBTU/hr natural gas-fired simple cycle CTG	15.110	Natural Gas	667	MMBTU/H	A nominally rated 667 MMBTU/H natural gas-fired simple cycle CTG. The CTG will utilize DLNB and good combustion practices.	Particulate matter, total PM10 (TPM10)	Pipeline quality natural gas, inlet air conditioning and good combustion practices.	4.5	LB/H	HOURLY
GAS TREATMENT PLANT	ALASKA GASLINE DEVELOPMENT CORPORATION	NORTH SLOPE BOROUGH	AK	8/13/2020	The Gas Treatment Plant (GTP) is part of one integrated liquefied natural gas (LNG) project to bring natural gas from Alaskas North Slope to international markets in the form of LNG, as well as for in-state deliveries in the form of natural gas. The GTP will take gas from the Prudhoe Bay Unit and the Point Thomson Unit and treat/process the gas, before it is sent 807 miles through a 42-inch diameter pipeline to a liquefaction facility in Nikiski on Alaskas Kenai Peninsula for export in foreign commerce. The emissions units at the stationary source will include cogeneration gas-fired turbines with supplemental firing duct burners for gas compression, simple cycle gas-fired turbines for power generation, gas-fired heaters for building and process heat, as well as flares for control of excess gas. In addition, the GTP will include a diesel-fired black start generator, several diesel-fired firewater pumps and emergency generators, and storage tanks for diesel and gasoline fuels.		Six (6) Simple Cycle Gas-Turbines (Power Generation)	15.110	Natural Gas	386	MMBtu/hr	EUs 25 -30 each provide 44 MW of power generation for the facility	Particulate matter, total (TPM)	Good Combustion Practices and burning clean fuels (NG)	0.007	LB/MMBTU	3-HOUR AVERAGE
GAS TREATMENT PLANT	ALASKA GASLINE DEVELOPMENT CORPORATION	NORTH SLOPE BOROUGH	AK	8/13/2020	The Gas Treatment Plant (GTP) is part of one integrated liquefied natural gas (LNG) project to bring natural gas from Alaskas North Slope to international markets in the form of LNG, as well as for in-state deliveries in the form of natural gas. The GTP will take gas from the Prudhoe Bay Unit and the Point Thomson Unit and treat/process the gas, before it is sent 807 miles through a 42-inch diameter pipeline to a liquefaction facility in Nikiski on Alaskas Kenai Peninsula for export in foreign commerce. The emissions units at the stationary source will include cogeneration gas-fired turbines with supplemental firing duct burners for gas compression, simple cycle gas-fired turbines for power generation, gas-fired heaters for building and process heat, as well as flares for control of excess gas. In addition, the GTP will include a diesel-fired black start generator, several diesel-fired firewater pumps and emergency generators, and storage tanks for diesel and gasoline fuels.		Six (6) Simple Cycle Gas-Turbines (Power Generation)	15.110	Natural Gas	386	MMBtu/hr	EUs 25 -30 each provide 44 MW of power generation for the facility	Particulate matter, total PM10 (TPM10)	Good Combustion Practices and burning clean fuels (NG)	0.007	LB/MMBTU	3-HOUR AVERAGE

Table C-3. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - PM

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
GAS TREATMENT PLANT	ALASKA GASLINE DEVELOPMENT CORPORATION	NORTH SLOPE BOROUGH	AK	8/13/2020	<p>The Gas Treatment Plant (GTP) is part of one integrated liquefied natural gas (LNG) project to bring natural gas from Alaskas North Slope to international markets in the form of LNG, as well as for in-state deliveries in the form of natural gas. The GTP will take gas from the Prudhoe Bay Unit and the Point Thomson Unit and treat/process the gas, before it is sent 807 miles through a 42-inch diameter pipeline to a liquefaction facility in Nikiski on Alaskas Kenai Peninsula for export in foreign commerce.</p> <p>The emissions units at the stationary source will include cogeneration gas-fired turbines with supplemental firing duct burners for gas compression, simple cycle gas-fired turbines for power generation, gas-fired heaters for building and process heat, as well as flares for control of excess gas. In addition, the GTP will include a diesel-fired black start generator, several diesel-fired firewater pumps and emergency generators, and storage tanks for diesel and gasoline fuels.</p>		Six (6) Simple Cycle Gas-Turbines (Power Generation)	15.110	Natural Gas	386	MMBtu/hr	EUs 25 -30 each provide 44 MW of power generation for the facility	Particulate matter, total PM2.5 (TPM2.5)	Good Combustion Practices and burning clean fuels (NG)	0.007	LB/MMBTU	3-HOUR AVERAGE

Table C-4. RBL Search Results for Large Fuel Oil Fired Turbines (Simple-Cycle) - PM

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
WOLVERINE POWER	WOLVERINE POWER SUPPLY COOPERATIVE, INC.	PRESQUE ISLE	MI	6/29/2011	Coal-fired power plant.		Turbine generator (EUBLACKSTART)	15.190	Diesel	540	MMBTU/H		Particulate matter, total PM10 (TPM10)		0.03	LB/MMBTU	TEST PROTOCOL
WOLVERINE POWER	WOLVERINE POWER SUPPLY COOPERATIVE, INC.	PRESQUE ISLE	MI	6/29/2011	Coal-fired power plant.		Turbine generator (EUBLACKSTART)	15.190	Diesel	540	MMBTU/H	This is a turbine generator identified in the permit as EUBLACKSTART. It has a throughput capacity of 540MMBTU/HR which equates to 102 MW. The maximum operation was based on 500 hours per year.	Particulate matter, total PM2.5 (TPM2.5)		16.2	LB/H	TEST PROTOCOL
HILL COUNTY GENERATING FACILITY	BRAZOS ELECTRIC COOPERATIVE	HILL	TX	4/7/2016	Four simple cycle combustion turbine electric generators are proposed. Natural gas or ultra-low sulfur diesel fuel oil are the fuels. Turbine model options are: General Electric (GE) 7FA.03, GE 7FA.04, GE 7FA.05, and Siemes SGT6-5000(5)ee. Electric output is between 684 and 928 megawatts (MW).		Simple Cycle Turbine	15.190	ULTRA LOW SULFUR DIESEL	171	MW	LIQUID FUEL ONLY USED AS BACKUP TO NATURAL GAS Each combustion turbine is limited to 624,000 million Btu of annual firing because these are peaking units. Emission control firing ULSD adds water injection.	Particulate matter, total PM10 (TPM10)	combustor designed for complete combustion and therefore minimizes emissions	9.8	LB/H	
HILL COUNTY GENERATING FACILITY	BRAZOS ELECTRIC COOPERATIVE	HILL	TX	4/7/2016	Four simple cycle combustion turbine electric generators are proposed. Natural gas or ultra-low sulfur diesel fuel oil are the fuels. Turbine model options are: General Electric (GE) 7FA.03, GE 7FA.04, GE 7FA.05, and Siemes SGT6-5000(5)ee. Electric output is between 684 and 928 megawatts (MW).		Simple Cycle Turbine	15.190	ULTRA LOW SULFUR DIESEL	171	MW	LIQUID FUEL ONLY USED AS BACKUP TO NATURAL GAS Each combustion turbine is limited to 624,000 million Btu of annual firing because these are peaking units. Emission control firing ULSD adds water injection.	Particulate matter, total PM2.5 (TPM2.5)	combustor designed for complete combustion and therefore minimizes emissions	9.8	LB/H	3-HR ROLLING AVERAGE

RBLC SEARCH RESULTS – CO

Appendix C - RBL Search Results
Washington County Power, LLC

Table C-5. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - CO

Facility Name	Corporate or Company Name	Facility County	State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel	Throughput	Throughput Units	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
PANDA SHERMAN POWER STATION	PANDA SHERMAN POWER LLC	GRAYSON	TX	2/3/2010	A combined-cycle power plant producing a nominal 600 MW with two Siemens SGT6-5000F (501F) or two GE 7FA gas turbines.	State permit 87225	Natural Gas-fired Turbines	16.210	Natural Gas	600	MW	2 Siemens SGT6-5000F or 2 GE Frame 7FA. Both capable of combined or simple cycle operation. 468 MMBtu/hr duct burners.	Carbon Monoxide	Good combustion practices	4.00	PPMVD	@ 15% O2, ROLLING 24-HR AVG, SIMPLE CYCLE
DAHLBERG COMBUSTION TURBINE ELECTRIC GENERATING FACILITY	SOUTHERN POWER COMPANY	JACKSON	GA	5/14/2010	PLANT DAHLBERG HAS PROPOSED TO CONSTRUCT AND OPERATE FOUR ADDITIONAL SIMPLE-CYCLE COMBUSTION TURBINES (SOURCE CODES: CT11-CT14) AND ONE FUEL OIL STORAGE TANK. THE PROPOSED PROJECT WILL HAVE A NOMINAL GENERATING CAPACITY OF 760 MW. THE FACILITY IS CURRENTLY PERMITTED TO OPERATE 10 DUAL-FUELED SIMPLE-CYCLE CTG's. AFTER THE EXPANSION, THE FACILITY WILL HAVE A TOTAL NOMINAL GENERATING CAPACITY OF 1530 MW.		SIMPLE CYCLE COMBUSTION TURBINE - ELECTRIC GENERATING PLANT	15.110	NATURAL GASE	1,530	MW	THE PROCESS USES FUEL OIL FOR BACKUP AT THE RATE OF 2129 MMBTU/H	Carbon Monoxide	GOOD COMBUSTION PRACTICES	9.00	PPM@15%O2	3-HOUR AVERAGE/CONDITION 3.3.24
PUEBLO AIRPORT GENERATING STATION	BLACK HILLS ELECTRIC GENERATION, LLC	PUEBLO	CO	7/22/2010	Combustion turbine power plant	New power plant consisting of 7 combustion turbines	Three simple cycle combustion turbines	15.110	natural gas	800	MMBTU/H	Three GE, LMS100PA, natural gas-fired, simple cycle CTG rated at 799.7 MMBtu per hour each, based on HHV.	Carbon Monoxide	Good Combustion Control and Catalytic Oxidation (CatOx)	10.00	PPMVD AT 15% O2	1-HR AVE
HOWARD DOWN STATION	VINELAND MUNICIPAL ELECTRIC UTILITY (VMEU)	CUMBERLAND	NJ	9/16/2010			SIMPLE CYCLE (NO WASTE HEAT RECOVERY) (>25 MW)	15.110	NATURAL GAS	5,000	MMFT3/YR	THE PROCESS CONSISTS OF ONE NEW TRENT 60 SIMPLE CYCLE COMBUSTION TURBINE. THE TURBINE WILL GENERATE 64 MW OF ELECTRICITY USING NATURAL GAS AS A PRIMARY FUEL (UP TO 8760 HOURS PER YEAR), WITH A BACKUP FUEL OF ULTRA LOW SULFUR DIESEL FUEL (ULSD) WHICH CAN ONLY BE COMBUSTED FOR A MAXIMUM OF 500 HOURS PER YEAR AND ONLY DURING NATURAL GAS CURTAILMENT. THE MAXIMUM HEAT INPUT RATE WHILE COMBUSTING NATURAL GAS IS 590 MMBTU/HR AND THE MAXIMUM HEAT INPUT RATE WHILE COMBUSTING ULSD IS 568 MMBTU/HR. THE TURBINE WILL UTILIZE WATER INJECTION AND SELECTIVE CATALYTIC REDUCTION TO CONTROL NOX EMISSION AND A CATALYTIC OXIDIZER TO CONTROL CO AND VOC EMISSION.	Carbon Monoxide	THE TURBINE WILL UTILIZE A CATALYTIC OXIDIZER TO CONTROL CO EMISSION, IN ADDITION TO USING CLEAN BURNING FUELS, NATURAL GAS AND ULTRA LOW SULFUR DISTILLATE OIL WITH 15 PPM SULFUR BY WEIGHT	5.00	PPMVD@15% O2	3HR ROLLING AVERAGE BASED ON 1-HR BLOCK
PSEG FOSSIL LLC KEARNY GENERATING STATION	PSEG FOSSIL LLC	HUDSON	NJ	10/27/2010	PSEG FOSSIL LLC KEARNY GENERATING STATION IS AN EXISTING ELECTRICITY GENERATING STATION.	This project consists of six new identical General Electric LM6000 sprint simple cycle combustion turbines burning natural gas. Each turbine will have a heat input rate of 485 million British thermal units per hour (MMBtu/hr) based on the high heating value of fuel (HHV). The combined maximum electricity generated by the six turbines will be 294 MW based on 2,978 hours of operation per turbine per year. All six new turbines will have water injection along with Selective Catalytic Reduction (SCR) systems to reduce Nitrogen Oxide (NOx) emissions and an oxidation catalyst to reduce Carbon Monoxide (CO) emissions	SIMPLE CYCLE TURBINE	15.110	Natural Gas	8,940,000	MMBtu/year (HHV)	Throughput <= 8.94xE6 MMBtu/year (HHV) combined for all six gas turbines. The 6 turbines are identical LM6000 simple cycle combustion turbines.	Carbon Monoxide	Oxidation Catalyst, Good combustion practices	5.00	PPMVD@15% O2	3-HR ROLLING AVERAGE BASED ON 1-HR BLOCK
CALCASIEU PLANT	ENTERGY GULF STATES LA LLC	CALCASIEU	LA	12/21/2011	320 MW POWER PLANT COMPRISED OF 2 NATURAL GAS-FIRED SIMPLE CYCLE COMBUSTION TURBINES.	APPLICATION ACCEPTED RECEIVED DATE = DATE OF ADMINISTRATIVE COMPLETENESS PSD TRIGGERED DUE TO RELAXATION OF A FEDERALLY-ENFORCEABLE CONDITION LIMITING POTENTIAL EMISSIONS BELOW MAJOR STATIONARY SOURCE THRESHOLDS.	TURBINE EXHAUST STACK NO. 1; NO. 2	15.110	NATURAL GAS	1,900	MM BTU/H EACH		Carbon Monoxide	DRY LOW NOX COMBUSTORS	781.00	LB/H	HOURLY MAXIMUM
CEDAR BAYOU ELECTRIC GERNERATION STATION	NRG TEXAS POWER	CHAMBERS	TX	9/12/2012	NRG is proposing to construct an additional electric power generation station at the existing site. The project will include two power blocks that can be operated in simple cycle or combined cycle modes. This entry is for the simple cycle operation. Each power block will contain a CTG with duct burners and HRSG. Three options were proposed: Siemens Model F5, GE7Fa, and Mitsubishi Heavy Industry G Frame. The units will produce between 215-263 MW each.		Simple Cycle Combustion Turbines	15.110	Natural Gas	225	MW	The gas turbines will be one of three options: (1) Two Siemens Model F5 (SF5) CTGs each rated at nominal capability of 225 megawatts (MW). (2) Two General Electric Model 7FA (GE7FA) CTGs each rated at nominal capability of 215 MW. (3) Two Mitsubishi Heavy Industry G Frame (MH1501G) CTGs each rated at a nominal electric output of 263 MW.	Carbon Monoxide	Good Combustion Practices	9.00	PPM	1HR ROLLING AVG.
R.M. HESKETT STATION	MONTANA-DAKOTA UTILITIES CO.	MORTON	ND	2/22/2013	Addition of a natural gas-fired turbine (Unit 3) to an existing coal-fired power plant. The turbine will be used for supplying peak power and is rated at 986 MMBtu/hr and 88 MWe at average site conditions.		Combustion Turbine	15.110	Natural gas	986	MMBTU/H	Turbine is a GE Model PG 7121 (7EA) used as a peaking unit.	Carbon Monoxide	Good Combustion	25.00	PPMVD @ 15% OXYGEN	4 H.R.A./WHEN > 50 MWE
WESTAR ENERGY - EMPORIA ENERGY CENTER	WESTAR ENERGY	LYON	KS	3/18/2013	The Westar Energy - Emporia Energy Center (Source ID: 1110046) is a fossil fuel power generation facility located in Emporia, Kansas.	This PSD permit with tracking number C-10656 is a modification of PSD permits C-9132 (issued on 5/5/2011) and C-7072 (issued 4/17/2007).	GE LM6000PC SPRINT Simple cycle combustion turbine	15.110	Pipeline quality natural gas	405	MMBTU/hr		Carbon Monoxide	utilize efficient combustion/design technology	63.80	LB/HR	FULL LOAD, AMBIENT TEMP < OR = TO 54 F
WESTAR ENERGY - EMPORIA ENERGY CENTER	WESTAR ENERGY	LYON	KS	3/18/2013	The Westar Energy - Emporia Energy Center (Source ID: 1110046) is a fossil fuel power generation facility located in Emporia, Kansas.	This PSD permit with tracking number C-10656 is a modification of PSD permits C-9132 (issued on 5/5/2011) and C-7072 (issued 4/17/2007).	GE 7FA Simple Cycle Combustion Turbine	15.110	Pipeline quality natural gas	1,780	MMBTU/HR		Carbon Monoxide	utilize efficient combustion/design technology	39.00	LB/HR	AT FULL LOAD
ECTOR COUNTY ENERGY CENTER	INVENERGY THERMAL DEVELOPMENT LLC	ECTOR	TX	5/13/2013	The proposed project is for two natural gas fired simple cycle CTGs. The proposed models include GE7Fa.03 and GE7Fa.05. They have an output of 165-193 MW. The new CTGs will operate as peaking units and will be limited to 2500 hours per year of operation each.		Simple Cycle Combustion Turbines	15.110	natural gas	180	MW		Carbon Monoxide	Good combustion practices	9.00	PPMVD	15%O2, 3HR AVERAGE
PIONEER GENERATING STATION	BASIN ELECTRIC POWER COOPERATIVE	WILLIAMS	ND	5/14/2013	Three GE LM6000 PC SPRINT natural gas fired turbines used to generate electricity for peak periods.	The permit was for the addition of 2 turbines to the station. Since a synthetic minor limit was relaxed for the first unit, BACT was required for all three turbines.	Natural gas-fired turbines	15.110	Natural gas	451	MMBTU/H	Rating is for each turbine.	Carbon Monoxide	Catalytic oxidation system	6.00	PPMVD	8 HR. ROLLING AVERAGE/EXCEPT STARTUP
LONESOME CREEK GENERATING STATION	BASIN ELECTRIC POWER COOP.	MCKENZIE	ND	9/16/2013	Three natural gas fired simple cycle turbines used to generate electricity for peak power demand. The turbines are GE LM6000 PF Sprint units with a nominal capacity of 45 MW each.		Natural Gas Fired Simple Cycle Turbines	15.110	Natural gas	412	MMBTU/H	The heat input is for a single unit.	Carbon Monoxide	Oxidation Catalyst	6.00	PPMVD	8-HOUR ROLLING AVERAGE EXCEPT STARTUP

Appendix C - RBL Search Results
Washington County Power, LLC

Table C-5. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - CO

Facility Name	Corporate or Company Name	Facility County	State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel	Throughput	Throughput Units	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
GUADALUPE GENERATING STATION	GUADALUPE POWER PARTNERS LP	GUADALUPE	TX	10/4/2013	Installing two natural gas-fired simple-cycle peaking combustion turbine generators. The two CTGs will produce between 383 and 454 MW combined. Four models are approved: GE7FA.03, GE7FA.04, GE7FA.05, or Siemens SW 5000F5.		(2) Simple cycle turbines	16.110	natural gas	190	MW	Four models are approved: GE7FA.03, GE7FA.04, GE7FA.05, or Siemens SW 5000F5. 383 MW to 454 MW total plant capacity.	Carbon Monoxide	DLN burners, limited operation	9.00	PPMVD	@15% O2, ALL LOADS
TROUTDALE ENERGY CENTER, LLC	TROUTDALE ENERGY CENTER, LLC	MULTNOMAH	OR	3/5/2014	Troutdale Energy Center (TEC) proposes to construct and operate a 653 megawatt (MW) electric generating plant in Troutdale, Oregon. TEC proposes to generate electricity with three natural gas-fired turbines, one of which will be a combined-cycle unit with duct burner and heat recovery steam generator.		GE LMS-100 combustion turbines, simple cycle with water injection	15.110	natural gas	1,690	MMBTU/H		Carbon Monoxide	Oxidation catalyst; Limit the time in startup or shutdown.	6.00	PPMDV AT 15% O2	3-HR ROLLING AVERAGE ON NG
ANTELOPE ELK ENERGY CENTER	GOLDEN SPREAD ELECTRIC COOPERATIVE, INC.	HALE	TX	4/22/2014	GSEC is proposing to build three additional new CTGs at the existing Antelope Elk Energy Center. The new facility will provide primarily peaking and intermediate power needs. The new units will be GE 7F5-Series gas turbines in simple cycle application, rated at 202 MW. Each turbine will operate a maximum of 4,572 hours per year.		Combustion Turbine-Generator(CTG)	15.110	Natural Gas	202	MW	Simple Cycle	Carbon Monoxide	Good combustion practices; limited hours	9.00	PPMVD	15% O2, 3HR AVG.
ANTELOPE ELK ENERGY CENTER	GOLDEN SPREAD ELECTRIC COOPERATIVE INC	HALE	TX	4/22/2014	Golden Spread Electric Cooperative (GSEC) currently owns and operates Antelope Station (now renamed Antelope Elk Energy Center), a 168 MW generating facility made up of 18 quick start engines. GSEC is proposing to build a new combustion turbine-generator (CTG) facility at Antelope Station, while the 18 engines will remain and continue to be authorized by TCEQ Standard Permit. The new turbine-generator will provide primarily peaking and intermediate power needs in a highly cyclical operation. The CTG will produce approximately 100 - 200 MW of electricity, depending on loading and ambient temperature.		Combustion turbine	15.110	natural gas	202	MW	new GE 7FA 5-Series gas turbine in a simple cycle application, with a maximum electric output of 202 megawatts (MW) and a maximum design capacity of 1,941 million British thermal units per hour (MMBtu/hr). The turbine will operate a maximum of 4,572 hours per year.	Carbon Monoxide	DLN combustors, good combustion practices	9.00	PPMVD	@15% O2, 3-HR ROLLING AVERAGE
ECTOR COUNTY ENERGY CENTER	INVENERGY THERMAL DEVELOPMENT LLC	ECTOR	TX	8/1/2014	The proposed project is to construct and operate two natural gas-fired simple-cycle combustion turbine generators (CTGs) at the Ector County Energy Center (ECEC), located approximately 20 miles northwest of Odessa, Texas, in Ector County.		(2) combustion turbines	15.110	natural gas	180	MW	(2) GE 7FA.03, 2500 hours of operation per year each	Carbon Monoxide	DLN combustors	9.00	PPMVD	@15% O2, 3-HR ROLLING AVG
ROANOK PRAIRIE GENERATING STATION	TENASKA ROANOK PRAIRIE PARTNERS (TRPP), LLC	GRIMES	TX	9/22/2014	The proposed project is to construct and operate the RPPS comprised of three new simple cycle combustion turbine generators (CTG), fueled by pipeline quality natural gas. The new CTGs will be peaking units, designed to operate during periods of high electric demand. The three CTGs will produce between 507 and 694 MW of electricity combined, depending on ambient temperature and the model of combustion turbine (CT) selected. The applicant is considering three models of CTs; one model will be selected and the permit revised to reflect the selection before construction begins. The three CT models are: (1) General Electric 7FA.04; (2) General Electric 7FA.05; or (3) Siemens SGT6-5000F.		(2) simple cycle turbines	15.110	natural gas	600	MW	The three possible CT models are: (1) General Electric 7FA.04; (2) General Electric 7FA.05; or (3) Siemens SGT6-5000F. will operate 2,920 hours per year at full load for each CT	Carbon Monoxide	DLN combustors	9.00	PPMVD	@15% O2, 3-HR ROLLING AVERAGE
PUEBLO AIRPORT GENERATING STATION	BLACK HILLS ELECTRIC GENERATION, LLC	PUEBLO	CO	12/11/2014	Electric generation	Permit modification to convert startup and shutdown BACT limits to an hourly basis (from event based).	Turbines - two simple cycle gas	15.110	natural gas	800	MMBTU/H each	GE LMS100PA, natural gas fired, simple cycle, combustion turbine.	Carbon Monoxide	Catalytic Oxidation.	55.00	LB/H	1-HR AVE / STARTUP AND SHUTDOWN
SR BERTRON ELECTRIC GENERATION STATION	NRG TEXAS POWER	HARRIS	TX	12/19/2014	NRG is proposing to construct an additional electric power generation station at the existing site. The project will include two power blocks that can be operated in simple cycle or combined cycle modes. This entry is for the simple cycle operation. Each power block will contain a CTG with duct burners and HRSG. Three options were proposed: Siemens Model F5, GE7Fa, and Mitsubishi Heavy Industry G Frame. The new units will produce between 215-263 MW each.		Simple cycle natural gas turbines	15.110	Natural Gas	225	MW		Carbon Monoxide	Good Combustion Practices	9.00	PPM	1HR ROLLING AVG.
INDECK WHARTON ENERGY CENTER	INDECK WHARTON, L.L.C.	WHARTON	TX	2/2/2015	Indeck Wharton, L.L.C. proposes to install three new natural gas fired combustion turbine generators (CTGs). The CTGs will either be the General Electric 7FA (~214 MW each) or the Siemens SGT6-5000F (~227 MW each), operating as peaking units in simple cycle mode.		(3) combustion turbines	15.110	natural gas	220	MW	The CTGs will either be the General Electric 7FA (~214 MW each) or the Siemens SGT6-5000F (~227 MW each), operating as peaking units in simple cycle mode	Carbon Monoxide	DLN combustors	4.00	PPMVD	@15% O2, 3-HR ROLLING AVG - SIEMENS
CLEAR SPRINGS ENERGY CENTER (CSEC)	NAVASOTA SOUTH PEAKERS OPERATING COMPANY II, LLC.	GUADALUPE	TX	5/8/2015	Navasota South Peakers Operating Company II LLC. proposes to install three new natural gas fired combustion turbine generators (CTGs). The CTGs will be the General Electric 7FA.04 (~214 MW each; manufacturers output at baseload, ISO at 183 MW), operating as peaking units in simple cycle.		Simple Cycle Turbine	15.110	natural gas	183	MW	The CTGs will be three General Electric 7FA.04 (~183 MW each for a total of 550 MW), operating as peaking units in simple cycle mode. Each turbine will be limited to 2,500 hours of operation per year. The new CTGs will use dry low-NOx (DLN) burners and may employ evaporative cooling for power enhancement.	Carbon Monoxide	DLN burners and good combustion practices	9.00	PPMVD @ 15% O2	ALL LOADS
ANTELOPE ELK ENERGY CENTER	GOLDEN SPREAD ELECTRIC COOPERATIVE, INC.	HALE	TX	5/12/2015	Golden Spread Electric Cooperative, Inc. (GSEC) is requesting authorization for three additional simple cycle electric generating plants at an existing site to meet increased energy demand in the area. The generating equipment consists of three new GE 7F5-Series natural gas-fired combustion turbine generators (CTGs). Each turbine has a maximum electric output of 202 MW.		Simple Cycle Turbine; Generator	15.110	natural gas	202	MW	3 additional GE 7F 5-Series Combustion Turbine Generators	Carbon Monoxide	Good combustion practices; limited operating hours	9.00	PPMVD @ 15% O2	3-HR AVERAGE
LAUDERDALE PLANT	FLORIDA POWER & LIGHT	BROWARD	FL	8/25/2015	Large natural gas- and oil-fired power facility, consisting of four combined cycle units, and many combustion turbines. Small peaking units being replaced with larger combustion turbines.	Re-affirmed BACT determinations in Permit No. 0110037-011-AC. Also, new GHG BACT determination. Technical evaluation available at https://arm-permit2k.dep.state.fl.us/nontv/0110037.013.AC.D.ZIP	Five 200-MW combustion turbines	15.110	Natural gas	2,100	MMBTU/hr (approx)	Five simple cycle GE 7F.05 turbines. Max of 3390 hours per year per turbine. Of the 3390 hours per year, up to 500 hour may be on ULSD fuel oil.	Carbon Monoxide	Good combustion minimizes CO formation	4.00	PPMVD@15% O2	NAT GAS, THREE 1-HR RUNS
SHAWNEE ENERGY CENTER	SHAWNEE ENERGY CENTER, LLC	HILL	TX	10/9/2015	Electric Generating Utility: The project will consist of four gas fired combustion turbines (CTGs). The CTGs are fueled with pipeline quality natural gas and will operate in simple cycle mode. The gas turbines will be one of two options.		Simple cycle turbines greater than 25 megawatts (MW)	15.110	natural gas	230	MW	Siemens Model SGT6-5000 F5e @ 230 MW or Second turbine option: General Electric Model 7FA.05TP @ 227 MW	Carbon Monoxide	dry low NOx burners and limited operation, clean fuel	9.00	PPMVD @ 15% O2	
NACOGDOCHES POWER ELECTRIC GENERATING PLANT	NACOGDOCHES POWER, LLC	NACOGDOCHES	TX	10/14/2015	Nacogdoches Power, LLC is requesting authorization for one natural gas fired, simple cycle combustion turbine generator (CTG). The CTG will be a Siemens F5 and have a nominal electric output of 232 megawatts (MW).		Natural Gas Simple Cycle Turbine (> 25 MW)	15.110	natural gas	232	MW	One Siemens F5 simple cycle combustion turbine generator	Carbon Monoxide	dry low NOx burners, good combustion practices, limited operation	9.00	PPMVD @ 15% O2	

Appendix C - RBL Search Results
Washington County Power, LLC

Table C-5. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - CO

Facility Name	Corporate or Company Name	Facility County	State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel	Throughput	Throughput Units	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
VAN ALSTYNE ENERGY CENTER (VAEC)	NAVASOTA NORTH COUNTRY PEAKERS OPERATING COMPANY I	GRAYSON	TX	10/27/2015	Navasota North Country Peakers Operating Company I LLC. proposes to install three new natural gas fired combustion turbine generators (CTGs). The CTGs will be the General Electric 7FA.04 (~214 MW each; manufacturers output at baseload, ISO at 183 MW), operating as peaking units in simple cycle.		Simple Cycle Turbine	15.110	natural gas	183	MW	The CTGs will be three General Electric 7FA.04 (~183 MW each for a total of 550 MW), operating as peaking units in simple cycle mode. Each turbine will be limited to 2,500 hours of operation per year. The new CTGs will use dry low-NOx (DLN) burners and may employ evaporative cooling for power enhancement.	Carbon Monoxide	DLN burners and good combustion practices	9.00	PPMVD @ 15% O2	
UNION VALLEY ENERGY CENTER	NAVASOTA SOUTH PEAKERS OPERATING COMPANY I, LLC.	NIXON	TX	12/9/2015	three new natural gas fired combustion turbine generators (CTGs). The CTGs will be the General Electric 7FA.04 (~214 megawatt (MW) each; manufacturers output at baseload, ISO at 183 MW), operating as peaking units in simple cycle		Simple Cycle Turbine	15.110	natural gas	183	MW	The CTGs will be three General Electric 7FA.04 (~183 MW each for a total of 550 MW), operating as peaking units in simple cycle mode. Each turbine will be limited to 2,500 hours of operation per year. The new CTGs will use dry low-NOx (DLN) burners and may employ evaporative cooling for power enhancement.	Carbon Monoxide	dry low NOx burners and good combustion practices	9.00	PPMVD @ 15% O2	ALL LOADS
DECORDOVA STEAM ELECTRIC STATION	DECORDOVA II POWER COMPANY LLC	HOOD	TX	3/8/2016	The DeCordova Station will consist of two combustion turbine generators (CTGs) operating in simple cycle or combined cycle modes. The gas turbines will be one of two options: Siemens or General Electric.		Combined Cycle; Cogeneration	15.210	natural gas	231	MW	2 CTGs to operate in simple cycle & combined cycle modes. 231 MW (Siemens) or 210 MW (GE). Simple cycle operations limited to 2,500 hr/vr.	Carbon Monoxide	OXIDATION CATALYST	4.00	PPM	
NECHES STATION	APEX TEXAS POWER LLC	CHEROKEE	TX	3/24/2016	either 4 simple cycle combustion turbine generators (CTGs) or two CTGs operating in simple cycle or combined cycle modes. The CTGs will be one of two options: Siemens or General Electric.		Large Combustion Turbines; 25 MW	15.110	natural gas	232	MW	4 Simple cycle CTGs, 2,500 hr/yr operational limitation. Facility will consist of either 232 MW (Siemens) or 220 MW (GE)	Carbon Monoxide	good combustion practices	9.00	PPM	
NECHES STATION	APEX TEXAS POWER LLC	CHEROKEE	TX	3/24/2016	either 4 simple cycle combustion turbine generators (CTGs) or two CTGs operating in simple cycle or combined cycle modes. The CTGs will be one of two options: Siemens or General Electric.		Combined Cycle; Cogeneration	15.210	natural gas	231	MW	2 CTGs to operate in simple cycle & combined cycle modes. 231 MW (Siemens) or 210 MW (GE) Simple cycle operations limited to 2,500 hr/yr.	Carbon Monoxide	OXIDATION CATALYST	4.00	PPM	HOURLY
HILL COUNTY GENERATING FACILITY	BRAZOS ELECTRIC COOPERATIVE	HILL	TX	4/7/2016	Four simple cycle combustion turbine electric generators are proposed. Natural gas or ultra-low sulfur diesel fuel oil are the fuels. Turbine model options are: General Electric (GE) 7FA.03, GE 7FA.04, GE 7FA.05, and Siemes SGT6-5000(S)ee. Electric output is between 684 and 928 megawatts (MW).		Simple cycle turbine	15.110	natural gas	171	MW	Each combustion turbine is limited to 2,920 hours of annual operation, including startup and shutdown hours.	Carbon Monoxide	Premixing of fuel and air enhances combustion efficiency and minimizes emissions.	9.00	PPMVD @ 15% O2	3-HR AVERAGE
BAYONNE ENERGY CENTER	BAYONNE ENERGY CENTER LLC	HUDSON	NJ	8/26/2016	The facility is adding two more new Roll Royce Trent 60 WLE (66 MW) each	The facility has eight existing simple cycle combustion turbines Rolls Royce Trent turbine 64 MW each. This permit allows the construction and operation of two more Rolls Royce Trent (WLE) simple cycle combustion turbines 66 MW each. The turbines will be dual fired, with natural gas as primary fuel and ultra low sulfur distillate oil with less than or equal to 15% sulfur by weight. The turbines will have SCR and Oxidation catalyst for removal of NOx, CO and VOC.	Simple Cycle Stationary Turbines firing Natural gas	15.110	Natural Gas	2,143,980	MMBTU/YR	The Siemens/Rolls Royce Trent 60 wet low emissions (WLE) combustion turbine generators (CTGs) will each have a maximum heat input rate while combusting natural gas of 643 million British thermal units per hour (MMBtu/hr) (higher heating value [HHV]) at 100 percent (%) load, at International Organization for Standardization (ISO) conditions of 59 degrees Fahrenheit (°F) and 60% relative humidity, generating 66 MW. The maximum heat input rate on ULSD at ISO condition would be 533.50 MMBtu/hr (HHV). Each of the CTG will be equipped with Water Injection and Selective Catalytic Reduction System (SCR) to control Nitrogen Oxide (NOx) emissions and Oxidation Catalyst to control Carbon Monoxide (CO) and Volatile Organic Compounds (VOC) emissions. The CTGs will have continuous emissions monitoring systems (CEMS) for NOx and CO.	Carbon Monoxide	Add-on control is CO Oxidation Catalyst, and use of natural gas as fuel for pollution prevention	5.00	PPMVD@15% O2	3 H ROLLING AV BASED ON ONE H BLOCK AV
DOSWELL ENERGY CENTER	DOSWELL LIMITED PARTNERSHIP DOSWELL ENERGY CENTER	HANAOVER	VA	10/4/2016	The facility is currently composed of four Kraftwerk Union/Siemens (Model: V84.2) combined cycle turbine units each equipped with a duct burner and supporting equipment (auxiliary boiler, fire pump, emergency generator and fuel oil storage tanks) under one Prevention of Significance Deterioration (PSD) permit and one simple cycle turbine unit under another PSD permit. The combined cycle turbines were permitted in a PSD permit originally issued on May 4, 1990 and last amended on August 3, 2005. The 190.5 MW simple cycle combustion turbine (CT-1) was added in a separate PSD permit dated April 7, 2000 and last amended on September 30, 2013.	DEC is proposing to add two GE 7FA simple cycle combustion turbines (CT-2 and CT-3) at the Doswell Energy Center. DEC is moving CT-2 and CT-3 from an existing permitted site in Desoto, Florida. They are both GE Frame 7FA Combustion Turbines that are very similar in age and capability to the DEC CT-1 (GE 7FA.03). The CT-2 and CT-3 maximum heat input assumed for natural gas firing is 1,961.0 MMBtu/hr (HHV).	Two (2) GE 7FA simple cycle combustion turbines	15.110	Natural Gas	1,961	MMBTU/HR		Carbon Monoxide	Pipeline Quality Natural Gas	13.99	LB	H/12 MO ROLLING TOTAL
WAVERLY FACILITY	PLEASANTS ENERGY, LLC	PLEASANTS	WV	1/23/2017	300 MW, natural gas fired, simple cycle peaking power facility	In this permitting action PSD only applies to the modified combustion turbines based on the relaxation of an original synthetic minor permit issued in 1999. Project also involves previous installation of turbo-charging. All BACT emission limits are given without turbocharging and startup/shutdown emissions are not included. Please contact above engineer for more information. There are two identical turbines but only one is listed.	GE Model 7FA Turbine	15.110	Natural Gas	1,571	mmbtu/hr	There are two identical units at the facility.	Carbon Monoxide	Good Combustion Practices	9.00	PPM	NATURAL GAS
CAMERON LNG FACILITY	CAMERON LNG LLC	CAMERON	LA	2/17/2017	a facility to liquefy natural gas for export (5 trains)	Permit PSD-LA-766, dated 10/1/13 for liquefaction trains 1,2, and 3 Permit PSD-LA-766(M1), dated 6/26/14, for minor changes; Permit PSD-LA-766(M2), dated 3/3/16, for train 4 and 5	Gas turbines (9 units)	15.110	natural gas	1,069	mmbtu/hr		Carbon Monoxide	good combustion practices and fueled by natural gas	15.00	PPMVD	@15%O2
GAINES COUNTY POWER PLANT	SOUTHWESTERN PUBLIC SERVICE COMPANY	0	TX	4/28/2017	constructed in phases, with natural gas-fired simple cycle combustion turbines (SCCTs) with dry low nitrogen oxide (NOx) burners (DLN) to be converted into 2-on-1 combined cycle combustion turbines (CCCTs) with selective catalytic reduction (SCRs), heat recovery steam generators (HRSGs, one per combustion turbine) and one steam turbine per two CCCTs. Federal control review only applies to the turbines and HRSGs.		Simple Cycle Turbine	15.110	natural gas	228	MW	Four Siemens SGT6-5000F5 natural gas fired combustion turbines	Carbon Monoxide	Good combustion practices; limited operating hours	9.00	PPMVD	3% O2 3-H AVG

Appendix C - RBLC Search Results
Washington County Power, LLC

Table C-5. RBLC Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - CO

Facility Name	Corporate or Company Name	Facility County	State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel	Throughput	Throughput Units	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
JACKSON COUNTY GENERATORS	SOUTHERN POWER	JACKSON	TX	1/26/2018	four natural gas-fired simple-cycle combustion turbines, five fuel gas heaters, and a firewater pump engine		Combustion Turbines	15.110	natural gas	920	MW	4 identical units, each limited to 2500 hours of operation per year	Carbon Monoxide	Dry low NOx burners	9.00	PPMVD	
JACKSON COUNTY GENERATORS	SOUTHERN POWER	JACKSON	TX	1/26/2018	four natural gas-fired simple-cycle combustion turbines, five fuel gas heaters, and a firewater pump engine		Combustion Turbines MSS	15.110	NATURAL GAS	-			Carbon Monoxide	Minimizing duration of startup/shutdown, using good air pollution control practices and safe operating practices.	0.01	TON/YR	
WAVERLY POWER PLANT	PLEASANTS ENERGY LLC	PLEASANTS	WV	3/13/2018	300 MW Simple-Cycle Peaking Plant	Modification to existing PSD Permit (R14-0034, RBLC Number WV-0027) to add advanced gas path technology to the turbines that was defined as a change in the method of operation that resulted a major modification to the turbines.	GE 7FA.004 Turbine	15.110	Natural Gas	168	MW	This one entry is for both turbines as they are the same. Each turbine, after this modification, is a nominal 167.8 MW GE Model 7FA.004. Has oil-fire backup.	Carbon Monoxide	Combustion Controls	33.90	LB/HR	
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WASHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG01 CO - Simple-Cycle Combustion Turbine 1 (Commissioning) [SCN0005]	15.110	Natural Gas	2,201	MM BTU/hr	Commissioning is a one-time event which occurs after construction and is not anticipated to exceed 180 days.	Carbon Monoxide	Good combustion practices & use of pipeline quality natural gas	2,000.00	LB/HR	HOURLY MAXIMUM
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WASHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG02 CO - Simple-Cycle Combustion Turbine 2 (Commissioning) [SCN0006]	15.110	natural gas	2,201	MM BTU/hr	Commissioning is a one-time event which occurs after construction and is not anticipated to exceed 180 days.	Carbon Monoxide	Good combustion practices & use of pipeline quality natural gas	2,000.00	LB/HR	HOURLY MAXIMUM
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WASHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG01 SUSD - Simple-Cycle Combustion Turbine 1 (Startup/Shutdown/Maintenance/Tuning/Runback) [EQT0019]	15.110	Natural Gas	2,201	MM BTU/hr	Limited to 600 hr/yr	Carbon Monoxide	Good combustion practices & use of pipeline quality natural gas	800.08	LB/HR	HOURLY MAXIMUM
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WASHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG02 SUSD - Simple-Cycle Combustion Turbine 2 (Startup/Shutdown/Maintenance/Tuning/Runback) [EQT0020]	15.110	Natural Gas	2,201	MM BTU/hr	limited to 600 hr/yr	Carbon Monoxide	Good combustion practices & use of pipeline quality natural gas	800.08	LB/HR	HOURLY MAXIMUM
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WASHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG01 NO - Simple-Cycle Combustion Turbine 1 (Normal Operations) [EQT0017]	15.110	Natural Gas	2,201	MM BTU/hr	Normal operations are based on 7000 hrs/yr	Carbon Monoxide	Good combustion practices & use of pipeline quality natural gas	6.00	PPMVD AT 15% OXYGEN	ANNUAL AVERAGE
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WASHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG02 NO - Simple-Cycle Combustion Turbine 2 (Normal Operations) [EQT0018]	15.110	Natural Gas	2,201	MM BTU/hr	Normal operations are based on 7000 hours per year	Carbon Monoxide	Good combustion practices & use of pipeline quality natural gas	6.00	PPMVD AT 15% O2	ANNUAL AVERAGE
DRIFTWOOD LNG FACILITY	DRIFTWOOD LNG LLC	CALCASIEU	LA	7/10/2018	Propose a new facility to liquefy natural gas for export		Compressor Turbines (20)	15.110	natural gas	540	mm btu/hr		Carbon Monoxide	Good Combustion Practices	25.00	PPMVD	@ 15% O2
CALCASIEU PASS LNG PROJECT	VENTURE GLOBAL CALCASIEU PASS, LLC	CAMERON	LA	9/21/2018	New Liquefied Natural Gas (LNG) production, storage, and export terminal.	Application Received September 2, 2015.	Simple Cycle Combustion Turbines (SCCT1 to SCCT3)	15.110	Natural Gas	927	MM BTU/h		Carbon Monoxide	Proper Equipment Design, Proper Operation, and Good Combustion Practices.	25.00	PPMV	30 DAY ROLLING AVERAGE
RIO BRAVO PIPELINE FACILITY	RIO GRANDE LNG LLC	CAMERON	TX	12/17/2018	Natural gas processing and liquefied natural gas (LNG) export terminal		Refrigeration Compression Turbines	15.110	NATL GAS	967	MMBTU/HR	Twelve General Electric Frame 7EA simple cycle combustion turbines to serve as drivers for refrigeration and compression at the site. There are six process trains and there are two turbines per train. One each of the pairs of turbines has a downstream heat exchanger in the exhaust stream. The heat exchanger heats oil in a closed circuit for process uses elsewhere in the natural gas liquefaction system.	Carbon Monoxide	Dry Low NOx burners. Good combustion practices	25.00	PPMVD	15% O2
LBWL--ERICKSON STATION	LANSING BOARD OF WATER AND LIGHT	EATON	MI	12/21/2018	Natural gas combined-cycle power plant.	The proposed new plant will be replacing the electrical generating capacity of both BWL's existing coal-fired power plants. BWL intends to retire those coal-fired power plants from service by 2025. However, before they can be retired, the new natural gas power plant must be operational. Emissions in the area will increase for a short period if the new combined-cycle plant is built. However, there will be overall reductions in emissions when the existing coal fired power plants are taken out of service.	EUCTGHRSG2--A 667 MMBTU/H natural gas fired CTG with a HRSG.	15.210	Natural gas	667	MMBTU/H	EUCTGHRSG2 is a nominally rated 667 MMBTU/H natural gas fired CTG coupled with a HRSG. The HRSG is equipped with a natural gas fired duct burner rated at 204 MMBTU/h to provide heat for additional steam production. The CTG is capable of operating in combined-cycle mode where the exhaust is routed to the HRSG or in simple-cycle mode where the HRSG is bypassed. The HRSG is not capable of operating independently from the CTG. The CTG/HRSG is equipped with a DLNB, SCR and oxidation catalyst.	Carbon Monoxide	An oxidation catalyst for CO control for each CTG/HRSG unit, good combustion practices.	4.00	PPM	PPMVD@15%O2; 24-H AVG; SEE NOTES
LBWL--ERICKSON STATION	LANSING BOARD OF WATER AND LIGHT	EATON	MI	12/21/2018	Natural gas combined-cycle power plant.	The proposed new plant will be replacing the electrical generating capacity of both BWL's existing coal-fired power plants. BWL intends to retire those coal-fired power plants from service by 2025. However, before they can be retired, the new natural gas power plant must be operational. Emissions in the area will increase for a short period if the new combined-cycle plant is built. However, there will be overall reductions in emissions when the existing coal fired power plants are taken out of service.	EUCTGSC1-A nominally rated 667 MMBTU/hr natural gas-fired simple cycle CTG	15.110	Natural gas	667	MMBTU/H	A nominally rated 667 MMBTU/H natural gas-fired simple cycle CTG. The CTG will utilize DLNB and good combustion practices.	Carbon Monoxide	Dry low NOx burners and good combustion practices.	9.00	LB/H	HOURLY EXCEPT DURING STARTUP/SHUTDOWN
LBWL--ERICKSON STATION	LANSING BOARD OF WATER AND LIGHT	EATON	MI	12/21/2018	Natural gas combined-cycle power plant.	The proposed new plant will be replacing the electrical generating capacity of both BWL's existing coal-fired power plants. BWL intends to retire those coal-fired power plants from service by 2025. However, before they can be retired, the new natural gas power plant must be operational. Emissions in the area will increase for a short period if the new combined-cycle plant is built. However, there will be overall reductions in emissions when the existing coal fired power plants are taken out of service.	EUCTGHRSG1--A 667 MMBTU/H NG fired combustion turbine generator coupled with a heat recovery steam generator (HRSG)	15.210	Natural gas	667	MMBTU/H	A nominally rated 667 MMBTU/hr natural gas-fired combustion turbine generator (CTG) coupled with a heat recovery steam generator (HRSG). The HRSG is equipped with a natural gas-fired duct burner rated at 204 MMBTU/hr to provide heat for additional steam production. The CTG is capable of operating in combined-cycle mode where the exhaust is routed to the HRSG or in simple-cycle mode where the HRSG is bypassed. The HRSG is not capable of operating independently from the CTG. The CTG/HRSG is equipped with a dry low NOx burner (DLNB), selective catalytic reduction (SCR) and oxidation catalyst.	Carbon Monoxide	An oxidation catalyst for CO control for each CTG/HRSG unit; good combustion practices.	4.00	PPM	PPMVD@15%O2; 24-H ROLL AVG; SEE NOTES

Table C-5. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - CO

Facility Name	Corporate or Company Name	Facility County	State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel	Throughput	Throughput Units	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
LBWL-ERICKSON STATION	LANSING BOARD OF WATER AND LIGHT	EATON	MI	12/21/2018	Natural gas combined-cycle power plant.	The proposed new plant will be replacing the electrical generating capacity of both BWL's existing coal-fired power plants. BWL intends to retire those coal-fired power plants from service by 2025. However, before they can be retired, the new natural gas power plant must be operational. Emissions in the area will increase for a short period if the new combined-cycle plant is built. However, there will be overall reductions in emissions when the existing coal fired power plants are taken out of service.	EUCTGHRSG1--A 667 MMBTU/H NG fired combustion turbine generator coupled with a heat recovery steam generator (HRSG)	15.210	Natural gas	667	MMBTU/H	A nominally rated 667 MMBTU/hr natural gas-fired combustion turbine generator (CTG) coupled with a heat recovery steam generator (HRSG). The HRSG is equipped with a natural gas-fired duct burner rated at 204 MMBTU/hr to provide heat for additional steam production. The CTG is capable of operating in combined-cycle mode where the exhaust is routed to the HRSG or in simple-cycle mode where the HRSG is bypassed. The HRSG is not capable of operating independently from the CTG. The CTG/HRSG is equipped with a dry low NOx burner (DLNB), selective catalytic reduction (SCR) and oxidation catalyst.	Carbon Monoxide	An oxidation catalyst for CO control for each CTG/HRSG unit; good combustion practices.	4.00	PPM	PPMVD@15%O2;24-H ROLL AVG; SEE NOTES
GAS TREATMENT PLANT	ALASKA GASLINE DEVELOPMENT CORPORATION	NORTH SLOPE BOROUGH	AK	8/13/2020	The Gas Treatment Plant (GTP) is part of one integrated liquefied natural gas (LNG) project to bring natural gas from Alaska's North Slope to international markets in the form of LNG, as well as for in-state deliveries in the form of natural gas. The GTP will take gas from the Prudhoe Bay Unit and the Point Thomson Unit and treat/process the gas, before it is sent 807 miles through a 42-inch diameter pipeline to a liquefaction facility in Nikiski on Alaska's Kenai Peninsula for export in foreign commerce. The emissions units at the stationary source will include cogeneration gas-fired turbines with supplemental firing duct burners for gas compression, simple cycle gas-fired turbines for power generation, gas-fired heaters for building and process heat, as well as flares for control of excess gas. In addition, the GTP will include a diesel-fired black start generator, several diesel-fired firewater pumps and emergency generators, and storage tanks for diesel and gasoline fuels.		Six (6) Simple Cycle Gas-Turbines (Power Generation)	15.110	Natural Gas	386	MMBTu/hr	EUs 25 -30 each provide 44 MW of power generation for the facility	Carbon Monoxide	Good Combustion Practices and burning clean fuels (NG)	15.00	PPMV @ 15% O2	3-HOUR AVERAGE

Table C-6. RBL Search Results for Large Fuel Oil Fired Turbines (Simple-Cycle) - CO Emission Limit

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel	Throughput	Throughput Units	PROCESS_NOTES	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
WOLVERINE POWER	WOLVERINE POWER SUPPLY COOPERATIVE, INC.	PRESQUE ISLE	MI	6/29/2011	Coal-fired power plant.		Turbine generator (EUBLACKSTART)	15.190	Diesel	540	MMBTU/H	This is a turbine generator identified in the permit as EUBLACKSTART. It has a throughput capacity of 540MMBTU/HR which equates to 102 MW. The maximum operation was based on 500 hours per year.	Carbon Monoxide		0.05	LB/MMBTU	TEST PROTOCOL
HILL COUNTY GENERATING FACILITY	BRAZOS ELECTRIC COOPERATIVE	HILL	TX	4/7/2016	Four simple cycle combustion turbine electric generators are proposed. Natural gas or ultra-low sulfur diesel fuel oil are the fuels. Turbine model options are: General Electric (GE) 7FA.03, GE 7FA.04, GE 7FA.05, and Siemes SGT6-5000(5)ee. Electric output is between 684 and 928 megawatts (MW).		Simple Cycle Turbine	15.190	ULTRA LOW SULFUR DIESEL	171	MW	LIQUID FUEL ONLY USED AS BACKUP TO NATURAL GAS Each combustion turbine is limited to 624,000 million Btu of annual firing because these are peaking units. Emission control firing ULSD adds water injection.	Carbon Monoxide	combustor designed for complete combustion and therefore minimizes emissions	20.00	PPMVD @ 15% O2	3-HR ROLLING AVERAGE

RBLC SEARCH RESULTS – VOC

Appendix C - RBL Search Results
Washington County Power, LLC

Table C-7. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - VOC

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel	Throughput	Throughput Units	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
PANDA SHERMAN POWER STATION	PANDA SHERMAN POWER LLC	GRAYSON	TX	2/3/2010	A combined-cycle power plant producing a nominal 600 MW with two Siemens SGT6-5000F (501F) or two GE 7FA gas turbines.	State permit 87225	Natural Gas-fired Turbines	16.210	Natural Gas	600	MW	2 Siemens SGT6-5000F or 2 GE Frame 7FA. Both capable of combined or simple cycle operation. 468 MMBtu/hr duct burners.	Volatile Organic Compounds (VOC)	Good combustion practices	1	PPMVD	@ 15% O ₂ , 3-HR AVG, SIMPLE CYCLE MODE
DAHLBERG COMBUSTION TURBINE ELECTRIC GENERATING FACILITY (P)	SOUTHERN POWER COMPANY	JACKSON	GA	5/14/2010	PLANT DAHLBERG HAS PROPOSED TO CONSTRUCT AND OPERATE FOUR ADDITIONAL SIMPLE-CYCLE COMBUSTION TURBINES (SOURCE CODES: CT11-CT14) AND ONE FUEL OIL STORAGE TANK. THE PROPOSED PROJECT WILL HAVE A NOMINAL GENERATING CAPACITY OF 760 MW. THE FACILITY IS CURRENTLY PERMITTED TO OPERATE 10 DUAL-FUELED SIMPLE-CYCLE CTG'S. AFTER THE EXPANSION, THE FACILITY WILL HAVE A TOTAL NOMINAL GENERATING CAPACITY OF 1530 MW.		SIMPLE CYCLE COMBUSTION TURBINE - ELECTRIC GENERATING PLANT	15.110	NATURAL GASE	1530	MW	THE PROCESS USES FUEL OIL FOR BACKUP AT THE RATE OF 2129 MMBTU/H	Volatile Organic Compounds (VOC)	GOOD COMBUSTION PRACTICES	5	PPM@15%O ₂	3 HOUR AVERAGE/CONTITION 3.3.24
PUEBLO AIRPORT GENERATING STATION	BLACK HILLS ELECTRIC GENERATION, LLC	PUEBLO	CO	7/22/2010	Combustion turbine power plant	New power plant consisting of 7 combustion turbines	Three simple cycle combustion turbines	15.110	natural gas	800	MMBTU/H	Three GE, LMS100PA, natural gas-fired, simple cycle CTG rated at 799.7 MMBtu per hour each based on HHV.	Volatile Organic Compounds (VOC)	Good Combustion Control and Catalytic Oxidation (CatOx)	2.50	PPMVD AT 15% O ₂	AVE OVER STACK TEST LENGTH
PUEBLO AIRPORT GENERATING STATION	BLACK HILLS ELECTRIC GENERATION, LLC	PUEBLO	CO	7/22/2010	Combustion turbine power plant	New power plant consisting of 7 combustion turbines	Three simple cycle combustion turbines	15.110	natural gas	800	MMBTU/H	Three GE, LMS100PA, natural gas-fired, simple cycle CTG rated at 799.7 MMBtu per hour each based on HHV.	Volatile Organic Compounds (VOC)	Good Combustion Control and Catalytic Oxidation (CatOx)	2.50	PPMVD AT 15% O ₂	AVE OVER STACK TEST LENGTH
PSEG FOSSIL LLC KEARNY GENERATING STATION	PSEG FOSSIL LLC	HUDSON	NJ	10/27/2010	PSEG FOSSIL LLC KEARNY GENERATING STATION IS AN EXISTING ELECTRICITY GENERATING STATION.	This project consists of six new identical General Electric LM6000 sprint simple cycle combustion turbines burning natural gas. Each turbine will have a heat input rate of 485 million British thermal units per hour (MMBtu/hr) based on the high heating value of fuel (HHV). The combined maximum electricity generated by the six turbines will be 294 MW based on 2,978 hours of operation per turbine per year. All six new turbines will have water injection along with Selective Catalytic Reduction (SCR) systems to reduce Nitrogen Oxide (NOx) emissions and an oxidation catalyst to reduce Carbon Monoxide (CO) emissions	SIMPLE CYCLE TURBINE	15.110	Natural Gas	8,940,000	MMBTU/year (HHV)	Throughput <= 8.94x10 ⁶ MMBtu/year (HHV) combined for all six gas turbines. The 6 turbines are identical LM6000 simple cycle combustion turbines.	Volatile Organic Compounds (VOC)	Oxidation Catalyst and good combustion practices, use of natural gas.	4.00	PPMVD@15% O ₂	AVERAGE OF THREE TESTS
CALCASIEU PLANT	ENTERGY GULF STATES LA LLC	CALCASIEU	LA	12/21/2011	320 MW POWER PLANT COMPRISED OF 2 NATURAL GAS-FIRED SIMPLE CYCLE COMBUSTION TURBINES.	APPLICATION ACCEPTED RECEIVED DATE = DATE OF ADMINISTRATIVE COMPLETENESS	TURBINE EXHAUST STACK NO. 1 & NO. 2	15.110	NATURAL GAS	1,900	MM BTU/H EACH		Volatile Organic Compounds (VOC)	DRY LOW NOX COMBUSTORS	7.00	LB/H	HOURLY MAXIMUM
WESTAR ENERGY - EMPORIA ENERGY CENTER	WESTAR ENERGY	LYON	KS	3/18/2013	The Westar Energy - Emporia Energy Center (Source ID: 1110046) is a fossil fuel power generation facility located in Emporia, Kansas.	This PSD permit with tracking number C-10656 is a modification of PSD permits C-9132 (issued on 5/5/2011) and C-7072 (issued 4/17/2007).	GE LM6000PC SPRINT Simple cycle combustion turbine	15.110	Pipeline quality natural gas	405	MMBTU/hr		Volatile Organic Compounds (VOC)	utilize efficient combustion/design technology	5.80	LB/HR	AT FULL LOAD
WESTAR ENERGY - EMPORIA ENERGY CENTER	WESTAR ENERGY	LYON	KS	3/18/2013	The Westar Energy - Emporia Energy Center (Source ID: 1110046) is a fossil fuel power generation facility located in Emporia, Kansas.	This PSD permit with tracking number C-10656 is a modification of PSD permits C-9132 (issued on 5/5/2011) and C-7072 (issued 4/17/2007).	GE 7FA Simple Cycle Combustion Turbine	15.110	Pipeline quality natural gas	1,780	MMBTU/HR		Volatile Organic Compounds (VOC)	will utilize efficient combustion/design technology	3.20	LB/HR	AT FULL LOAD
TROUTDALE ENERGY CENTER, LLC	TROUTDALE ENERGY CENTER, LLC	MULTNOMAH	OR	3/5/2014	Troutdale Energy Center (TEC) proposes to construct and operate a 653 megawatt (MW) electric generating plant in Troutdale, Oregon. TEC proposes to generate electricity with three natural gas-fired turbines, one of which will be a combined-cycle unit with duct burner and heat recovery steam generator.		GE LMS-100 combustion turbines, simple cycle with water injection	15.110	natural gas	1,690	MMBTU/H		Volatile Organic Compounds (VOC)	Oxidation catalyst; Limit the time in startup or shutdown.	-		
TROUTDALE ENERGY CENTER, LLC	TROUTDALE ENERGY CENTER, LLC	MULTNOMAH	OR	3/5/2014	Troutdale Energy Center (TEC) proposes to construct and operate a 653 megawatt (MW) electric generating plant in Troutdale, Oregon. TEC proposes to generate electricity with three natural gas-fired turbines, one of which will be a combined-cycle unit with duct burner and heat recovery steam generator.		GE LMS-100 combustion turbines, simple cycle with water injection	15.110	natural gas	1,690	MMBTU/H		Volatile Organic Compounds (VOC)	Oxidation catalyst; Limit the time in startup or shutdown.	-		
LAUDERDALE PLANT	FLORIDA POWER & LIGHT	BROWARD	FL	4/22/2014	Large natural gas- and oil-fired power facility, consisting of four combined cycle units, and many combustion turbines. Small peaking units being replaced with larger combustion turbines.	In this project, 24 peaking turbines from the Lauderdale facility are being replaced with five 200 MW combustion turbines at Lauderdale. The turbines will fire primarily natural gas, but may also fire ULSD fuel oil. Triggers PSD for NOx, PM, CO, VOC, and GHG. GHG permit issued by US EPA Region 4. Technical evaluation available at http://arm-permit2k.dep.state.fl.us/nontv/0110037.011.AC.D.ZIP	Five 200-MW combustion turbines	15.110	Natural gas	2,000	MMBTU/hr (approx)	Throughput could vary slightly (+/- 120 MMBtu/hr) depending on final selection of turbine model and firing of natural gas or oil. Primary fuel is expected to be gas. Each turbine limited to 3300 hrs per rolling 12-month period. Of these 3300 hrs, no more than 500 may use ULSD fuel oil.	Volatile Organic Compounds (VOC)	Good combustion practice	3.77	LB/H	THREE ONE-HR RUNS (NATURAL GAS)
ROANOK'S PRAIRIE GENERATING STATION	TENASKA ROANOK'S PRAIRIE PARTNERS (TRPP), LLC	GRIMES	TX	9/22/2014	The proposed project is to construct and operate the RPGS comprised of three new simple cycle combustion turbine generators (CTG), fueled by pipeline quality natural gas. The new CTGs will be peaking units, designed to operate during periods of high electric demand. The three CTGs will produce between 507 and 694 MW of electricity combined, depending on ambient temperature and the model of combustion turbine (CT) selected. The applicant is considering three models of CTs; one model will be selected and the permit revised to reflect the selection before construction begins. The three CT models are: (1) General Electric 7FA.04; (2) General Electric 7FA.05; or (3) Siemens SGT6- 5000F.		(2) simple cycle turbines	15.110	natural gas	600	MW	The three possible CT models are: (1) General Electric 7FA.04; (2) General Electric 7FA.05; or (3) Siemens SGT6- 5000F. will operate 2,920 hours per year at full load for each CT	Volatile Organic Compounds (VOC)	good combustion	1.40	PPMVD	@15% O ₂ GE OPTION
ANTELOPE ELK ENERGY CENTER	GOLDEN SPREAD ELECTRIC COOPERATIVE, INC.	HALE	TX	5/12/2015	Golden Spread Electric Cooperative, Inc. (GSEC) is requesting authorization for three additional simple cycle electric generating plants at an existing site to meet increased energy demand in the area. The generating equipment consists of three new GE 7F5-Series natural gas-fired combustion turbine generators (CTGs). Each turbine has a maximum electric output of 202 MW.		Simple Cycle Turbine & Generator	15.110	natural gas	202	MW	3 additional GE 7F 5-Series Combustion Turbine Generators	Volatile Organic Compounds (VOC)	Good combustion practices	2.00	PPMVD @ 15% O ₂	
SHAWNEE ENERGY CENTER	SHAWNEE ENERGY CENTER, LLC	HILL	TX	10/9/2015	Electric Generating Utility: The project will consist of four gas fired combustion turbines (CTGs). The CTGs are fueled with pipeline quality natural gas and will operate in simple cycle mode. The gas turbines will be one of two options.		Simple cycle turbines greater than 25 megawatts (MW)	15.110	natural gas	230	MW	Siemens Model SGT6-5000 F5e @ 230 MW or Second turbine option: General Electric Model 7FA.05TP @ 227 MW	Volatile Organic Compounds (VOC)	Pipeline quality natural gas; limited hours; good combustion practices.	1.40	PPMV	
NACOGDOCHES POWER ELECTRIC GENERATING PLANT	NACOGDOCHES POWER, LLC	NACOGDOCHES	TX	10/14/2015	Nacogdoches Power, LLC is requesting authorization for one natural gas fired, simple cycle combustion turbine generator (CTG). The CTG will be a Siemens F5 and have a nominal electric output of 232 megawatts (MW).		Natural Gas Simple Cycle Turbine (>25 MW)	15.110	natural gas	232	MW	One Siemens F5 simple cycle combustion turbine generator	Volatile Organic Compounds (VOC)	Pipeline quality natural gas; limited hours; good combustion practices.	2.00	PPMVD @ 15% O ₂	

Appendix C - RBL Search Results
Washington County Power, LLC

Table C-7. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - VOC

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel	Throughput	Throughput Units	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
DECORDOVA STEAM ELECTRIC STATION	DECORDOVA II POWER COMPANY LLC	HOOD	TX	3/8/2016	The DeCordova Station will consist of two combustion turbine generators (CTGs) operating in simple cycle or combined cycle modes. The gas turbines will be one of two options: Siemens or General Electric.		Combined Cycle & Cogeneration	15.210	natural gas	231	MW	2 CTGs to operate in simple cycle & combined cycle modes. 231 MW (Siemens) or 210 MW (GE). Simple cycle operations limited to 2,500 hr/yr.	Volatile Organic Compounds (VOC)	OXIDATION CATALYST	2.00	PPM	
NECHES STATION	APEX TEXAS POWER LLC	CHEROKEE	TX	3/24/2016	either 4 simple cycle combustion turbine generators (CTGs) or two CTGs operating in simple cycle or combined cycle modes. The CTGs will be one of two options: Siemens or General Electric.		Large Combustion Turbines > 25 MW	15.110	natural gas	232	MW	4 Simple cycle CTGs, 2,500 hr/yr operational limitation. Facility will consist of either 232 MW (Siemens) or 220 MW (GE)	Volatile Organic Compounds (VOC)	good combustion practices	2.00	PPM	
NECHES STATION	APEX TEXAS POWER LLC	CHEROKEE	TX	3/24/2016	either 4 simple cycle combustion turbine generators (CTGs) or two CTGs operating in simple cycle or combined cycle modes. The CTGs will be one of two options: Siemens or General Electric.		Combined Cycle & Cogeneration	15.210	natural gas	231	MW	2 CTGs to operate in simple cycle & combined cycle modes. 231 MW (Siemens) or 210 MW (GE) Simple cycle operations limited to 2,500 hr/yr.	Volatile Organic Compounds (VOC)	OXIDATION CATALYST	2.00	PPM	
HILL COUNTY GENERATING FACILITY	BRAZOS ELECTRIC COOPERATIVE	HILL	TX	4/7/2016	Four simple cycle combustion turbine electric generators are proposed. Natural gas or ultra-low sulfur diesel fuel oil are the fuels. Turbine model options are: General Electric (GE) 7FA.03, GE 7FA.04, GE 7FA.05, and Siemes SGT6-5000(5)ee. Electric output is between 684 and 928 megawatts (MW).		Simple cycle turbine	15.110	natural gas	171	MW	Each combustion turbine is limited to 2,920 hours of annual operation, including startup and shutdown hours.	Volatile Organic Compounds (VOC)	Premixing of fuel and air enhances combustion efficiency and minimizes emissions.	5.40	LB/H	
BAYONNNE ENERGY CENTER	BAYONNNE ENERGY CENTER LLC	HUDSON	NJ	8/26/2016	Facility consists of 8 existing Roll Royce Trent 60 WLE (64 MW) each. The facility is adding two more new Roll Royce Trent 60 WLE (66 MW) each	The facility has eight existing simple cycle combustion turbines Rolls Royce Trent turbine 64 MW each. This permit allows the construction and operation of two more Rolls Royce Trent (WLE) simple cycle combustion turbines 66 MW each. The turbines will be dual fired, with natural gas as primary fuel and ultra low sulfur distillate oil with less than or equal to 15% sulfur by weight. The turbines will have SCR and Oxidation catalyst for removal of NOx, CO and VOC.	Simple Cycle Stationary Turbines firing Natural gas	15.110	Natural Gas	2,143,980	MMBTU/YR	The Siemens/Rolls Royce Trent 60 wet low emissions (WLE) combustion turbine generators (CTGs) will each have a maximum heat input rate while combusting natural gas of 643 million British thermal units per hour (MMBtu/hr) (higher heating value [HHV]) at 100 percent (%) load, at International Organization for Standardization (ISO) conditions of 59 degrees Fahrenheit (°F) and 60% relative humidity, generating 66 MW. The maximum heat input rate on ULSD at ISO condition would be 533.50 MMBtu/hr (HHV). Each of the CTG will be equipped with Water Injection and Selective Catalytic Reduction System (SCR) to control Nitrogen Oxide (NOx) emissions and Oxidation Catalyst to control Carbon Monoxide (CO) and Volatile Organic Compounds (VOC) emissions. The CTGs will have continuous emissions monitoring systems (CEMs) for NOx and CO.	Volatile Organic Compounds (VOC)	Add-on VOC control is Oxidation Catalyst, and use of natural gas as fuel for pollution prevention	2.00	PPMVD@15% O2	3 H ROLLING AV BASED ON ONE H BLOCK AV
BAYONNNE ENERGY CENTER	BAYONNNE ENERGY CENTER LLC	HUDSON	NJ	8/26/2016	Facility consists of 8 existing Roll Royce Trent 60 WLE (64 MW) each. The facility is adding two more new Roll Royce Trent 60 WLE (66 MW) each	The facility has eight existing simple cycle combustion turbines Rolls Royce Trent turbine 64 MW each. This permit allows the construction and operation of two more Rolls Royce Trent (WLE) simple cycle combustion turbines 66 MW each. The turbines will be dual fired, with natural gas as primary fuel and ultra low sulfur distillate oil with less than or equal to 15% sulfur by weight. The turbines will have SCR and Oxidation catalyst for removal of NOx, CO and VOC.	Simple Cycle Stationary Turbines firing Natural gas	15.110	Natural Gas	2,143,980	MMBTU/YR	The Siemens/Rolls Royce Trent 60 wet low emissions (WLE) combustion turbine generators (CTGs) will each have a maximum heat input rate while combusting natural gas of 643 million British thermal units per hour (MMBtu/hr) (higher heating value [HHV]) at 100 percent (%) load, at International Organization for Standardization (ISO) conditions of 59 degrees Fahrenheit (°F) and 60% relative humidity, generating 66 MW. The maximum heat input rate on ULSD at ISO condition would be 533.50 MMBtu/hr (HHV). Each of the CTG will be equipped with Water Injection and Selective Catalytic Reduction System (SCR) to control Nitrogen Oxide (NOx) emissions and Oxidation Catalyst to control Carbon Monoxide (CO) and Volatile Organic Compounds (VOC) emissions. The CTGs will have continuous emissions monitoring systems (CEMs) for NOx and CO.	Volatile Organic Compounds (VOC)	Add-on VOC control is Oxidation Catalyst, and use of natural gas as fuel for pollution prevention	2.00	PPMVD@15% O2	3 H ROLLING AV BASED ON ONE H BLOCK AV
PUENTE POWER		VENTURA	CA	10/13/2016	Utility		Gas turbine	15.110	Natural gas	262	MW		Volatile Organic Compounds (VOC)		2.00	PPMVD AS METHANE	1 HOUR@15%O2
CAMERON LNG FACILITY	CAMERON LNG LLC	CAMERON	LA	2/17/2017	a facility to liquefy natural gas for export (5 trains)	Permit PSD-LA-766, dated 10/1/13 for liquefaction trains 1,2, and 3 Permit PSD-LA-766(M1), dated 6/26/14, for minor changes; Permit PSD-LA-766(M2), dated 3/3/16, for train 4 and 5	Gas turbines (9 units)	15.110	natural gas	1,069	mm btu/hr		Volatile Organic Compounds (VOC)	good combustion practices and fueled by natural gas	1.60	PPMVD	@15%O2
GAINES COUNTY POWER PLANT	SOUTHWESTERN PUBLIC SERVICE COMPANY		TX	4/28/2017	constructed in phases, with natural gas-fired simple cycle combustion turbines (SCCTs) with dry low nitrogen oxide (NOx) burners (DLN) to be converted into 2-on-1 combined cycle combustion turbines (CCCTs) with selective catalytic reduction (SCRs), heat recovery steam generators (HRSGs, one per combustion turbine) and one steam turbine per two CCCTs. Federal control review only applies to the turbines and HRSGs.		Simple Cycle Turbine	15.110	natural gas	228	MW	Four Siemens SGT6-5000F5 natural gas fired combustion turbines	Volatile Organic Compounds (VOC)	Pipeline quality natural gas; limited hours; good combustion practices	2.00	PPMVD	145% O2
JACKSON COUNTY GENERATORS	SOUTHERN POWER	JACKSON	TX	1/26/2018	four natural gas-fired simple-cycle combustion turbines, five fuel gas heaters, and a firewater pump engine		Combustion Turbines	15.110	natural gas	920	MW	4 identical units, each limited to 2500 hours of operation per year	Volatile Organic Compounds (VOC)	Good combustion practices	2.00	PPMVD	
JACKSON COUNTY GENERATORS	SOUTHERN POWER	JACKSON	TX	1/26/2018	four natural gas-fired simple-cycle combustion turbines, five fuel gas heaters, and a firewater pump engine		Combustion Turbines MSS	15.110	NATURAL GAS	-			Volatile Organic Compounds (VOC)	Minimizing duration of startup/shutdown, using good air pollution control practices and safe operating practices.	0.06	TON/YR	
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WSHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG01 CO - Simple-Cycle Combustion Turbine 1 (Commissioning) [SCN0005]	15.110	Natural Gas	2,201	MM BTU/hr	Commissioning is a one-time event which occurs after construction and is not anticipated to exceed 180 days.	Volatile Organic Compounds (VOC)	Good combustion practices & use of pipeline quality natural gas	-		
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WSHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG02 CO - Simple-Cycle Combustion Turbine 2 (Commissioning) [SCN0006]	15.110	natural gas	2,201	MM BTU/hr	Commissioning is a one-time event which occurs after construction and is not anticipated to exceed 180 days.	Volatile Organic Compounds (VOC)	Good combustion practices & use of pipeline quality natural gas	-		

Appendix C - RBL Search Results
Washington County Power, LLC

Table C-7. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - VOC

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel	Throughput	Throughput Units	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WASHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG01 SUSD - Simple-Cycle Combustion Turbine 1 (Startup/Shutdown/Maintenance/Tuning/Runback) [EQT0019]	15.110	Natural Gas	2,201	MM BTU/hr	Limited to 600 hr/yr	Volatile Organic Compounds (VOC)	Good combustion practices & use of pipeline quality natural gas	-		
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WASHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG02 SUSD - Simple-Cycle Combustion Turbine 2 (Startup/Shutdown/Maintenance/Tuning/Runback) [EQT0020]	15.110	Natural Gas	2,201	MM BTU/hr	limited to 600 hr/yr	Volatile Organic Compounds (VOC)	Good combustion practices & use of pipeline quality natural gas	-		
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WASHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG01 NO - Simple-Cycle Combustion Turbine 1 (Normal Operations) [EQT0017]	15.110	Natural Gas	2,201	MM BTU/hr	Normal operations are based on 7000 hrs/yr	Volatile Organic Compounds (VOC)	Good combustion practices & use of pipeline quality natural gas	-		
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WASHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG02 NO - Simple-Cycle Combustion Turbine 2 (Normal Operations) [EQT0018]	15.110	Natural Gas	2,201	MM BTU/hr	Normal operations are based on 7000 hours per year	Volatile Organic Compounds (VOC)	Good combustion practices & use of pipeline quality natural gas	-		
DRIFTWOOD LNG FACILITY	DRIFTWOOD LNG LLC	CALCASIEU	LA	7/10/2018	Propose a new facility to liquefy natural gas for export		Compressor Turbines (20)	15.110	natural gas	540	mm btu/hr		Volatile Organic Compounds (VOC)	Good Combustion Practices and Use of low sulfur facility fuel gas	2.00E-03	LB/MM BTU	HHV
CALCASIEU PASS LNG PROJECT	VENTURE GLOBAL CALCASIEU PASS, LLC	CAMERON	LA	9/21/2018	New Liquefied Natural Gas (LNG) production, storage, and export terminal.	Application Received September 2, 2015.	Simple Cycle Combustion Turbines (SCCT1 to SCCT3)	15.110	Natural Gas	927	MM BTU/h		Volatile Organic Compounds (VOC)	Proper Equipment Design, Proper Operation, and Good Combustion Practices.	1.40	PPMV	3 HOUR AVERAGE
CALCASIEU PASS LNG PROJECT	VENTURE GLOBAL CALCASIEU PASS, LLC	CAMERON	LA	9/21/2018	New Liquefied Natural Gas (LNG) production, storage, and export terminal.	Application Received September 2, 2015.	Simple Cycle Combustion Turbines (SCCT1 to SCCT3)	15.110	Natural Gas	927	MM BTU/h		Volatile Organic Compounds (VOC)	Proper Equipment Design, Proper Operation, and Good Combustion Practices.	1.40	PPMV	3 HOUR AVERAGE
CALCASIEU PASS LNG PROJECT	VENTURE GLOBAL CALCASIEU PASS, LLC	CAMERON	LA	9/21/2018	New Liquefied Natural Gas (LNG) production, storage, and export terminal.	Application Received September 2, 2015.	Simple Cycle Combustion Turbines (SCCT1 to SCCT3)	15.110	Natural Gas	927	MM BTU/h		Volatile Organic Compounds (VOC)	Proper Equipment Design, Proper Operation, and Good Combustion Practices.	1.40	PPMV	3 HOUR AVERAGE
RIO BRAVO PIPELINE FACILITY	RIO GRANDE LNG LLC	CAMERON	TX	12/17/2018	Natural gas processing and liquefied natural gas (LNG) export terminal		Refrigeration Compression Turbines	15.110	NATL GAS	967	MMBTU/HR	Twelve General Electric Frame 7EA simple cycle combustion turbines to serve as drivers for refrigeration and compression at the site. There are six process trains and there are two turbines per train. One each of the pairs of turbines has a downstream heat exchanger in the exhaust stream. The heat exchanger heats oil in a closed circuit for process uses elsewhere in the natural gas liquefaction system.	Volatile Organic Compounds (VOC)	Good combustion practices	2.00	PPMVD	15% O2
LBWL-ERICKSON STATION	LANSING BOARD OF WATER AND LIGHT	EATON	MI	12/21/2018	Natural gas combined-cycle power plant.	The proposed new plant will be replacing the electrical generating capacity of both BWL's existing coal-fired power plants. BWL intends to retire those coal-fired power plants from service by 2025. However, before they can be retired, the new natural gas power plant must be operational. Emissions in the area will increase for a short period if the new combined-cycle plant is built. However, there will be overall reductions in emissions when the existing coal fired power plants are taken out of service.	EUCTGHRSG2--A 667 MMBTU/H natural gas fired CTG with a HRSG.	15.210	Natural gas	667	MMBTU/H	EUCTGHRSG2 is a nominally rated 667 MMBTU/H natural gas fired CTG coupled with a HRSG. The HRSG is equipped with a natural gas fired duct burner rated at 204 MMBTU/h to provide heat for additional steam production. The CTG is capable of operating in combined-cycle mode where the exhaust is routed to the HRSG or in simple-cycle mode where the HRSG is bypassed. The HRSG is not capable of operating independently from the CTG. The CTG/HRSG is equipped with a DLNB, SCR and oxidation catalyst.	Volatile Organic Compounds (VOC)	An oxidation catalyst for VOC control and good combustion practices.	3.00	PPM	PPMVD@15%O2; HOURLY; SEE NOTES
LBWL-ERICKSON STATION	LANSING BOARD OF WATER AND LIGHT	EATON	MI	12/21/2018	Natural gas combined-cycle power plant.	The proposed new plant will be replacing the electrical generating capacity of both BWL's existing coal-fired power plants. BWL intends to retire those coal-fired power plants from service by 2025. However, before they can be retired, the new natural gas power plant must be operational. Emissions in the area will increase for a short period if the new combined-cycle plant is built. However, there will be overall reductions in emissions when the existing coal fired power plants are taken out of service.	EUCTGHRSG1--A 667 MMBTU/H NG fired combustion turbine generator coupled with a heat recovery steam generator (HRSG)	15.210	Natural gas	667	MMBTU/H	A nominally rated 667 MMBTU/hr natural gas-fired combustion turbine generator (CTG) coupled with a heat recovery steam generator (HRSG). The HRSG is equipped with a natural gas-fired duct burner rated at 204 MMBTU/hr to provide heat for additional steam production. The CTG is capable of operating in combined-cycle mode where the exhaust is routed to the HRSG or in simple-cycle mode where the HRSG is bypassed. The HRSG is not capable of operating independently from the CTG. The CTG/HRSG is equipped with a dry low NOx burner (DLNB), selective catalytic reduction (SCR) and oxidation catalyst.	Volatile Organic Compounds (VOC)	An oxidation catalyst for VOC control for each CTG/HRSG unit, good combustion practices.	3.00	PPM	PPMVD@15%O2; EXCSTART/SHUT; NOTE
LBWL-ERICKSON STATION	LANSING BOARD OF WATER AND LIGHT	EATON	MI	12/21/2018	Natural gas combined-cycle power plant.	The proposed new plant will be replacing the electrical generating capacity of both BWL's existing coal-fired power plants. BWL intends to retire those coal-fired power plants from service by 2025. However, before they can be retired, the new natural gas power plant must be operational. Emissions in the area will increase for a short period if the new combined-cycle plant is built. However, there will be overall reductions in emissions when the existing coal fired power plants are taken out of service.	EUCTGHRSG2--A 667 MMBTU/H natural gas fired CTG with a HRSG.	15.210	Natural gas	667	MMBTU/H	EUCTGHRSG2 is a nominally rated 667 MMBTU/H natural gas fired CTG coupled with a HRSG. The HRSG is equipped with a natural gas fired duct burner rated at 204 MMBTU/h to provide heat for additional steam production. The CTG is capable of operating in combined-cycle mode where the exhaust is routed to the HRSG or in simple-cycle mode where the HRSG is bypassed. The HRSG is not capable of operating independently from the CTG. The CTG/HRSG is equipped with a DLNB, SCR and oxidation catalyst.	Volatile Organic Compounds (VOC)	An oxidation catalyst for VOC control and good combustion practices.	3.00	PPM	PPMVD@15%O2; HOURLY; SEE NOTES
LBWL-ERICKSON STATION	LANSING BOARD OF WATER AND LIGHT	EATON	MI	12/21/2018	Natural gas combined-cycle power plant.	The proposed new plant will be replacing the electrical generating capacity of both BWL's existing coal-fired power plants. BWL intends to retire those coal-fired power plants from service by 2025. However, before they can be retired, the new natural gas power plant must be operational. Emissions in the area will increase for a short period if the new combined-cycle plant is built. However, there will be overall reductions in emissions when the existing coal fired power plants are taken out of service.	EUCTGSC1-A nominally rated 667 MMBTU/hr natural gas-fired simple cycle CTG	15.110	Natural gas	667	MMBTU/H	A nominally rated 667 MMBTU/H natural gas-fired simple cycle CTG. The CTG will utilize DLNB and good combustion practices.	Volatile Organic Compounds (VOC)	Good combustion practices.	5.00	LB/H	HOURLY EXCEPT DURING STARTUP/SHUTDOWN

Table C-7. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - VOC

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel	Throughput	Throughput Units	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
LBWL-ERICKSON STATION	LANSING BOARD OF WATER AND LIGHT	EATON	MI	12/21/2018	Natural gas combined-cycle power plant.	The proposed new plant will be replacing the electrical generating capacity of both BWL's existing coal-fired power plants. BWL intends to retire those coal-fired power plants from service by 2025. However, before they can be retired, the new natural gas power plant must be operational. Emissions in the area will increase for a short period if the new combined-cycle plant is built. However, there will be overall reductions in emissions when the existing coal fired power plants are taken out of service.	EUCTGHRSG1--A 667 MMBTU/H NG fired combustion turbine generator coupled with a heat recovery steam generator (HRSG)	15.210	Natural gas	667	MMBTU/H	A nominally rated 667 MMBTU/hr natural gas-fired combustion turbine generator (CTG) coupled with a heat recovery steam generator (HRSG). The HRSG is equipped with a natural gas-fired duct burner rated at 204 MMBTU/hr to provide heat for additional steam production. The CTG is capable of operating in combined-cycle mode where the exhaust is routed to the HRSG or in simple-cycle mode where the HRSG is bypassed. The HRSG is not capable of operating independently from the CTG. The CTG/HRSG is equipped with a dry low NOx burner (DLNB), selective catalytic reduction (SCR) and oxidation catalyst.	Volatile Organic Compounds (VOC)	An oxidation catalyst for VOC control for each CTG/HRSG unit, good combustion practices.	3.00	PPM	PPMVD@15%O2; HOURLY EXCSTART/SHUT; NOTE
GAS TREATMENT PLANT	ALASKA GASLINE DEVELOPMENT CORPORATION	NORTH SLOPE BOROUGH	AK	8/13/2020	The Gas Treatment Plant (GTP) is part of one integrated liquefied natural gas (LNG) project to bring natural gas from Alaska's North Slope to international markets in the form of LNG, as well as for in-state deliveries in the form of natural gas. The GTP will take gas from the Prudhoe Bay Unit and the Point Thomson Unit and treat/process the gas, before it is sent 807 miles through a 42-inch diameter pipeline to a liquefaction facility in Nikiski on Alaska's Kenai Peninsula for export in foreign commerce. The emissions units at the stationary source will include cogeneration gas-fired turbines with supplemental firing duct burners for gas compression, simple cycle gas-fired turbines for power generation, gas-fired heaters for building and process heat, as well as flares for control of excess gas. In addition, the GTP will include a diesel-fired black start generator, several diesel-fired firewater pumps and emergency generators, and storage tanks for diesel and gasoline fuels.		Six (6) Simple Cycle Gas-Turbines (Power Generation)	15.110	Natural Gas	386	MMBTU/hr	EUs 25 -30 each provide 44 MW of power generation for the facility	Volatile Organic Compounds (VOC)	Good Combustion Practices and burning clean fuels (NG)	2.20E-03	LB/MMBTU	3-HOUR AVERAGE
GAS TREATMENT PLANT	ALASKA GASLINE DEVELOPMENT CORPORATION	NORTH SLOPE BOROUGH	AK	8/13/2020	The Gas Treatment Plant (GTP) is part of one integrated liquefied natural gas (LNG) project to bring natural gas from Alaska's North Slope to international markets in the form of LNG, as well as for in-state deliveries in the form of natural gas. The GTP will take gas from the Prudhoe Bay Unit and the Point Thomson Unit and treat/process the gas, before it is sent 807 miles through a 42-inch diameter pipeline to a liquefaction facility in Nikiski on Alaska's Kenai Peninsula for export in foreign commerce. The emissions units at the stationary source will include cogeneration gas-fired turbines with supplemental firing duct burners for gas compression, simple cycle gas-fired turbines for power generation, gas-fired heaters for building and process heat, as well as flares for control of excess gas. In addition, the GTP will include a diesel-fired black start generator, several diesel-fired firewater pumps and emergency generators, and storage tanks for diesel and gasoline fuels.		Six (6) Simple Cycle Gas-Turbines (Power Generation)	15.110	Natural Gas	386	MMBTU/hr	EUs 25 -30 each provide 44 MW of power generation for the facility	Volatile Organic Compounds (VOC)	Good Combustion Practices and burning clean fuels (NG)	2.20E-03	LB/MMBTU	3-HOUR AVERAGE

Table C-8. RBL Search Results for Large Fuel Oil Fired Turbines (Simple-Cycle) - VOC

Facility Name	Corporate or Company Name	Facility County	State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel	Throughput	Throughput Units	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Units	Emission Limit 1 Average Time Condition
HILL COUNTY GENERATING FACILITY	BRAZOS ELECTRIC COOPERATIVE	HILL	TX	4/7/2016	Four simple cycle combustion turbine electric generators are proposed. Natural gas or ultra-low sulfur diesel fuel oil are the fuels. Turbine model options are: General Electric (GE) 7FA.03, GE 7FA.04, GE 7FA.05, and Siemes SGT6-5000(5)ee. Electric output is between 684 and 928 megawatts (MW).		Simple Cycle Turbine	15.190	ULTRA LOW SULFUR DIESEL	171	MW	LIQUID FUEL ONLY USED AS BACKUP TO NATURAL GAS Each combustion turbine is limited to 624,000 million Btu of annual firing because these are peaking units. Emission control firing ULSD adds water injection.	Volatile Organic Compounds (VOC)	combustor designed for complete combustion and therefore minimizes emissions	3.30	LB/H	

RBLC SEARCH RESULTS – GHG

Table C-9. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - GHG

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Unit	Emission Limit 1 Average Time Condition
YORK GENERATION FACILITY	YORK PLANT HOLDINGS, LLC	YORK COUNTY	PA	3/1/2012	This plan approval will allow for the construction and temporary operation of two new combustion turbines at the facility.		COMBUSTION TURBINE, DUAL FUEL, T01 and T02 (2 Units)	15.900	Natural Gas	634	MMBTU/H	The combined number of hours of operation for both turbines shall not exceed 6000 hours per each consecutive 12-month period. The combined number of hours of distillate fuel oil firing for both turbines shall not exceed 1700 hours per each consecutive 12-month period. The liquid distillate fuel oil fired in the combustion turbines shall be ultra low sulfur kerosene - maximum sulfur content of 15 ppm or ultra low sulfur diesel (ULSD) - maximum sulfur content of 15 ppm (as defined in ASTM standard D975 Table 1). In addition to operational limits, air emissions will be minimized by Catalytic Oxidizer for CO control and Water injection followed by Selective Catalytic Reduction system utilizing aqueous ammonia for NOx control.	Carbon Dioxide Equivalent (CO2e)		1330	LB/MWH	30 DAY ROLLING
PIO PICO ENERGY CENTER	PIO PICO ENERGY CENTER, LLC	OTAY MESA	CA	11/19/2012	CONSTRUCTION OF THREE GENERAL ELECTRIC (GE) LMS100 NATURAL GAS-FIRED COMBUSTION TURBINE-GENERATORS (CTGS) RATED AT 100 MW EACH. THE PROJECT WILL HAVE AN ELECTRICAL OUTPUT OF 300 MW.	NOTE: PERMIT ISSUED 11/19/2012. ENVIRONMENTAL APPEALS BOARD REMANDED THE PM BACT ANALYSIS TO REGION 9 ON 8/2/2013. FINAL PERMIT ISSUED ON 2/28/2014. ONE PETITION FILED IN 9TH CIRCUIT FEDERAL COURT CHALLENGING THE FINAL PERMIT DECISION. THIS LAWSUIT WAS DISMISSED ON 6/17/2014 IN RESPONSE TO PETITIONERS MOTION FOR VOLUNTARY DISMISSAL.	COMBUSTION TURBINES (NORMAL OPERATION)	15.110	NATURAL GAS	300	MW	Three simple cycle combustion turbine generators (CTG). Each CTG rated at 100 MW (nominal net).	Carbon Dioxide Equivalent (CO2e)		1328	LB/MW-H	GROSS OUTPUT
R.M. HESKETT STATION	MONTANA-DAKOTA UTILITIES CO.	MORTON	ND	2/22/2013	Addition of a natural gas-fired turbine (Unit 3) to an existing coal-fired power plant. The turbine will be used for supplying peak power and is rated at 986 MMBtu/hr and 88 MWe at average site conditions.		Combustion Turbine	15.110	Natural gas	986	MMBTU/H	Turbine is a GE Model PG 7121 (7EA) used as a peaking unit.	Carbon Dioxide Equivalent (CO2e)		413198	TONS/12 MONTH	12 MONTH ROLLING TOTAL
PIONEER GENERATING STATION	BASIN ELECTRIC POWER COOPERATIVE	WILLIAMS	ND	5/14/2013	Three GE LM6000 PC SPRINT natural gas fired turbines used to generate electricity for peak periods.	The permit was for the addition of 2 turbines to the station. Since a synthetic minor limit was relaxed for the first unit, BACT was required for all three turbines.	Natural gas-fired turbines	15.110	Natural gas	451	MMBTU/H	Rating is for each turbine.	Carbon Dioxide Equivalent (CO2e)		243147	T/12 MON ROLL TOTAL	12 MONTH ROLLING TOTAL/EACH UNIT
LONESOME CREEK GENERATING STATION	BASIN ELECTRIC POWER COOP.	MCKENZIE	ND	9/16/2013	Three natural gas fired simple cycle turbines used to generate electricity for peak power demand. The turbines are GE LM6000 PF Sprint units with a nominal capacity of 45 MW each.		Natural Gas Fired Simple Cycle Turbines	15.110	Natural gas	412	MMBTU/H	The heat input is for a single unit.	Carbon Dioxide Equivalent (CO2e)	High efficiency turbines	220122	TONS	12 MONTH ROLLING TOTAL
RENAISSANCE POWER LLC	LS POWER DEVELOPMENT LLC	MONTCALM	MI	11/1/2013	For technical questions regarding this permit, please contact the permit engineer, Melissa Byrnes, at 517-284-6790. Thank you.	Other facility-wide pollutants not listed below (tpy): PM10=211.19+ PM2.5=205.24+ Lead=0.0027+ CO2e=5,398,441+ Sulfuric Acid Mist=5.67+	FG-CTG1-4 Natural gas fueled combined cycle combustion turbine generators (CTG)	15.210	Natural gas	2147	MMBTU/H	FG-CTG1-4: Four natural gas fired CTGs with each turbine containing a heat recovery steam generator (HRSG) to operate in combined cycle. Two CTGs (with HRSGs) are connected to one steam turbine generator. Each CTG is equipped with a dry low NOx (DLN) burner, a selective catalytic reduction (SCR) system, and a catalytic oxidation system. The throughput capacity is 2,147 MMBtu/hr for each CTG. The turbines are existing simple cycle turbines that will be retrofit to be combined cycle units.	Carbon Dioxide Equivalent (CO2e)	Good combustion practices/energy efficiency	1000	LB/MW-H	12-MONTH ROLLING AVERAGE
RENAISSANCE POWER LLC	LS POWER DEVELOPMENT LLC	MONTCALM	MI	11/1/2013	For technical questions regarding this permit, please contact the permit engineer, Melissa Byrnes, at 517-284-6790. Thank you.	Other facility-wide pollutants not listed below (tpy): PM10=211.19+ PM2.5=205.24+ Lead=0.0027+ CO2e=5,398,441+ Sulfuric Acid Mist=5.67+	FG-CTG/DB1-4 Natural gas fueled combined cycle combustion turbine generators; duct burner on HRSG	15.210	Natural gas	2807	MMBTU/H	Four natural gas-fired CTGs with each turbine containing a heat recovery steam generator (HRSG) to operate in combined cycle. The two CTGs (with HRSGs) are connected to one steam turbine generator. Each CTG is equipped with a dry low NOx (DLN) burner and a selective catalytic reduction (SCR) system, and a catalytic oxidation system. Additionally, the HRSG is operated with a natural gas fired duct burner during supplemental firing. The turbines are existing simple cycle turbines which will be retrofit to be combined cycle. Operational restriction is 4000 hrs/year that each DB can operate.	Carbon Dioxide Equivalent (CO2e)	Good combustion practices/energy efficiency	1000	LB/MW-H	12-MONTH ROLLING AVERAGE

Table C-9. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - GHG

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Unit	Emission Limit 1 Average Time Condition
TROUTDALE ENERGY CENTER, LLC	TROUTDALE ENERGY CENTER, LLC	MULTNOMAH	OR	3/5/2014	Troutdale Energy Center (TEC) proposes to construct and operate a 653 megawatt (MW) electric generating plant in Troutdale, Oregon. TEC proposes to generate electricity with three natural gas-fired turbines, one of which will be a combined-cycle unit with duct burner and heat recovery steam generator.		GE LMS-100 combustion turbines, simple cycle with water injection	15.110	natural gas	1690	MMBTU/H		Carbon Dioxide Equivalent (CO2e)	Thermal efficiency Clean fuels	1707	LB OF CO2 /GROSS MWH	365-DAY ROLLING AVERAGE
INDECK WHARTON ENERGY CENTER	INDECK WHARTON, LLC	WHARTON	TX	5/12/2014	Indeck proposes to construct a peaking power plant, the Indeck Wharton Energy Center, generally located south of Danevang, Texas. To meet the anticipated demand for peak power, Indeck proposes to construct three identical natural gas-fired F-class simple cycle combustion turbines with associated support equipment. Indeck proposes that the three new combustion turbine generators (CTGs) will be either General Electric (GE) 7FA.05 or Siemens SGT6-5000F(5). The GE 7FA.05 has a base-load electric power output of approximately 213 megawatts (MW, net nominal), and the Siemens SGT6-5000F(5) has a base-load electric power output of approximately 225 MW (net nominal). This project also proposes to install one emergency diesel generator, one diesel fire water pump, one natural gas pipeline heater, and other auxiliary equipment.	The Texas Commission on Environmental Quality is the permitting authority for the non-GHG emissions associated with this project.	Simple Cycle Combustion Turbine, GE 7FA.05	15.110	Pipeline Natural Gas	0		Indeck proposes to construct three identical natural gas-fired F-class simple cycle combustion turbines with associated support equipment. Indeck proposes that the three new combustion turbine generators (CTGs) will be either General Electric (GE) 7FA.05 or Siemens SGT6-5000F(5). The GE 7FA.05 has a base-load electric power output of approximately 213 megawatts (MW, net nominal), and the Siemens SGT6-5000F(5) has a base-load electric power output of approximately 225 MW (net nominal).	Carbon Dioxide Equivalent (CO2e)		1276	LB CO2/MWHR (GROSS)	2,500 OPERATIONAL HR ROLLING DAILY/CT
INDECK WHARTON ENERGY CENTER	INDECK WHARTON, LLC	WHARTON	TX	5/12/2014	Indeck proposes to construct a peaking power plant, the Indeck Wharton Energy Center, generally located south of Danevang, Texas. To meet the anticipated demand for peak power, Indeck proposes to construct three identical natural gas-fired F-class simple cycle combustion turbines with associated support equipment. Indeck proposes that the three new combustion turbine generators (CTGs) will be either General Electric (GE) 7FA.05 or Siemens SGT6-5000F(5). The GE 7FA.05 has a base-load electric power output of approximately 213 megawatts (MW, net nominal), and the Siemens SGT6-5000F(5) has a base-load electric power output of approximately 225 MW (net nominal). This project also proposes to install one emergency diesel generator, one diesel fire water pump, one natural gas pipeline heater, and other auxiliary equipment.	The Texas Commission on Environmental Quality is the permitting authority for the non-GHG emissions associated with this project.	Simple Cycle Combustion Turbine, SGT-5000F(5)	15.110	Pipeline Natural Gas	0		Indeck proposes to construct three identical natural gas-fired F-class simple cycle combustion turbines with associated support equipment. Indeck proposes that the three new combustion turbine generators (CTGs) will be either General Electric (GE) 7FA.05 or Siemens SGT6-5000F(5). The GE 7FA.05 has a base-load electric power output of approximately 213 megawatts (MW, net nominal), and the Siemens SGT6-5000F(5) has a base-load electric power output of approximately 225 MW (net nominal).	Carbon Dioxide Equivalent (CO2e)		1337	LB CO2/MWHR (GROSS)	2500 OPERATIONAL HR ROLLING DAILY/CT
PUEBLO AIRPORT GENERATING STATION	BLACK HILLS ELECTRIC GENERATION, LLC	PUEBLO	CO	5/30/2014	Power generation facility		Turbine - simple cycle gas	15.110	natural gas	375	MMBTU/H	One (1) General Electric, simple cycle, gas turbine electric generator, Unit 6 (CT08), model: LM6000, SN: N/A, rated at 375 MMBtu per hour.	Carbon Dioxide Equivalent (CO2e)	Good Combustion Control	1600	LB/MW H GROSS	ROLLING 365-DAY AVE
ECTOR COUNTY ENERGY CENTER	INVENERGY THERMAL DEVELOPMENT LLC	ECTOR	TX	8/1/2014	Invenergy proposes to construct a 330 MW peak power plant (known as the Ector County Energy Center Plant (ECEC)), located in Goldsmith, Ector County, Texas. With this proposed project, Invenergy plans to construct two natural gas-fired simple-cycle turbines, General Electric (GE) Model 7FA.03, and associated equipment, a fire water pump engine, a natural gas-fired dew-point heater, and two circuit breakers. For the purposes of this proposed permitting action, GHG emissions are permitted for the two turbines, the fire water pump engine, the natural gas-fired dew-point heater, and the circuit breakers, as well as for fugitive emissions, and maintenance, startup and shutdown emissions.	Texas Commission on Environmental Quality is the permitting authority for the non-GHG emissions associated with this project.	Simple Cycle Combustion Turbine, GE 7FA.03	15.110	Natural Gas	11707	Btu/kWh (HHV)		Carbon Dioxide Equivalent (CO2e)		1393	LB CO2/MWHR (GROSS)	2500 OPERATIONAL HR ROLLING DAILY/CT
ECTOR COUNTY ENERGY CENTER	INVENERGY THERMAL DEVELOPMENT LLC	ECTOR	TX	8/1/2014	Invenergy proposes to construct a 330 MW peak power plant (known as the Ector County Energy Center Plant (ECEC)), located in Goldsmith, Ector County, Texas. With this proposed project, Invenergy plans to construct two natural gas-fired simple-cycle turbines, General Electric (GE) Model 7FA.03, and associated equipment, a fire water pump engine, a natural gas-fired dew-point heater, and two circuit breakers. For the purposes of this proposed permitting action, GHG emissions are permitted for the two turbines, the fire water pump engine, the natural gas-fired dew-point heater, and the circuit breakers, as well as for fugitive emissions, and maintenance, startup and shutdown emissions.	Texas Commission on Environmental Quality is the permitting authority for the non-GHG emissions associated with this project.	Simple Cycle Combustion Turbine-MSS	15.110	Natural Gas	0			Carbon Dioxide Equivalent (CO2e)		21	TON CO2E/EVENT	EACH MSS EVENT

Table C-9. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - GHG

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Unit	Emission Limit 1 Average Time Condition
GUADALUPE GENERATING STATION	GUADALUPE POWER PARTNERS, L.P.	GUADALUPE	TX	12/2/2014	GPP proposes to add two (2) new gas-fired simple-cycle combustion turbines of 227 MW (nominal) electric generating capacity each to the 1,000 MW (nominal) existing major stationary source, Guadalupe Generating Station (GGS), located in Marion, Texas. The proposed project will provide peaking capacity at an existing natural gas fired combined cycle electric generating station. The two new natural gas-fired simple-cycle turbines are proposed to provide a fast ramp up for additional peaking capacity during peak electricity demand periods. In addition, the project also includes the installation of a firewater pump engine, circuit breakers and associated fugitive emissions.	The Texas Commission on Environmental Quality is the permitting authority for the non-GHG emissions associated with this project. See CN600132120 and RN100225820	Simple Cycle Combustion Turbine Generator	15.110	Pipeline Natural Gas	10673	Btu/kWh	Natural gas-fired simple cycle combustion turbine generators (CTG) will be General Electric 7FA.05 (GE 7FA.05), each with a maximum base-load electric power output of 227 megawatts (MW, nominal). Combined gross heat rate limit of 10,279,456 MMBtu/yr.	Carbon Dioxide Equivalent (CO2e)		1293.3	LB CO2/MWHR (GROSS)	12-MONTH ROLLING AVERAGE (NORMAL OPER)
GUADALUPE GENERATING STATION	GUADALUPE POWER PARTNERS, L.P.	GUADALUPE	TX	12/2/2014	GPP proposes to add two (2) new gas-fired simple-cycle combustion turbines of 227 MW (nominal) electric generating capacity each to the 1,000 MW (nominal) existing major stationary source, Guadalupe Generating Station (GGS), located in Marion, Texas. The proposed project will provide peaking capacity at an existing natural gas fired combined cycle electric generating station. The two new natural gas-fired simple-cycle turbines are proposed to provide a fast ramp up for additional peaking capacity during peak electricity demand periods. In addition, the project also includes the installation of a firewater pump engine, circuit breakers and associated fugitive emissions.	The Texas Commission on Environmental Quality is the permitting authority for the non-GHG emissions associated with this project. See CN600132120 and RN100225820	Simple Cycle Combustion Turbine Generator	15.110	Pipeline Natural Gas	10673	Btu/kWh	Natural gas-fired simple cycle combustion turbine generators (CTG) will be General Electric 7FA.05 (GE 7FA.05), each with a maximum base-load electric power output of 227 megawatts (MW, nominal). Combined gross heat rate limit of 10,279,456 MMBtu/yr.	Carbon Dioxide Equivalent (CO2e)		1293.3	LB CO2/MWHR (GROSS)	12-MONTH ROLLING AVERAGE (NORMAL OPER)
SABIC INNOVATIVE PLASTICS MT. VERNON, LC	SABIC INNOVATIVE PLASTICS MT. VERNON, LC	POSEY	IN	12/11/2014	PLASTIC MANUFACTURING PLANT		COMBUSTION TURBINE:COGEN	15.110	NATURAL GAS	1812	MMBTU/H		Carbon Dioxide Equivalent (CO2e)		937379	T/YR	
ANTELOPE ELK ENERGY CENTER	GOLDEN SPREAD ELECTRIC COOPERATIVE, INC.	HALE	TX	5/20/2015	Golden Spread Electric Cooperative, Inc. (GSEC) is requesting authorization for three additional simple cycle electric generating plants at an existing site to meet increased energy demand in the area. The generating equipment consists of three new GE 7F5-Series natural gas-fired combustion turbines (CTG). Each turbine has a maximum electric output of 202 MW.		Simple Cycle Turbine Generator	15.110	natural gas	202	MW	3 additional GE 7F 5-Series Combustion Turbine Generators	Carbon Dioxide Equivalent (CO2e)	Energy efficiency, good design & combustion practices	1304	LB CO2/MWHR	
ROLLING HILLS GENERATING, LLC		VINTON	OH	5/20/2015	Electrical services	Note: The proposed modification was not installed. Chapter 31 major modification to convert four of the existing five simple cycle peaking units, SW501F turbines nominally rated at 209 megawatts (MW) each, to combined cycle configuration consisting of two 2x1 combined cycle blocks, the addition of four heat recovery steam generators (HRSGs), each of which will be equipped with duct burners, and two steam turbine generators. Permit includes 2 options for the units. Siemens Westinghouse Power Corp. SW501F, (Scenario 1: 200 MW, with 2022 MMBtu/hr input & 550 MMBtu/hr duct burner. Scenario 2: 207.5 MW with 2144 MMBtu/hr input & 550 MMBtu/hr duct burner.) combined cycle natural gas fired turbine with Dry Low-NOX combusters, SCR and duct burner. Emissions increase noted below is for scenario 1. Scenario 2 = 5101.7 CO, 449.31 NOx, 346.8 PM and 600.62 VOC.	Combustion Turbines, Scenario 1 (4, identical) (P001, P002, P004, P005)	15.210	Natural gas	2022	MMBTU/H	Scenario 1 only. Other scenario added as separate process. Siemens Westinghouse Power Corp. SW501F, (Scenario 1: 200 MW, with 2022 MMBtu/hr input & 550 MMBtu/hr duct burner. Scenario 2: 207.5 MW with 2144 MMBtu/hr input & 550 MMBtu/hr duct burner.) combined cycle natural gas fired turbine with Dry Low-NOX combusters, SCR and duct burner.	Carbon Dioxide Equivalent (CO2e)	high efficiency	7471	BTU/KW-H	HHV NET PER EACH CCT BLOCK. SEE NOTES.

Table C-9. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - GHG

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Unit	Emission Limit 1 Average Time Condition
ROLLING HILLS GENERATING, LLC		VINTON	OH	5/20/2015	Electrical services	Note: The proposed modification was not installed. Chapter 31 major modification to convert four of the existing five simple cycle peaking units, SW501F turbines nominally rated at 209 megawatts (MW) each, to combined cycle configuration consisting of two 2x1 combined cycle blocks, the addition of four heat recovery steam generators (HRSGs), each of which will be equipped with duct burners, and two steam turbine generators. Permit includes 2 options for the units. Siemens Westinghouse Power Corp. SW501F, (Scenario 1: 200 MW, with 2022 MMBtu/hr input & 550 MMBtu/hr duct burner. Scenario 2: 207.5 MW with 2144 MMBtu/hr input & 550 MMBtu/hr duct burner.) combined cycle natural gas fired turbine with Dry Low-NOX combusters, SCR and duct burner. Emissions increase noted below is for scenario 1. Scenario 2 = 5101.7 CO, 449.31 NOx, 346.8 PM and 600.62 VOC.	Combustion Turbines, Scenario 2 (4, identical) (P001, P002, P004, P005)	15.210	Natural gas	2144	MMBTU/H	Scenario 1 only. Other scenario added as separate process. Siemens Westinghouse Power Corp. SW501F, (Scenario 1: 200 MW, with 2022 MMBtu/hr input & 550 MMBtu/hr duct burner. Scenario 2: 207.5 MW with 2144 MMBtu/hr input & 550 MMBtu/hr duct burner.) combined cycle natural gas fired turbine with Dry Low-NOX combusters, SCR and duct burner.	Carbon Dioxide Equivalent (CO2e)	high efficiency	7471	BTU/KW-H	HHV NET PER EACH CCT BLOCK. SEE NOTES.
LAUDERDALE PLANT	FLORIDA POWER & LIGHT	BROWARD	FL	8/25/2015	Large natural gas- and oil-fired power facility, consisting of four combined cycle units, and many combustion turbines. Small peaking units being replaced with larger combustion turbines.	Re-affirmed BACT determinations in Permit No. 0110037-011-AC. Also, new GHG BACT determination. Technical evaluation available at https://arm-permit2k.dep.state.fl.us/nontv/0110037.013.AC.D.ZIP	Five 200-MW combustion turbines	15.110	Natural gas	2100	MMBTU/hr (approx)	Five simple cycle GE 7F.05 turbines. Max of 3390 hours per year per turbine. Of the 3390 hours per year, up to 500 hour may be on ULSD fuel oil.	Carbon Dioxide	Use of natural gas with restricted use of ULSD as backup fuel	1372	LB/MWH	NAT GAS OPERATION, 12-OR 36- MO ROLLING
FORT MYERS PLANT	FLORIDA POWER & LIGHT (FPL)	LEE	FL	9/10/2015	Electric power plant, consists of a 6-on-2 combined-cycle unit (Units 2A through 2F) and two modern simple-cycle combustion turbines. Primary fuel is natural gas. Also includes 12 gas turbines (63 MW each) for peaking, introduced into service in 1974. This project entails decommissioning 10 of the 12 peaking turbines. They will be replaced with two new GE 7F.05 turbines, each with nominal capacity of 200 MW	Technical evaluation available at https://arm-permit2k.dep.state.fl.us/nontv/0710002.022.AC.D.ZIP	Combustion Turbines	15.110	Natural gas	2262.4	MMBTU/hr gas	Two GE 7F.05 turbines, approximately 200 MW each. Natural-gas is primary fuel. Permitted 3390 hr/yr of operation, of which no more than 500 hr may be on fuel oil. Dry Low-NOx, with wet injection for oil firing.	Carbon Dioxide Equivalent (CO2e)	Use of low-emitting fuel and efficient turbine	1374	LB CO2E / MWH	FOR NATURAL GAS OPERATION
SR BERTRON ELECTRIC GENERATING STATION	NRG TEXAS POWER	HARRIS	TX	9/15/2015	Electric Generating Utility: The project will consist of two gas fired combustion turbines (CTGs) each equipped with a supplementary fired [duct burners (DBs)] heat recovery steam generator (HRSG). The CTGs and DBs are fueled with pipeline quality natural gas. The CTGs will operate in simple cycle and combined cycle modes. The gas turbines will be one of four options.		Simple cycle turbines greater than 25 megawatts (MW) firing natural gas	15.110	natural gas	359	MW	4 options: General Electric (GE) 7HA 359 MW GE 7FA 215 MW Siemens SF5 (SF5) 225 MW Mitsubishi 501G (MHIS10G) 263 MW	Carbon Dioxide		1232	LB /MW H	
CEDAR BAYOU ELECTRIC GENERATING STATION	NRG TEXAS POWER	CHAMBERS	TX	9/15/2015	Electric Generating Utility: The project will consist of two gas fired combustion turbines (CTGs) each equipped with a supplementary fired [duct burners (DBs)] heat recovery steam generator (HRSG). The CTGs and DBs are fueled with pipeline quality natural gas. The CTGs will operate in simple cycle and combined cycle modes. The gas turbines will be one of four options.		Simple cycle turbines greater than 25 megawatts (MW)	15.110	natural gas	359	MW	4 turbine options General Electric 7HA 359 MW GE 7FA 215 MW Siemens SF5 (SF5) 225 MW Mitsubishi 501G (MHIS10G) 263 MW	Carbon Dioxide		1232	LB CO2/MWH	
SR BERTRON ELECTRIC GENERATING STATION	NRG TEXAS POWER	HARRIS	TX	9/15/2015	Electric Generating Utility: The project will consist of two gas fired combustion turbines (CTGs) each equipped with a supplementary fired [duct burners (DBs)] heat recovery steam generator (HRSG). The CTGs and DBs are fueled with pipeline quality natural gas. The CTGs will operate in simple cycle and combined cycle modes. The gas turbines will be one of four options.		Combined cycle and cogeneration turbines greater than 25 MW firing natural gas	15.210	natural gas	301	MMBTU/H	GE 7HA 359 MW + a 301 million British thermal units per hour (MMBTU/hr) duct burner (DB) GE7FA 215 MW + a 523 MMBtu/hr DB SF5 225 MW + 688 MMBtu/hr DB MHIS10G 263 MW + 686 MMBtu/hr DB	Carbon Dioxide		825	LB /MW H	
CEDAR BAYOU ELECTRIC GENERATING STATION	NRG TEXAS POWER	CHAMBERS	TX	9/15/2015	Electric Generating Utility: The project will consist of two gas fired combustion turbines (CTGs) each equipped with a supplementary fired [duct burners (DBs)] heat recovery steam generator (HRSG). The CTGs and DBs are fueled with pipeline quality natural gas. The CTGs will operate in simple cycle and combined cycle modes. The gas turbines will be one of four options.		Combined cycle and cogeneration turbines greater than 25 MW	15.210	natural gas	301	MMBTU/H	4 turbines options GE 7HA 359 MW + a 301 million British thermal units per hour (MMBTU/hr) duct burner (DB) GE7FA 215 MW + a 523 MMBtu/hr DB SF5 225 MW + 688 MMBtu/hr DB MHIS10G 263 MW + 686 MMBtu/hr DB	Carbon Dioxide		825	LB CO2/MWH	

Table C-9. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - GHG

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Unit	Emission Limit 1 Average Time Condition
SHAWNEE ENERGY CENTER	SHAWNEE ENERGY CENTER, LLC	HILL	TX	11/10/2015	Electric Generating Utility: The project will consist of four gas fired combustion turbines (CTGs). The CTGs are fueled with pipeline quality natural gas and will operate in simple cycle mode. The gas turbines will be one of two options.		Simple cycle turbines greater than 25 megawatts (MW)	15.110	natural gas	230	MW	Siemens Model SGT6-5000 F5 230 MW or Second turbine option: General Electric Model 7FA.05TP 227 MW	Carbon Dioxide Equivalent (CO2e)		1398	LB/MWH	
CLEAR SPRINGS ENERGY CENTER (CSEC)	NAVASOTA SOUTH PEAKERS OPERATING COMPANY II, LLC.	GUADALUPE	TX	11/13/2015	Navasota South Peakers Operating Company II LLC proposes to install three new natural gas fired combustion turbine generators (CTGs). Each CTG will be a General Electric 7FA.04 model that can produce approximately 183 Megawatts (MW) each based upon the manufacturers projected output at baseload operating as peaking units in simple cycle.		Simple Cycle Turbine	15.110	natural gas	183	MW	The CTGs will be three General Electric 7FA.04 (~183 MW each for a total of 550 MW), operating as peaking units in simple cycle mode. Each turbine will be limited to 2,500 hours of operation per year. The new CTGs will use dry low-NOx (DLN) burners and may employ evaporative cooling for power enhancement.	Carbon Dioxide Equivalent (CO2e)	Low carbon fuel, good combustion, efficient combined cycle design	1461	LB/MWH	
UNION VALLEY ENERGY CENTER	NAVASOTA SOUTH PEAKERS OPERATING COMPANY II, LLC.	NIXON	TX	12/16/2015	three new natural gas fired combustion turbine generators (CTGs). The CTGs will be the General Electric 7FA.04 (~214 megawatt (MW) each; manufacturers output at baseload, ISO at 183 MW), operating as peaking units in simple cycle.		Simple Cycle Turbine	15.110	natural gas	183	MW	The CTGs will be three General Electric 7FA.04 (~183 MW each for a total of 550 MW), operating as peaking units in simple cycle mode. Each turbine will be limited to 2,500 hours of operation per year. The new CTGs will use dry low-NOx (DLN) burners and may employ evaporative cooling for power enhancement.	Carbon Dioxide Equivalent (CO2e)		1461	LB/MWH	
VAN ALSTYNE ENERGY CENTER	NAVASOTA NORTH PEAKERS OPERATING COMPANY I, LLC.	GRAYSON	TX	1/13/2016	Navasota North Peakers Operating Company I, LLC. proposes to install three new natural gas fired combustion turbine generators (CTGs). The CTGs will be the General Electric 7FA.04 (~214 megawatt (MW) each; manufacturers output at baseload, ISO at 183 MW), operating as peaking units in simple cycle.		Simple Cycle Turbine	15.110	natural gas	183	mw	The CTGs will be three General Electric 7FA.04 (~183 MW each for a total of 550 MW), operating as peaking units in simple cycle mode. Each turbine will be limited to 2,500 hours of operation per year. The new CTGs will use dry low-NOx (DLN) burners and may employ evaporative cooling for power enhancement.	Carbon Dioxide		1461	LB/MWH	
NACOGDOCHES POWER ELECTRIC GENERATING PLANT	NACOGDOCHES POWER	NACOGDOCHES	TX	3/1/2016	Electric Generation		Combined Cycle Cogeneration	15.110	natural gas	232	MW		Carbon Dioxide Equivalent (CO2e)	Good Combustion Practices	1316	LB/MWH	HR
NECHES STATION	APEX TEXAS POWER LLC	CHEROKEE	TX	3/24/2016	either 4 simple cycle combustion turbine generators (CTGs) or two CTGs operating in simple cycle or combined cycle modes. The CTGs will be one of two options: Siemens or General Electric.		Large Combustion Turbines > 25 MW	15.110	natural gas	232	MW	4 Simple cycle CTGs, 2,500 hr/yr operational limitation. Facility will consist of either 232 MW (Siemens) or 220 MW (GE)	Carbon Dioxide Equivalent (CO2e)	good combustion practiceS	1341	LB/MWH	
NECHES STATION	APEX TEXAS POWER LLC	CHEROKEE	TX	3/24/2016	either 4 simple cycle combustion turbine generators (CTGs) or two CTGs operating in simple cycle or combined cycle modes. The CTGs will be one of two options: Siemens or General Electric.		Combined Cycle & Cogeneration	15.210	natural gas	231	MW	2 CTGs to operate in simple cycle & combined cycle modes. 231 MW (Siemens) or 210 MW (GE) Simple cycle operations limited to 2,500 hr/yr.	Carbon Dioxide Equivalent (CO2e)	GOOD COMBUSTION PRACTICES	924	LB/MWH	
HILL COUNTY GENERATING FACILITY	BRAZOS ELECTRIC COOPERATIVE	HILL	TX	4/7/2016	Four simple cycle combustion turbine electric generators are proposed. Natural gas or ultra-low sulfur diesel fuel oil are the fuels. Turbine model options are: General Electric (GE) 7FA.03, GE 7FA.04, GE 7FA.05, and Siemens SGT6-5000(5)ee. Electric output is between 684 and 928 megawatts (MW).		Simple cycle turbine	15.110	natural gas	171	MW	Each combustion turbine is limited to 2,920 hours of annual operation, including startup and shutdown hours.	Carbon Dioxide Equivalent (CO2e)		1434	LB/MWH	
INVENERGY NELSON EXPANSION LLC	INVENERGY	LEE	IL	9/27/2016	Peaking facility at an existing major source. The expansion will consist of two simple cycle combustion turbines and a fuel heater.		Two Simple Cycle Combustion Turbines	15.110	Natural Gas	190	MW	Two simple cycle combustion turbines used for peaking purposes and fired primarily on natural gas with ULSD as a secondary fuel.	Carbon Dioxide Equivalent (CO2e)	Turbine-generator design and proper operation	0		
DOSWELL ENERGY CENTER	DOSWELL LIMITED PARTNERSHIP DOSWELL ENERGY CENTER	HANAOVER	VA	10/4/2016	The facility is currently composed of four Kraftwerk Union/Siemens (Model: V84.2) combined cycle turbine units each equipped with a duct burner and supporting equipment (auxiliary boiler, fire pump, emergency generator and fuel oil storage tanks) under one Prevention of Significant Deterioration (PSD) permit and one simple cycle turbine unit under another PSD permit. The combined cycle turbines were permitted in a PSD permit originally issued on May 4, 1990 and last amended on August 3, 2005. The 190.5 MW simple cycle combustion turbine (CT-1) was added in a separate PSD permit dated April 7, 2000 and last amended on September 30, 2013.	DEC is proposing to add two GE 7FA simple cycle combustion turbines (CT-2 and CT-3) at the Doswell Energy Center. DEC is moving CT-2 and CT-3 from an existing permitted site in Desoto, Florida. They are both GE Frame 7FA Combustion Turbines that are very similar in age and capability to the DEC CT-1 (GE 7FA.03). The CT-2 and CT-3 maximum heat input assumed for natural gas firing is 1,961.0 MMBtu/hr (HHV).	Two (2) GE 7FA simple cycle combustion turbines	15.110	Natural Gas	1961	MMBTU/HR		Carbon Dioxide Equivalent (CO2e)	Good combustion, maintenance and use of active combustion dynamic monitoring systems.	0		

Appendix C - RBL Search Results
Washington County Power, LLC

Table C-9. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - GHG

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Unit	Emission Limit 1 Average Time Condition
DECORDOVA STEAM ELECTRIC STATION (DECORDOVA STATION)	DECORDOVA II POWER COMPANY LLC	HOOD	TX	10/4/2016	two combustion turbines (CTGs) authorized to operate in simple cycle or combined cycle.	The simple cycle operations were issued in 2013, but the combined cycle criteria pollutant PSD permit / state amendment was issued on March 8, 2016. This GHG initial review is linked to the 2016 action which added combined cycle capability, it does not apply to the simple cycle operations which were authorized in 2013.	Combined Cycle and Cogeneration (>25 MW)	15.210	natural gas	213	MW	Two turbine options: GE 7FA [210 megawatts (MW)] or Siemens 5000F (231MW)	Carbon Dioxide Equivalent (CO2e)	good combustion practices and firing low carbon fuel.	966	LB/MW H	
WAVERLY FACILITY	PLEASANTS ENERGY, LLC	PLEASANTS	WV	1/23/2017	300 MW, natural gas fired, simple cycle peaking power facility	In this permitting action PSD only applies to the modified combustion turbines based on the relaxation of an original synthetic minor permit issued in 1999. Project also involves previous installation of turbo-charging. All BACT emission limits are given without turbocharging and startup/shutdown emissions are not included. Please contact above engineer for more information. There are two identical turbines but only one is listed.	GE Model 7FA Turbine	15.110	Natural Gas	1571	mmbtu/hr	There are two identical units at the facility.	Carbon Dioxide	Use of Natural Gas, Selection of GE7FA	1300	LB/MW-HR	NATURAL GAS
CAMERON LNG FACILITY	CAMERON LNG LLC	CAMERON	LA	2/17/2017	a facility to liquefy natural gas for export (5 trains)	Permit PSD-LA-766, dated 10/1/13 for liquefaction trains 1,2, and 3 Permit PSD-LA-766(M1), dated 6/26/14, for minor changes; Permit PSD-LA-766(M2), dated 3/3/16, for train 4 and 5	Gas turbines (9 units)	15.110	natural gas	1069	mm btu/hr		Carbon Dioxide Equivalent (CO2e)	good combustion practices and fueled by natural gas; Use high thermal efficiency turbines	0		
GAINES COUNTY POWER PLANT	SOUTHWESTERN PUBLIC SERVICE COMPANY		TX	4/28/2017	constructed in phases, with natural gas-fired simple cycle combustion turbines (SCCTs) with dry low nitrogen oxide (NOx) burners (DLN) to be converted into 2-on-1 combined cycle combustion turbines (CCCTs) with selective catalytic reduction (SCRs), heat recovery steam generators (HRSGs), one per combustion turbine) and one steam turbine per two CCCTs. Federal control review only applies to the turbines and HRSGs.		Simple Cycle Turbine	15.110	natural gas	227.5	MW	Four Siemens SGT6-5000F5 natural gas fired combustion turbines	Carbon Dioxide Equivalent (CO2e)	Pipeline quality natural gas; limited hours; good combustion practices	1300	LB/MW H	
JACKSON COUNTY GENERATING FACILITY	SOUTHERN POWER	JACKSON	TX	6/30/2017	simple cycle electric generation		Simple Cycle Turbines	15.110	natural gas	920	MW	The facility will consist of four Siemens F5 model (~230 megawatts (MW) each for a total of 920 MW), operating as peaking units in simple cycle mode. Each turbine will be limited to 2,500 hours of operation per year.	Carbon Dioxide Equivalent (CO2e)	energy efficiency designs, practices, and procedures, CT inlet air cooling, periodic CT burner maintenance and tuning, reduction in heat loss, i.e., insulation of the CT, instrumentation and controls	1316	LB/MW HR	
MUSTANG STATION	GOLDEN SPREAD ELECTRIC COOPERATIVE, INC.	YOAKUM	TX	8/16/2017	GE7FA combustion turbine (Unit 6) to increase the hours of operation to 3000 hours per year. The turbine construction was completed the first quarter of 2013 and initial firing began on April 1, 2013.		Simple Cycle Turbine	15.110	NATURAL GAS	162.8	MW	Unit 6 Turbine is limited to 3000 hours per year.	Carbon Dioxide Equivalent (CO2e)	Pipeline quality natural gas and good combustion practices	120	LB/MMBTU	
WAVERLY POWER PLANT	PLEASANTS ENERGY LLC	PLEASANTS	WV	3/13/2018	300 MW Simple-Cycle Peaking Plant	Modification to existing PSD Permit (R14-0034, RBL Number WV-0027) to add advanced gas path technology to the turbines that was defined as a change in the method of operation that resulted a major modification to the turbines.	GE 7FA.004 Turbine	15.110	Natural Gas	167.8	MW	This one entry is for both turbines as they are the same. Each turbine, after this modification, is a nominal 167.8 MW GE Model 7FA.004. Has oil-fire backup.	Carbon Dioxide Equivalent (CO2e)	Use of natural gas & use of GE 7FA.004	0		
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WSHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG01 SUSD - Simple-Cycle Combustion Turbine 1 (Startup/Shutdown/Maintenance/Tuning/Runback) [EQT0019]	15.110	Natural Gas	2201	MM BTU/hr	Limited to 600 hr/yr	Carbon Dioxide Equivalent (CO2e)	Facility-wide energy efficiency measures, such as improved combustion measures, and use of pipeline quality natural gas.	120	LB/MM BTU	ANNUAL AVERAGE
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WSHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG02 SUSD - Simple-Cycle Combustion Turbine 2 (Startup/Shutdown/Maintenance/Tuning/Runback) [EQT0020]	15.110	Natural Gas	2201	MM BTU/hr	limited to 600 hr/yr	Carbon Dioxide Equivalent (CO2e)	Facility-wide energy efficiency measures, such as improved combustion measures, and use of pipeline quality natural gas.	120	LB/MM BTU	ANNUAL AVERAGE
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WSHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG01 NO - Simple-Cycle Combustion Turbine 1 (Normal Operations) [EQT0017]	15.110	Natural Gas	2201	MM BTU/hr	Normal operations are based on 7000 hrs/yr	Carbon Dioxide Equivalent (CO2e)	Facility-wide energy efficiency measures, such as improved combustion measures, and use of pipeline quality natural gas.	50	KG/GJ	ANNUAL AVERAGE
WASHINGTON PARISH ENERGY CENTER	WASHINGTON PARISH ENERGY CENTER ONE, LLC	WSHINGTON PARISH	LA	5/23/2018	New 414 MW electric generating plant which provides electricity during peak demand. It consists of two simple-cycle turbine generators which fire natural gas only.	Application Accepted Date reflects date of administrative completeness.	CTG02 NO - Simple-Cycle Combustion Turbine 2 (Normal Operations) [EQT0018]	15.110	Natural Gas	2201	MM BTU/hr	Normal operations are based on 7000 hours per year	Carbon Dioxide Equivalent (CO2e)	Facility-wide energy efficiency measures, such as improved combustion measures, and use of pipeline quality natural gas.	50	KG/GJ	ANNUAL AVERAGE

Table C-9. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - GHG

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Unit	Emission Limit 1 Average Time Condition
DRIFTWOOD LNG FACILITY	DRIFTWOOD LNG LLC	CALCASIEU	LA	7/10/2018	Propose a new facility to liquefy natural gas for export		Compressor Turbines (20)	15.110	natural gas	540	mm btu/hr		Carbon Dioxide Equivalent (CO2e)	Use Low Carbon Fuel, Energy Efficiency Measures, and Good Combustion Practices	0		
CALCASIEU PASS LNG PROJECT	VENTURE GLOBAL CALCASIEU PASS, LLC	CAMERON	LA	9/21/2018	New Liquefied Natural Gas (LNG) production, storage, and export terminal.	Application Received September 2, 2015.	Simple Cycle Combustion Turbines (SCCT1 to SCCT3)	15.110	Natural Gas	927	MM BTU/h		Carbon Dioxide Equivalent (CO2e)	Exclusively combust low carbon fuel gas, good combustion practices, good operation and maintenance practices, and insulation	1426146	T/YR	ANNUAL TOTAL
RIO BRAVO PIPELINE FACILITY	RIO GRANDE LNG LLC	CAMERON	TX	12/17/2018	Natural gas processing and liquefied natural gas (LNG) export terminal		Refrigeration Compression Turbines	15.110	NATL GAS	967	MMBTU/HR	Twelve General Electric Frame 7EA simple cycle combustion turbines to serve as drivers for refrigeration and compression at the site. There are six process trains and there are two turbines per train. One each of the pairs of turbines has a downstream heat exchanger in the exhaust stream. The heat exchanger heats oil in a closed circuit for process uses elsewhere in the natural gas liquefaction system.	Carbon Dioxide Equivalent (CO2e)	Good combustion practices and use of pipeline quality natural gas.	0		
LBWL--ERICKSON STATION	LANSING BOARD OF WATER AND LIGHT	EATON	MI	12/21/2018	Natural gas combined-cycle power plant.	The proposed new plant will be replacing the electrical generating capacity of both BWL's existing coal-fired power plants. BWL intends to retire those coal-fired power plants from service by 2025. However, before they can be retired, the new natural gas power plant must be operational. Emissions in the area will increase for a short period if the new combined-cycle plant is built. However, there will be overall reductions in emissions when the existing coal fired power plants are taken out of service.	EUCTGHRSG2--A 667 MMBTU/H natural gas fired CTG with a HRSG.	15.210	Natural gas	667	MMBTU/H	EUCTGHRSG2 is a nominally rated 667 MMBTU/H natural gas fired CTG coupled with a HRSG. The HRSG is equipped with a natural gas fired duct burner rated at 204 MMBTU/h to provide heat for additional steam production. The CTG is capable of operating in combined-cycle mode where the exhaust is routed to the HRSG or in simple-cycle mode where the HRSG is bypassed. The HRSG is not capable of operating independently from the CTG. The CTG/HRSG is equipped with a DLNB, SCR and oxidation catalyst.	Carbon Dioxide Equivalent (CO2e)	low carbon fuel (pipeline quality natural gas), good combustion practices and energy efficiency measures.	430349	T/YR	12-MO ROLLING TIME PERIOD
LBWL--ERICKSON STATION	LANSING BOARD OF WATER AND LIGHT	EATON	MI	12/21/2018	Natural gas combined-cycle power plant.	The proposed new plant will be replacing the electrical generating capacity of both BWL's existing coal-fired power plants. BWL intends to retire those coal-fired power plants from service by 2025. However, before they can be retired, the new natural gas power plant must be operational. Emissions in the area will increase for a short period if the new combined-cycle plant is built. However, there will be overall reductions in emissions when the existing coal fired power plants are taken out of service.	EUCTGHRSG2--A 667 MMBTU/H natural gas fired CTG with a HRSG.	15.210	Natural gas	667	MMBTU/H	EUCTGHRSG2 is a nominally rated 667 MMBTU/H natural gas fired CTG coupled with a HRSG. The HRSG is equipped with a natural gas fired duct burner rated at 204 MMBTU/h to provide heat for additional steam production. The CTG is capable of operating in combined-cycle mode where the exhaust is routed to the HRSG or in simple-cycle mode where the HRSG is bypassed. The HRSG is not capable of operating independently from the CTG. The CTG/HRSG is equipped with a DLNB, SCR and oxidation catalyst.	Carbon Dioxide	low carbon fuel (pipeline quality natural gas), good combustion practices and energy efficiency measures.	1000	LB/MW-H	GROSS ENERGY OUTPUT; 12-OPERATING MO AVG
LBWL--ERICKSON STATION	LANSING BOARD OF WATER AND LIGHT	EATON	MI	12/21/2018	Natural gas combined-cycle power plant.	The proposed new plant will be replacing the electrical generating capacity of both BWL's existing coal-fired power plants. BWL intends to retire those coal-fired power plants from service by 2025. However, before they can be retired, the new natural gas power plant must be operational. Emissions in the area will increase for a short period if the new combined-cycle plant is built. However, there will be overall reductions in emissions when the existing coal fired power plants are taken out of service.	EUCTGHRSG1--A 667 MMBTU/H NG fired combustion turbine generator coupled with a heat recovery steam generator (HRSG)	15.210	Natural gas	667	MMBTU/H	A nominally rated 667 MMBTU/hr natural gas-fired combustion turbine generator (CTG) coupled with a heat recovery steam generator (HRSG). The HRSG is equipped with a natural gas-fired duct burner rated at 204 MMBTU/hr to provide heat for additional steam production. The CTG is capable of operating in combined-cycle mode where the exhaust is routed to the HRSG or in simple-cycle mode where the HRSG is bypassed. The HRSG is not capable of operating independently from the CTG. The CTG/HRSG is equipped with a dry low NOx burner (DLNB), selective catalytic reduction (SCR) and oxidation catalyst.	Carbon Dioxide Equivalent (CO2e)	Low carbon fuel (pipeline quality natural gas), good combustion practices and energy efficiency measures.	430349	T/YR	12-MO ROLLING TIME PERIOD
LBWL--ERICKSON STATION	LANSING BOARD OF WATER AND LIGHT	EATON	MI	12/21/2018	Natural gas combined-cycle power plant.	The proposed new plant will be replacing the electrical generating capacity of both BWL's existing coal-fired power plants. BWL intends to retire those coal-fired power plants from service by 2025. However, before they can be retired, the new natural gas power plant must be operational. Emissions in the area will increase for a short period if the new combined-cycle plant is built. However, there will be overall reductions in emissions when the existing coal fired power plants are taken out of service.	EUCTGHRSG1--A 667 MMBTU/H NG fired combustion turbine generator coupled with a heat recovery steam generator (HRSG)	15.210	Natural gas	667	MMBTU/H	A nominally rated 667 MMBTU/hr natural gas-fired combustion turbine generator (CTG) coupled with a heat recovery steam generator (HRSG). The HRSG is equipped with a natural gas-fired duct burner rated at 204 MMBTU/hr to provide heat for additional steam production. The CTG is capable of operating in combined-cycle mode where the exhaust is routed to the HRSG or in simple-cycle mode where the HRSG is bypassed. The HRSG is not capable of operating independently from the CTG. The CTG/HRSG is equipped with a dry low NOx burner (DLNB), selective catalytic reduction (SCR) and oxidation catalyst.	Carbon Dioxide	Low carbon fuel (pipeline quality natural gas), good combustion practices and energy efficiency measures.	1000	LB/MW-H	12-OPERATING MO. AVG; SEE NOTES

Table C-9. RBL Search Results for Large Natural Gas Fired Turbines (Simple-Cycle) - GHG

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Unit	Emission Limit 1 Average Time Condition
GAS TREATMENT PLANT	ALASKA GASLINE DEVELOPMENT CORPORATION	NORTH SLOPE BOROUGH	AK	8/13/2020	<p>The Gas Treatment Plant (GTP) is part of one integrated liquefied natural gas (LNG) project to bring natural gas from Alaskas North Slope to international markets in the form of LNG, as well as for in-state deliveries in the form of natural gas. The GTP will take gas from the Prudhoe Bay Unit and the Point Thomson Unit and treat/process the gas, before it is sent 807 miles through a 42-inch diameter pipeline to a liquefaction facility in Nikiski on Alaskas Kenai Peninsula for export in foreign commerce.</p> <p>The emissions units at the stationary source will include cogeneration gas-fired turbines with supplemental firing duct burners for gas compression, simple cycle gas-fired turbines for power generation, gas-fired heaters for building and process heat, as well as flares for control of excess gas. In addition, the GTP will include a diesel-fired black start generator, several diesel-fired firewater pumps and emergency generators, and storage tanks for diesel and gasoline fuels.</p>		Six (6) Simple Cycle Gas-Turbines (Power Generation)	15.110	Natural Gas	386	MMBtu/hr	EUs 25 -30 each provide 44 MW of power generation for the facility	Carbon Dioxide Equivalent (CO2e)	Good combustion practices and clean burning fuel (NG)	117.1	LB/MMBTU	3-HOUR AVERAGE
ECTOR COUNTY ENERGY CENTER	ECTOR COUNTY ENERGY CENTER LLC	ECTOR	TX	8/17/2020	increase the hours of operation for the two simple cycle gas turbines		Simple Cycle Turbines	15.110	natural gas	0			Carbon Dioxide Equivalent (CO2e)	Best management practices and good combustion practices, clean fuel	1514	LB/MWHR	

Table C-10. RBL Search Results for Large Fuel Oil Fired Turbines (Simple-Cycle) - GHG

Facility Name	Corporate or Company Name	Facility County	Facility State	Permit Issuance Date	Facility Description	Permit Notes	Process Name	Process Type	Primary Fuel Type	Throughput	Throughput Unit	Process Notes	Pollutant	Control Method Description	Emission Limit 1	Emission Limit 1 Unit	Emission Limit 1 Average Time Condition
HILL COUNTY GENERATING FACILITY	BRAZOS ELECTRIC COOPERATIVE	HILL	TX	4/7/2016	Four simple cycle combustion turbine electric generators are proposed. Natural gas or ultra-low sulfur diesel fuel oil are the fuels. Turbine model options are: General Electric (GE) 7FA.03, GE 7FA.04, GE 7FA.05, and Siemes SGT6-5000(5)ee. Electric output is between 684 and 928 megawatts (MW).		Simple Cycle Turbine	15.190	ULTRA LOW SULFUR DIESEL	171	MW	LIQUID FUEL ONLY USED AS BACKUP TO NATURAL GAS Each combustion turbine is limited to 624,000 million Btu of annual firing because these are peaking units. Emission control firing ULSD adds water injection.	Carbon Dioxide Equivalent (CO2e)		1434	LB/MWH	

APPENDIX D. CONTROL COST ANALYSES

**Appendix D - BACT Cost Assessment
Washington County Power - Sandersville**

Table D-1. Potential Emissions from Combustion Turbine Systems

Pollutant Emissions	Emission Factor¹⁻² (lb/MMBtu)	Maximum Annual Operating Capacity³ (MMBtu/yr/turbine)	Maximum Annual Emissions for each Turbine⁴ (tpy)
<i>Natural Gas</i>			
NO _x (Natural Gas)	3.00E-02	5,298,000	79.3
CO (Natural Gas)	1.82E-02		48.3
VOC (Natural Gas)	6.37E-03		16.9
CO ₂ (Natural Gas)	116.98		309,870
<i>Fuel Oil</i>			
NO _x (Fuel Oil)	1.40E-01	945,000	66.0
CO (Fuel Oil)	4.05E-02		19.1
VOC (Fuel Oil)	1.59E-02		42.1
CO ₂ (Fuel Oil)	163.05		77,042
Total NO_x Emissions (per turbine)			145.4
Total CO Emissions (per turbine)			67.4
Total VOC Emissions (per turbine)			59.0
Total CO₂ Emissions (per turbine)			386,912

1. Emission factors for natural gas based on current vendor guarantees of 9 ppm @ 15% O₂ for NO_x/CO and 1.4 ppm @ 15% O₂ for VOC.

2. Emission factors for fuel oil combustion are obtained from the proposed BACT limit selection.

3. Maximum Annual Operating Capacity anticipated for sustainable operation for one (1) turbine.

Natural Gas 1,766 MMBtu/hr

Fuel Oil 1,890 MMBtu/hr

4. Emissions (tpy) = EF (lb/MMBtu) * Maximum Annual Operating Capacity (MMBtu/yr) / 2,000 lb/ton

**Appendix D - BACT Cost Assessment
Washington County Power - Sandersville**

Table D-2. Selective Catalytic Reduction (SCR) Economic Feasibility Assessment For Capital Cost

Capital Cost Summary	Capital Cost
DIRECT COSTS	
PURCHASED EQUIPMENT COST (PEC)¹	PEC = \$11,303,389
TOTAL DIRECT CAPITAL COST (DCC)²	DCC = \$11,303,389
INDIRECT COSTS³	
Engineering (10% of PEC)	\$1,130,339
General Facilities (5% of PEC)	\$565,169
Process Contingency (5% of PEC)	\$565,169
TOTAL INDIRECT CAPITAL COST (ICC)	ICC = \$2,260,678
PROJECT CONTINGENCY (15% of ICC + DCC) (PC)³	PC = \$2,034,610
OTHER PREPRODUCTION COSTS	
Preproduction Cost (2% of (DCC+ ICC + PC))	\$311,974
TOTAL CAPITAL INVESTMENT (TCI = DC + IC + PC)	TCI = \$15,910,650

1. Based on data obtained for another project by Trinity Consultants from Black & Veatch in 2010, for a similarly sized unit. The purchased equipment cost was corrected for inflation to 2020 dollars.

2. Freight, instrumentation, initial catalyst charge, and direct installation costs are assumed to be included in the purchase cost.

3. U.S. EPA CCM, Section 4.2, Chapter 2, "Selective Catalytic Reduction," Sixth Edition, October 2000.

**Appendix D - BACT Cost Assessment
Washington County Power - Sandersville**

Table D-3. Selective Catalytic Reduction (SCR) Economic Feasibility Assessment For Annual Cost

Annual Cost Summary	Annual Cost
DIRECT ANNUAL COSTS	
OPERATION AND MAINTENANCE¹	
Maintenance (0.5% of TCI)	\$79,553
REAGENT	
Requirement ² 73 lb/hr at \$483.10 per ton ²	\$61,716
CATALYST	
Catalyst Replacement ³	\$1,784,746
Catalyst Life (years)	3.00
Annual Interest Rate (%)	7.00%
Future Worth Factor	0.381
Total Annual Catalyst Replacement Cost	\$680,080
UTILITIES⁴	
Electricity 413.15 kW/hr at \$0.0638 per kW-hr	\$92,257
<hr/>	
TOTAL DIRECT ANNUAL COSTS (DAC)	DAC = \$913,606
<hr/>	
INDIRECT OPERATING COSTS¹	
Overhead (0% for SCR)	\$0
Administrative Charges (0% of TCI)	\$0
Property Taxes (0% of TCI)	\$0
Insurance (0% of TCI)	\$0
Capital Recovery (CRF x TCI)	
20 years @ 7.00% interest CRF ⁵ = 0.0944	\$1,501,853
<hr/>	
TOTAL INDIRECT ANNUAL COSTS (IAC)	IAC = \$1,501,853
<hr/>	
TOTAL ANNUALIZED COST (TAC = DAC + IAC)	TAC= \$2,415,459
<hr/>	
Cost Effectiveness Summary	
Annual Control Cost (\$)	\$2,415,459
Pollutant to be Removed [NO_x] (tpy)⁶	119.88
CONTROL COST EFFECTIVENESS (\$/ton)	\$20,150

1. U.S. EPA CCM, Section 4, Chapter 2, "Selective Catalytic Reduction," Seventh Edition, June 2019.

2. Reagent cost taken from Appendix A.2.3 of U.S. EPA's *Petroleum Refinery Tier 2 BACT Analysis Report* dated January 16, 2001 (available at <http://www.epa.gov/ttn/caaa/t1/memoranda/bactrpt.pdf>). The \$300/ton reagent cost from this document was corrected for inflation to 2020 dollars.

3. Catalyst replacement cost and ammonia flow rate based on data obtained for another project by Trinity Consultants which was provided by Cormetech in 2010, for a similarly sized unit. The catalyst replacement cost was corrected for inflation to 2020 dollars.

4. Based on power consumption and electricity cost equations in U.S. EPA CCM, Section 4.2, Chapter 2, "Selective Catalytic Reduction," Sixth Edition, October 2000. Assumes a duct pressure drop of 2 inches of water, catalyst pressure drop of 0.75 inches of water, and three catalyst layers. Electricity price based on average retail price of electricity in Georgia in January through September 2019 for the industrial sector (www.eia.doe.gov).

5. Interest rate conservatively set at 7.00%, based on EPA's seven percent social interest rate from the U.S. EPA CCM, Section 1, Chapter 2, "Cost Estimation: Concepts and Methodology," Sixth Edition, January 2002.

6. NO_x emissions reductions based on the following controlled limits for units with SCR:

Gas Combustion	SCR Controlled NO _x Rate	2 ppm	@ 15% O ₂	6.66E-03 lb/MMBtu	17.6 tpy
Fuel Oil Combustion	SCR Controlled NO _x Rate	5 ppm	@ 15% O ₂	1.66E-02 lb/MMBtu	7.9 tpy

**Appendix D - BACT Cost Assessment
Washington County Power - Sandersville**

Table D-4. Oxidation Catalyst Economic Feasibility Assessment Calcs

Capital Cost Summary	Capital Cost
DIRECT COSTS¹	
TOTAL PURCHASED EQUIPMENT COST (PEC)	PEC = \$2,808,644
(1) Purchased Equipment	
(a) Total Equipment ²	\$2,380,207
(b) Instrumentation (0.1 x [1a])	\$238,021
(c) Sales taxes (0.03 x [1a])	\$71,406
(d) Freight (0.05x [1a])	\$119,010
TOTAL DIRECT INSTALLATION COST, DC	DC = \$842,593
(2) Direct Installation	
(a) Foundation (0.08 x PEC)	\$224,692
(a) Handling (0.14 x PEC)	\$393,210
(c) Electrical (0.04 x PEC)	\$112,346
(d) Piping (0.02 x PEC)	\$56,173
(e) Insulation (0.01 x PEC)	\$28,086
(f) Painting (0.01 x PEC)	\$28,086
TOTAL DIRECT COST (TDC)	TDC = \$3,651,237
INDIRECT COSTS¹	
(3) Engineering (0.1 x PEC)	\$280,864
(4) Construction (0.05 x PEC)	\$140,432
(5) Contractor fees (0.1 x PEC)	\$280,864
(6) Start-up (0.02 x PEC)	\$56,173
(7) Performance test (0.01 x PEC)	\$28,086
TOTAL INDIRECT COST (TIC)	TIC = \$786,420
PROJECT CONTINGENCY ((TDC + TIC)*0.1)³	PC = \$443,766
TOTAL CAPITAL INVESTMENT (TCI = DC + IC + PC)⁴	TCI = \$4,881,423

1. General costing approach from EAPCCM = EPA Air Pollution Control Cost Manual, Seventh Edition, February 2018. Section 3, Chapter 2 (Incinerators and Oxidizers).

2. Oxidation Catalyst equipment cost per a letter from Michael G. Tritapoe (TVA) to Mr. James P. Johnston (TDEC) with BACT analysis for OC on simple cycle large frame combustion turbines, dated July 31, 2019.

3. Assumes a project contingency of 10%.

4. Total Capital Investment = Total Direct Cost + Total Indirect Cost + Project Contingency

**Appendix D - BACT Cost Assessment
Washington County Power - Sandersville**

Table D-5. Oxidation Catalyst Economic Feasibility Assessment Calcs

Annualized Cost	Annual Cost
TOTAL CAPITAL INVESTMENT, TCI	TCI = \$4,881,423
DIRECT ANNUAL COSTS¹	
ANNUAL LABOR COST (1a + 1b)	\$9,600
(1) Operating Labor	
(a) Operating Cost	\$8,350
(b) Supervisor (0.15 x 1a)	1250
MAINTENANCE LABOR AND MATERIALS (2a +2b)	\$11,500
(2) Maintenance	
(a) Labor	\$5,750
(b) Material (100% of 1a)	\$5,750
(3) Equipment Life	
(a) Interest Rate	7.00%
(b) CRF ²	0.086
(c) Annual Cost ³	\$969,499
TOTAL DIRECT ANNUAL COSTS (DAC)	DAC = \$990,599
INDIRECT ANNUAL COSTS	
(4) Overhead (0.6 x (AClabor + Maintenance Labor and Materials))	\$12,660
(5) Administrative charges (0.02 x TCI)	\$97,628
(6) Property Tax (0.01 x TCI)	\$48,814
(7) Insurance (0.01 x TCI)	\$48,814
(8) Capital Recovery (CRFx (TCI - 1.08*Annual Catalyst Cost))	\$329,029
TOTAL INDIRECT ANNUAL COSTS (IAC)	IAC = \$536,946
TOTAL ANNUALIZED COST (TAC = DAC + IAC)⁴	TAC= \$1,527,545
Cost Effectiveness Summary	
POLLUTANT TO BE REMOVED (CO) (tpy)⁵	53.95
POLLUTANT TO BE REMOVED (VOC) (tpy)⁵	47.20
COST EFFECTIVENESS (\$/ton CO removed)	\$28,312
COST EFFECTIVENESS (\$/ton VOC removed)	\$32,360

1. Bureau of Labor Statistics, National Occupational Employment and Wage Estimates – United States, January 2021 (Stats last updated May 2019). Hourly rates for maintenance based on data for Industrial Machinery Installation, Repair, and Maintenance Workers (49-9040). Hourly rates for operators based on data for Power Plant Operators (51-8013): https://www.bls.gov/oes/current/oes_nat.htm.

Operating Labor Cost = 3,500 hours of Operation/Labor = 0.5 hours/shift × Labor Rate (\$38.16/hr) × (Operating Hours/8 hours/shift)

Maintenance Labor Cost = 3,500 hours of Operation/Labor = 0.5 hours/shift × Labor Rate (\$28.67/hr) × (Operating Hours/8 hours/shift)

2. The capital recovery factor, CRF, is a function of the equipment life and the opportunity cost of the capital (i.e., interest rate). For example, for a 25-year equipment life and a 7% interest rate, CRF = 0.086.

3. Based on 2003 EPA Economic Analysis (Conservatively no CPI or cost ratios used)

https://www.epa.gov/sites/production/files/2020-07/documents/combustion-turbines_eia_neshap_final_08-2003.pdf

4. TOTAL ANNUAL COST = Direct Annual Costs + Indirect Annual Costs

5. CO/VOC emissions reduction conservatively assumes the oxidation catalyst will achieve an 80% control efficiency on the uncontrolled value in Table D-1.

**Appendix D - BACT Cost Assessment
Washington County Power - Sandersville**

Table D-6. Calculation of Project Power Output Changes

Parameters	Value
Annual CO ₂ Captured (tpy) ¹	1,392,882
CO ₂ Captured (kg/yr) ²	1,263,603,225
Proposed Project Increase in Power Output (MW) ³	48
Energy Used for Capture (kWh/kg CO ₂ processed) ⁴	0.354
Energy Used for Capture (kWh/yr) ⁵	447,315,542
Energy Used for Capture (MWh/yr)	447,316
Power Output Before Project (MW)	680
Power Output After Project (without CCS)(MW)	728
Power Used for Capture if CCS included (MW) ⁶	128
Power Output After Project (with CCS)(MW)	600

1. Presumes 90% capture of the CO₂ emissions based on the sustainable annual capacity of the facility.
2. CO₂ Captured (kg/yr) = CO₂ Captured (tpy) * 2,000 (lb/ton) / 2.20462 (lb/kg)
3. Proposed Project Increase in Power Output (MW) is based on the ratio of Natural Gas to Fuel Oil Heat Input Capacity, which is then applied to -the output (MW) for all four generators to estimate project increases. kW = MW * 1,000 kW/MW. Theoretical estimate based on heat input difference between gas and fuel oil.
4. David, Jeremy and Howard Herzog, The Cost of Carbon Capture, published 2000, p. 2, accessed at <http://citeseerx.ist.psu.edu/viewdoc/download?doi=10.1.1.195.9269&rep=rep1&type=pdf>
5. Energy Used for Capture (kWh/yr) = Energy Used for Capture (kWh/kg CO₂ processed) * CO₂ Captured (kg/yr)
6. Power Used for Capture (MW) = Energy Used for Capture (MWh/yr) / 3.500 (hr/yr). Hours represents sum of 3,000 hour for natural gas combustion and 500 hours for fuel oil combustion.

**Appendix D - BACT Cost Assessment
Washington County Power - Sandersville**

Table D-7. Assumptions Used in CCS Cost Estimation for Turbines¹

Parameters	Value Unit
Pipeline Length ²	246 mi
Pipeline Diameter ^{3,4,5}	21 in
Average Storage Site Depth ⁶	287 m 940 ft
Number of Injection Wells ⁷	2
Uncontrolled Annual Natural Gas CO ₂ Emissions ⁸	1,239,479 tpy
Uncontrolled Maximum Natural Gas Daily CO ₂ Emissions ⁸	9,916 tpd
Uncontrolled Annual Fuel Oil CO ₂ Emissions ⁸	308,169 tpy
Uncontrolled Maximum Daily Fuel Oil CO ₂ Emissions ⁸	14,792 tpd
Control Efficiency ⁹	90%
Annual Captured CO ₂ Emissions	1,392,882 tpy
Daily Maximum Captured CO ₂ Emissions	13,313 tpd
Post-Project Net Power Output without CCS	728 MW
Post-Project Net Power Output with CCS ¹⁰	600 MW

Gas because there are limited available resources to adapt these figures to natural gas pipeline connections to simple cycle turbines.

2. Distance from the facility to the nearest potential CO₂ sequestration facility (Black Warrior Basin) per the Southeast Regional Carbon Sequestration Partnership (SECARB), conservatively assuming the shortest distance as the pipeline route. Note that this site utilized an injection well as part of SECARB's Phase I study, but that injection well has reverted back to its original use for coalbed methane production.

http://secarbon.org/index.php?page_id=8 and <http://secarbon.org/files/black-warrior-basin.pdf>

3. Estimating Carbon Dioxide Transport and Storage Costs, National Energy Technology laboratory, U.S. DOE, DOE/NETL-2010/1447 (March 2010), Figure 3. The required diameter for a 246 mile long pipeline is 18 inches at 10,000 tons/day CO₂. <http://www.canadiancleanpowercoalition.com/pdf/CTS11%20-%20QGESSTransport.pdf>

4. The required diameter is conservatively estimated by scaling 18 inches of diameter (necessary for a 10,000 tons/day CO₂ flowrate) by the square root of the ratio of the flowrates.

$18 \text{ inches} * (\text{Daily Maximum Captured CO}_2 \text{ Emissions} / 10,000)^{1/2} = \text{Necessary diameter in inches.}$

See the 1-D inlets & outlets (for incompressible flow) section of

https://www.mne.psu.edu/cimbala/Learning/Fluid/CV_Mass/home.htm for reference.

5. *Carbon Dioxide Transport and Storage Costs in NETL Studies*, National Energy Technology laboratory, U.S. DOE, DOE/NETL-2017/1819 (November 2017), Exhibit 2-2. The calculated diameter for a 246 mile long pipeline is 21 inches at 10,000 tons/day CO₂. Since a 21 inch pipeline would not be available for installation, a 20 inch size was selected.

https://www.netl.doe.gov/projects/files/QGESSTransportandStorageCostsinNETLStudies_110617.pdf

6. The shallowest injection depth at Black Warrior Basin is 940 feet or 286.51 meters. Shallowest depth is used for conservatism. http://secarbon.org/index.php?page_id=8

7. Each injection well can only accommodate an average of 10,320 tons/day based on the document in reference 2.

8. Emissions calculated in Table D-1.

9. 90% CCS Control Efficiency from https://sequestration.mit.edu/pdf/David_and_Herzog.pdf

10. Net Power Output with CCS = Power Output After Project (without CCS) - Power Used for Capture if CCS included (MW)

Table D-8. Capital and O&M Costs of Carbon Capture

**Appendix D - BACT Cost Assessment
Washington County Power - Sandersville**

	December 2018 Dollars	November 2020 Dollars²
Capture Capital Costs for CCCTs ^{1,2}	\$ 622,642,559	\$ 644,937,769
Total Capital	\$ 622,642,559	\$ 644,937,769
O&M		
Fixed Operating Costs ^{2,4}	\$ 18,845,106	\$ 19,519,900.25
Variable Operating Costs ^{2,5}	\$ --	\$ 7,468,713
Total O&M	\$ 18,845,106	\$ 26,988,613

1. Based on the September 2019 DOE Report, *Cost and Performance Baseline for Fossil Energy Plants Volume 1: Bituminous Coal and Natural Gas to Electricity*, the total capital cost difference between a natural gas CCCT energy facility with and without capture in terms of \$/kW (net) is relied upon to estimate the capital costs associated with capture equipment. Exhibit 5-17, Case B31A Total Plant Cost Details (page 505) and Exhibit 5-31, Case B31B Total Plant Cost Details (page 524).

Capture Capital Costs for CCCTs = [Total Plant Capital Cost (capture) (\$/kW) * Post-Project Net Power Output with CCS (kW)] - [Total Plant Capital Cost (no capture) (\$/kW) * Post-Project Net Power Output without CCS Penalty (kW)]

Total Plant Capital Cost - No Capture	780	\$/kW
Total Plant Capital Cost - With Capture	1984	\$/kW

2. Costs were adjusted from specified dollars to the November 2020 dollars per the consumer price index for all items: <https://www.bls.gov/data/>

CPI for December 2018	251.233
CPI for November 2020	260.229

3. Note that the four turbines would share a carbon capture system; therefore additional cost is required for connecting the turbines to a single carbon capture system. WCP conservatively estimated there is no additional cost for connecting the turbines into a single pipeline for purposes of this estimate.

4. Based on the September 2019 DOE Report, *Cost and Performance Baseline for Fossil Energy Plants Volume 1: Bituminous Coal and Natural Gas to Electricity*, the total fixed operating cost difference between a natural gas CCCT energy facility with and without capture in terms of \$/kW (net) is relied upon to estimate the fixed operating costs associated with capture equipment. Exhibit 5-19, Case B31A Initial and Annual Operating and Maintenance Costs (page 507) and Exhibit 5-33, Case B31B Initial and Annual Operating and Maintenance Costs (page 526).

Fixed Operating Costs = [Total Fixed Operating Cost (capture)(\$/kW) * Post-Project Net Power Output with CCS (kW)] - [Total Fixed Operating Cost (no capture) (\$/kW) * Post-Project Net Power Output without CCS (kW)]

Total Fixed Operating Costs - No Capture	26.792	\$/kW
Total Fixed Operating Costs - With Capture	63.911	\$/kW

**Appendix D - BACT Cost Assessment
Washington County Power - Sandersville**

5. Based on the September 2019 DOE Report, Cost and Performance Baseline for Fossil Energy Plants Volume 1: Bituminous Coal and Natural Gas to Electricity, the total variable operating cost difference between a natural gas CCT energy facility with and without capture in terms of \$/kWh (net) is relied upon to estimate the variable operating costs associated with capture equipment. Exhibit 5-19. Case B31A Initial and Annual Operating and Maintenance Costs (page 507) and Exhibit 5-33. Case B31B Initial and Annual Operating and Maintenance Costs (page 526). The Total Variable Operating Cost was re-evaluated below to remove the Ammonia and SCR Catalyst and serves as a conservative estimate to connect to a Simple Cycle Combustion Turbine. Annualized variable operating costs were calculated assuming the lowest possible hours of operation for the facility for the year, which are 3,000 hours/yr for Natural Gas and 500 hours/yr for Fuel Oil.

Variable Operating Costs = [Total Variable Operating Cost (capture)(\$/kWh) * Post-Project Net Power Output with CCS (kW)] - [Total Variable Operating

<i>Maintenance Materials</i>	<i>1.19E-03</i>	<i>\$/kWh</i>
<i>Water Cost</i>	<i>2.28E-04</i>	<i>\$/kWh</i>
<i>Makeup and Waste Water Treatment Chemicals</i>	<i>1.96E-04</i>	<i>\$/kWh</i>
Total Variable Operating Costs - No Capture	1.62E-03	\$/kWh
<i>Maintenance Materials</i>	<i>3.04E-03</i>	<i>\$/kWh</i>
<i>Water Cost</i>	<i>4.21E-04</i>	<i>\$/kWh</i>
<i>Makeup and Waste Water Treatment Chemicals</i>	<i>3.63E-04</i>	<i>\$/kWh</i>
<i>CO₂ Capture System Chemicals</i>	<i>1.51E-03</i>	<i>\$/kWh</i>
<i>Triethylene Glycol Consumption</i>	<i>1.73E-04</i>	<i>\$/kWh</i>
<i>Triethylene Glycol Waste Disposal</i>	<i>8.89E-06</i>	<i>\$/kWh</i>
<i>Thermal Reclaimer Unit Waste</i>	<i>1.33E-06</i>	<i>\$/kWh</i>
Total Variable Operating Costs - With Capture	5.52E-03	\$/kWh

Table D-9. Capital and O&M Costs of Pipeline Transportation

Capital Costs	Factor	Unit	December 2011 Dollars	December 2018 Dollars	November 2020 Dollars ³
Pipeline Costs¹					
Pipeline Cost	\$	1,700,000 \$/mi for a 20 inch pipeline	--	\$ 418,200,000	\$ 433,174,654
Total Capital			--	\$ 418,200,000	\$ 433,174,654
O&M²					
Fixed O&M	\$	8,454 \$/mile/yr	\$ 2,079,684	--	\$ 2,398,145

1. Based on National Energy Technology Laboratory guidance, "Carbon Dioxide Transport and Storage Costs in NETL Studies," DOE/NETL-2019/2044, Exhibit 2-3, August 2019, for a 20 inch pipeline using the Parker model. The pipeline cost was available for a 20 inch or a 24 inch pipeline diameter. Although Table D-3 above calculates the necessary pipeline diameter as 21 inches for maximum daily operations, a 20 inch pipeline diameter is conservatively chosen for the pipeline cost calculation.

2. Annual O&M costs per National Energy Technology Laboratory guidance, "Carbon Dioxide Transport and Storage Costs in NETL Studies," DOE/NETL-2013/1614, Exhibit 2, March 2013.

3. Costs were adjusted from December 2011 and December 2018 dollars to the November 2020 dollars per the consumer price index for all items:
<https://www.bls.gov/data/>

CPI for December 2011	225.672
CPI for December 2018	251.233
CPI for November 2020	260.229

**Appendix D - BACT Cost Assessment
Washington County Power - Sandersville**

Table D-10. Capital and O&M Costs of Geological Storage

Capital Costs¹	Factor	Unit	June 2007 Dollars	November 2020 Dollars²
Site Screening and Evaluation		\$	\$ 4,738,488	#####
Injection Wells	$240,714 * e^{0.0008 * \text{well-depth}}$	\$/injection well, well-depth(m)	\$ 605,447	\$ 756,195
Injection Equipment	$94,029 * (7,389 / (280 * \# \text{ of injection wells}))^{0.5}$	\$/injection well	\$ 683,110	\$ 853,196
Liability Bond		\$	\$ 5,000,000	\$ 6,244,936
Total Capital			\$ 11,027,045	\$ 13,772,638
O&M¹				
Pore Space Acquisition	0.334	\$/short tons CO ₂ captured	\$ 465,223	\$ 581,057
Normal Daily Expenses	11,566	\$/injection well	\$ 23,132	\$ 28,892
Consumables	2,995	\$/yr/short tons CO ₂ /day	\$ 39,872,098	\$ 49,799,743
Surface Maintenance	$23,478 * (7,389 / (280 * \# \text{ of injection wells}))^{0.5}$	\$/injection well	\$ 85,282	\$ 106,517
Subsurface Maintenance	7.08	\$/ft depth/injection well	\$ 13,310	\$ 16,625
Total O&M			\$ 40,459,045	\$ 50,532,833

1. "Estimating Carbon Dioxide Transport and Storage Costs," National Energy Technology Laboratory, U.S. DOE, DOE/NETL-2010/1447, Table 3, March 2010. <http://www.canadiancleanpowercoalition.com/pdf/CTS11%20-%20QGESstransport.pdf>

2. Costs were adjusted from June 2007 dollars to the November 2020 dollars per the consumer price index for all items: <https://www.bls.gov/data/>

CPI for June 2007	208.352
CPI for November 2020	260.229

**Appendix D - BACT Cost Assessment
Washington County Power - Sandersville**

Table D-11. Overall Cost of CCS and Cost Effectiveness

			November 2020 Dollars
Total Capital Investment (TCI) ¹			\$ 1,091,885,061
Capital Recovery Factor (CRF) ²	7% interest, 10 year lifespan	0.14	
Amortized Cost	CRF*TCI		\$ 155,459,868
Total O&M Cost			\$ 79,919,591
Total Annualized Cost	Amortized Cost + O&M Costs		\$ 235,379,459
Cost Effectiveness (\$/ton)³			\$ 168.99

1. Total Capital Investment (TCI) is equal to the sum of capital costs for carbon capture, transportation, and storage.

2. Calculated using the formula from the EPA OAQPS Control Cost Manual.

3. Cost Effectiveness = Total Annualized Cost (\$)/ CO₂ Emissions Captured (tons).

APPENDIX E. SIP PERMIT APPLICATION FORMS



SIP AIR PERMIT APPLICATION

EPD Use Only

Date Received: _____ Application No. _____

FORM 1.00: GENERAL INFORMATION

1. Facility Information

Facility Name: Washington County Power
AIRS No. (if known): 04-13- 303 - 00039
Facility Location: Street: 1177 County Line Road
City: Sandersville Georgia Zip: 31082 County: Washington
Is this facility a "small business" as defined in the instructions? Yes: No:

2. Facility Coordinates

Latitude: 33° 5 '21.5" **NORTH** Longitude: 82° 58' 51.5" **WEST**
UTM Coordinates: 315104.54 **EAST** 3662933.05 **NORTH** **ZONE** 17S

3. Facility Owner

Name of Owner: Washington County Power, LLC
Owner Address Street: 1177 County Line Road
City: Sandersville State: GA Zip: 31082

4. Permitting Contact and Mailing Address

Contact Person: Mike Spranger Title: Plant Manager
Telephone No.: 404-832-7571 Ext. _____ Fax No.: _____
Email Address: mikespranger@cogentrix.com
Mailing Address: Same as: Facility Location: Owner Address: Other:
If Other: Street Address: 208 Cherry Hill Road
City: Monroe State: GA Zip: 30656

5. Authorized Official

Name: Mike Spranger Title: Plant Manager
Address of Official Street: 1177 County Line Road
City: Sandersville State: GA Zip: 31082

This application is submitted in accordance with the provisions of the Georgia Rules for Air Quality Control and, to the best of my knowledge, is complete and correct.

Signature: _____ Date: _____

6. Reason for Application: (Check all that apply)

- New Facility (to be constructed)
 Revision of Data Submitted in an Earlier Application
 Existing Facility (initial or modification application)
 Application No.: _____
 Permit to Construct
 Date of Original Submittal: _____
 Permit to Operate
 Change of Location
 Permit to Modify Existing Equipment:
 Affected Permit No.: _____

7. Permitting Exemption Activities (for permitted facilities only):

Have any exempt modifications based on emission level per Georgia Rule 391-3-1-.03(6)(i)(3) been performed at the facility that have not been previously incorporated in a permit?

- No**
 Yes, please fill out the SIP Exemption Attachment (See Instructions for the attachment download)

8. Has assistance been provided to you for any part of this application?

- No**
 Yes, SBAP
 Yes, a consultant has been employed or will be employed.

If yes, please provide the following information:

Name of Consulting Company: Trinity Consultants
 Name of Contact: Justin Fickas
 Telephone No.: 678-441-9977, ext. 228 Fax No.: 678-441-9978
 Email Address: jfickas@trinityconsultants.com
 Mailing Address: Street: 3495 Piedmont Road, Building 10, Suite 905
 City: Atlanta State: GA Zip: 30305

Describe the Consultant's Involvement:

Prepared potential to emit calculations, application narrative, and SIP forms

9. Submitted Application Forms: Select only the necessary forms for the facility application that will be submitted.

No. of Forms	Form
x	2.00 Emission Unit List
x	2.01 Boilers and Fuel Burning Equipment
x	2.02 Storage Tank Physical Data
	2.03 Printing Operations
	2.04 Surface Coating Operations
	2.05 Waste Incinerators (solid/liquid waste destruction)
	2.06 Manufacturing and Operational Data
x	3.00 Air Pollution Control Devices (APCD)
	3.01 Scrubbers
	3.02 Baghouses & Other Filter Collectors
	3.03 Electrostatic Precipitators
x	4.00 Emissions Data
	5.00 Monitoring Information
s	6.00 Fugitive Emission Sources
x	7.00 Air Modeling Information

10. Construction or Modification Date

Estimated Start Date: Late 2021

11. If confidential information is being submitted in this application, were the guidelines followed in the “Procedures for Requesting that Submitted Information be treated as Confidential”?

No Yes

12. New Facility Emissions Summary

Criteria Pollutant	New Facility	
	Potential (tpy)	Actual (tpy)
Carbon monoxide (CO)	N/A	N/A
Nitrogen oxides (NOx)	N/A	N/A
Particulate Matter (PM) (filterable only)	N/A	N/A
PM <10 microns (PM10)	N/A	N/A
PM <2.5 microns (PM2.5)	N/A	N/A
Sulfur dioxide (SO ₂)	N/A	N/A
Volatile Organic Compounds (VOC)	N/A	N/A
Greenhouse Gases (GHGs) (in CO ₂ e)	N/A	N/A
Total Hazardous Air Pollutants (HAPs)	N/A	N/A
Individual HAPs Listed Below:		
	N/A	N/A

13. Existing Facility Emissions Summary

Criteria Pollutant	Current Facility		After Modification	
	Potential (tpy)	Actual (tpy)	Potential (tpy)	Actual (tpy)
Carbon monoxide (CO)	99.53	N/A	291.77	N/A
Nitrogen oxides (NOx)	249	N/A	624.48	N/A
Particulate Matter (PM) (filterable only)	N/A	N/A	109.10	N/A
PM <10 microns (PM10)	63.71	N/A	173.01	N/A
PM <2.5 microns (PM2.5)	63.71	N/A	173.01	N/A
Sulfur dioxide (SO ₂)	79.6	N/A	9.64	N/A
Volatile Organic Compounds (VOC)	9.83	N/A	103.99	N/A
Greenhouse Gases (GHGs) (in CO ₂ e)	N/A	N/A	1,560,525	N/A
Total Hazardous Air Pollutants (HAPs)	3.46	N/A	13.91	N/A
Individual HAPs Listed Below:				
Formaldehyde	N/A	N/A	8.06	N/A
Toluene	N/A	N/A	1.39	N/A
Xylenes	N/A	N/A	0.72	N/A

Acetaldehyde	N/A	N/A	0.42	N/A
Ethylbenzene	N/A	N/A	0.34	N/A
Propylene Oxide	N/A	N/A	0.31	N/A

14. 4-Digit Facility Identification Code:

SIC Code: 4911 SIC Description: Electric Services

NAICS Code: 49119902 NAICS Description: Generation, electric power

15. Description of general production process and operation for which a permit is being requested. If necessary, attach additional sheets to give an adequate description. Include layout drawings, as necessary, to describe each process. References should be made to source codes used in the application.

This facility is currently authorized to operate five simple cycle combustion turbines, each capable of generating 169 MW of electricity. However, only four combustion turbines have been built. Each combustion turbine can only burn natural gas. A permit is being requested to retrofit the turbines to add the capacity to also fire fuel oil.

16. Additional information provided in attachments as listed below:

- Attachment A - Area Map and Process Flow Diagram
- Attachment B - Emission Calculations
- Attachment C - RBLC Search Results
- Attachment D - Control Cost Analyses
- Attachment E - SIP Permit Application Forms
- Attachment F - _____

17. Additional Information: Unless previously submitted, include the following two items:

- Plot plan/map of facility location or date of previous submittal: _____
- Flow Diagram or date of previous submittal: _____

18. Other Environmental Permitting Needs:

Will this facility/modification trigger the need for environmental permits/approvals (other than air) such as Hazardous Waste Generation, Solid Waste Handling, Water withdrawal, water discharge, SWPPP, mining, landfill, etc.?

- No** **Yes, please list below:**

19. List requested permit limits including synthetic minor (SM) limits.

20. Effective March 1, 2019, permit application fees will be assessed. The fee amount varies based on type of permit application. Application acknowledgement emails will be sent to the current registered fee contact in the GECO system. If fee contacts have changed, please list that below:

Fee Contact name: Mike Spranger

Fee Contact email address: mikespranger@cogentrix.com

Fee Contact phone number: 404-832-7571

Fee invoices will be created through the GECO system shortly after the application is received. It is the applicant's responsibility to access the facility GECO account, generate the fee invoice, and submit payment within 10 days after notification.

Facility Name: Washington County Power

Date of Application: February 2021

FORM 2.01 – BOILERS AND FUEL BURNING EQUIPMENT

Emission Unit ID	Type of Burner	Type of Draft ¹	Design Capacity of Unit (MMBtu/hr Input)	Percent Excess Air	Dates		Date & Description of Last Modification
					Construction	Installation	
T1	Dry-Low NOx Burner	N/A	1766 for NG, 1890 for FO	N/A	TBD/2021	TBD/2021	Modified TBD/2021 for fuel oil capacity
T2	Dry-Low NOx Burner	N/A	1766 for NG, 1890 for FO	N/A	TBD/2021	TBD/2021	Modified TBD/2021 for fuel oil capacity
T3	Dry-Low NOx Burner	N/A	1766 for NG, 1890 for FO	N/A	TBD/2021	TBD/2021	Modified TBD/2021 for fuel oil capacity
T4	Dry-Low NOx Burner	N/A	1766 for NG, 1890 for FO	N/A	TBD/2021	TBD/2021	Modified TBD/2021 for fuel oil capacity

¹ This column does not have to be completed for natural gas only fired equipment.

Facility Name: Washington County Power

Date of Application: February 2021

FUEL DATA

Emission Unit ID	Fuel Type	Potential Annual Consumption				Hourly Consumption		Heat Content		Percent Sulfur		Percent Ash in Solid Fuel	
		Total Quantity		Percent Use by Season		Max.	Avg.	Min.	Avg.	Max.	Avg.	Max.	Avg.
		Amount	Units	Ozone Season May 1 - Sept 30	Non-ozone Season Oct 1 - Apr 30								
T1	Natural Gas	5,194	MMscf/yr	N/A	N/A	1.73 MMscf/hr	N/A	N/A	1766 MMBtu/hr	<0.001	N/A	N/A	N/A
T1	Fuel Oil	6,750	Mgal/yr	0	100	13.5 Mgal/hr	N/A	N/A	1890 MMBtu/hr	0.0015	N/A	N/A	N/A
T2	Natural Gas	5,194	MMscf/yr	N/A	N/A	1.73 MMscf/hr	N/A	N/A	1766 MMBtu/hr	<0.001	N/A	N/A	N/A
T2	Fuel Oil	6,750	Mgal/yr	0	100	13.5 Mgal/hr	N/A	N/A	1890 MMBtu/hr	0.0015	N/A	N/A	N/A
T3	Natural Gas	5,194	MMscf/yr	N/A	N/A	1.73 MMscf/hr	N/A	N/A	1766 MMBtu/hr	<0.001	N/A	N/A	N/A
T3	Fuel Oil	6,750	Mgal/yr	0	100	13.5 Mgal/hr	N/A	N/A	1890 MMBtu/hr	0.0015	N/A	N/A	N/A
T4	Natural Gas	5,194	MMscf/yr	N/A	N/A	1.73 MMscf/hr	N/A	N/A	1766 MMBtu/hr	<0.001	N/A	N/A	N/A
T4	Fuel Oil	6,750	Mgal/yr	0	100	13.5 Mgal/hr	N/A	N/A	1890 MMBtu/hr	0.0015	N/A	N/A	N/A

Fuel Supplier Information

Fuel Type	Name of Supplier	Phone Number	Supplier Location			
			Address	City	State	Zip
Natural Gas	GA Power	(855) 936-7438	Black Warrior Basin Pipeline	N/A	AL/GA	N/A
Fuel Oil	TBD	TBD	TBD	TBD	TBD	TBD

Facility Name: Washington County Power

Date of Application: February 2021

Form 3.00 – AIR POLLUTION CONTROL DEVICES - PART A: GENERAL EQUIPMENT INFORMATION

APCD Unit ID	Emission Unit ID	APCD Type (Baghouse, ESP, Scrubber etc)	Date Installed	Make & Model Number (Attach Mfg. Specifications & Literature)	Unit Modified from Mfg Specifications?	Gas Temp. °F		Inlet Gas Flow Rate (acfm)
						Inlet	Outlet	
WI1	T1	Water Injection	TBD/2021	TBD	N/A	1,113	TBD	717
WI1	T2	Water Injection	TBD/2021	TBD	N/A	1,113	TBD	717
WI1	T3	Water Injection	TBD/2021	TBD	N/A	1,113	TBD	717
WI1	T4	Water Injection	TBD/2021	TBD	N/A	1,113	TBD	717
LNB1	T1	Low NOx Burner	TBD/2021	N/A	N/A	N/A	1,113	N/A
LNB2	T2	Low NOx Burner	TBD/2021	N/A	N/A	N/A	1,113	N/A
LNB3	T3	Low NOx Burner	TBD/2021	N/A	N/A	N/A	1,113	N/A
LNB4	T4	Low NOx Burner	TBD/2021	N/A	N/A	N/A	1,113	N/A

Facility Name: Washington County Power

Date of Application: February 2021

Form 3.00 – AIR POLLUTION CONTROL DEVICES – PART B: EMISSION INFORMATION

APCD Unit ID	Pollutants Controlled	Percent Control Efficiency		Inlet Stream To APCD		Exit Stream From APCD		Pressure Drop Across Unit (Inches of water)
		Design	Actual	lb/hr	Method of Determination	lb/hr	Method of Determination	
WI1	NOx	50%	N/A	TBD	Calculated	TBD	TBD	N/A
WI2	NOx	50%	N/A	TBD	Calculated	TBD	TBD	N/A
WI3	NOx	50%	N/A	TBD	Calculated	TBD	TBD	N/A
WI4	NOx	50%	N/A	TBD	Calculated	TBD	TBD	N/A
LNB1	NOx	50%	NOx	N/A	Calculated	N/A	N/A	N/A
LNB2	NOx	50%	NOx	N/A	Calculated	N/A	N/A	N/A
LNB3	NOx	50%	NOx	N/A	Calculated	N/A	N/A	N/A
LNB4	NOx	50%	NOx	N/A	Calculated	N/A	N/A	N/A

Facility Name: Washington County Power

Date of Application: February 2021

February 2021

FORM 4.00 – EMISSION INFORMATION

Emission Unit ID	Air Pollution Control Device ID	Stack ID	Pollutant Emitted	Emission Rates				Method of Determination
				Hourly Actual Emissions (lb/hr)	Hourly Potential Emissions (lb/hr)	Actual Annual Emission (tpy)	Potential Annual Emission (tpy)	
T1-T4	W1	T1-T4	CO	N/A	435.07	N/A	283.44	Emission Factors
T1-T4	W1	T1-T4	NOx	N/A	1,268.04	N/A	610.94	Emission Factors
T1-T4	W1	T1-T4	Total PM	N/A	204.13	N/A	172.00	Emission Factors
T1-T4	W1	T1-T4	Total PM10	N/A	204.13	N/A	172.00	Emission Factors
T1-T4	W1	T1-T4	Total PM2.5	N/A	204.13	N/A	172.00	Emission Factors
T1-T4	W1	T1-T4	SO2	N/A	15.58	N/A	9.19	Emission Factors
T1-T4	W1	T1-T4	VOC	N/A	165.24	N/A	102.45	Emission Factors
T1-T4	W1	T1-T4	CO2e	N/A	2,064,077	N/A	1,549,985	Emission Factors
T1-T4	W1	T1-T4	Total HAP	N/A	5.16	N/A	13.32	Emission Factors
H1-H2	N/A	H1-H2	CO	N/A	1.66	N/A	7.29	Emission Factors
H1-H2	N/A	H1-H2	NOx	N/A	1.98	N/A	8.67	Emission Factors
H1-H2	N/A	H1-H2	Total PM	N/A	3.76E-02	N/A	0.16	Emission Factors
H1-H2	N/A	H1-H2	Total PM10	N/A	0.15	N/A	0.66	Emission Factors
H1-H2	N/A	H1-H2	Total PM2.5	N/A	0.15	N/A	0.66	Emission Factors
H1-H2	N/A	H1-H2	SO2	N/A	2.83E-02	N/A	0.12	Emission Factors
H1-H2	N/A	H1-H2	VOC	N/A	0.11	N/A	0.48	Emission Factors
H1-H2	N/A	H1-H2	CO2e	N/A	2,365	N/A	10,360	Emission Factors
H1-H2	N/A	H1-H2	Total HAP	N/A	0.12	N/A	0.53	Emission Factors
ST1	N/A	ST1	VOC Total HAP	N/A	0.15 0.17	N/A	0.66 5.89E-02	Emission Factors

Facility Name: Washington County Power

Date of Application: February 2021

FORM 7.00 – AIR MODELING INFORMATION: Stack Data

Stack ID	Emission Unit ID(s)	Stack Information			Dimensions of largest Structure Near Stack		Exit Gas Conditions at Maximum Emission Rate			
		Height Above Grade (ft)	Inside Diameter (ft)	Exhaust Direction	Height (ft)	Longest Side (ft)	Velocity (ft/sec)	Temperature (°F)	Flow Rate (acfm)	
									Average	Maximum
T1	T1	90	18.50	Vertical	40	23.4	160	1,113	N/A	717
T2	T2	90	18.50	Vertical	40	23.4	160	1,113	N/A	717
T3	T3	90	18.50	Vertical	40	23.4	160	1,113	N/A	717
T4	T4	90	18.50	Vertical	40	23.4	160	1,113	N/A	717
H1	H1	15	1.30	Vertical	40	23.4	16	780	N/A	0.354
H2	H1	15	1.30	Vertical	40	23.4	16	780	N/A	0.354
TANK	ST1	48	N/A	Vertical	40	23.4	N/A	Ambient	N/A	N/A

NOTE: If emissions are not vented through a stack, describe point of discharge below and, if necessary, include an attachment. List the attachment in Form 1.00 *General Information*, Item 16.

The Storage Tank was modeled via TankESP, see the Emission Calculation Data in Appendix B for this data.

