

ENVIRONMENTAL PROTECTION DIVISION
PUBLIC NOTICE
WATERSHED PROTECTION BRANCH

September 13, 2018
Notice Issue Date

Athens / Clarke County
City / County

October 15, 2018
Notice Close Date

BV-029-18-02
Control Number

University of Georgia Golf Course – Off-Site Development - Gravity Sewer Line Extension
(2429 South Milledge Avenue, Athens, GA 30605)
Activity

This notice is issued to inform the public of a receipt of an application for a variance submitted pursuant to a state environmental Law. The public is invited to comment during the 30-day period on the proposed activity. Site plans are available for review and are located in the following EPD office: Watershed Protection Branch, 200 Piedmont Avenue SW, Suite 418 West, Atlanta, GA 30334. Please contact Ms. Thais Edwards at (404) 463-2382 or email thais.edwards@dnr.ga.gov to schedule an appointment to review the plans. Since the EPD has no authority to zone property or determine land use, only those comments addressing environmental issues related to air, water, and land protection will be considered in the application review process. Written comments should be submitted to: Program Manager, NonPoint Source Program, Erosion and Sedimentation Control, 2 Martin Luther King Jr. Drive SW, Suite 1462 East, Atlanta, GA 30334.

Type of Permit Application: Variance to encroach within the 25-foot State waters buffer.

Applicable Law: Georgia Erosion and Sedimentation Act O.C.G.A. 12-7-1 et seq.

Applicable Rules: Erosion and Sedimentation Control Chapter 391-3-7

Basis under which variance shall be considered {391-3-7-.05 (2)(a-k)}: (d)

Description and Location of Proposed Activity:

The proposed project will consist of installing approximately 1,800 linear feet of 8" Ø ductile iron pipe (DIP) and PVC pipe gravity sanitary sewer lines and new manholes across the University of Georgia Golf Course to an off-site development located along South Milledge Avenue in Athens. The extension of the existing gravity sanitary sewer line will consist of limited open-cut construction. The streambanks along Will Hunter Branch will returned to original grades (to the extent practicable) and stabilized with vegetated riprap (i.e., joint planting with live stakes) and all open-cut trenches will be backfilled and restored to current existing conditions to the extent practicable. The proposed project will result in approximately 37 linear feet (2,098 square feet) of buffer disturbances along Will Hunter Branch, a tributary to the North Oconee River in the Upper Oconee Watershed.

Name and Address of Permit Applicant: Conway Broun
CBRH, LLC
1020 Barber Creek Drive, Suite 202
Watkinsville, GA 30677

Summary of Rules Requirements for Variance Application:

The application for a variance must include an approved Erosion and Sediment Control Plan with control measures based on sound conservation and engineering practices which meet or exceed the standards in the "Manual for Erosion and Sediment Control in Georgia" and which will minimize erosion and deposition of sediments on adjacent lands or into State waters.

For Additional Information Contact:

Frank M. Carubba, Environmental Engineer
EPD Watershed Protection Branch
NonPoint Source Program
2 Martin Luther King Jr. Drive SW, Suite 1462 East
Atlanta, GA 30334
Telephone: (404) 651-8550