



GEORGIA
DEPARTMENT OF NATURAL RESOURCES

ENVIRONMENTAL PROTECTION DIVISION

Richard E. Dunn, Director

Watershed Protection Branch

2 Martin Luther King, Jr. Drive
Suite 1152, East Tower
Atlanta, Georgia 30334
404-463-1511

DEC 14 2017

Honorable Myron Mixon, Mayor
City of Unadilla
P.O. Box 307
Unadilla, Georgia 31091

RE: Comments Received for City of Unadilla
Water Pollution Control Plant (WPCP)
LAS Permit No. GAJ020151
Dooly County

Dear Mayor Mixon:

We are in receipt of your comments regarding the permit issuance for the Town of Unadilla WPCP. Specifically, the comments requested that the Biochemical Oxygen Demand and Total Suspended Solids sampling type from the treatment pond system be changed from composite to grab. We agree that the sample type should be listed as grab due to the facility's design. We appreciate your interest in this matter.

After consideration of your comments, EPD has determined that the permit is protective of water quality standards and we have issued the permit.

If you have any questions, please contact Emily Wingo of my staff at 404-463-4932 or emily.wingo@dnr.ga.gov.

Sincerely,

Jeffrey Larson, Assistant Branch Chief
Watershed Protection Branch

JL\elw

CC: Trey Pearson, Tindall Enterprises, Inc. (treypearson@tindallenterprises.net)