



GEORGIA
DEPARTMENT OF NATURAL RESOURCES

ENVIRONMENTAL PROTECTION DIVISION

Richard E. Dunn, Director

Watershed Protection Branch

2 Martin Luther King, Jr. Drive
Suite 1152, East Tower
Atlanta, Georgia 30334
404-463-1511

JAN 23 2018

Mr. Ron Medders, Regional Manager
Utilities Incorporated of Georgia, Inc.
12 Landings Way
Savannah, Georgia 31411

RE: Comments Received for Olde Atlanta Club
Water Reclamation Facility
LAS Permit No. GAJ030980
Forsyth County


Dear Mr. Medders:

We are in receipt of your comments regarding the permit issuance for the Olde Atlanta Club Water Reclamation Facility. Specifically, the comments requested that the sampling frequency for fecal coliform bacteria be consistent with the current permit. As the facility has installed dual disinfection, EPD modified the sample frequency to two days per week. In addition, we have attached a fact sheet addendum which documents changes in the attached permit. We appreciate your interest in this matter.

After consideration of your comments, EPD has determined that the permit is protective of water quality standards and we have issued the permit.

If you have any questions, please contact Emily Wingo of my staff at 404-463-4932 or emily.wingo@dnr.ga.gov.

Sincerely,


Jeffrey Larson, Assistant Branch Chief
Watershed Protection Branch

JL\elw

CC: Malcolm E. Gavin, Utilities Incorporated of Georgia, Inc., (MEGavin@uiwater.com)
Wayne Lanier, Utilities Incorporated of Georgia, Inc., (cwlanier@uiwater.com)
James Cooley, EPD Mountain District – Cartersville Office (James.Cooley@dnr.ga.gov)