



GEORGIA
DEPARTMENT OF NATURAL RESOURCES

ENVIRONMENTAL PROTECTION DIVISION

Richard E. Dunn, Director

Watershed Protection Branch

2 Martin Luther King, Jr. Drive
Suite 1152, East Tower
Atlanta, Georgia 30334
404-463-1511

FEB 08 2017

Ms. Diane Schleicher, City Manager
City of Tybee Island
P.O. Box 2749
Tybee Island, Georgia 31328

RE: Comments Received for
City of Tybee Island
Water Pollution Control Plant (WPCP)
NPDES Permit No. GA0020061
(Chatham County)

Dear Ms. Schleicher:

Thank you for your comments regarding the permit issuance for the City of Tybee Island Water Pollution Control Plant. Attached is a summary of comments received and our responses to the issues raised. In addition, we have attached a fact sheet addendum which documents changes (if any) in the attached permit. We appreciate your interest in this matter.

After consideration of your comments, EPD has determined that the permit is protective of water quality standards and we have issued the permit.

If you have any questions, please contact Yilin Fan of my staff at 404-463-4936 or Yilin.Fan@dnr.ga.gov.

Sincerely,

Jeffrey Larson, Assistant Branch Chief
Watershed Protection Branch

JL\yf
Attachment: Response to Comments

cc: Mr. Fred Sororian – Thomas & Hutton. (sororian.f@thomasandhutton.com)

**Public Comments and EPD Responses on Draft NPDES Permit
City of Tybee Island WPCP – GA0026001**

| COMMENTS RECEIVED | EPD RESPONSE |
|---|--|
| <p>Why did EPD increase the testing frequency requirements for ammonia, BOD, Total Phosphorus and Total Suspended Solids?</p> | <p>The monitoring frequency is based on the size of the facility per EPD policy. The maximum design flow of the facility is 1.15 MGD and EPD based the monitoring frequencies on this flow. The monitoring frequencies must be maintained the same for year-round.</p> |