

Georgia Department of Natural Resources

Environmental Protection Division

2 Martin Luther King Jr. Drive, Suite 1456, Atlanta, Georgia 30334

Richard E. Dunn, Director

(404) 656-4713

July 21, 2016

Mr. Anthony H. Abbott, President
Consolidated Utilities, Inc.
119 West Oglethorpe Ave.
Savannah, GA 31404

RE: Larchmont Estates
Water Pollution Control Plant (WPCP)
NPDES Permit No. GA0034819
Chatham County
Ogeechee River Basin

Dear Mr. Abbott:

Pursuant to the Georgia Water Quality Control Act, as amended; the Federal Water Pollution Control Act, as amended; and the Rules and Regulations promulgated thereunder, we have today issued the attached National Pollutant Discharge Elimination System (NPDES) permit for the referenced water pollution control plant.


Your facility has been assigned to the following EPD office for reporting and compliance. Signed copies of all required reports shall be submitted to the following address:

Georgia Environmental Protection Division
Coastal District – Brunswick Office
400 Commerce Center Drive
Brunswick, Georgia 31523

Please be advised that on and after the effective date indicated in the attached NPDES permit, the permittee must comply with all the terms, conditions and limitations of this permit.

If you have questions, please contact Yilin Fan at 404-463-4936 or Yilin.fan@dnr.ga.gov.

Sincerely,



Richard E. Dunn
Director

RED/yf

Attachment: Permit

cc: Environmental Protection Agency

PERMIT No. GA0034819

STATE OF GEORGIA
DEPARTMENT OF NATURAL RESOURCES
ENVIRONMENTAL PROTECTION DIVISION

AUTHORIZATION TO DISCHARGE UNDER THE
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

In accordance with the provisions of the Georgia Water Quality Control Act (Georgia Laws 1964, p. 416, as amended), hereinafter called the State Act; the Federal Water Pollution Control Act, as amended (33 U.S. C. 1251 et seq.), hereinafter called the Federal Act; and the Rules and Regulations promulgated pursuant to each of these Acts,

Consolidated Utilities, Inc.
119 West Oglethorpe Ave.
Savannah, GA 31404

is authorized to discharge from a facility located at

Larchmont Estates Water Pollution Control Plant
201 Shetland Court
Savannah, Georgia 31419
(Chatham County)

to receiving waters

Little Ogeechee River
(Ogeechee River Basin)

in accordance with effluent limitations, monitoring requirements and other conditions set forth in the permit.

This permit is issued in reliance upon the permit application signed on May 11, 2015, any other applications upon which this permit is based, supporting data entered therein or attached thereto, and any subsequent submittal of supporting data.

This permit shall become effective on August 1, 2016.

This permit and the authorization to discharge shall expire at midnight, July 30, 2021.

Issued this 21th day of July, 2016.



A handwritten signature in black ink, appearing to read "R. M. E. O.", is written over a horizontal line.

Director,
Environmental Protection Division

PART I

EPD is the Environmental Protection Division of the Department of Natural Resources.

The Federal Act referred to is The Clean Water Act.

The State Act referred to is The Water Quality Control Act (Act No. 870).

The State Rules referred to are The Rules and Regulations for Water Quality Control (Chapter 391-3-6).

A. SPECIAL CONDITIONS

1. MONITORING

The concentration of pollutants in the discharge will be limited as indicated by the table(s) labeled "Effluent Limitations and Monitoring Requirements." The effluent shall meet the requirements in the table(s) or the condition in paragraph I.A.1.a., whichever yields the higher quality effluent.

- a. For 5 day biochemical oxygen demand (BOD₅) and total suspended solids (TSS), the arithmetic mean of the values of the effluent samples collected during a month shall not exceed 15 percent of the arithmetic mean of values for influent samples collected at approximately the same times (85 percent removal). In accordance with Chapter 391-3-6-.06(4)(d) 2., of the State Rules, under certain conditions the 85 percent removal requirement may not be applicable, as specified in 40 CFR 133.
- b. The monthly average, other than for fecal coliform bacteria, is the arithmetic mean of values obtained for samples collected during a calendar month.
- c. The weekly average, other than for fecal coliform bacteria, is the arithmetic mean of values obtained for samples collected during a 7 day period. The week begins 12:00 midnight Saturday and ends at 12:00 midnight the following Saturday. To define a different starting time for the sampling period, the permittee must notify the EPD in writing. For reporting required by I.C.2. of this permit, a week that starts in one month and ends in another month shall be considered part of the second month. The permittee may calculate and report the weekly average as a 7 day moving average.
- d. Fecal coliform bacteria will be reported as the geometric mean of the values for the samples collected during the time periods in I.A.1.b. and I.A.1.c.
- e. Untreated wastewater influent samples required by I.B. shall be collected before any return or recycle flows. These flows include returned activated sludge, supernatants, centrates, filtrates, and backwash.
- f. Effluent samples required by I.B. of this permit shall be collected after the final treatment process and before discharge to receiving waters. Composite samples may be collected before chlorination with written EPD approval.
- g. A composite sample shall consist of a minimum of 5 subsamples collected at least once every 2 hours for at least 8 hours and shall be composited proportionately to flow.

- h. Flow measurements shall be conducted using the flow measuring device(s) in accordance with the approved design of the facility. If instantaneous measurements are required, then the permittee shall have a primary flow measuring device that is correctly installed and maintained. If continuous recording measurements are required, then flow measurements must be made using continuous recording equipment. Calibration shall be maintained of the continuous recording instrumentation to $\pm 10\%$ of the actual flow.

Flow shall be measured manually to check the flow meter calibration at a frequency of once a month. If secondary flow instruments are in use and malfunction or fail to maintain calibration as required, the flow shall be computed from manual measurements or by other method(s) approved by EPD until such time as the secondary flow instrument is repaired. For facilities which utilize alternate technologies for measuring flow, the flow measurement device must be calibrated semi-annually by qualified personnel.

Records of the calibration checks shall be maintained.

- i. If secondary flow instruments malfunction or fail to maintain calibration as required in I.A.1.h., the flow shall be computed from manual measurements taken at the times specified for the collection of composite samples.
- j. Some parameters must be analyzed to the detection limits specified by the EPD. These parameters will be reported as "not detected" when they are below the detection limit and will then be considered in compliance with the effluent limit. The detection limit will also be reported.
- k. Urban Water Reuse: the use of reclaimed water as a substitute for other water sources for the beneficial irrigation of areas that may be accessible to the public, such as golf courses, residential and commercial landscaping, parks, athletic fields, roadway medians, and landscape impoundments.
- l. Reclaimed Water: wastewater that has received treatment to urban water reuse standards, meets the treatment criteria specific in the Guidelines for Water Reclamation and Urban Water Reuse, and is utilized at a reuse area or is sent to a designated user for reuse.
- m. Reject Water: wastewater that does not meet the 3 NTU criteria or water treated after the disinfection system has failed.
- n. Designated User or User: any site or facility, where reclaimed water is beneficially used under a contract with the permittee. User may also be defined as the customer to be supplied with reclaimed water who has a written user agreement with the permittee. In addition, a designated user may also be a purveyor that provides reclaimed water to other customers.

2. SLUDGE DISPOSAL REQUIREMENTS

Sludge shall be disposed of according to the regulations and guidelines established by the EPD and the Federal Act section 405(d) and (e), and the Resource Conservation and Recovery Act (RCRA). In land applying nonhazardous municipal sewage sludge, the permittee shall comply with the general criteria outlined in the most current version of the EPD "Guidelines for Land Application of Sewage Sludge (Biosolids) at Agronomic Rates" and with the State Rules, Chapter 391-3-6-.17. Before disposing of municipal sewage sludge by land application or any

method other than co-disposal in a permitted sanitary landfill, the permittee shall submit a sludge management plan to EPD for written approval. This plan will become a part of the NPDES Permit after approval and modification of the permit. The permittee shall notify the EPD of any changes planned in an approved sludge management plan.

If an applicable management practice or numerical limitation for pollutants in sewage sludge is promulgated under Section 405(d) of the Federal Act after approval of the plan, then the plan shall be modified to conform with the new regulations.

3. SLUDGE MONITORING REQUIREMENTS

The permittee shall develop and implement procedures to ensure adequate year-round sludge disposal. The permittee shall monitor and maintain records documenting the quantity of sludge removed from the facility. Records shall be maintained documenting that the quantity of solids removed from the facility equals the solids generated on an average day. The total quantity of sludge removed from the facility during the reporting period shall be reported each month with the Discharge Monitoring Reports as required under Part I.C.2. of this permit. The quantity shall be reported on a dry weight basis (dry tons).

Pond treatment systems are required to report the total quantity of sludge removed from the facility only during the months that sludge is removed.

4. INTRODUCTION OF POLLUTANTS INTO THE PUBLICLY OWNED TREATMENT WORKS (POTW)

The permittee must notify EPD of:

- a. Any new introduction of pollutants into the POTW from an indirect discharger that would be subject to Sections 301 or 306 of the Federal Act if the pollutants were directly discharged to a receiving stream; and
- b. Any substantial change in the volume or character of pollutants from a source that existed when the permit was issued.

This notice shall include information on the quality and quantity of the indirect discharge introduced and any anticipated impact on the quantity or quality of effluent to be discharged from the POTW.

5. EFFLUENT TOXICITY AND BIOMONITORING REQUIREMENTS

The permittee shall comply with effluent standards or prohibitions established by section 307(a) of the Federal Act and with Chapter 391-3-6-.03(5)(e) of the State Rules and may not discharge toxic pollutants in concentrations or combinations that are harmful to humans, animals, or aquatic life.

If toxicity is suspected in the effluent, the EPD may require the permittee to perform any of the following actions:

- a. Acute biomonitoring tests;
- b. Chronic biomonitoring tests;

- c. Stream studies;
- d. Priority pollutant analyses;
- e. Toxicity reduction evaluations (TRE); or
- f. Any other appropriate study.

The EPD will specify the requirements and methodologies for performing any of these tests or studies. Unless other concentrations are specified by the EPD, the critical concentration used to determine toxicity in biomonitoring tests will be the effluent instream wastewater concentration (IWC) based on the permitted monthly average flow of the facility and the critical low flow of the receiving stream (7Q10). The endpoints that will be reported are the effluent concentration that is lethal to 50% of the test organisms (LC50) if the test is for acute toxicity and the no observed effect concentration (NOEC) of effluent if the test is for chronic toxicity.

The permittee must eliminate effluent toxicity and supply the EPD with data and evidence to confirm toxicity elimination.

6. URBAN WATER REUSE

- a. Designated Users:

Upon receiving authorization to operate at the B.2. limitations, the permittee may provide reuse water to designated users. The permittee may provide reuse water to additional designated users as long as prior written notice is provided to the EPD and a public notice is provided to the community. The additional users list will be considered an addendum to the permit, but the permit will not be reopened to add new designated users. The permittee must keep records of the volume of reuse water provided to each of its designated users.

- b. User Agreement:

Any designated user receiving reuse water from the permittee must enter into an agreement with the permittee. At a minimum the agreement must address all items which are in EPD's Guidelines for Water Reclamation and Urban Water Reuse (Section 9.2).

B.1.a. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS:

The discharge from the water pollution control plant shall be limited and monitored by the permittee as follows effective on the date of the permit and continuing until permit expiration.

Parameters	Discharge limitations in mg/L (kg/day) unless otherwise specified		Monitoring Requirements		
	Monthly Average	Weekly Average	Measurement Frequency	Sample Type	Sample Location
Flow (MGD)	1.0	1.25	Seven Days/Week	Continuous Recording	Effluent
Biochemical Oxygen Demand, 5-day	5 (19)	7.5 (24)	Three Days/Week	Composite	Influent & Effluent
Total Suspended Solids	20 (76)	30 (95)	Three Days/Week	Composite	Influent & Effluent
Fecal Coliform Bacteria (#/100mL)	200	400	Two Days/Week	Grab	Effluent
Ammonia, as N	1.0 (3.8)	1.5 (4.7)	Three Days/Week	Composite	Effluent
Total Phosphorus, as P ^{(1) (2)}	Report (Report)	Report (Report)	Three Days/Week	Composite	Effluent
Ortho-Phosphorus, as P ⁽²⁾	Report (Report)	Report (Report)	Three Days/Week	Composite	Effluent

Parameters	Discharge limitations in mg/L (kg/day) unless otherwise specified	Monitoring Requirements		
		Measurement Frequency	Sample Type	Sample Location
pH, Minimum – Maximum (Standard Unit)	6.0 – 8.5	Seven Days/Week	Grab	Effluent
Dissolved Oxygen, Minimum	6.0	Seven Days/Week	Grab	Effluent
Organic Nitrogen, as N ⁽³⁾	Report	One Day/Month	Composite	Effluent
Total Kjeldahl Nitrogen ⁽³⁾	Report	One Day/Month	Composite	Effluent
Nitrate-Nitrite ⁽³⁾	Report	One Day/Month	Composite	Effluent
Long-Term Biochemical Oxygen Demand ⁽⁴⁾	Report	See Below	Composite	Effluent
Whole Effluent Toxicity Test (%) ⁽⁵⁾	Report NOEC	Annually	Composite	Effluent
Priority Pollutants ⁽⁶⁾	Report	See Below	Grab	Effluent

(1) The permit may be reopened to include a phosphorus limit.
(2) Total Phosphorus and Ortho-Phosphorus must be analyzed from the same sample.
(3) Organic Nitrogen, Total Kjeldahl Nitrogen, and Nitrate-Nitrite must be analyzed from the same sample.
(4) Refer to Part I.C.9. LONG-TERM BIOCHEMICAL OXYGEN DEMAND
(5) Refer to Part I.C.10. CHRONIC WHOLE EFFLUENT TOXICITY
(6) Refer to Part I.C.11. PRIORITY POLLUTANTS

B.1.b. INSTREAM SURFACE WATER QUALITY MONITORING: Little Ogeechee River

The permittee shall perform monitoring of the Little Ogeechee River as follows effective on the date of permit issuance.

Parameters	Instream Monitoring	Monitoring Requirements ⁽³⁾		
		Measurement Frequency	Sample Type	Sample Location ⁽¹⁾
Temperature (°C) ⁽²⁾	Report	One Day/Week	Grab	Upstream & Downstream
Dissolved Oxygen (mg/L) ⁽²⁾	Report	One Day/Week	Grab	Upstream & Downstream
Ammonia, as N (mg/L)	Report	Quarterly	Grab	Upstream & Downstream
Specific Conductivity (µmhos/cm) ⁽²⁾	Report	One Day/Week	Grab	Upstream & Downstream
pH (Standard Units) ⁽²⁾	Report	One Day/Week	Grab	Upstream & Downstream

⁽¹⁾ Monitoring should be conducted upstream and downstream from the discharge as close to the following locations as possible:

Sampling Station	Access Point	Latitude	Longitude
Little Ogeechee River, Upstream (NW) of discharge	Via end of Canyon Drive	32.013549	-81.241447
Little Ogeechee River, Downstream of discharge	Via east side of Hwy 17, following high ground under utility pools	32.007761	-81.236892

⁽²⁾ These parameters should be sampled during May – October.

⁽³⁾ All samples should be taken while the stream current is out-going, as close to low tide as possible, to minimize the influence of the tidal flood. The Ft. Pulaski tide gauge info can be found at the following link: <http://tidesandcurrents.noaa.gov/waterlevels.html?id=8670870>

B.2 EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Discharge to reuse system:

The discharge from the water pollution control plant shall be limited and monitored by the permittee as specified below starting on the date EPD provides approval of construction completion and written authorization to operate under the B.2. effluent limitations (1.0 MGD with urban water reuse):

Parameters	Discharge Limitations Monthly Average in mg/L unless otherwise specified	Monitoring Requirements		
		Measurement Frequency	Sample Type	Sample Location
Flow (MGD) ⁽¹⁾	0.1	Seven Days/Week	Continuous	Effluent
Five-Day Biochemical Oxygen Demand	5.0	Three Days/Week	Composite	Influent & Effluent
Total Suspended Solids	5	Three Days/Week	Composite	Influent & Effluent
Fecal Coliform Bacteria (#/100mL) ⁽²⁾	23	Seven Days/Week	Grab	Effluent

⁽¹⁾ The discharge from the storage tank to reuse customers shall not exceed a 0.1 MGD monthly average and a 0.125 MGD weekly average.

The permittee must keep records of the volume of reuse water provided to each of its designated users.

⁽²⁾ Fecal Coliform Bacteria counts per individual sample shall not exceed 100/100mL.

Parameters	Discharge Limitations	Monitoring Requirements		
		Measurement Frequency	Sample Type	Sample Location
Turbidity, Maximum (NTU) ⁽³⁾	3	Seven Days/Week	Continuous	Effluent

⁽³⁾ This is an instantaneous maximum limitation. Continuous turbidity monitoring prior to disinfection is required. Treated effluent exceeding 3 NTU shall be rejected.

C. MONITORING AND REPORTING

1. REPRESENTATIVE SAMPLING

Samples and measurements of the monitored waste shall represent the volume and nature of the waste stream. The permittee shall maintain a written sampling and monitoring schedule.

2. REPORTING

a. Monitoring results obtained during the calendar month shall be summarized for each month and reported on the Discharge Monitoring Report (DMR). The results of each sampling event shall be reported on the Operating Monitoring Report (OMR) and submitted as an attachment to the DMR. The DMR and OMR and any other required forms, reports and/or information shall be completed, signed and certified by a principal executive officer or ranking elected official, or by a duly authorized representative of that person who has the authority to act for or on behalf of that person, and submitted to EPD, postmarked no later than the 15th day of the month following the reporting period.

b. However, upon final approval from EPD to use the online NetDMR application for the submittal of DMRs and OMRs required by this permit, the permittee shall submit the DMRs and OMRs to EPD utilizing the online NetDMR submittal process. The permittee shall submit the DMR no later than 11:59 p.m. on the 15th day of the month following the reporting period.

c. Signed copies of these and all other reports required herein, unless otherwise stated, shall be submitted to the EPD Office listed on the permit issuance letter signed by the Director of EPD.

d. All instances of noncompliance not reported under Part I.B. and Part II.A. shall be reported at the time the operation monitoring report is submitted.

e. Unless otherwise specified in this permit, quarterly samples shall be taken during the periods January-March, April-June, July-September, and October-December. Semiannual samples shall be taken during the periods January-June and July-December. Results from these samples shall be reported to the EPD on the monitoring report for the last month of the period. Results of annual samples will be reported on the June monitoring report.

3. MONITORING PROCEDURES

All analytical methods, sample containers, sample preservation techniques, and sample holding times must be consistent with the techniques and methods listed in 40 CFR Part 136. The analytical method used shall be sufficiently sensitive. EPA-approved methods must be applicable to the concentration ranges of the NPDES permit samples.

4. RECORDING OF RESULTS

For each required parameter analyzed, the permittee shall record:

a. The exact place, date, and time of sampling, and the person(s) collecting the sample. For flow proportioned composite samples, this shall include the instantaneous flow and

the corresponding volume of each sample aliquot, and other information relevant to document flow proportioning of composite samples;

- b. The dates and times the analyses were performed;
- c. The person(s) who performed the analyses;
- d. The analytical procedures or methods used; and
- e. The results of all required analyses.

5. ADDITIONAL MONITORING BY PERMITTEE

If the permittee monitors required parameters at the locations designated in I.B. more frequently than required, the permittee shall analyze all samples using approved analytical methods specified in I.C.3. The results of this additional monitoring shall be included in calculating and reporting the values on the Discharge Monitoring Report forms. The permittee shall indicate the monitoring frequency on the report. The EPD may require in writing more frequent monitoring, or monitoring of other pollutants not specified in this permit.

6. RECORDS RETENTION

The permittee shall retain records of:

- a. All laboratory analyses performed including sample data, quality control data, and standard curves;
- b. Calibration and maintenance records of laboratory instruments;
- c. Calibration and maintenance records and recordings from continuous recording instruments;
- d. Process control monitoring records;
- e. Facility operation and maintenance records;
- f. Copies of all reports required by this permit;
- g. All data and information used to complete the permit application; and
- h. All monitoring data related to sludge use and disposal.

These records shall be kept for at least three years. Sludge handling records must be kept for at least five years. Either period may be extended by EPD written notification.

7. PENALTIES

Both the Federal and State Acts provide that any person who falsifies or tampers with any monitoring device or method required under this permit, or who makes any false statement, representation, or certification in any record submitted or required by this permit shall, if convicted, be punished by a fine or by imprisonment or by both. The Acts include procedures

for imposing civil penalties for violations or for negligent or intentional failure or refusal to comply with any final or emergency order of the Director of the EPD.

8. WATERSHED PROTECTION PLAN

The permittee has developed a watershed protection plan. The permittee's approved watershed protection plan shall be enforceable through this permit.

The watershed protection plan provides for the following:

- a. The watershed protection plan shall apply to all basins and subbasins that are served by the facility. The plan will utilize the information generated in the permittee's watershed assessment to establish a baseline of watershed conditions and to provide ongoing long-term monitoring according to the approved plan to either verify that the plan is effective or to modify the plan such that water quality standards will be achieved.
- b. The watershed protection plan must include a schedule for correcting current water quality problems that are causing water quality standards violations. The permittee shall provide ongoing monitoring to verify that the actions taken to correct the water quality problems are effective.
- c. The permittee shall develop and put in place best management practices (BMPs) to prevent future water quality standards violations.
- d. The permittee shall provide ongoing monitoring to verify that the BMPs are working or to provide the information necessary to modify the BMPs to achieve water quality standards.

Annual Report

Each June 30th the permittee is to submit the following to EPD:

- a. An annual certification statement documenting that the plan is being implemented as approved. The certification statement shall read as follows: "I certify, under penalty of law, that the watershed protection plan is being implemented. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."
- b. All watershed plan data collected during the previous year in an electronic format. This data shall be archived using a digital format such as a spreadsheet developed in coordination with EPD. All archived records, data, and information pertaining to the watershed protection plan shall be maintained permanently.
- c. A progress report that provides a summary of the BMPs that have been implemented and documented water quality improvements. The progress report shall also include any necessary changes to the watershed protection plan.

9. LONG-TERM BIOCHEMICAL OXYGEN DEMAND TESTING

The permittee shall perform a 120-day Long-Term BOD test once during the permit cycle. The test should be performed on an effluent sample collected during the critical period from June 1

through September 30. The results of this test shall be provided to EPD prior to renewal of the permit.

10. CHRONIC WHOLE EFFLUENT TOXICITY (WET)

The permittee shall conduct annual chronic Whole Effluent Toxicity (WET) tests. The testing must include the most current U.S. Environmental Protection Agency (EPA) chronic aquatic toxicity testing manuals. The referenced document is entitled Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, 4th Edition, U.S. EPA, 821-R-02-013, October 2002. Definitive tests must be run on the same samples concurrently using both an invertebrate species (i.e., *Ceriodaphnia dubia*) and a vertebrate species (i.e., *Fathead Minnow*, *Pimephales promelas*) and should include a dilution equal to the facility's instream wastewater concentration (IWC) of 73%.

If the test results indicate effluent toxicity, the permittee may be required to perform additional WET tests, and/or to submit a toxicity reduction evaluation upon notification by the EPD and/or the permit may be reopened to incorporate a WET limit.

11. PRIORITY POLLUTANTS

The permittee must conduct three scans of the priority pollutants during the first year after receiving EPD written authorization to commence operation under the B.1.a. effluent limitations (1.0 MGD), with the first test being conducted within 90 days of this authorization. The priority pollutant scans must be measured at least to EPD detection limits and must represent seasonal variation. Total recoverable mercury must be sampled and analyzed using EPA Method 1631E. If substances are measured at levels of concern, then the permittee may be required to perform additional priority pollutant analyses or the permit may be modified to include effluent limitations for priority pollutants.

PART II

A. MANAGEMENT REQUIREMENTS

1. FACILITY OPERATION

The permittee shall maintain and operate efficiently all treatment or control facilities and related equipment installed or used by the permittee to achieve compliance with this permit. Efficient operation and maintenance include effective performance, adequate funding, adequate operator staffing and training, and adequate laboratory and process controls, including appropriate quality assurance procedures. Back-up or auxiliary facilities or similar systems shall be operated only when necessary to achieve permit compliance.

2. CHANGE IN DISCHARGE

Any anticipated facility expansions, or process modifications which will result in new, different, or increased discharges of pollutants requires the submission of a new NPDES permit application. If the changes will not violate the permit effluent limitations, the permittee may notify EPD without submitting an application. The permit may then be modified to specify and limit any pollutants not previously limited.

3. NONCOMPLIANCE NOTIFICATION

If, for any reason the permittee does not comply with, or will be unable to comply with any effluent limitations specified in the permittee's NPDES permit, the permittee shall provide EPD with an oral report within 24 hours from the time the permittee becomes aware of the circumstances followed by a written report within five (5) days of becoming aware of such condition. The written submission shall contain the following information:

- a. A description of the noncompliance and its cause; and
- b. The period of noncompliance, including the exact date and times; or, if not corrected, the anticipated time the noncompliance is expected to continue; and
- c. The steps taken to reduce, eliminate, and prevent recurrence of the noncomplying discharge.

4. ANTICIPATED NONCOMPLIANCE NOTIFICATION

The permittee shall give written notice to the EPD at least 10 days before:

- a. Any planned changes in the permitted facility; or
- b. Any activity which may result in noncompliance with the permit.

5. OTHER NONCOMPLIANCE

The permittee must report all instances of noncompliance not reported under other specific reporting requirements, at the time monitoring reports are submitted. The reports shall contain the information required under conditions of twenty-four hour reporting.

6. OPERATOR CERTIFICATION REQUIREMENTS

B.1. (Discharge to Little Ogeechee River)

The person responsible for the daily operation of the facility must be a Class II Certified Operator in compliance with the Georgia State Board of Examiners for Certification of Water and Wastewater Plant Operators and Laboratory Analysts Act, as amended, and as specified by Subparagraph 391-3-6-.12 of the Rules and Regulations for Water Quality Control. All other operators must have the minimum certification required by this Act.

B.2. (Reuse)

a. For reuse plants which do not have automatic diversion:

The operator in responsible charge (ORC) for the facility shall be a Class I Biological Wastewater Operator. On-site operation shall be 24 hours per day, 7 days per week by an on-site operator (OSO) who is certified Class II Biological Wastewater Operator or higher. All Operators (other than the ORC and OSO) shall have a minimum of a Class III biological Wastewater Operator certification.

b. For reuse plants which have automatic diversion but do not have an electronic monitoring and alarm system:

The operator in responsible charge (ORC) for the facility shall be a Class I Biological Wastewater Operator. On-site operation shall be by an on-site operator (OSO) who is certified Class II Biological Wastewater Operator or higher for a minimum of 8 hours per day, 7 days per week in conjunction with automatic diversion of reclaimed water that does not meet the turbidity criteria and with the automatic diversion of reclaimed water should any component of the disinfection system fail. All operators (other than the ORC and OSO) shall have a minimum of a Class III Biological Wastewater Operator certification.

c. For reuse plants that have automatic diversion and have an electronic monitoring and alarm system:

The operator in responsible charge (ORC) shall be a Class I Biological Wastewater Operator. On-site operation shall be by an on-site operator (OSO) who is certified Class II Biological Wastewater Operator or higher for a minimum of 4 hours per day, 7 days per week in conjunction with automatic diversion of reclaimed water that does not meet the turbidity criteria and with the automatic diversion of reclaimed water should any component of the disinfection system fail. An operator shall be on call during all periods the plant is unattended and must be able to respond to the plant site within one hour of an alarm. The electronic monitoring and alarm system must record the date and time of all alarms and the date and time of alarm override. All operators (other than the ORC and the OSO) shall have a minimum of a Class III biological Wastewater Operator certification.

7. LABORATORY ANALYST CERTIFICATION REQUIREMENTS

Laboratory Analysts must be certified in compliance with the Georgia State Board of Examiners for Certification of Water and Wastewater Treatment Plant Operators and Laboratory Analysts Act, as amended.

8. BYPASSING

Any diversion of wastewater from or bypassing of wastewater around the permitted treatment works is prohibited, except if:

- a. Bypassing is unavoidable to prevent loss of life, personal injury, or severe property damage;
- b. There are no feasible alternatives to bypassing; and
- c. The permittee notifies the EPD at least 10 days before the date of the bypass.

Feasible alternatives to bypassing include use of auxiliary treatment facilities and retention of untreated waste. The permittee must take all possible measures to prevent bypassing during routine preventative maintenance by installing adequate back-up equipment.

The permittee shall operate the facility and the sewer system to minimize discharge of pollutants from combined sewer overflows or bypasses and may be required by the EPD to submit a plan and schedule to reduce bypasses, overflows, and infiltration.

Any unplanned bypass must be reported following the requirements for noncompliance notification specified in II.A.3. The permittee may be liable for any water quality violations that occur as a result of bypassing the facility.

9. POWER FAILURES

If the primary source of power to this water pollution control facility is reduced or lost, the permittee shall use an alternative source of power to reduce or control all discharges to maintain permit compliance.

10. ADVERSE IMPACT

The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge disposal which might adversely affect human health or the environment.

11. NOTICE CONCERNING ENDANGERING WATERS OF THE STATE

Whenever, because of an accident or otherwise, any toxic or taste and color producing substance, or any other substance which would endanger downstream users of the waters of the State or would damage property, is discharged into such waters, or is so placed that it might flow, be washed, or fall into them, it shall be the duty of the person in charge of such substances at the time to forthwith notify EPD in person or by telephone of the location and nature of the danger, and it shall be such person's further duty to immediately take all reasonable and necessary steps to prevent injury to property and downstream users of said water.

Spills and Major Spills:

A "spill" is any discharge of raw sewage by a Publicly Owned Treatment Works (POTW) to the waters of the State.

A "major spill" means:

1. The discharge of pollutants into waters of the State by a POTW that exceeds the weekly average permitted effluent limit for biochemical oxygen demand (5-day) or total suspended solids by 50 percent or greater in one day, provided that the effluent discharge concentration is equal to or greater than 25 mg/L for biochemical oxygen demand or total suspended solids.
2. Any discharge of raw sewage that 1) exceeds 10,000 gallons or 2) results in water quality violations in the waters of the State.

"Consistently exceeding effluent limitation" means a POTW exceeding the 30 day average limit for biochemical oxygen demand or total suspended solids for at least five days out of each seven day period during a total period of 180 consecutive days.

The following specific requirements shall apply to POTW's. If a spill or major spill occurs, the owner of a POTW shall immediately:

- a. Notify EPD, in person or by telephone, when a spill or major spill occurs in the system.
- b. Report the incident to the local health department(s) for the area affected by the incident. The report at a minimum shall include the following:
 1. Date of the spill or major spill;
 2. Location and cause of the spill or major spill;
 3. Estimated volume discharged and name of receiving waters; and
 4. Corrective action taken to mitigate or reduce the adverse effects of the spill or major spill.
- c. Post a notice as close as possible to where the spill or major spill occurred and where the spill entered State waters and also post additional notices along portions of the waterway affected by the incident (i.e. bridge crossings, boat ramps, recreational areas, and other points of public access to the affected waterway). The notice at a minimum shall include the same information required in 11(b)(1-4) above. These notices shall remain in place for a minimum of seven days after the spill or major spill has ceased.
- d. Within 24 hours of becoming aware of a spill or major spill, the owner of a POTW shall report the incident to the local media (television, radio, and print media). The report shall include the same information required in 11(b)(1-4) above.
- e. Within five (5) days (of the date of the spill or major spill), the owner of a POTW shall submit to EPD a written report which includes the same information required in 11(b)(1-4) above.
- f. Within 7 days (after the date of a major spill), the owner of a POTW responsible for the major spill, shall publish a notice in the largest legal organ of the County where the incident occurred. The notice shall include the same information required in 11(b)(1-4) above.
- g. The owner of a POTW shall immediately establish a monitoring program of the receiving waters affected by a major spill or by consistently exceeding an effluent limit, with such monitoring being at the expense of the POTW for at least one year. The monitoring program shall include an upstream sampling point as well as sufficient downstream locations to accurately characterize the impact of the major spill or the consistent

exceedence of effluent limitations described in the definition of "Consistently exceeding effluent limitation" above. As a minimum, the following parameters shall be monitored in the receiving stream:

1. Dissolved Oxygen;
2. Fecal Coliform Bacteria;
3. pH;
4. Temperature; and
5. Other parameters required by the EPD.

The monitoring and reporting frequency as well as the need to monitor additional parameters will be determined by EPD. The results of the monitoring will be provided by the POTW owner to EPD and all downstream public agencies using the affected waters as a source of a public water supply.

- h. Within 24 hours of becoming aware of a major spill, the owner of a POTW shall provide notice of a major spill to every county, municipality, or other public agency whose public water supply is within a distance of 20 miles downstream and to any others which could be potentially affected by the major spill.

12. UPSET PROVISION

Provision under 40 CFR 122.41(n)(1)-(4), regarding "Upset" shall be applicable to any civil, criminal, or administrative proceeding brought to enforce this permit.

B. RESPONSIBILITIES

1. COMPLIANCE

The permittee must comply with this permit. Any permit noncompliance is a violation of the Federal Act, State Act, and the State Rules, and is grounds for:

- a. Enforcement action;
- b. Permit termination, revocation and reissuance, or modification; or
- c. Denial of a permit renewal application.

It shall not be a defense of the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity to maintain compliance with the conditions of this permit.

2. RIGHT OF ENTRY

The permittee shall allow the Director of the EPD, the Regional Administrator of EPA, and their authorized representatives, agents, or employees after they present credentials to:

- a. Enter the permittee's premises where a regulated activity or facility is located, or where any records required by this permit are kept;
- b. Review and copy any records required by this permit;

- c. Inspect any facilities, equipment, practices, or operations regulated or required by this permit; and
- d. Sample any substance or parameter at any location.

3. SUBMITTAL OF INFORMATION

The permittee shall furnish any information required by the EPD to determine whether cause exists to modify, revoke and reissue, or terminate this permit or to determine compliance with this permit. The permittee shall also furnish the EPD with requested copies of records required by this permit. If the permittee determines that any relevant facts were not included in a permit application or that incorrect information was submitted in a permit application or in any report to the EPD, the permittee shall promptly submit the additional or corrected information.

4. TRANSFER OF OWNERSHIP OR CONTROL

A permit may be transferred to another person by a permittee if:

- a. The permittee notifies the Director in writing at least 30 days in advance of the proposed transfer;
- b. An agreement is written containing a specific date for transfer of permit responsibility including acknowledgment that the existing permittee is liable for violations up to that date, and that the new permittee is liable for violations from that date on. This agreement must be submitted to the Director at least 30 days in advance of the proposed transfer; and
- c. The Director does not notify the current permittee and the new permittee within 30 days of EPD intent to modify, revoke and reissue, or terminate the permit. The Director may require that a new application be filed instead of agreeing to the transfer of the permit.

5. AVAILABILITY OF REPORTS

Except for data determined to be confidential by the Director of EPD under O.C.G.A. 12-5-26 or by the Regional Administrator of EPA under the Code of Federal Regulations, Title 40, Part 2, all reports prepared to comply with this permit shall be available for public inspection at an EPD office. Effluent data, permit applications, permittees' names and addresses, and permits shall not be considered confidential.

6. PERMIT MODIFICATION

This permit may be modified, terminated, or revoked and reissued in whole or in part during its term for causes including, but not limited to:

- a. Permit violations;
- b. Obtaining this permit by misrepresentation or by failure to disclose all relevant facts;
- c. Changing any condition that requires either a temporary or permanent reduction or elimination of the permitted discharge;
- d. Changes in effluent characteristics; and

- e. Violations of water quality standards.

The filing of a request by the permittee for permit modification, termination, revocation and reissuance, or notification of planned changes or anticipated noncompliance does not negate any permit condition.

7. CIVIL AND CRIMINAL LIABILITY

Nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance.

8. PROPERTY RIGHTS

The issuance of this permit does not convey any property rights of either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, or any infringement of Federal, State or local laws or regulations.

9. EXPIRATION OF PERMIT

The permittee shall submit an application for permit reissuance at least 180 days before the expiration date of this permit. The permittee shall not discharge after the permit expiration date without written authorization from the EPD. To receive this authorization, the permittee shall submit the information, forms, and fees required by the EPD no later than 180 days before the expiration date.

10. CONTESTED HEARINGS

Any person aggrieved or adversely affected by any action of the Director of the EPD shall petition the Director for a hearing within 30 days of notice of the action.

11. SEVERABILITY

The provisions of this permit are severable. If any permit provision or the application of any permit provision to any circumstance is held invalid, the provision does not affect other circumstances or the remainder of this permit.

12. PREVIOUS PERMITS

All previous State water quality permits issued to this facility for construction or operation are revoked by the issuance of this permit. The permit governs discharges from this facility under the National Pollutant Discharge Elimination System (NPDES).

PART III

INDUSTRIAL PRETREATMENT PROGRAM FOR PUBLICLY OWNED TREATMENT WORKS (POTW)

1. The permittee may establish and operate an approved industrial pretreatment program.
2. If the EPD determines that the permittee is required to develop a local industrial pretreatment program, the permittee will be notified in writing. The permittee shall immediately begin development of an industrial pretreatment program and shall submit it to the EPD for approval no later than one year after the notification.
3. During the interim period between determination that a program is needed and approval of the program, all industrial pretreatment permits shall be issued by the EPD.
4. The permittee shall notify the EPD of all industrial users connected to the system or proposing to connect to the system from the date of issuance of this permit.
5. Implementation of the Pretreatment Program developed by the State can be delegated to the permittee following the fulfillment of requirements detailed in 391-3-6-.09 of the Rules and Regulations for Water Quality Control.