

**Exhibit 8.8 Protocol for Selecting Stage 2 DBPR (Subpart V)  
Compliance Monitoring Sites**

Steps <sup>1</sup> [required by rule]		Stage 2 Compliance Monitoring Sites Selected <sup>2</sup>
1	Select the location with the highest TTHM LRAA	1 <sup>st</sup> highest TTHM site
2	Select the remaining location with the highest HAA5 LRAA	1 <sup>st</sup> highest HAA5 site
3	<p><u>For subpart H systems:</u> Select the remaining existing Stage 1 DBPR average residence time compliance monitoring location with the highest HAA5 LRAA</p> <p><u>For ground water systems:</u> Select the remaining existing Stage 1 DBPR maximum residence time compliance monitoring location with the highest HAA5 LRAA</p> <p><i>Skip this step if you have no more Stage 1 DBPR sites</i></p>	1 <sup>st</sup> Stage 1 DBPR site
4	Select the remaining location with the next highest TTHM LRAA.	2 <sup>nd</sup> highest TTHM site
5	Select the remaining location with the next highest TTHM LRAA	3 <sup>rd</sup> highest TTHM site
6	Select the remaining location with the next highest HAA5 LRAA	2 <sup>nd</sup> highest HAA5 site
7	<p><u>For subpart H systems:</u> Select the remaining existing Stage 1 DBPR average residence time compliance monitoring location with the highest TTHM LRAA</p> <p><u>For ground water systems:</u> Select the remaining existing Stage 1 DBPR maximum residence time compliance monitoring location with the highest TTHM LRAA</p> <p><i>Skip this step if you have no more Stage 1 DBPR</i></p>	2 <sup>nd</sup> Stage 1 DBPR site
8	Select the remaining location with the next highest HAA5 LRAA	3 <sup>rd</sup> highest HAA5 site
<p><i>If you need more Stage 2 DBPR compliance monitoring locations, Go back to <b>Step 1</b> of this protocol and repeat the steps until you have selected the required number of total sites.</i></p>		

1. All steps are based on calculated LRAAs for standard monitoring sites and Stage 1 DBPR compliance monitoring sites. This means that existing Stage 1 DBPR sites can be selected in steps *other than* 3 or 7. Systems will Stop when they reach the required number of Stage 2 DBPR compliance monitoring sites.
2. Systems cannot select the same site as a highest TTHM and a highest HAA5 compliance monitoring site.