

**Georgia Environmental Protection Division - Underground Storage Tank (UST) Management Program**  
Public Record Report for FFY 2024

**General Information**

Public Record Posted Date: October 11, 2024

Total Number of UST Facilities: 9,940  
Total Number of USTs: 29,820

**Summary Information For Inspections**

Number of UST Facilities Inspected: 3,416  
Inspection Period Dates Were From: To: 10/01/2023 - 09/30/2024  
Percent Compliance (Combined Measure): 41%

**Note:** Tank, facility, and on-site inspection information is based on underground storage tanks regulated under Subtitle I that satisfy the definition of UST in 40 CFR 280.12, except for those tanks identified in 40 CFR 280.10(b) as excluded USTs and those deferred in 40 CFR 280.10(c). Inspections measure compliance with EPA TCR for the combined measures of Spill Prevention, Overfill Prevention, Corrosion Protection and Release Detection.

**Summary Information for Releases**

Number of Confirmed UST Releases: 165  
Release Period Dates Were From: To: 10/01/2023 - 09/30/2024

**Summary Information for Release Sources And Causes**

Source	Cause															
	Spill		Overfill		Phys/Mech		Corrosion		Install		Other		Unknown			
	#	%	#	%	#	%	#	%	#	%	#	%	#	%		
Tank	6	4%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	6	100%
Piping	2	1%	0	0%	0	0%	0	0%	2	100%	0	0%	0	0%	0	0%
Dispenser	7	4%	6	86%	0	0%	0	0%	1	14%	0	0%	0	0%	0	0%
Submerged Turbine Pump	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Delivery Problem	5	3%	3	60%	2	40%	0	0%	0	0%	0	0%	0	0%	0	0%
Other	46	28%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	46	100%
Unknown	99	60%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	99	100%
Totals	165		9		2		0		3		0		0		151	

# = number, % = percent of total number

**If you have site specific or general UST questions or you cannot download this report, please contact the UST Program by calling 404-362-2687.**

**Note:** Release, source and cause information is based on underground storage tanks regulated under Subtitle I that satisfy the definition of UST in 40 CFR 280.12, except for those USTs identified in 40 CFR 280.10(b) UST's deferred in 40 CFR 280.10(c) and those used for emergency power generation (deferred from release detection by 40 CFR 280.10(d)) are included as part of the public record.

This report reflects data from releases reported to EPD during the time period of the report. Source and cause data were collected using on-site inspections and reports from facilities. The locations of these releases were not identifiable. "OTHER" is an identifiable source that does not fit specific locations identified in the chart.

