

State of Georgia

Department of Natural Resources

Environmental Protection Division

Public Water Systems

2025 Compliance Summary Report

This Annual Compliance Report provides a summary of maximum contaminant level (MCL), significant monitoring/reporting (M/R), and treatment technique (TT) violations during calendar year 2025 for public water systems (PWSs) in the State of Georgia.

Introduction

The US Environmental Protection Agency (EPA) established the Public Water System Supervision (PWSS) Program under the authority of the 1974 Safe Drinking Water Act (SDWA). Under the SDWA and the 1986 Amendments, EPA sets national limits on contaminant levels in drinking water to ensure that the water is safe for human consumption. These limits are known as Maximum Contaminant Levels (MCLs) and Maximum Residual Disinfectant Levels (MRDLs). For some regulations, EPA established treatment techniques in lieu of an MCL to control unacceptable levels of contaminants in drinking water. EPA also regulates how often public water systems (PWSs) monitor their drinking water for contaminants and report the monitoring result to the states or EPA. Generally, the larger the population served by a water system, the more frequent the monitoring and reporting (M/R) requirements. In addition, EPA requires PWSs to monitor for unregulated contaminants to provide data for future regulatory development. Finally, EPA requires PWSs to notify the public when they have violated these regulations. The 1996 Amendments to the SDWA require public notification to include a clear and understandable explanation of the nature of the violation, its potential adverse health effects, steps that the PWS is undertaking to correct the violation and the possibility of alternative water supplies during the violation.

The SDWA applies to the 50 states, the District of Columbia, Indian Lands, Puerto Rico, the U.S. Virgin Islands, American Samoa, Guam, and the Commonwealth of the Northern Mariana Islands.

The SDWA allows states, tribes, and territories to seek EPA approval to administer their own PWSS programs. The authority to run a PWSS program is called primacy. For a state to receive primacy, EPA must determine that the state meets certain requirements laid out in the SDWA and federal regulations, including the adoption of drinking water regulations that are at least as stringent as the federal regulations and a demonstration that they can enforce the program requirements. Of the 56 states and territories, all but Wyoming and the District of Columbia have Primacy. The EPA Regional Offices administer the PWSS programs within these two jurisdictions.

The 1986 SDWA Amendments gave Indian Tribes the right to apply for and receive primacy. EPA currently administers PWSS programs on all Indian lands except the Navajo Nation, which was granted primacy in late 2000.

Annual State PWS Report

Each quarter, primacy states submit data to the federal Safe Drinking Water Information System (SDWIS/FED), an automated database maintained by EPA. The data submitted include, but are not limited to, PWS inventory statistics, the incidence of MCL, MRDL, monitoring, and treatment technique violations, and the enforcement actions taken against violators. Section 1414(c)(3) of the Safe Drinking Water Act requires states to provide EPA with an annual report of violations of the primary drinking water standards. The annual compliance report provides the numbers of violations in each of six categories: MCLs, MRDLs, treatment techniques, variances and exemptions, significant monitoring violations, and significant consumer notification violations. The EPA Regional Offices report the information for Wyoming, the District of Columbia, and all Indian Lands but the Navajo Nation. EPA stores this data in an automated database called the Safe Drinking Water Information System (SDWIS). This report is based on data in Georgia Safe Drinking Water Information System (SDWIS/STATE) and retrieved from the federal version of the Safe Drinking Water Information System (SDWIS/FED).

Public Water System

A Public Water System (PWS) is defined as a system that provides water via piping or other constructed conveyances for human consumption to at least 15 service connections or serves an average of at least 25 people for at least 60 days each year. There are three types of PWSs. PWSs can be community (such as towns), non-transient non-community (such as schools or factories), or transient non-community systems (such as rest stops or parks). For this report, when the acronym PWS is used, it means systems of all types unless specified in greater detail.

Maximum Contaminant Level

Under the Safe Drinking Water Act (SDWA), the EPA sets national limits on contaminant levels in drinking water to ensure that the water is safe for human consumption. These limits are known as Maximum Contaminant Levels (MCLs).

Maximum Residual Disinfection Level

The EPA sets national limits on residual disinfection levels in drinking water to reduce the risk of exposure to disinfectant byproducts formed when public water systems add chemical disinfection for either primary or residual treatment. These limits are known as Maximum Residual Disinfectant Levels (MRDLs).

Treatment Techniques

For some regulations, the EPA establishes treatment techniques (TTs) in lieu of an MCL to control unacceptable levels of certain contaminants. For example, treatment techniques have been established for viruses, some bacteria, and turbidity.

Variations and Exemptions

The Safe Drinking Water Act Amendments of 1996 allows for variations and exemptions to specific requirements of the Act to be granted under certain circumstances. If, due to the characteristics of the raw water sources reasonably available, a PWS cannot meet the MCL, a primacy state can grant the PWS a variance from the applicable primary drinking water regulation on the condition that the system installs the best available technology, treatment techniques, or other means which the Director finds are available (taking cost into account). The state must find that the variance will not result in an unreasonable risk to health, and shall prescribe, at the time the variance is granted, a schedule (including increments of progress) in accordance with which the PWS must come into compliance with the MCL.

Small systems (serving 3,300 or fewer persons; or 10,000 or fewer persons with the Director's approval) may be granted variations if they cannot afford (as determined by application of the Director's affordability criteria) to comply with certain MCLs (non-microbial, promulgated after January 1, 1986) by means of treatment, alternative source of water, or restructuring or consolidation. Small systems must, within 3 years, install and operate EPA approved small system variance technology. The variance must ensure adequate protection of human health, and the variance shall be reviewed not less than every 5 years to determine whether the system remains eligible for the variance. A primacy State may by exemption relieve a PWS of its obligation to comply with an MCL, treatment technique, or both if the system's noncompliance results from compelling factors (which may include economic factors, if the system was in operation on the effective date of the MCL or treatment technique requirement) or if not in operation by that date, only if no reasonable alternative source of drinking water is available to such new systems, management or restructuring changes cannot reasonably be made that will result in compliance with the SDWA or improvement of water quality, and the exemption will not result in an unreasonable risk to public health. The State will require the PWS to comply with the MCL or treatment technique as expeditiously as practicable, but not later than 3 years after the otherwise applicable compliance date.

Monitoring

A PWS is required to monitor and verify that the levels of contaminants do not exceed the MCL. If a PWS fails to have its water tested as required or fails to report test results correctly to the primacy agent, then a monitoring violation occurs.

Significant Monitoring Violations

For this report, significant monitoring violations are defined as any major monitoring violation that has occurred during the specified report interval. A major monitoring violation (except for the Surface Water Treatment Rule) occurs when no samples were collected or no results are reported during a compliance period. A major Surface Water Treatment Rule M/R violation occurs when fewer than 10% of the required samples are taken or no results are reported during a reporting interval. A minor violation occurs when some but not all of the required numbers of samples are taken.

Consumer Notification

Every Community Water System is required to deliver to its customers a brief annual water quality report. This report is to include some educational material, and will provide information on the source water, the levels of any detected contaminants, and compliance with drinking water regulations.

Significant Consumer Notification Violations

For this report, a significant public notification violation occurred if a community water system completely failed to provide its customers with the required annual water quality report.

Public Notice Violation

The Public Notification Rule requires all PWS to notify their consumers any time a PWS violated a national primary drinking water regulation or has a situation posing a risk to public health. Notices must be provided to persons served (not just billing consumers).

Obtaining Copy of 2025 Public Water Systems Report

As required by the Safe Drinking Water Act, the State of Georgia has made the 2025 Annual Public Water Systems Report available to the public. Interested individuals can obtain a copy of the 2025 Annual Public Water Systems Report for Georgia by accessing the Department of Natural Resources' website at <https://epd.georgia.gov/publications>

Georgia's 2025 Compliance Summary Report

MCLs, Treatment Techniques, and Significant Monitoring/Reporting

January 1, 2025 to December 31, 2025

Definitions

Filtered Systems: Water Systems that have installed filtration treatment [40 CFR 141, Subpart H].

Inorganic Contaminants: Non-carbon-based compounds such as metals, nitrates, and asbestos. These contaminants are naturally occurring in some water, but can get into water through farming, chemical manufacturing, and other human activities. EPA has established MCLs for 15 inorganic contaminants [40 CFR 141.62].

Lead and Copper Rule: This Rule established national limits on lead and copper in drinking water [40 CFR 141.80-91]. Lead and copper corrosion pose various health risks when ingested at any level and can enter drinking water from household pipes and plumbing fixtures. Georgia reports violations of the Lead and Copper Rule in the following eight categories:

Initial Lead and Copper Tap M/R: A violation where a system did not meet initial lead and copper testing requirements or failed to report the results of those tests to the State.

Follow-up or Routine Lead and Copper Tap M/R: A violation where a system did not meet follow-up or routine lead and copper tap testing requirements or failed to report the results of those tests to the State.

Treatment Installation: Violations for a failure to install optimal corrosion control treatment system or source water treatment system which would reduce lead and copper levels in water at the tap. (One number is to be reported for the sum of violations in both categories).

Lead Service Line Replacement: A violation for a system's failure to replace lead service lines on the schedule required by the regulation.

Public Education: A violation where a system did not provide required public education about reducing or avoiding lead intake from water.

Monitoring: EPA specifies which water testing methods the water systems must use and sets schedules for the frequency of testing. A water system that does not follow EPA's schedule or methodology is in violation [40 CFR 141].

Failure to report LSL-Initial (4G): A system that fails to submit an initial inventory of service lines to the State by October 16, 2024. CFR §141.90(e)(1)

Failure to notify of Known or Potential LSL (4H): A system with lead, GRR, or LSU service lines, fails to demonstrate to the state annually by July 1 that it delivered

information to affected consumers with a lead, galvanized requiring replacement, or lead status unknown service line in accordance with § 141.85(e) for the previous calendar year. [141.90(f)(4)]

States must report monitoring violations that are significant as determined by the EPA Administrator in consultation with the states. For purposes of this report, significant monitoring violations are major violations, and they occur when no samples are taken or no results are reported during a compliance period. A major monitoring violation for the Surface Water Treatment Rule occurs when at least 90% of the required samples are not taken or results are not reported during the compliance period.

Organic Contaminants: Carbon-based compounds, such as industrial solvents and pesticides. These contaminants generally get into water through runoff from cropland or discharge from factories. EPA has set legal limits on 54 organic contaminants that are to be reported [40 CFR 141.61].

Radionuclides: Radioactive particles which can occur naturally in water or result from human activity. EPA has set legal limits on four types of radionuclides: radium-226, radium-228, gross alpha, and beta particle/photon radioactivity [40 CFR 141]. Violations for these contaminants are to be reported using the following three categories:

Gross Alpha: A violation for alpha radiation above MCL of 15 picocuries/liter (pCi/L). Gross alpha includes radium-226 but excludes radon and uranium.

Combined Radium-226 and Radium-228: A violation for combined radiation from these two isotopes above MCL of 5 pCi/L.

Combined Uranium: A violation for combined uranium above MCL of 30 micrograms/liter (µg/L).

Reporting Interval: In 1997, EPA and drinking water stakeholders agreed that both state and national annual reports would discuss drinking water violations on a calendar year basis (January 1 to December 31). Therefore, compliance reports will be submitted to EPA by July 1 for the preceding calendar year.

SDWIS Violation Code and Descriptions: Specific numeric codes from the Safe Drinking Water Information System (SDWIS) are assigned to each violation type. Violation Type Descriptions are also included in SDWIS. The violations to be reported include exceeding contaminant MCLs, failure to comply with treatment requirements, and failure to meet monitoring and reporting requirements.

Surface Water Treatment Rule: The Surface Water Treatment Rule establishes criteria under which water systems supplied by surface-water sources, or ground-water sources under the direct influence of surface water, must filter and disinfect their water [40 CFR 141, Subpart H]. Violations of the "Surface Water Treatment Rule" are to be reported for the following four categories:

Monitoring, Routine/Repeat (for filtered systems): A violation for a system's failure to carry out required tests or to report the results of those tests to the State.

Treatment Techniques (for filtered systems): A violation for a system's failure to properly treat its water.

Monitoring, Routine/Repeat (for unfiltered systems): A violation for a system's failure to carry out required water tests or to report the results of those tests to the State.

Failure to Filter (for unfiltered systems): A violation for a system's failure to properly treat its water. Data for this violation code will be supplied to the states by EPA.

Revised Total Coliform Rule (RTCR): The Revised Total Coliform Rule took effect on April 1, 2016. RTCR is a revision to EPA's 1989 Total Coliform Rule (TCR). The Revised Total Coliform Rule establishes regulations for microbiological contaminants in drinking water. These contaminants can cause short-term health problems. If a system fails to collect the required number of samples per sampling period, a monitoring violation occurs. States are required to report the following assessments and violations:

Major Routine and Follow-up Monitoring Violation: Occurs when a system does not perform any of the required routine monitoring.

Minor Routine and Follow-up Monitoring Violation: Occurs when a system performs some, but not all, of the required routine monitoring.

E. coli MCL Violation: Occurs when a routine sample is E. coli positive and any of the corresponding repeat samples are total coliform positive, E. coli positive, or not taken. Also, an E. coli MCL violation may occur when a routine sample is total coliform positive and either the corresponding repeat samples are E. coli positive or the repeat samples were not analyzed for E. coli.

Level 1 Assessments: A Level 1 Assessment is triggered when a water system collecting fewer than 40 samples per month or quarter has two or more total coliform positive routine/repeat samples in the same month. Or, a system that collects 40 or more samples per month has greater than 5.0% of the routine/repeat samples in the same month be total coliform positive or fails to take every repeat sample after a total coliform positive sample.

Level 2 Assessments: A Level 2 Assessment is triggered when a water system incurs an E. coli MCL violation, or a water system receives a second Level 1 Assessment within a rolling 12-month period.

Treatment Techniques: A water disinfection process that EPA requires instead of an MCL for contaminants that laboratories cannot adequately measure. Failure to meet other operational and system requirements under the Surface Water Treatment and the Lead and Copper Rules have also been included in this category of violation for purposes of this report.

Unfiltered Systems: Water systems that do not need to filter their water before disinfecting it

because the source is very clean [40 CFR, Subpart H].

Violation: A failure to meet any state or federal drinking water regulation.

State of Georgia 2025
MCL/MRDL & Treatment Technique Violations Summary Tables

Volatile and Synthetic Organic Contaminants

| | MCL (mg/L) ¹ | MCLs | | Treatment Techniques | | Significant Monitoring/Reporting | |
|------------------------------------|----------------------------|----------------------------|--|-------------------------|--|-------------------------------------|--|
| | | Number of Violations | Number of Systems with Violations | Number of Violations | Number of Systems with Violations | Number of Violations | Number of Systems with Violations |
| 1,1,1-Trichloroethane | 0.20 | 0 | 0 | | | 0 | 0 |
| 1,1,2-Trichloroethane | 0.005 | 0 | 0 | | | 0 | 0 |
| 1,1-Dichloroethylene | 0.007 | 0 | 0 | | | 0 | 0 |
| 1,2,4-Trichlorobenzene | 0.07 | 0 | 0 | | | 0 | 0 |
| 1,2-Dibromo-3-chloropropane (DBCP) | 0.0002 | 0 | 0 | | | 0 | 0 |
| 1,2-Dichlorethane | 0.005 | 0 | 0 | | | 0 | 0 |
| 1,2-Dichloropropane | 0.005 | 0 | 0 | | | 0 | 0 |
| 2,3,7,8-TCDD (Dioxin) | 3x10 ⁻⁸ | 0 | 0 | | | 0 | 0 |
| 2,4,5-TP | 0.05 | 0 | 0 | | | 0 | 0 |
| 2,4-D | 0.07 | 0 | 0 | | | 0 | 0 |
| Acrylamide | | | | 0 | 0 | | |
| Alachlor | 0.002 | 0 | 0 | | | 0 | 0 |
| Atrazine | 0.003 | 0 | 0 | | | 0 | 0 |
| Benzene | 0.005 | 0 | 0 | | | 0 | 0 |
| Benzo[a]pyrene | 0.0002 | 0 | 0 | | | 0 | 0 |
| Carbofuran | 0.04 | 0 | 0 | | | 0 | 0 |
| Carbon tetrachloride | 0.002 | 0 | 0 | | | 0 | 0 |
| Chlordane | 0.002 | 0 | 0 | | | 0 | 0 |
| Chlorobenzene | 0.10 | 0 | 0 | | | 0 | 0 |
| cis-1,2-Dichloroethylene | 0.07 | 0 | 0 | | | 0 | 0 |
| Dalapon | 0.2 | 0 | 0 | | | 0 | 0 |
| Di(2-ethylhexyl)adipate | 0.4 | 0 | 0 | | | 0 | 0 |
| Di(2-ethylhexyl)phthalate | 0.006 | 0 | 0 | | | 0 | 0 |
| Dichloromethane | 0.005 | 0 | 0 | | | 0 | 0 |

| | MCL (mg/L) ¹ | MCLs | | Treatment Techniques | | Significant Monitoring/Reporting | |
|---------------------------------|-------------------------|----------------------|-----------------------------------|----------------------|-----------------------------------|----------------------------------|-----------------------------------|
| | | Number of Violations | Number of Systems with Violations | Number of Violations | Number of Systems with Violations | Number of Violations | Number of Systems with Violations |
| Dinoseb | 0.007 | 0 | 0 | | | 0 | 0 |
| Diquat | 0.02 | 0 | 0 | | | 0 | 0 |
| Endothall | 0.1 | 0 | 0 | | | 0 | 0 |
| Endrin | 0.002 | 0 | 0 | | | 0 | 0 |
| Epichlorohydrin | | | | 0 | 0 | | |
| Ethylbenzene | 0.7 | 0 | 0 | | | 0 | 0 |
| Ethylene dibromide | 0.00005 | 0 | 0 | | | 0 | 0 |
| Glyphosate | 0.7 | 0 | 0 | | | 0 | 0 |
| Heptachlor | 0.0004 | 0 | 0 | | | 0 | 0 |
| Heptachlor epoxide | 0.0002 | 0 | 0 | | | 0 | 0 |
| Hexachlorobenzene | 0.001 | 0 | 0 | | | 0 | 0 |
| Hexachlorocyclopentadiene | 0.05 | 0 | 0 | | | 0 | 0 |
| Lindane | 0.0002 | 0 | 0 | | | 0 | 0 |
| Methoxychlor | 0.04 | 0 | 0 | | | 0 | 0 |
| Monochlorobenzene | 0.1 | 0 | 0 | | | 0 | 0 |
| o-Dichlorobenzene | 0.6 | 0 | 0 | | | 0 | 0 |
| Oxamyl (Vydate) | 0.2 | 0 | 0 | | | 0 | 0 |
| para-Dichlorobenzene | 0.075 | 0 | 0 | | | 0 | 0 |
| Pentachlorophenol | 0.001 | 0 | 0 | | | 0 | 0 |
| Picloram | 0.5 | 0 | 0 | | | 0 | 0 |
| Simazine | 0.004 | 0 | 0 | | | 0 | 0 |
| Styrene | 0.1 | 0 | 0 | | | 0 | 0 |
| Tetrachloroethylene | 0.005 | 0 | 0 | | | 0 | 0 |
| Toluene | 1 | 0 | 0 | | | 0 | 0 |
| Total polychlorinated biphenyls | 0.0005 | 0 | 0 | | | 0 | 0 |
| Toxaphene | 0.003 | 0 | 0 | | | 0 | 0 |
| Trans-Dichloroethylene | 0.1 | 0 | 0 | | | 0 | 0 |

| | MCL (mg/L) ¹ | MCLs | | Treatment Techniques | | Significant Monitoring/Reporting | |
|-------------------|-------------------------|----------------------|-----------------------------------|----------------------|-----------------------------------|----------------------------------|-----------------------------------|
| | | Number of Violations | Number of Systems with Violations | Number of Violations | Number of Systems with Violations | Number of Violations | Number of Systems with Violations |
| Trichloroethylene | 0.005 | 0 | 0 | | | 0 | 0 |
| Vinyl chloride | 0.002 | 0 | 0 | | | 0 | 0 |
| Xylenes (total) | 10 | 0 | 0 | | | 0 | 0 |
| Subtotal | | 0 | 0 | 0 | 0 | 0 | 0 |

*Volatile Organic Contaminant samples and schedules are monitored as a group. Monitoring schedules varies.

Inorganic Contaminants

| | MCL (mg/L) ¹ | MCLs | | Treatment Techniques | | Significant Monitoring/Reporting | |
|---------------------------|--------------------------------|----------------------|-----------------------------------|----------------------|-----------------------------------|----------------------------------|------------------------------------|
| | | Number of Violations | Number of Systems with Violations | Number of Violations | Number of Systems with Violations | *Number of Violations | *Number of Systems with Violations |
| Antimony | 0.006 | 0 | 0 | | | *3 | *2 |
| Arsenic | 0.05 | 3 | 2 | | | *3 | *2 |
| Asbestos | 7 million fibers/ 10um long | 5 | 1 | | | *3 | *2 |
| Barium | 2 | 0 | 0 | | | *3 | *2 |
| Beryllium | 0.004 | 0 | 0 | | | *3 | *2 |
| Cadmium | 0.005 | 0 | 0 | | | *3 | *2 |
| Chromium | 0.1 | 0 | 0 | | | *3 | *2 |
| Cyanide (as free cyanide) | 0.2 | 0 | 0 | | | *3 | *2 |
| Fluoride | 4.0 | 15 | 4 | | | *3 | *2 |
| Mercury | 0.002 | 0 | 0 | | | *3 | *2 |
| Nickel | 0.1 | 0 | 0 | | | *3 | *2 |
| Nitrate | 10 (as Nitrogen) | **0 | **0 | | | *63 | *51 |
| Nitrite | 1 (as Nitrogen) | **0 | **0 | | | *63 | *51 |

| | | | | | | | |
|-----------------|-------|----|---|--|--|----|----|
| Selenium | 0.05 | 0 | 0 | | | *3 | *2 |
| Thallium | 0.002 | 0 | 0 | | | *3 | *2 |
| Subtotal | | 23 | 7 | | | 66 | 53 |

*Inorganic Compound samples and schedules are monitored as a group. Monitoring schedules varies.

** One system on quarterly monitoring sampled for all IOCs but did not sample for Asbestos.

***Nitrate-Nitrite samples and schedules are monitored as a group. Monitoring schedules varies.

Stage 2 Disinfectants and Disinfection By-Products Rule

| | MCL (mg/L) ¹ | MCLs | | Treatment Techniques | | Significant Monitoring/Reporting | |
|-------------------------------|-------------------------|----------------------|-----------------------------------|----------------------|-----------------------------------|----------------------------------|-----------------------------------|
| | | Number of Violations | Number of Systems with Violations | Number of Violations | Number of Systems with Violations | Number of Violations | Number of Systems with Violations |
| Total Trihalomethanes (TTHM) | 0.080 | 96 | 22 | | | *12 | *12 |
| Total Haloacetic Acids (HAA5) | 0.060 | 76 | 17 | | | *12 | *12 |
| Total Carbon | | | | 1 | 1 | | |
| Subtotal | | 172 | ^28 | 1 | 1 | 12 | 12 |

*Stage 2 Disinfection By-Products samples and schedules are monitored as a group. Monitoring schedules varies.

^Subtotals reflect the number of unique water systems. Some systems may receive a violation for multiple analytes.

Radionuclides

| | MCL | MCLs | | Treatment Techniques | | Significant Monitoring/Reporting | |
|-------------------------------------|----------|----------------------|-----------------------------------|----------------------|-----------------------------------|----------------------------------|-----------------------------------|
| | | Number of Violations | Number of Systems with Violations | Number of Violations | Number of Systems with Violations | Number of Violations | Number of Systems with Violations |
| Gross alpha, excl radon and uranium | 15pCi/P | 18 | 9 | | | *6 | 6 |
| Radium-226 and radium-228 | 5pCi/P | 10 | 4 | | | *6 | 6 |
| Gross beta | 4mrem/yr | 0 | 0 | | | 0 | 0 |
| Uranium | 30 ug/L | 2 | 1 | | | *6 | 6 |
| Subtotal | | 30 | ^12 | | | 6 | 6 |

*Radionuclides samples and schedules are monitored as a group. Monitoring schedules varies.

^Subtotals reflect the number of unique water systems. Some systems may receive a violation for multiple analytes.

Revised Total Coliform Rule

| | MCL (mg/L) ¹ | MCLs | | Treatment Techniques | | Significant Monitoring/Reporting | |
|--|-------------------------|----------------------|-----------------------------------|----------------------|-----------------------------------|----------------------------------|-----------------------------------|
| | | Number of Violations | Number of Systems with Violations | Number of Violations | Number of Systems with Violations | Number of Violations | Number of Systems with Violations |
| MCL Violations | Presence | 2 | 2 | | | | |
| Monitoring, Routine Major (3A) (RTCR) | | | | | | 218 | 153 |
| Monitoring, Routine, Major (3B) (RTCR) | | | | | | 8 | 8 |
| Monitoring, Routine Minor (3A) (RTCR) | | | | | | 10 | 10 |
| Monitoring, Routine Minor (3B) (RTCR) | | | | | | 0 | 0 |
| Report Sample Result/Fail Monitor (4B) (RTCR) | | | | | | 0 | 0 |
| Failure to Conduct Assessment Monitoring (2A) (RTCR) | | | | 7 | 7 | | |
| Subtotal | | 2 | 2 | 7 | 7 | 236 | 171 |

Groundwater Rule

| | MCL (mg/L) ¹ | Treatment Techniques | | | | Significant Monitoring/Reporting | |
|---|-------------------------|----------------------|-----------------------------------|----------------------|-----------------------------------|----------------------------------|-----------------------------------|
| | | Number of Violations | Number of Systems with Violations | Number of Violations | Number of Systems with Violations | Number of Violations | Number of Systems with Violations |
| Monitor GWR Triggered/Additional, Major | | | | | | 46 | 38 |
| Monitor GWR Triggered/Additional, Minor | | | | | | 0 | 0 |
| Failure to Address Deficiency | | 1 | 1 | | | | |
| Subtotal | | 1 | 1 | | | 46 | 38 |

Surface Water Treatment Rule

| | MCL (mg/L) ¹ | MCLs | | Treatment Techniques | | Significant Monitoring/Reporting | |
|----------------------------|-------------------------|----------------------|-----------------------------------|----------------------|-----------------------------------|----------------------------------|-----------------------------------|
| | | Number of Violations | Number of Systems with Violations | Number of Violations | Number of Systems with Violations | Number of Violations | Number of Systems with Violations |
| Filtered Systems | | | | | | | |
| Monitoring, Routine/Repeat | | | | | | 0 | 0 |
| Treatment Techniques | | | | 2 | 1 | | |
| Unfiltered Systems | | | | | | | |
| Monitoring, Routine/Repeat | | | | | | 0 | 0 |
| Failure to Filter | | | | 0 | 0 | | |
| Subtotal | | | | 2 | 1 | 0 | 0 |

Lead and Copper Rule

| | MCL (mg/L) ¹ | MCLs | | Treatment Techniques | | Significant Monitoring/Reporting | |
|---|-------------------------|----------------------|-----------------------------------|----------------------|-----------------------------------|----------------------------------|-----------------------------------|
| | | Number of Violations | Number of Systems with Violations | Number of Violations | Number of Systems with Violations | Number of Violations | Number of Systems with Violations |
| Initial Lead and Copper tap M/R | | | | | | 0 | 0 |
| Follow-up or Routine Lead and Copper Tap M/R | | | | | | 53 | 53 |
| Failure to report LSL-Initial, 4G | | | | | | 276 | 276 |
| Failure to notify of Known or Potential LSL, 4H | | | | | | 84 | 84 |
| Treatment Installation | | | | 0 | 0 | | |
| Public Education | | | | 0 | 0 | 0 | 0 |
| Subtotal | | | | 0 | 0 | 413 | ^395 |

^Subtotals reflect the number of unique water systems. Some systems may receive a violation for multiple analytes.

Public Notice Rule

| | MCL (mg/L) ¹ | MCLs | | Treatment Techniques | | Significant Monitoring/Reporting | |
|--------------------------------|-------------------------|----------------------|-----------------------------------|----------------------|-----------------------------------|----------------------------------|-----------------------------------|
| | | Number of Violations | Number of Systems with Violations | Number of Violations | Number of Systems with Violations | Number of Violations | Number of Systems with Violations |
| Public Notification Violations | | | | | | 4 | 1 |
| Subtotal | | | | | | 4 | 1 |

Consumer Confidence Report

| | Significant Monitoring/Reporting | |
|--|----------------------------------|-----------------------------------|
| | Number of Violations | Number of Systems with Violations |
| Failed to Submit Report | 170 | 170 |
| Failed CCR Adequacy/Availability/Content | 155 | 155 |
| Subtotal | 325 | ^231 |

^Subtotals reflect the number of unique water systems. Some systems may receive a violation for multiple criteria.

Disclaimer:

¹Values are in milligrams per liter (mg/L), unless otherwise specified.


Dioxin, Asbestos, and Cyanide sampling have been waived by the State for some water systems based on special sampling conducted for these potential contaminants.


After the dates reflected in this summary report, some systems have already returned to compliance and are no longer in violation status.

Summary

The purpose of this report is to inform and educate the public of Georgia’s Public Water Systems compliance with the Safe Drinking Water Act.

There were 723 water systems that had approximately 1,346 violations in calendar year 2025. One water system may have more than one violation. There were 623 community water systems, 48 non-transient non-community water systems, and 52 transient non-community water systems that had violations. There was a total of 226 health based MCL violations (225 violations from community water systems, 0 violations from non-transient non-community water systems, and 1 violation from transient non-community water systems) from a total of 49 water systems (48 community water systems, 0 non-transient non-community water systems, and 1 transient non-community water system). There was a total of 1,120 non-health based violations (976 violations from community water systems, 59 violations from non-transient non-community water systems, and 85 violations from transient non-community water systems) that include monitoring/reporting and treatment technique violations from 689 water systems (589 community water systems, 48 non-transient non-community water systems, and 52 transient non-community water systems) (see Appendix A). Appendix A is a listing of Georgia’s Public Water Systems that had violations for calendar year 2025.





^Subtotals reflect the number of unique water systems. Some systems may have both Health Based and Non-Health Based violations and were not counted twice in the total number.

The overall number of violations determined in calendar year 2025 increased compared to the violations determined in the previous three calendar years. This increase can be attributed largely to the issuance of two new Lead and Copper violation types, 4G and 4H. The number of health-based violations also increased compared to the violations determined in the previous three calendar years. This increase mostly came from an increase in DBP violations, which could be due to record-breaking temperatures experienced in Georgia in the 3rd and 4th quarters of 2024 as well as the 2nd quarter of 2025. It is also notable that the triennial compliance period for several analytes is still active and violations will not be determined for those until calendar year 2026. Most violations are brief in duration and quickly resolved.

The majority of all drinking water violations for calendar year 2025 were non-health based violations which involved failure to submit a sample, failure to report test results, or failure to provide an annual Consumer Confidence Report. These administrative violations do not mean there were any problems with the quality of the drinking water.

GA EPD is working with PWS to ensure that corrosive water does not cause public health problems. The reaction between corrosive water and lead and copper piping can result in unsafe levels of lead and copper in drinking water. More than 2,000 public water systems have participated in a phased monitoring program which began in 1992.

The public can access drinking water facilities' information any time on Georgia's EPD public drinking water watch website at: <http://gadinkingwater.net>

Georgia's 2025 Annual Compliance Summary Report was published on June 30, 2026, on Georgia's Department of Natural Resources website at <https://epd.georgia.gov/publications>. A detailed copy of this report is available for review at 2 MLK, Jr. Dr. S.W., Suite 418 West Balcony, Atlanta, GA 30334 between the hours of 8:00 a.m. and 4:30 p.m., Monday through Friday (appointments preferred).

For additional information about this report contact:

**Jennifer Morson, Manager
Department of Natural Resources
Environmental Protection Division
Drinking Water Compliance Program
Phone: (470) 524-0576
E-mail: Jennifer.Morson@dnr.ga.gov**