GA EPD-UNDERGROUND STORAGE TANK MANAGEMENT PROGRAM 3 YEAR SPILL PREVENTION EQUIPMENT (SPILL BUCKET) INTEGRITY TEST REPORT (HYDROSTATIC AND VACUUM METHOD)

Facility Name:				Owner:				
Address:				Address:				
City, County, Zip:				City, State, Zip:				
Facility I.D. #:				Phone #:				
Tester Name:					Tester Phone #:			
Tester Company:					Test Date:			
Instructions								
Double walled spill prevention equipment does not require testing.								
2. Testing must be performed in accordance with a nationally recognized code of practice (such as PEI RP-1200 or equivalent) or the								
manufacturer's instructions.								
3. Keep a record copy of this testing for 3 years. Code of Practice or Manufacturer's Instructions used:								
	nstructions used:	ı		1				
Tank # Product Stored								
Product Stored			~				□ voouum	
	□ vacuum □ pressure	□ vacuum □ pressure		□ vacuum □ pressure		□ vacuum □ pressure	□ vacuum □ pressure	
Test method used	☐ hydrostatic	☐ hydrostatic		☐ hydrostatic		☐ hydrostatic	☐ hydrostatic	
	☐ manufacturer's	☐ manufacturer's		☐ manufacturer's			☐ manufacturer's	
	instructions	instructions		instructions		instructions	instructions	
Basin free of cracks or holes?	-) -)			□ yes		□ yes	□ yes	
(if no, it fails without testing)	□ no	□ no		□ no		□ no	□ no	
Water, fuel, trash & debris removed	□ yes	□ yes		□ ye		□ yes	□ yes	
from basin prior to test? (dispose of properly)	□ no □ n/a	│		□ no		□ no □ n/a	□ no □ n/a	
Drain valve operational and seals	□ yes	□ yes		□ li/a		□ yes	□ yes	
properly?	□ no			□ no		□ no	□ no	
(where applicable)	□ n/a	□ n/a	□ n/a		a	□ n/a	□ n/a	
Water, fuel, trash & debris removed	□ yes	□ yes		□ ye:	c	□ yes	□ yes	
from basin prior to test?	□ yes	□ yes		□ ye.		□ no	□ yes	
(dispose of properly)								
Fill pipe cap seals properly?	□ yes □ no	□ yes □ no		□ ye		□ yes □ no	□ yes □ no	
	□ n/a	□ n/a		□ n/a		□ n/a	□ n/a	
Was enough water added to				□ yes				
completely fill the basin?	□ yes □ no	□ yes	□ no			□ yes □ no	□ yes □ no	
(Hydrostatic test only)		L 110		□ no			<u> </u>	
Test start time	<u>:</u>	:	:		:	<u>:</u>	-	
Test end time (hydrostatic test - minimum 1 hour)	-		-		-	-	-	
Measured water level drop in inches								
accurate to 1/16 inch								
(Hydrostatic test)								
Vacuum drop in inches water column (vacuum test)								
Results of test								
(Hydrostatic test fails if level drops 1/8	Писсе					Писсе	Писс	
inch or more.) (Vacuum test fails if	□pass □fail	□pass □fail □inconclusive		□pas □fail		□pass □fail	□pass □fail	
cannot maintain 30 inches water column	□inconclusive			□inconclusive		□inconclusive	☐inconclusive	
or if vacuum drops more than 4 inches water column.)			Jidoivo		onoidono			
Tester's initials and date tested	/ /		/ /		/ /	/ /	/ /	
Repairs Needed	Date of Repair		Description of any Repairs					
I hereby certify that all the information contained in this report is true, accurate and in full compliance with legal								
requirements.								
Tester's Signature: Date:								
Dutc.								